

486 -Work Order In Progress

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
805	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. INSPECTION COMPLETED AS PER RUBEN SOLIS	4/1/2005 6/8/2005 Medium	Aida Salcedo Ruben Solis		Alma Del Valle Daycare
547	Complete MARCIA BENTO - FILE CABINET KEY WILL NOT OPEN. replace loc at file cabinet and 2 locks at nurses office and room 107.	3/18/2005 4/8/2005 Medium	Luz Griego Hector Lozoya		Alma Del Valle Daycare
1160	Closed Work Orders 4/12/05. .5 building walk thru. .5 pull weeds. 7.0 pull out lockers at g.m.s. 4/12 - 8	4/14/2005 4/12/2005 Medium	Joe Ramirez Joe Ramirez		Anthony ES
1164	Closed Work Orders 4/14/05. 2.0 cleaning front part of main building. 2.0 taking partitions to g.m.s. for art fair. 4.0 continue clean up around building. 4/14 - 8	4/14/2005 4/14/2005 Medium	Joe Ramirez Joe Ramirez		Anthony ES
1162	Closed Work Orders 4/13/05. .5 building walk thru. 2.0 adjust student desks rm112 old main. 5.5 service ac's at a/c/ d/c. 4/13 - 8	4/14/2005 4/13/2005 Medium	Joe Ramirez Joe Ramirez		Anthony ES
1155	Closed Work Orders 4/8/05 .5 building walk thru. 1.5 g.m.s. to measure for lockers. 6.5 cutting 2x4 for parent center. 4/8 - 8.5	4/14/2005 4/8/2005 Medium	Joe Ramirez Joe Ramirez		Anthony ES
1157	Closed Work Orders 4/11/05. .5 building walk thru. 6.0 service a/c's in primary building. 1.5 watering trees. 4/11- 8	4/14/2005 4/11/2005 Medium	Joe Ramirez Joe Ramirez		Anthony ES
1148	Closed Work Orders 4/5/04 .5 building walk thru. 6.5 service ac's old cafeteria. 1.0 watering trees. 4/5 - 8	4/14/2005 4/5/2005 Medium	Joe Ramirez Joe Ramirez		Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1152	Closed Work Orders 4/7/05 .5 building walk thru. 7.5 service a/c's and replace filters. 4/7 - 8	4/14/2005 4/7/2005 Medium	Joe Ramirez Joe Ramirez		Anthony ES
2726	Complete CARPET EXTRACTOR DOES NOT SPRAY WATER,NEED TO GET FIXED ASAP. CLEANED NOZZLE ASSY AS PER JIMMY	6/13/2005 6/13/2005 Medium	Jimmy Carbajal Jimmy Carbajal	Hallway/Corridor	Anthony ES
100	Void "MS. ZUBIA PORTABLE ROOM 219 PRIMARY SIDE. INTERCOM IS NOT WORKING. THEY CAN'T PAGE THE OFFICE IN CASE OF AN EMERGENCY." Technology Work Order	3/7/2005 Medium	karla Quesada		Anthony ES
1778	Duplicate Request As per Principal Mrs. Marquez please clean Dona Ana room at the upper primary village by May 24, 2005. DUPLICATED, HAD ALREADY BEEN SUBMITTED. SEE W.O. #1747 SUBMITTED ON 5/10/05. M.S.	5/10/2005 Medium	karla Quesada Sal Acuna		Anthony ES
1780	Complete As per Mrs. Marquez please set up banquet tables on May 17, 2005 by 3:30 p.m. SET UP TABLES @ A.E FOR PARTY	5/10/2005 6/3/2005 Medium	karla Quesada Jimmy Carbajal		Anthony ES
610	Closed Work Orders 3/16/05. .5 building walk thru. 2.5 finish running water lines to a/c's annex. 1.0 unclogging custodians mop sink. 2.0deepening tree wells and watering. 2.0 repairing swings.	3/24/2005 Medium	Joe Ramirez Margret Villalobos		Anthony ES
611	Closed Work Orders 3/17/05. .5 building walk thru. 6.5 repairing swings. .5 repairing door closure.	3/24/2005 Medium	Joe Ramirez Margret Villalobos		Anthony ES
612	Closed Work Orders 3/21/05. .5 prep and patch hallway wall. 7.0 painting hallway main bldg. .5 clean up.	3/24/2005 Medium	Joe Ramirez Margret Villalobos		Anthony ES
613	Closed Work Orders 3/22/05. 3.0 safety training , s.t.m.s. 4.5 painting at auto shop. .5 clean up and back to a.e.	3/24/2005 Medium	Joe Ramirez Margret Villalobos		Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
614	Closed Work Orders 3/23/05. 1.5 cutting and installing backing on book shelf. 6.5 finish painting at auto shop & clean up.	3/24/2005 Medium	Joe Ramirez Margret Villalobos		Anthony ES
596	Closed Work Orders 3/1/05. .5 building walk thru. 2.0 pulling weeds from around building. 1.0 taking down broken swing..5 touch up a/c d/c. 1.5 continue pulling weeds. 2.5 assemble 2 tables, help custodians adjust tables for banquet.	3/24/2005 Medium	Joe Ramirez Margret Villalobos		Anthony ES
597	Closed Work Orders 3/2/05. .5 building walk thru. 2.5 cutting weeds. 5.0 taking down tree loading trailer.	3/24/2005 Medium	Joe Ramirez Margret Villalobos		Anthony ES
598	Closed Work Orders 3/3/03 .5 building walk thru. 6.0 continue cutting weeds apply round up along fence. 1.5 installing water fountain.	3/24/2005 Medium	Joe Ramirez Margret Villalobos		Anthony ES
602	Closed Work Orders 3/4/05. .5 building walk thru. 1.5 hanging wall shelves. 1.0 warehouse to pick up supplies. 3.0 cutting weeds. 2.0 help plumber with water fountain.	3/24/2005 Medium	Joe Ramirez Margret Villalobos		Anthony ES
603	Closed Work Orders 3/7/05. .5 building walk thru. 1.0 continue cutting weeds. 3.0 finish hanging shelves & painting. 1.0 clean around storage shed. 1.5 cutting weeds. 1.0 finish installing urinals.	3/24/2005 Medium	Joe Ramirez Margret Villalobos		Anthony ES
604	Closed Work Orders 3/9/05. .5 building walk thru. 2.0 hang overhead screens in two classrooms. 5.5 installing motors and wiring a/c units annex building.	3/24/2005 Medium	Joe Ramirez Margret Villalobos		Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
605	Closed Work Orders 3/8/05. .5 building walk thru. 1.5 painting . 6.0 cutting weeds and apply round up.	3/24/2005 Medium	Joe Ramirez Margret Villalobos		Anthony ES
606	Closed Work Orders 3/11/05. .5 building walk thru. 2.0 cutting weeds. 5.5 working on broken sprinklers.	3/24/2005 Medium	Joe Ramirez Margret Villalobos		Anthony ES
607	Closed Work Orders 3/14/05 .5 building walk thru. 2.0 cutting weeds. 5.5 working on running water lines to a/c's annex bldg.	3/24/2005 Medium	Joe Ramirez Margret Villalobos		Anthony ES
608	Closed Work Orders 3/15/05. .5 building walk thru. 1.5 working on boiler. 3.0 changing lightbulbs in main & primary bldg. 1.5 installing t.p. dispensers & paper towel disp. 1.5 cutting weeds.	3/24/2005 Medium	Joe Ramirez Margret Villalobos		Anthony ES
1811	Complete electrical fro new a/c replacement conectar unidad de refrig. to portable.	5/11/2005 5/10/2005 Medium	Jaime Gomez Enrique Sotelo	Portables	Anthony ES
1976	Work In Progress cover walls , where a/c's were removed	5/17/2005 Medium	Jaime Gomez Danny Miranda	Classroom	Anthony ES 214
1346	Closed Work Orders 4/15/05 .5 building walk thru. 3.5 painting a wall in primary building. 2.0 cutting weeds. 2.0 service a/c's at a/c d/c. 4/15 - 8	4/22/2005 4/15/2005 Medium	Joe Ramirez Joe Ramirez		Anthony ES
1347	Closed Work Orders 4/18/05. .5 building walk thru. 7.5 installing new lavatory and building a furr out in drug safe building. 4/18 - 8	4/22/2005 4/18/2005 Medium	Joe Ramirez Joe Ramirez		Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1348	Closed Work Orders 4/19/05. .5 building walk thru. 2.0 adjust several a/c's. 2.0 tape joints on furr out. 1.5 watering trees. 2.0 lining soccer field. 4/19 - 8	4/22/2005 4/19/2005 Medium	Joe Ramirez Joe Ramirez		Anthony ES
1349	Closed Work Orders 4/20/05. .5 building walk thru. 1.5 2nd.coat furr out. 2.0 water trees. 2.0 adjust more a/c's. 2.0 cutting weeds. 4/20 - 8	4/22/2005 4/20/2005 Medium	Joe Ramirez Joe Ramirez		Anthony ES
1350	Closed Work Orders 4/21/05. .5 building walk thru. 4.0 cutting weeds around student drop area and along fence line. 3.5 paint some walls and paint the lines on the soccer field. 4/21 - 8	4/22/2005 4/21/2005 Medium	Joe Ramirez Joe Ramirez		Anthony ES
1534	Closed Work Orders 4/22/05 .5 building walk thru. 4.5 edging along fence and building. 3.0 installing splash guard in old cafeteria. 4/22 - 8	4/29/2005 4/22/2005 Medium	Joe Ramirez Joe Ramirez		Anthony ES
3061	Complete ROOM 22 - BROKEN WINDOW HANDLE AND BROKE INTO ROOM. CASE# 07-65533	6/29/2005 6/24/2005 Medium	Marco Fattorini Hector Villalobos		Anthony ES
482	Complete Please generate a w.o for Manny and have him assign the keys to the cafeteria mangager before the end of the week. Have Manny test the keys before he issues them out. AE - H (gate key)	3/17/2005 3/17/2005 Medium	Michael Munoz Hector Lozoya		Anthony ES
911	Complete Lucky,Joe WE need to find out which lockers are to be moved and re-locate to GMS. Rudy will assist. move locker from AE to GMS	4/6/2005 6/3/2005 Medium	Michael Munoz Hector Villalobos		Anthony ES
882	Work In Progress freezer at 20 degrees Rebecca Saenz - SNP Manager (505) 882-3507	4/6/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
883	Duplicate Request plastic tube for clorox dispenser broke off to dishmachine Rebecca Saenz - SNP Manager (505) 882-3507 duplicate #1140	4/6/2005 4/15/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Anthony ES
462	Complete DISPOSAL DOWN REBECCA SAENZ - K-1 882-5607 unclogged garbage disposal and reset	3/16/2005 3/30/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Anthony ES
465	Complete DISHMACHINE MAKING ALOT OF NOISE REBECCA SAENZ - SNP MANAGER (882-5607) ROUND SS SPOON IN IMPELLAR HOUSING, REMOVED AND NO MORE NOISE.	3/16/2005 3/23/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Anthony ES
2285	Complete NEED CARPET REPLACED IN MS. COOKS CLASSROOM. CARPET IS VERY DIRTY WITH PEE, VOMIT, ETC. AS PER E-MAIL ON 5/20/05 FROM AIDA TO MIKE MUNOZ. old carpet was removed and new carpet, covebase installed .	5/25/2005 6/8/2005 Medium	Aida Salcedo Michael Munoz	Classroom	Anthony ES MS. COOK
1747	Complete JIMMY & SAL -DONNA ANNA BUILDING. EQUIPMENT NEEDS TO BE MOVED OUT TO CHAPTER BUILDING AND THEN A GENERAL CLEANING NEEDS TO BE DONE. MOVED FURNITURE & DID A GENERAL CLEANING, DUSTED & VACUUMED.	5/9/2005 5/11/2005 Medium	Aida Salcedo	Classroom	Anthony ES
766	Work In Progress NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005.	4/1/2005 Medium	Aida Salcedo Carlos Lujan		Anthony ES
157	Complete Mid Bldg Room 4 - Door lock not working.	3/8/2005 3/7/2005 Medium	Hector Lozoya	Classroom	Anthony ES
1862	Work In Progress New unit that was installed in Nurces area is not sufficient. Need to provide more cooling. Please see Mike	5/11/2005 Medium	Jaime Gomez		Anthony ES
1880	Complete As per Ms. Marquez. Would like 1 enter and 1 exit gates. cars are bottling up.	5/12/2005 6/13/2005 Medium	Ruben Ronquillo	Parking Lot	Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2391	Void please replace the carpets and cove base in portables 219&220. water line broke and flooded rroms. DUPLICATE 2285 - COMPLETED ON 6/10/05	5/31/2005 6/14/2005 Medium	Michael Munoz	Classroom	Anthony ES
2867	Work In Progress need four sinks Anthony elem girls r.r.`s	6/20/2005 Medium	Danny Miranda Fred Appenzoller		Anthony ES
2868	Duplicate Request need four sinks Anthony elem girls r.r.`s DUPLICATE REQUEST. SEE W.O. #2867	6/20/2005 Medium	Danny Miranda		Anthony ES
2296	Closed Work Orders 5/17/05 1. remove a/c units from annex blg 7. jumping balloons all day 5/17 - 8	5/25/2005 5/17/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2294	Closed Work Orders 5/16/05 2. watering trees 4. install new a/c unit old main office 1. cutting weeds 1. log on work order log 5/16 - 8	5/25/2005 5/16/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2302	Closed Work Orders 5/20/05 2. watering trees 1.remove old a/c annex blg 3. install new a/c unit room 307 2. remove bulletin boards all rooms andmove box to room E 5/20 - 8	5/26/2005 5/20/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2303	Closed Work Orders 5/23/5 8. remove wall tile repair wall mild blg office 5/23 - 8	5/26/2005 5/23/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2304	Closed Work Orders 5/24/05 2. watering trees 2. moving grass 1. move boxes to loma linda 5. replacewater pump a/c cafeteria mild 2.5 repair holes on wall mild blg hallway 5/24 - 8	5/26/2005 5/24/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2305	Closed Work Orders 5/25/05 1. cover vents in cafeteria mild blg 7. painting walls hallway milg blg 5/25 - 8	5/26/2005 5/25/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2300	Closed Work Orders 5/18/05 2. remove old a/c units annex blg 5. replace a/c pump room 319 5. replace a/c pump p.e room 5. cutting weeds and edging old main 5/18 - 3.5	5/26/2005 5/18/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2390	Work In Progress room 207 door will not lock need to fix a.s. a. p. for today	5/31/2005 Medium	Hector Villalobos Hector Lozoya	Classroom	Anthony ES
2454	Closed Work Orders 5/31/05 8. painted room 207 old main blg 5/31 - 8	6/2/2005 5/31/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2455	Closed Work Orders 6/1/05 4. cutting weeds and used roundup for weeds 4. painted lounge mild blg 6/1 - 8	6/2/2005 6/1/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2452	Closed Work Orders 5/27/05 6.5 monthly inspection 1.5 shop put gas and pick up supplies 5/27 - 8	6/2/2005 5/27/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2450	Closed Work Orders 5/26/05 8. monthly inspection 5/26 - 8	6/2/2005 5/26/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1953	Closed Work Orders 5/10/05 2. getting information on a/c units 6. installing refrigeration unit pt 219 5/10 - 8	5/16/2005 5/10/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1954	Closed Work Orders 5/11/05 1.5 watering trees 4. installing refrigeration pt 219 2.5 cutting grass 5/11 - 8	5/16/2005 5/11/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1957	Closed Work Orders 5/12/05 8. edging and watering grass 5/12 - 8	5/16/2005 5/12/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1960	Closed Work Orders 5/13/05 2. line up scorer field 1.5 go to shop put gas pick up supplies 4.field day 5/13 - 8	5/16/2005 5/13/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1937	Void Larry from warehouse to pick up furniture at custodial storage Needs to be routed to the Purchasing Warehouse.	5/13/2005 Medium	Hector Villalobos Margret Villalobos	Custodial	Anthony ES
1938	Complete annex blg outside lighting are not working REPAIR FOTOCELL ON EXTERIOR LIGHTS.	5/13/2005 5/27/2005 Medium	Hector Villalobos Enrique Sotelo		Anthony ES
1557	Complete Project assist center a/c unit needs to be wire connect new a/c 240v at project assist and change out double switch.	5/2/2005 5/20/2005 Medium	Hector Villalobos Enrique Sotelo	Classroom	Anthony ES
1558	Work In Progress uuper primary daycare center need to be spray all 3 room for pest control Faxed PO on 5/9/05 45012727	5/2/2005 Medium	Hector Villalobos Margret Villalobos	Classroom	Anthony ES
1320	Complete pick up medicine cadinet at sths over to anthony elementary nurse PICKUP MEDICINE AT SHOP	4/21/2005 4/30/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1321	Work In Progress hook up electrical power to storage outside	4/21/2005 Medium	Hector Villalobos Enrique Sotelo	Athletic Field	Anthony ES
1323	Complete install lights outside of chapter blg CAMBIAR 2 LAMPS EXTERIOR	4/21/2005 4/26/2005 Medium	Hector Villalobos Enrique Sotelo		Anthony ES
1324	Complete need two 4l 580 belts and one 4l570 gave lucky 2 belts	4/21/2005 4/21/2005 Medium	Hector Villalobos Jaime Gomez	Classroom	Anthony ES
1451	Complete old cafeteria custodial storage sink is clog unclog drain	4/27/2005 4/28/2005 Medium	Hector Villalobos Fred Appenzoller	Electrical Room	Anthony ES
1452	Complete custodial new blower is not working repaired leaf blower	4/27/2005 4/28/2005 Medium	Hector Villalobos Angel Gonzales	Custodial	Anthony ES
1437	Closed Work Orders 4/21/05 8. cutting weeds and edging by old main annex blg 4/21 - 8	4/26/2005 4/21/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1439	Closed Work Orders 4/22/05 1.5 125823 check all emergency lighting 1.5 125824 check all exit signs 2. 125825 check all fire extinguisher 3. old cafeteria install wall paneling 4/22 - 8	4/26/2005 4/22/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1440	Closed Work Orders 4/25/05 3. cleaning a/c units chapter blg 3. mild blg cleaning a/c units 2. edging uuper primary blg 4/25 - 8	4/26/2005 4/25/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1714	Closed Work Orders 4/26/05 7. cutting weeds and mowing grass 1. log on work order log 4/26 - 8	5/6/2005 4/26/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1715	Closed Work Orders 4/27/058. monthly inspection 4/27 - 8	5/6/2005 4/27/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1716	Closed Work Orders 4/28/05 check hoods and fire extinguisher dimar systems 4/28 - 8	5/6/2005 4/28/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1657	Complete boys bathroom mild blg need partition hardware repair rr partitions and doors.	5/4/2005 5/4/2005 Medium	Hector Villalobos Danny Miranda	Hallway/Corridor	Anthony ES
1647	Complete we need to replace all old lighting ballasts two for one ballasts room 110 HELP LUCKY CHANGE OUT BALLAST.	5/4/2005 5/20/2005 Medium	Hector Villalobos Enrique Sotelo	Classroom	Anthony ES
1791	Closed Work Orders 5/2/05 5. clog toilet pt 217 5. clog sink pt 218 2.replace brun out light at annex blg 1.5 replace brun out lighting at mild blg 3.5 edging grass at mild blg 5/2 - 8	5/10/2005 5/2/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1793	Closed Work Orders 5/4/05 1.5 watering grass mild blg old main blg 6.5 refilling sidewalk with crusher fine chapter blg 5/4 - 8	5/10/2005 5/4/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1794	Closed Work Orders 5/5/05 2. helping load lunches on buss clean cafeteria 2. repair spinklers football field 2. watering trees 2. line up scorer field 5/5 - 8	5/10/2005 5/5/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1800	Closed Work Orders 5/9/05 7. assemble and disassemble furniture move p.e 1.get in informationon a/c units 5/9 - 8	5/10/2005 5/9/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1797	Closed Work Orders 5/6/05 2.install ballasts room 110 6.clean out a/c and install a/c unit leaning center 5/6 - 8	5/10/2005 5/6/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1817	Complete will need 4 electric cords for jumping balloons on 5/ 16/ 05 ASKED RAMIRO FOR TEMP OUTLETS TO USE AT ANTHONY.	5/11/2005 5/18/2005 Medium	Hector Villalobos Enrique Sotelo	Parking Lot	Anthony ES
1870	Complete proect assist center change two locks a.s.a.p. installed 2 locks at offices	5/12/2005 5/16/2005 Medium	Hector Villalobos Hector Lozoya	Classroom	Anthony ES
1874	Complete need small welder to repair wheels	5/12/2005 5/12/2005 Medium	Hector Villalobos Ruben Ronquillo	Football Field	Anthony ES
1286	Complete need a 230 receptacle at pump house install 120 v outlet - 50 amp for welder	4/20/2005 4/25/2005 Medium	Hector Villalobos Enrique Sotelo	Electrical Room	Anthony ES
1287	Closed Work Orders 4/14/05 1. check boilers 1. art partitions at gms 6. edging and cleaning mild blg 4/14 - 8	4/20/2005 4/14/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1288	Closed Work Orders 4/15/05 1. check boilers 1. setup for career day 1.5 shop put gas pick up supplies 4. cleaing a/c units upper primary 4/15 - 7.5	4/20/2005 4/15/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1289	Closed Work Orders 4/18/05 1. check boilers 1. pick up art prtation at gms 6. cleaning a/c units at upper primary 4/18 - 8	4/20/2005 4/18/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1290	Closed Work Orders 4/20/05 1. check boilers 6. edging and cutting weeds by old primary blg 1. log on work order log 4/20 - 8	4/20/2005 4/20/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1143	Closed Work Orders 4/8/05 1. check boilers 5.5 mowing grass 5. lockers at mild school rudy 1. log on work order log 4/8 - 8	4/14/2005 4/8/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1144	Closed Work Orders 4/11/05 1. check boilers 6. cleaning a/c units at old primary 1. watering trees 4/11 - 8	4/14/2005 4/11/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1145	Closed Work Orders 4/12/05 1. check boilers 7. 911 moving lockersuot of gym mild school 4/12 - 1	4/14/2005 4/12/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
1038	Work In Progress replace a/c unit in cafeteria 63 a/c unit Medium	4/11/2005	Hector Villalobos Jaime Gomez	Cafeteria	Anthony ES
1039	Work In Progress primary office to replace 45 sidedraft master cool Medium	4/11/2005	Hector Villalobos Jaime Gomez		Anthony ES
1040	Complete need two 4l 680 belts for a/c unit gave lucky 2 belts Medium	4/11/2005 4/11/2005	Hector Villalobos Jaime Gomez	Classroom	Anthony ES
972	Closed Work Orders 4/1/05 1. check boilers 1.5 at shop put gas pick up supplies 5.5 edging by mild blg 4/1 - 8	4/8/2005 4/1/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
973	Closed Work Orders 4/4/05 1. check boilers 7. cleaning a/c units annex blg 4/4 - 8	4/8/2005 4/4/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
974	Closed Work Orders 4/5/05 1. check boilers 6. cleaning a/c units old cafeteria 1. waternig trees by mild blg 4/5 - 8	4/8/2005 4/5/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
975	Closed Work Orders 4/7/05 1. check boilers 3. clean a/c units mild cafeteria 2. clean a/c units pts 217 to 220 2. clean a/c units upper primary blg 4/7 - 8	4/8/2005 4/7/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
761	Complete room 319 door will not unlock REPLACE 2 LOCKSET AND REKEY CORES AND CHECK DOOR AT MAIN BLDG. Medium	4/1/2005 4/1/2005	Hector Villalobos Hector Lozoya	Classroom	Anthony ES
762	Complete Need keys made for mail box recut 2 mailbox keys Medium	4/1/2005 4/1/2005	Hector Villalobos Hector Lozoya	Office	Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
763	Complete Custodial storage replace faucet replace mop sink faucet in custodial room.	4/1/2005 4/6/2005 Medium	Hector Villalobos Fred Appenzoller	Custodial	Anthony ES
764	Work In Progress rooms 3 4 5 6 7 8 emergency windows do not open	4/1/2005 Medium	Hector Villalobos Ruben Ronquillo	Classroom	Anthony ES
748	Closed Work Orders 3/31/ 1. check boilers 1. mild blg repair window room 20 5. monthly inspection 1. log on work orders log	3/31/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
745	Closed Work Orders 3/29/05 4. mowing grass 1. check boilers 1.5 125563 check emergency lighting 1.5 125564 check all exit signs have to replace two mild milg 5. repair outside sign of school	3/31/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
746	Closed Work Orders 3/30/05 1. check boilers 2. 125565 check all fire extinguisher 4. cutting weeds by annex pts and parking lot 1. repair old main office door	3/31/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
822	Complete Drug free blg water heater has a leak 6 gal 120 volts replacs sink and faucet and base REMOVED CABINET AND WATER HEATER, INSTALLED NEW LAV AND WATER HEATER.	4/4/2005 4/20/2005 Medium	Hector Villalobos Fred Appenzoller		Anthony ES
823	Work In Progress ALL windows in old primary blg do not open	4/4/2005 Medium	Hector Villalobos Ruben Ronquillo	Classroom	Anthony ES
820	Work In Progress Pump house tank has a big leak upper primary	4/4/2005 Medium	Hector Villalobos Ricardo Jacquez	Athletic Field	Anthony ES
374	Complete primary boiler is not working fix a.s.a.p CHANGED OUT THERMOCOUPLE, PILOT LITE NOT STAYING ON.	3/15/2005 3/15/2005 Medium	Hector Villalobos Jaime Gomez	Electrical Room	Anthony ES
328	Complete back door will not lock repair panic par and rekey core	3/11/2005 3/17/2005 Medium	Hector Villalobos Hector Lozoya	Cafeteria	Anthony ES
331	Work In Progress need 8 sheet metal plates 20x20	3/11/2005 Medium	Hector Villalobos Jaime Gomez	Classroom	Anthony ES
102	Work In Progress need to remove dirt with tractor by dumpster	3/7/2005 Medium	Hector Villalobos Lorenzo Hernandez	Cafeteria	Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
103	Work In Progress boiler room we have a leak in pipe line	3/7/2005 Medium	Hector Villalobos Jaime Gomez	Mechanical Room	Anthony ES
104	Complete annex bldg office door handle came off	3/7/2005 3/7/2005 Medium	Hector Villalobos Hector Lozoya	Classroom	Anthony ES
153	Closed Work Orders 2/28/05 1. check boilers 1.124587 repair floor tile 6. monthly inspection	3/8/2005 3/8/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
150	Closed Work Orders 2/25/05 1. check boilers 3. monthly inspection 4. 124587 mild cafeteria polycrylic doors and stage	3/8/2005 3/8/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
160	Closed Work Orders 3/3/05 1. chech boilers 3. cutting weeds and roundup 4. monthly inspection	3/8/2005 3/8/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
161	Closed Work Orders 3/4/05 1. check boilers 1. upper primary bathrooms replace ceiling tiles 1.5 go to shop put gas and pick up supplies	3/8/2005 3/8/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
156	Closed Work Orders 3/2/05 1. check boilers 1. set up computer book room mild bld 6. remove dead trees	3/8/2005 3/8/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
205	Work In Progress Annex Bldg Girls rr - Broken window 45 1/2 x 14 3/4.	3/9/2005 Medium	Hector Villalobos Ruben Ronquillo	Restroom (Girls)	Anthony ES Annex Bldg
226	Work In Progress need to fill in sidewalk with crusher fine	3/10/2005 Medium	Hector Villalobos Lorenzo Hernandez	Athletic Field	Anthony ES
227	Work In Progress need tractor to scrape off weeds	3/10/2005 Medium	Hector Villalobos Lorenzo Hernandez	Athletic Field	Anthony ES
228	Work In Progress pt 217 replace heating and cooling	3/10/2005 Medium	Hector Villalobos Jaime Gomez	Classroom	Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
229	Duplicate Request annex girls bathroom broken window size 45 1/2 x 14 3/4	3/10/2005 Medium	Hector Villalobos Ruben Ronquillo		Anthony ES
230	Void Mrs marquez is requesting a basketball courts VOID - CAPITAL PROJECT - NEEDS TO BE SUBMITTED TO CMT FOR APPROVAL AND FUNDING. - A. HOLGUIN 3/15/05 -MKV	3/10/2005 Medium	Hector Villalobos Michael Munoz	Athletic Field	Anthony ES
628	Closed Work Orders 3/24/05 7. painting special ed room old main blg 1. log on work order log	3/24/2005 3/29/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
587	Closed Work Orders 3/16/05 1. check biolers 2. annex blg working on 1/2 water line for a/c units 1. old cafeteria clog drain line custodal room 4. pruning evergreens trees by mild blg	3/23/2005 3/29/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
588	Closed Work Orders 3/17/05 1.check biolers 5. unclog toilet old main blg 6.5pruning evergreens trees mild blg	3/23/2005 3/29/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
623	Work In Progress 3/18/05 1. check boilers 1.5 go to shop put gas pick up supplies 5.5 pruning trees by football field	3/24/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
624	Closed Work Orders 3/21/05 8. 125306 painting walls and replace code base	3/24/2005 3/29/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
625	Closed Work Orders 3/22/05 4. painting room 119 old main blg 4. workshop at STMS	3/24/2005 3/29/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
626	Closed Work Orders 3/23/05 2. repair sidewalk by pts 217 with cement 2. painting walls room 119 old main blg 2. painting outside walls annex blg 1. clean condensation line on refrigerator mild blg office 1. log on work order log	3/24/2005 3/29/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
471	Closed Work Orders 3/9/05 1. check boilers 7. 12470 wire new a/c units annex blg	3/16/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
457	Closed Work Orders 3/7/05 1. check boilers 7. cutting weeds moving weeds clean around storage	3/16/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
458	Closed Work Orders 3/8/05 1. check boilers 1. logon work order log 2. wire new a/c units annex blg 4. edging and cutting weeds	3/16/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
489	Work In Progress replace long gate with half swing and half slide. gate 3 and 1. Had a injury with a custodial	3/17/2005 Medium	Hector Villalobos Michael Munoz		Anthony ES
474	Closed Work Orders 3/10/05 1. check boilers 1.5 watering trees 1.5 repairing sprinklers by mild blg 3. install new heater p.e room E	3/17/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
475	Closed Work Orders 3/11/05 1. check boilers 4. repairing sprinklers football fields	3/17/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
476	Closed Work Orders 3/14/05 1. check boilers 3. edging and cutting weeds by old main blg 4. install new 1/2 inch water line for a/c units annex blg	3/17/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
477	Closed Work Orders 3/15/05 1. check boilers 5. edging and cutting weeds by annex pts 2. pruning evergreens trees by mild blg	3/17/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
478	Complete need a H master key for oscar RECUT H MASTER FOR OSCAR	3/17/2005 3/21/2005 Medium	Hector Villalobos Hector Lozoya	Custodial	Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
479	Complete south exit door broken door handle REPAIR PANIC BAR AND REPLACE HANDLE.	3/17/2005 3/21/2005 Medium	Hector Villalobos Hector Lozoya	Hallway/Corridor	Anthony ES
2624	Work In Progress Paint all hallways old main blg	6/8/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2619	Work In Progress Paint room 4 mild blg	6/8/2005 Medium	Hector Villalobos Hector Villalobos	Classroom	Anthony ES
2620	Work In Progress Paint room 8 mild blg	6/8/2005 Medium	Hector Villalobos Hector Villalobos	Classroom	Anthony ES
2621	Work In Progress Paint all bathrooms mild blg	6/8/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2626	Work In Progress Paint room 24 mild blg	6/8/2005 Medium	Hector Villalobos Hector Villalobos	Classroom	Anthony ES
2627	Work In Progress Paint lounge old main and mild blg	6/8/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2628	Work In Progress Drug free repair floor tile door replace lock and cove base	6/8/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2629	Work In Progress On 5/11/05 they spray one room at daycare center they need to spray all daycare rooms FAXED PO# 4501399 6/16/05-MKV	6/8/2005 Medium	Hector Villalobos Margret Villalobos	Classroom	Anthony ES
2614	Work In Progress Paint all hallways mild blg	6/8/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2615	Work In Progress Remove bulletin boards and wall tile from wall front office hallway mild blg	6/8/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2616	Work In Progress Room 217 needs to be paint	6/8/2005 Medium	Hector Villalobos Hector Villalobos	Classroom	Anthony ES
2617	Work In Progress Paint room 207	6/8/2005 Medium	Hector Villalobos Hector Villalobos	Classroom	Anthony ES
2666	Closed Work Orders 6/2/05 2. movning grass 2. repair sprinklers football field 1. log on work orders 1.5 126256 check emergency lighting 1.5 126257 check all exit signs 6/2 - 8	6/9/2005 6/2/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2668	Closed Work Orders 6/6/05 8. 911 move lockers to gms 6/6 - 8	6/9/2005 6/6/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2670	Closed Work Orders 6/7/05 2. watering trees 2.repair holes where locker were hallway 4.2620 remove eveything from wall to paint 6/7 - 4	6/9/2005 6/7/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2673	Closed Work Orders 6/8/05 2.5 126258 check all fire extinguisher 5.5 2620 painting room 8 6/8 - 2.5	6/9/2005 6/8/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2811	Complete Daycare center K riskna need to turn in keys to lock smith today is her last day	6/16/2005 6/16/2005 Medium	Hector Villalobos Hector Lozoya		Anthony ES
2812	Work In Progress Mrs marquez is requesting that the old cabinets in the old main blg and mild blg lounge be replace	6/16/2005 Medium	Hector Villalobos Danny Miranda		Anthony ES
2794	Closed Work Orders 6/8/05 2.5 126258 check all fire extinguisher 4.5 painting room 8 1. log on orders log 6/8 - 8	6/15/2005 6/8/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2795	Closed Work Orders 6/9/05 8. 2621 painting bathrooms mild blg	6/15/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2796	Closed Work Orders 6/10/05 8. 2621 paniting bathrooms mild blg	6/15/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2797	Closed Work Orders 6/13/05 8. 2619 painting room 4 mild blg	6/15/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2994	Work In Progress Upper primary pump house irrigation is not working	6/27/2005 Medium	Hector Villalobos Raul Sanchez		Anthony ES
3114	Closed Work Orders 6/29/05 7. cutting grass and edging 1. log on work order log 6/29 - 8	7/1/2005 6/29/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
3115	Closed Work Orders 6/30/05 8. monthy inspection 6/30 - 8	7/1/2005 6/30/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
3060	Complete CHAPTER BLDG - OUTSIDE WALLS AND DOOR WERE GRAFFITI 8 BROKEN SPRINKLERS. CASE# 2005-05396	6/21/2005 6/21/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
3075	Closed Work Orders 6/21/05 5. painting graffit chapter blg and doors 2. 26226 painting room 24 1. log on work order log 6/21 - 6	6/29/2005 6/21/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
3076	Closed Work Orders 6/22/05 5. repair broken sprinklers at soccer field 3. 2626 painting room 24 6/22 - 5	6/29/2005 6/22/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
3077	Closed Work Orders 6/23/05 4.repair broken sprinklers at football field 4.2626 painting room 24 6/23 - 4	6/29/2005 6/23/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
3078	Closed Work Orders 6/24/05 2. 2627 painting mail box and lounge walls 1.5 shop put gas pick up supplies 4.5 2627 painting mail box and lounge 6/24 - 1.5	6/29/2005 6/24/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
3079	Closed Work Orders 6/27/05 1. pump houses not working 7.2616 repair holes on wall painting room pt 217 6/27 - 1	6/29/2005 6/27/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
3080	Closed Work Orders 6/28/05 4. watering trees and useding roundup 4. 2616 painting pt 217 6/28- 4	6/29/2005 6/28/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2925	Closed Work Orders 6/16/05 8. 2614 painting hallways mild blg 6/16-8	6/21/2005 6/16/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2930	Closed Work Orders 6/20/05 4. cutting grass 4.2626repair holes on wall to be painted room 24 6/20-8	6/21/2005 6/20/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2927	Closed Work Orders 6/17/05 2. 114806 repair sprinkler valves soccer field 6. 2614 painting hallway mild blg 6/17-8	6/21/2005 6/17/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2921	Closed Work Orders 6/14/05 8.2614 painting hallways mild blg 6/14-8	6/21/2005 6/14/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
2922	Closed Work Orders 6/15/05 2. watering trees 5.2614 painting hallways 1. log on work order log 6/15-8	6/21/2005 6/15/2005 Medium	Hector Villalobos Hector Villalobos		Anthony ES
835	Void MID BLDG RM 3 -TOILET NOT FLUSHING Test Work Order	4/5/2005 Medium	Fred Appelzoller	Classroom	Anthony ES
2783	Complete MILK COOLER TEMP. IS AT 55. THIS MORNING. LAURA B. SNP MGR 882-5607 CHECKED MILK COOLER TENP AT 38 DEGREES WORKING FINE	6/15/2005 6/30/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	Anthony ES
370	Complete ANTHONY ELEM. K-1 CAMPUS FREEZER IS AT 10 DEGREES BECKY S. SNP MGR - 882-3507 ck'd freezer had dirty condensor, cleaned checked temp - ok.	3/14/2005 3/14/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	Anthony ES
371	Complete ANTHONY ELEM. 2-3 CAMPUS FREEZER IS AT 10 DEGREE BECKY S. SNP MGR 882-5607 ck'd freezer dirty condensor, cleaned and ck'd temp - ok.	3/14/2005 3/14/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	Anthony ES
254	Complete Anthony 2-3 campus: Electric Plug to milk cooler is sparking. Goes On/Off. Becky S. SNP Manager 882-5607 replaced 2 wall outlets.	3/10/2005 3/11/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	Anthony ES
256	Complete Anthony K-1 campus: Faucet fall off sink Becky S. SNP Manager 882-3507 install new delta faucet.	3/10/2005 3/11/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	Anthony ES
655	Complete Anthony Elem. 2-3 campus Door stop to kitchen door cracked in half. Could it be replace. Becky S. - SNP Manager 882-5607 replaced doorstep	3/29/2005 4/1/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	Anthony ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
900	Duplicate Request DISHWASHER - BLEACH PIPE BROKE BECKY SAENZ - AE MGR 882-3507 duplicate #883	4/6/2005 4/8/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	Anthony ES
901	Complete AE 2-3 CAMPUS MIXER: OIL IS MIXING WHEN MIXING. BECKY SAENZ - AE MGR 882-5607 CHECKED MIXER COULD NOT SEE ANY VISIBLE SIGN OF OIL LEAK, RAN MIXER FOR 15 TO 20 MINUTES NO OIL LEAK ANYWHERE.	4/6/2005 4/20/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	Anthony ES
486	Complete Anthony Elem. 2-3 campus: Managers key will not open kitchen door, key goes around and around. Will need to get in during the spring break to serve the head start kids and day cares. Becky SNP Mgr REKEY CYLINDER AT CAFETERIA	3/17/2005 3/21/2005 Medium	Jacqueline Aguilar Hector Lozoya	Cafeteria	Anthony ES
2286	Complete ANTHONY 2-3 CAMPUS - MILK COOLER IS NOT COOLING LAURA B. SSP MGR 882-5607 CLEANED CONDENSOR COIL	5/25/2005 5/31/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	Anthony ES
1061	Complete NEED TO HAVE A VACUUM REPAIRED REPAIRED PER JIMMY CARBAJAL. REPLACED NOZZLE ASSY, FAN, BELT, BRUSH, ADJUST-O- RITE PLATE, REAR AXLE ASSY & WHEEL RETAINER.	4/12/2005 4/12/2005 Medium	Jimmy Carbajal Jimmy Carbajal		Anthony ES
1500	Work In Progress Irrigation Wells - Need Grounds to pick up old well column piping and dispose of it properly.	4/28/2005 Medium	Raul Sanchez Lorenzo Hernandez		Anthony ES
2222	Work In Progress Room 140 - Need to replace door closer.	5/23/2005 Medium	Hector Lozoya Danny Miranda		Berino ES
840	Complete asp Alfredo Holguin contact Ted Reyes,have him repair&test BFP preventer CKD WITH TED REYES HAD CARLOS ARELLANO TEST & REPAIR BFP	4/5/2005 4/15/2005 Medium	David Villalobos David Villalobos		Berino ES
2649	Complete reconectar portables reconnect 2 portables	6/9/2005 6/28/2005 Medium	Enrique Sotelo Enrique Sotelo	Portables	Berino ES
2480	Work In Progress CONNECT UTILITIES TO PORTABLES (4).	6/3/2005 Medium	Fred Appelzoller Fred Appelzoller		Berino ES PORTABLES
2798	Work In Progress need 2 red covers for royal ...4 belt s for royals	6/15/2005 Medium	Jimmy Cortez Jimmy Carbajal		Berino ES
2819	Work In Progress burmisher needs new ring to hold pad on.the one it has is broken and we cant take it off.thanks	6/16/2005 Medium	Jimmy Cortez Jimmy Carbajal		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2944	Work In Progress need 3 new brushes for royals vaccums	6/22/2005 Medium	Jimmy Cortez Jimmy Carbajal		Berino ES
832	Complete NEED NEW BRUSHS FOR ROYAL DELIVERED 5 BRUSH ASSY.	4/5/2005 4/11/2005 Medium	Jimmy Cortez Jimmy Carbajal		Berino ES
441	Work In Progress CHARGER NEEDS TO BE FIXED AGAIN	3/16/2005 Medium	Jimmy Cortez Jimmy Carbajal		Berino ES
576	Complete vaccum need to be work on need cap for tirethe red cap where belt gos. REPLACED PARTS(ISSUED THRU SITE NET) & DID P.M.	3/23/2005 3/29/2005 Medium	Jimmy Cortez Jimmy Carbajal		Berino ES
402	Complete belts for royal 4 DELIVERED 3 BELTS, REMOVED FROM INVENTORY THRU ACT 1000	3/15/2005 3/18/2005 Medium	Jimmy Cortez Jimmy Carbajal		Berino ES
2275	Duplicate Request i need 45 paper roll dispensorsbut ill take what you have in stockthanks DUPLICATE, SEE W.O. #1822 DATED 5/12/05. HAD ALREADY REQUESTED THRU E-MAIL THAT HE ORDER THRU SITE NET, HE STATED THAT HE ALREADY HAD.	5/25/2005 5/25/2005 Medium	Jimmy Cortez Maria Sitters		Berino ES
2239	Void THE ALARM AT THE SCHOOL KEEPS GOING OFF EVERY 15 MINGET IT FIXED THIS IS A TECHNOLOGY WORK ORDER - MKV	5/24/2005 Medium	Jimmy Cortez Margret Villalobos		Berino ES
1523	Complete vaccum tire fell off again REPLACED PARTS (ISSUED THRU SITE NET) ALONG WITH 50 FEET OF EXTENSION CORD & ALDO DID P.M.	4/29/2005 5/24/2005 Medium	Jimmy Cortez Jimmy Carbajal		Berino ES
1709	Complete vaccum needs to be worked on tires fell off need 4 new belts	5/6/2005 5/24/2005 Medium	Jimmy Cortez Jimmy Carbajal		Berino ES
	DELIVERED 2 BELTS				
1744	Complete vaccum cleaner need s repaire REPLACED PARTS (ISSUED THRU SITE NET) AND DID P.M.	5/9/2005 5/24/2005 Medium	Jimmy Cortez Jimmy Carbajal		Berino ES
1822	Complete need 45 ropll dispencerse to replace 990 s REQUESTED THAT JIMMY CORTEZ ORDER THRU THE SITE NET.	5/11/2005 5/12/2005 Medium	Jimmy Cortez Aida Salcedo		Berino ES
814	Complete WALK-IN FREEZER NOT WORKING. REMOVED BAD DEFROST TIMER,INSTALLED NEW ONE	4/4/2005 3/29/2005 Medium	Danny Orozco Danny Orozco	Cafeteria	Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1615	Complete As per David V. we need to relocate a portion of the chain link fence at Berino Elem. Due to the fact that it is located right on top of the shut off vavle to the fire hydrant. I believe a work order was submitted for this a long time ago.	5/3/2005 6/10/2005 Medium	David Villalobos Michael Munoz		Berino ES
	FAXED PURCHASE ORDER ON 5/26/05				
2495	Work In Progress NEED TO PICK UP SHARPS CONTAINERS FROM NURCES OFFICE ON NEXT TRIP OVERTHERE.	6/3/2005 Medium			Berino ES
2955	Work In Progress Please clean area where portables where moved i.e trash, stairs cinder blocks etc and clean on the exterior of rock wall on the east side.	6/23/2005 Medium	Ramiro Holguin		Berino ES
2956	Work In Progress please check all portables and see if all blocking cinder blocks are placed properly and repair if neede.	6/23/2005 High	Ramiro Holguin	Parking Lot	Berino ES
1836	Duplicate Request Need for Academy fence to relocate fence and gate by side walk as per Peter of Desert sands water. Gate and fence are on top of there water valve. Please see Ramiro at site. VOID THIS IS A DUPLICATE WORK ORDER.	5/11/2005 Medium	Michael Munoz	Parking Lot	Berino ES
601	Complete remove commodes and re-install when new floor covering is installed. portables 143-144 REMOVE W/C FROM ROOM.	3/24/2005 4/13/2005 Medium	Fred Appelzoller		Berino ES
769	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. COMPLETED	4/1/2005 4/26/2005 Medium	Aida Salcedo Jimmy Cortez		Berino ES
483	Complete Please generate a w.o for Manny and have him assign the keys to the cafeteria mangager before the end of the week. Have Manny test the keys before he issues them out. BE (Gate Key)	3/17/2005 3/17/2005 Medium	Michael Munoz Hector Lozoya		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
557	Closed Work Orders 3/18/05 0.5 ROUTINE CHECK OF BOILERS CLOSE GATES 0.5 SEND IN DAILY LOG AND W.O. CHECK EMAIL 1.5 WATER EVERYTHING IN FRONT OF BUILDING 1.5 PICKUP SUPPLIES AT P.P. 0.5 UNCLOG SINK ROOM 103 0.5 CLEAN AND LUBRICATE WINDOWS ROOM 100 2.0 REPLACE WINDOW SCREENS WITH NEW ONES WESTWING 1.0 EMPTY TRASH CANS FILL OUT DAILY WORK LOG	3/21/2005 3/29/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
646	Closed Work Orders 3/23/05 2.0 WATER EVERYTHING IN FRONT OF BUILDING FINISH PUTTING IN BUBBLERS 1.0 USE WEED EATER ON WEEDS NEXT TO PORTABLES 141,142 1.0 CHECK OUT PORTABLES THAT WERE CARPETED WITH MIKE AND RICHARD 4.0 FINISH INSTALLING PARTITION ON R.R. EASTWING FILL IN DAILY WORK LOG	3/29/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
642	Closed Work Orders 3/21/05 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.5 WATER EVERYTHING IN FRONT OF BUILDING 2.0 RUN BUBBLERS TO ROSE BUSHE AND PALM TREE 1.0 HELP RAUL WITH WATER FILTERS 2.5 REPLACE MIDDLE PARTITION IN BOYS R.R. EASTWING 0.5 CHECK ON CARPET PEOPLE FILL IN DAILY WORK LOG	3/29/2005 3/29/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
643	Closed Work Orders 3/22/05 4.0 ATTEND SAFETY MEETING AT SANTA TERESA MIDDLE SCHOOL 2.0 JAIME AND FRED HELP ME PUT WET SECTION ON TOP OF ROOF AND LOWER SOME BAD A/C UNITS 2.0 CHECK SPRINKERS REPLACE THE ONES NOT TURNING FILL OUT DAILY WORK LOG	3/29/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
687	Closed Work Orders 3/29/05 0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.0 PICKUP SAW-SAW AND SANDER AT LOMA LINDE 1.0 TRIM STAIRS IN PORTABLES 139,144 3.0 ASSIST DIMAR WITH CHECKING ALL FIRE EQUIPMENT IN BUILDING AND CAFETERIA 1.0 ASSIST SUN CITY GLASS IN CAFETERIA WITH SERVER GLASS 1.0 CUT R.R. DOORS IN PORTABLE 152 BECAUSE OF CARPET ALSO FILL IN DAILY WORK LOG	3/30/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
481	Closed Work Orders 3/16/05 0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.5 WATER EVERYTHING IN FRONT OF BUILDING 1.5 CUT WEEDS AROUND PORTABLES WESTSIDE NEXT TO PARKING AREA 1.5 WATER PINE TREES ON WESTSIDE ADJUST BUBBLERS ALSO SPRAY ROUNDUP ON WEEDS 1.5 SERVICE A/C FOR CONFERNCE ROOM AND LIBRARY 1.0 CHANGE TIME ON TIMER FOR SPRINKLER FILL IN DAILY	3/17/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
515	Closed Work Orders 3/17/05 0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.0 CHECK OUT A/C WATER LEAK REMOVE TRASH FROM ROOF TOP 3.0 HELP DANNY WITH WASHER 1.0 HELP MANNY WITH STORAGE DOOR 1.5 SERVICE A/C FOR LIBRARY ALSO LOOK AT PORTABLES WITH MIKE ON ROOMS GETTTING CARPET 0.5 FILL IN DAILY WORK LOG	3/18/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
436	Closed Work Orders 3/15/05 0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.0 SPOT PAINT RESTROOM IN WESTWING 1.0 CHANGE OUT LIGHTS ROOM 122 AND IN HALLWAY WESTWING 1.0 REPLACE SHARPENER P.150 AND REHUNG CABINET DOOR P.150 1.0 REPALCE LIGHTS IN MR. CORDONAS AND MR. SANCHEZ OFFICE ALSO UNCLOG TOILET P. 155 1.5 INSTALL BASEBOARD IN RESTROOM P. 157 1.5 REPAIR WATER LEAK CHECK WINDOW ROOM 114 FILL IN DAILY WORK LOG	3/16/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
234	Closed Work Orders 3/09/05 o.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.5 WATER ROSES AND PLAM TREES FRONT LAWN CUT WEEDS 1.5 SPRAY ROUNDUP FRONT PARKING AREA AND FRONT FENCE LINE AND EAST FENCE LINE 1.0 SPRAY ROUNDUP NORTHEAST FENCE AREA AND AROUND PINE TREES 2.5 SERVICE A/C OFFICE LOUNGE AND TEACHER LOUNGE ALSO ROOM 111 0.5 FIL IN DAILY WORK LOG	3/10/2005 3/16/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
236	Complete PORTABLE 137 A/C UNIT WILL NOT TURN ON PUSH BOTTOMS ARE NOT WORKING repaced control board	3/10/2005 4/20/2005 Medium	Ramiro Holguin Jaime Gomez		Berino ES
203	Work In Progress NEED PLAYGROUND FERTELIZES	3/9/2005 Medium	Ramiro Holguin Lorenzo Hernandez		Berino ES
201	Closed Work Orders 3/08/05 0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.0 SERVICE A/C P. 136 2.0 HELP DANNY WITH KITCHEN DRIAN 0.5 CHECK PORTALBES MAKE LIST ON ONES THAT NEED CARPET 2.0 SERVICE A/C 141,147 0.5 GET MY EVALUATION WITH MIKE 1.0 CHECK SPRINKLER ON PLAYGROUND FILL IN DAILY LOG	3/9/2005 3/9/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
162	Closed Work Orders 3/07/05 0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES 1.0 SEND IN DAILY WORK LOG AND ONE WEEK OF LOGS DUE TO THE NEW SYSTEM 1.5 WATER ROSES PLAM TREES AND FRONT LAWN 2.0 HELP DANNY WITH KITCHEN WORK ORDERS 3.0 SERVICE A/C P.136,142,143,144 AND FILL IN DAILY WORK LOG	3/8/2005 3/8/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
115	<p>Closed Work Orders 2/25/05</p> <p>0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES</p> <p>0.5 SEND IN DAILY WORK LOG AND W. O. CHECK EMAIL</p> <p>2.0 REPLACE LIGHTS ROOM 129 ALSO CHANGE OUT ELECTRICAL BALLAST GRILLS R.R. SOUTHWEST WING</p> <p>2.0 HELP BOYS CLEAN CURBS IN BUS TURNAROUND</p> <p>2.0 REPLACE WINDOW SCREENS IN SOUTHWING</p> <p>1.0 EMPTY OUTSIDE TRASH CANS FIL IN DAILY WORK LOG</p> <p>2/28/05</p> <p>0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES</p> <p>0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL</p> <p>2.0 WATER ROSE BUSHES AND PLAM TREES CUT WEEDS</p> <p>1.0 REMOVE SEE-SAW LEFT FOOTING TO HEAVEY FOR BACKHOLE TO PICKUP</p> <p>1.5 REMOVE PINE NEEDLES FROM UNDER PINE TREES</p> <p>1.5 INSTALL PARK BENCH AROUND PLAM TREES</p> <p>1.0 INSTALL FRAME HOOKS FOR PICTURES MR. SANCHEZ OFFICE</p> <p>3/01/05</p> <p>0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES</p> <p>0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL</p> <p>1.0 CHANGE OUT MARQUEE SIGN</p> <p>2.0 SPRAY HERBICIDE ON FRONT LAWN WATER PINE TREES PICKUP MORE PINE NEEDLES</p> <p>2.5 STARTED PAINTING OUTSIDE TRASH CANS</p> <p>1.5 CHECK SPRINKLES ON PLAYGROUND FILL IN DAILY WORK LOG</p> <p>3/03/05</p> <p>0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES</p> <p>3.0 CUT WEEDS ALONG FENCE LINE PLAYGROUND AREA ALSO SPRAY HERBICIDE</p> <p>1.5 CUT WEEDS AROUND PORTABLES NORTH AREA WATER MEXICANS ELDERS TREES</p> <p>2.0 SERVICE OFFICE A/C</p> <p>0.5 FILL IN DAILY WORK LOG AND WORK ON COMPUTER TO LOG IN</p> <p>3/04/05</p> <p>0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES</p> <p>1.5 MAKE MONTHLY REPORTS</p> <p>2.0 PICKUP SUPPLIES AT P.P.</p> <p>1.0 CLEAN OUT WINDOWS P. 134 INSTALL DOOR STOPPER</p> <p>2.0 STARTED UNCOVERING A/C IN MIDDLE WING</p> <p>1.0 EMPTY OUTSIDE TRASH CANS FILL IN DAILY WORK LOG</p>	<p>3/7/2005 3/16/2005 Medium</p>	<p>Ramiro Holguin Ramiro Holguin</p>	<p>Hallway/Corridor</p>	<p>Berino ES</p>

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
283	Closed Work Orders 3/10/05 0.5 ROTUINE CHECK OF BOILERS CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 0.5 MAKE ADJUSTMENTS ON SOME A/C FLOATS EASTWING 2.5 W.O. 236 HELP JIAME 1.0 PICKUP RASIERS AT GROUNDS DEPT. TO REPAIR BROKEN SPINKLERS ON PLAYGROUND 2.0 REPAIR BROKEN SPINKLERS AND CHECK 1.0 HELP JAIME PUT A/C UNIT BACK ON WALL P. 137 FILL IN DAILY WORK LOG	3/11/2005 3/11/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
342	Closed Work Orders 3/11.05 0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.5 WATER ROSE BUSHES AND PLAM TREES FRONT LAWN 1.5 MOW COURTYARD AREA WATER MEXICAN ELDERS FILL IN DAILY WORK LOG	3/14/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
343	Complete DANNY OROZCO WASHER IN KITCHEN NEEDS TO BE CHECK OUT LEAKING WATER took machine apart found hole in drain line, repaired and put back together.	3/14/2005 3/17/2005 Medium	Ramiro Holguin Danny Orozco		Berino ES
379	Closed Work Orders 3/11/05 0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.5 WATER EVERYTHING IN FRONT OF BUILDING ALSO EMPTY ALL OUTSIDE TRASH CANS 1.5 WATER MEXICAN ELDER TREES AND COURTYARD AREA ALSO CHECK PORTABLES WITH MIKE ON THE ONES GETTING CARPET 1.5 CHANGE OUT ELECTRICAL BALLAST ROOM 124 AND LIGHTS ALSO LIGHTS IN MENS AND WOMENS R.R. WESTWING 1.0 WORK ON WATER LEAK NEXT TO PORTABLE ON WESTSIDE 1.0 CHANGE OUT LIGHTS IN COMPUTER LAB FILL IN DAILY WORK LOG	3/15/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1089	Closed Work Orders 4/12/05 0.5 ROUTINE CHECK OF BOILERS AND ROBERT CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.5 EMPTY TRASH CANS CUT WEEDS AROUND PORTABLES ON NORTHSIDE AREA 1.5 SREVICE A/C NORTHWEST WING 1.5 HELP JAIME INSTALL WALL PANEL P. 138 1.0 CHECK OUT A/C UNIT P. 152 FILL IN DAILY WORK LOG 4/12 - 6	4/13/2005 4/12/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1090	Complete JAIME GOMEZ A/C UNIT IN PORTABLE 152 IS NOT COOLING NEEDS TO BE CHECK OUT Troubleshoot unit, had a bad contactor, removed unit to change out contactor.	4/13/2005 4/13/2005 Medium	Ramiro Holguin Jaime Gomez		Berino ES
1049	Closed Work Orders 4/11/05 0.5 ROUTINE CHECK OF BOILERS AND ROBERT CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.0 CHANGE OUT MARQUEE SIGN 2.0 WATER EVERTHING IN FRONT OF BUILDING ALSO PICKUP TRASH ALONG FENCE LINE 3.5 SERVICE A/C NORTHWEST WING 0.5 FILL IN DAILY WORK LOG 4/11/05 - 8	4/12/2005 4/11/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1174	Closed Work Orders 4/13/05 0.5 ROUTINE CHECK OF BOILERS AND ROBERT CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.5 WATER EVERYTHING IN FRONT OF BUILDING 2.5 STARTED A/C SERVICE ON NORTHEAST WING 1.0 HELP JAIME WITH A/C P. 137 2.0 SERVICE A/C KITCHEN AREA FILL IN DAILY WORK LOG 4/13 - 8	4/15/2005 4/13/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1175	Closed Work Orders 4/14/05 0.5 ROUTINE CHECK OF BOILERS AND ROBERT CLOSE GATES 1.5 TAKE ART SHOW PANELS TO GMS AND SETUP 1.0 SHOW DANNY THE RAIN CUTTERS I NEED AND WERE 1.0 SERVICE A/C UNIT GYM MIDDLE ONE 2.5 SERVICE A/C IN MIDDLE EASTWING 1.0 HELP JAIME WITH A/C P. 137 0.5 FILL IN DALIY WORK LOG	4/15/2005 4/14/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
	4/14 - 8				
1209	Closed Work Orders 4/15/05 0.5 ROUTINE CHECK OF BOILERS AND ROBERT CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W. O. CHECK EMAIL 1.5 REPLACE A/C ON KITCHEN AREA WITH NEW ONE 1.5 PICKUP SUPPLIES AT P.P. 3.0 REPLACE A/C ROOMS 107,103 1.0 REPLACE A/C PUMP P. 143 FILL IN DAILY WORK LOG	4/18/2005 4/15/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
	4/15 - 8				
1210	Complete MANNY LOZOYA KEY TO TV ROOM NEEDS TO BE REPLACE KEY WAS BENT duplicate 2 - b53 keys	4/18/2005 4/18/2005 Medium	Ramiro Holguin Hector Lozoya		Berino ES
1238	Closed Work Orders 4/19/05 0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.5 WATER EVERYTHING IN FRONT BUILDING 1.5 PICKUP ART SHOW PANELS AT G.M.S. PUT THEM IN ARE STORAGE SHED 2.0 REPLACE A/C FOR LIBRARY ALSO REMOVE ALL OLD A/C FROM ROOF TOP 1.0 HELP JAIME TAKE OLD A/C TO LANDFILL 1.0 REPLACE AIR FILTERS IN A/C UNITS P. 152,153 ALSO FILL IN DAILY WORK LOG	4/19/2005 4/18/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
	4/18 - 8				
1239	Complete 4/19/05 NEED TO REPLACE A/C IN KITCHEN AREA AND LIBRARY removed both mastercools and replaced with new ones. removed old coolers from roof and took to dump.	4/19/2005 4/19/2005 Medium	Ramiro Holguin Jaime Gomez		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1299	Closed Work Orders 4/19/05 0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 3.0 SPRAY ARSENAL AROUND SWING SEW GETTING SAND ALSO EAST PARKING AREA AND FENCE LINE 1.0 CHECK A/C ROOM 114,101 1.0 INSTALL CAFETERIA PARKING SIGNS ON EAST FENCE LINE 2.0 CHECK OUT SPRINKLERS ON WESTSIDE OF PLAYGROUND ALSO FILL IN DAILY WORK LOG 4/19 -8	4/21/2005 4/19/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1300	Closed Work Orders 4/20/05 0.5 ROUTINE CHECK OF BOILERS AND SHUT DOWN BOILERS CHECK WITH JIMMY CLOSE GATES 3.5 WATER EVERYTHING IN FRONT OF BUILDING ALSO TRIM ALL PALM TREES 1.0 SHOW POMS AND ASSOCIATES SEE-SAW BEING CHECK OUT TO BE RE-INSTALL 2.0 SERVICE GYM A/C ON WESTSIDE 1.0 MET WITH MIKE AND ALFERDO ON SEE-SAW FILL IN DAILY WORK LO 4/20 - 8	4/21/2005 4/20/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
719	Closed Work Orders 3/30/05 0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.5 WATER EVERYTHING IN FRONT OF BUILDING 1.5 ADJUST DOOR CLOSURES IN P. 152 REPLACE LIGHTS 2.0 INSTALL BACK TOILETS IN P. 143,144 ALSO REPLACE LIGHTS IN ROOMS 1.5 CLEAN OR REPLACE AIR FILTERS IN ALL REFRIGATION UNITS FILL IN DAILY WORK LOG	3/31/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
720	Work In Progress PLAYGROUND NEEDS TO BE AERATED	3/31/2005 Medium	Ramiro Holguin Lorenzo Hernandez		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
845	Closed Work Orders 4/01/05 0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.0 DO ALL P.M. REPORTS SO THEY CAN BE TURN IN 2.0 PICKUP UP SUPPLIES AT P. P. 1.5 WATER EVERYTHING IN FRONT OF BUILDING 1.5 SPRAY ROUNDUP AROUND PORTABLES NORTHSIDE AREA 1.0 CHECK BACKFLOW PREVENTOR WITH DAVID FILL OUT DAILY WORK LOG 4/1 - 8	4/5/2005 4/1/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
846	Work In Progress JAIME GOMEZ NEED TO REPLACE FOUR A/C UNITS WESTWING 131,128 ON EASTWING 103,107 ALL 6500	4/5/2005 Medium	Ramiro Holguin Jaime Gomez		Berino ES
847	Complete MANNY LOZOYA JIMMYS OFFICE DOOR NOT WORKING NEEDS TO BE CHECK OUT. repair lockset and install barrel bolt	4/5/2005 4/6/2005 Medium	Ramiro Holguin Hector Lozoya		Berino ES
759	Closed Work Orders 3/31/05 0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.0 RE-GLUE VINLY IN SOUTHWESTWING NEXT TO ROOM 114 0.5 SHOW CARPET PEOPLE WHICH PORTABLE NEEDS CARPET 2.5 SERVICE A/C IN SOUTHWEST WING 2.5 INSTALL PARTITIONS IN BOYS R.R. SOUTHWEST WING 0.5 FILL OUT DAILY WORK LOG	4/1/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
877	Closed Work Orders 4/04/05 0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES 1.5 WATER EVERYTHING IN FRONT OF BUILDING 2.0 DIG OUT FOOTING AROUND PALM TREE FOR CEMENT SLAP 1.5 SPRAY ROUNDUP ON WEEDS FRONT PARKING AREA 1.0 CUT BOARDS TO SIZE FOR STAIRS AND RAMPS 1.5 INSTALL FLOOR DOOR STOPPPER IN CAFETERIA AND FILL IN DAILY WORK LOG 4/4 - 8	4/6/2005 4/4/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
878	Closed Work Orders 4/05/05 0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES 1.5 MAKE NAME PLATES AT P.P. 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.5 ADJUST DOOR CLOSURE P. 152 ALSO RE- ATTACH RAIN GUTTER P. 145 2.0 REPLACE BOARDS ON RAMP P. 136 1.5 REMOVE REFRIGATION UNIT FROM WALL P.138 0.5 FILL IN DAILY WORK LOG 4/5 - 4	4/6/2005 4/5/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
916	Closed Work Orders 4/06/05 0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.5 WATER EVERTHING IN FRONT OF BUILDING PICKUP TRASH 1.0 HELP MANNY WITH DOOR IN JIMMYS OFFICE 0.5 UNCLOG TIOLET IN WOMENS R.R. FRONT LOBBY 2.5 REPLACE WET SECTION ON A/C AND SERVICE A/C IN SOUTHWEST WING 0.5 FILL IN DAILY WORK LOG 1.0 PICKUP NEW BADGE AT MAIN OFFICE 4/6 - 7.5	4/7/2005 4/6/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1001	Closed Work Orders 4/07/05 0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG W.O. CHECK EMAIL 3.0 FINISH SERVCEING A/C ON SOUTHWEST WING 3.0 STARTED CLEANING A/C ON NORTH WESTWING 0.5 FILL IN DAILY WORK LOG 4/7 - 8	4/11/2005 4/7/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1002	Closed Work Orders 4/08/05 0.5 ROUTINE CHECK OF BOILERS AND JIMMY CLOSE GATES 1.5 RISE SPRINKERS ON NORTHSIDE NEXT TO WALL ALSO CUT WEEDS 3.5 SERVICE A/C MIDDLE WEST WING CHANGE OUT WET SECTION ON ONE A/C UNIT 2.0 COVER UP HOLE IN WALL P. 138 WERE A/C UNIT WAS REMOVED 0.5 FILL IN DAILY WORK LOG 4/8 - 8	4/11/2005 4/8/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1339	Closed Work Orders 4/21/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W. O. CHECK EMAIL 1.5 SPRAY ARSENAL AROUND PORTABLES NORTH AREA ALSO CUT WEEDS 1.5 WATER MEXICAN ELDERS AND COURTYARD AREA ALSO CUT WEEDS 1.0 CHECK A/C IN ROOM 118 ALSO REPLACE FLOAT IN GYM A/C 1.5 MET WIYH MIKE AT ANTHONY ELEM. TO SHOW ME ALARM CODES FOR THE SCHOOL 1.5 EMPTY ALL TRASH CANS FILL IN DAILY WORK LOG 4/21 - 8	4/22/2005 4/21/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1449	Closed Work Orders 4/26/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.0 PICKUP TRASH EASTSIDE OF BUILDING ALSO UNCLOG SINK ROOM 104, REPAIR TABLE SPEECH ROOM 4.0 SPREAD OUT SAND IN PLAYGROUND ALSO COVER HOLES IN PLAYGROUND. 1.0 CHECK OUT SINK IN P. 150 CHANGE OUT LIGHTS 0.5 CHECK OUT POWER OUTAGE 0.5 FILL IN DALIY WORK LOG 4/26-8	4/27/2005 4/26/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1420	Closed Work Orders 4/25/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES 1.5 WATER EVERYTHING IN FRONT OF BUILDING 5.5 SPREAD OUT SAND IN PLAYGROUND EQUIPMENT 0.5 FILL IN DAILY WORK LOG 4/25-8	4/26/2005 4/25/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1382	Closed Work Orders 4/22/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O.O CHECK EMAIL 1.5 WATER EVERYTHING IN FRONT OF BUILDING PICKUP TRASH EASTSIDE FENCE LINE 1.5 WATER PINE TREES WESTSIDE ALSO CHECK OUT A/C ROMM 123 4/22 - 4	4/25/2005 4/22/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1599	Complete JAIME GOMEZ EXHAST UNIT IN EASTWING RESTOOMS NEEDS MOTOR REPLACE NOT WORKING belt was too big for exhaust. replaced with new belt. left motor for stcok	5/3/2005 5/9/2005 Medium	Ramiro Holguin Jaime Gomez		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1597	Closed Work Orders 5/02/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.5 WATER EVERYTHING IN FRONT OF BUILDING 1.0 CHECK ON A/C LEAKING WATER ON EASTWING AND KITCHEN AREA 3.0 COVER HOLES WITH SAND IN PLAYGROUND AREA ALSO REMOVE SAND BUILDUP ON CURBS EAST AND WEST PARKING AREAS 1.0 CHECK EXHAST UNIT EASTWING RESTROOMS 0.5 FILL IN DAILY WORK LOG 5/2 - 8	5/3/2005 5/2/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1550	Closed Work Orders 4/27/05 0.5 CHECK WITH JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 6.5 WORK ON PLAYGROUND WITH SAND 0.5 FILL IN DAILY WORK LOG 4/27 - 8	5/2/2005 4/27/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1551	Closed Work Orders 4/28/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES 1.0 REPLACE WATER LINE ADJUST A/C ROOM 124 6.0 DIG OUT GRASS AROUND SWING SET INSTALL SAND 0.5 FILL DAILY WORK LOG 4/28 - 8	5/2/2005 4/28/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1553	Closed Work Orders 4/29/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES 1.5 MAKE MONTHLY REPORTS AND TURN IN PAPER WORK 0.5 STOP AT ANTHONY ELEM. AND TALK TO MRS. MARQUEZ 1.5 PICKUP SUPPLIES AT P.P. 3.5 HELP BETO AND MANNY WITH PLAYGROUND 0.5 FIL IN DALIY WORK LOG 4/29 - 8	5/2/2005 4/29/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1772	Closed Work Orders 5/09/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.5 WATER EVERYTHING IN FRONT OF BUILDING 3.5 W. O. 1770 1.5 REMOVE ROADSIDE SIGN ALSO BINGO MACHINE AND STAND 0.5 FILL OUT DAILY WORK LOG 5/9 - 4.5	5/10/2005 5/9/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1770	Complete 5/09/05 ENRIQUE SOTELO ELECTRICAL OUTLETS FOR COPY MACHINES ARE NOT WORKING NO POWER BREAKERS ARE FINE FIX PROBLEM ON OUTLET FOR COPY MACHINE.	5/10/2005 5/10/2005 Medium	Ramiro Holguin Enrique Sotelo		Berino ES
1873	Complete 5/12/05 FRED APPELZOLLER NEED SNAKE MACHINE TO UNCLOG URINAL NORTHWEST WING POUR 3 CONTAINERS OF CLEAR FLUSH AND USED AUGER ,RAN MINIROOTER THRU DRAIN.	5/12/2005 5/11/2005 Medium	Ramiro Holguin Fred Appelzoller		Berino ES
1875	Complete 5/12/05 FRED APPELZOLLER NEED TO REPLACE SMALL TOILET WITH STANDARD TIOLET ROOM 106 REPLACED BROKEN W/C WITH NEW ONE.	5/12/2005 5/13/2005 Medium	Ramiro Holguin Fred Appelzoller		Berino ES
1876	Closed Work Orders 5/10/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 2.0 DESASEMBLE BOOK SHELVES ROOM 109 1.0 SHOW SOUND AND SIGNAL AROUND BUILDING 1.0 CHANGE OUT MARQEE SIGN 2.0 W.O. 1873 1.0 CHECK OUT A/C ROOM 131 FILL OUT DAILY WORK LOG 5/10 - 6	5/12/2005 5/10/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1877	Closed Work Orders 5/11/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES 1.5 WATER EVERTHING IN FRONT OF BUILDING 2.0 PICKUP PARKING CURBS AT P.P. INSTALL ON EASTSIDE PARKING 0.5 INSTALL LOCK ON BREAKER BOX FOR WALKING FREEZER 2.5 REPLACE BOARDS ON RAMP P. 136 1.0 REPLACE FLOAT ON A/C ALSO CHECK OUT A/C PUMP P. 147 FILL OUT DAILY WORK LOG 5/11 - 8	5/12/2005 5/11/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1672	Closed Work Orders 5/05/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES 1.5 WATER EVERYTHING IN FRONT OF BUILDING ALSO CUT WEEDS 1.0 CUT WEEDS AROUND PINE TREES SOUTHWEST AREA 1.0 HELP LORENZO WITH INVENTORY ON ALL A/C 3.0 REMOVE SAND BUILD UP ALONG FRONT FENCE LINE ON EASTSIDE 0.5 SHOW FENCE CONTRACTORS WERE GATE IS GOING 0.5 FILL IN DAILY WORK LOG 5/5- 8	5/5/2005 5/5/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1736	Closed Work Orders 5/05/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.0 REPAIR TABLE P. 144 ALSO INSTALL FILL VALVE IN RESTROOM ROOM 106 4.0 REMOVE SAND FROM WESTSIDE FENCE LINE 1.0 SERVICE A/C ON EASTSIDE OF GYM 1.0 EMPTY ALL OUTSIDE TRASH CANS FILL IN DAILY WORK LOG 5/5 - 8	5/9/2005 5/5/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1737	Closed Work Orders 5/06/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.5 WATER EVERYTHING IN FRONT OF BUILDING 1.5 CHECK A/C LEAKING WATER REPLACE A/C PUMP KITCHEN AREA ALSO WATER MEXICAN ELDERS TREES 1.5 RUN EXTENTION CORDS FOR BINGO KITCHEN ALSO SETUP BINGO STAND AND MACHINE AND CHECK IT OUT 1.0 PICKUP KEY FROM MANNY AT HIGH SCHOOL 1.5 EMPTY TRASH CANS FILL OUT DAILY WORK LOG 5/6 - 7.5	5/9/2005 5/6/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1738	Complete ENRIQUE SOTELO NEED TO SETUP ELECTRICAL BOARD OUTLETS FOR SPRING FESTIVAL FRIDAY 5/13/05 install panel box w/temp outlets.	5/9/2005 5/18/2005 Medium	Ramiro Holguin Enrique Sotelo		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1946	Closed Work Orders 5/12/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES 1.0 TRIM GRASS AROUND PALM TREES WITH WEED EATER 1.5 MOW GRASS FRONT LAWN AND EAST PLAYGROUND 1.0 HELP JAIME PUT A/CS ON ROOF TOP 1.5 EMPTY TRASH CANS REPAIR BOARDS ON RAMP P.137 1.5 HELP JAIME AND ENRIQUE INSTALL A/C ROOMS 126,131 1.0 TRIM MEXICAN ELDER FILL OUT DAILY WORK LOG 5/12 - 8	5/16/2005 5/12/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1947	Closed Work Orders 5/13/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES 1.0 PICKUP SUPPLIES AT P.P. 6.5 HELP SETUP FOR SPRING FESTIVAL AND PICKUP TRASH 5/13 - 8	5/16/2005 5/13/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
1977	Work In Progress 5/17/05 GROUNDS NEED TRACTOR TO REMOVE BROKEN CONCRETE AND CONCRETE SLAP TO RELOCATE SEE-SAW	5/17/2005 Medium	Ramiro Holguin Lorenzo Hernandez		Berino ES
1975	Closed Work Orders 5/16/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES 0.5 SEND IN DALIY WORK LOG AND W.O. CHECK EMAIL 1.5 WATER EVERYTHING IN FRONT OF BUILDING CUT WEEDS 1.5 WATER MEXICAN ELDER TREES AND COURTYARD AREA EMPTY TRASH FOR FIELD DAY 5/16 - 4	5/17/2005 5/16/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
2104	Closed Work Orders 5/17/05 0.5 ROUTINE CHECK WIYH JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 3.0 CHANGE OUT A/C MOTOR IN KITCHEN AREA ALSO REPAIR FLOAT ON GYM A/C BREAK DOWN OID A/CS TO REMOVE FROM ROOF TOP 0.5 ANCHOR DOWN PARKING CURBS 1.5 REPLACE SOAP DESPENSORS IN ALL BOYS RESTROOMS 2.0 CHECK ALL SPRINKLERS IN PLAYGROUND AND MARK THE ONES NOT WORKING FILL OUT DAILY WORK LOG 5/17 - 8	5/19/2005 5/17/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2105	Closed Work Orders 5/18/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES 2.0 CUT WEEDS IN FRONT OF WEST PARKING AND WATER EVERYTHING IN FRONT OF BUILDING 1.5 CUT WEEDS ALONG FENCE LINE IN NORTHWEST WALL 2.5 REMOVE WET SHEETROCK AND INSTALL NEW ONE ALSO COVER WITH CAM LITE PANELING 0.5 UNCLOG TOILET ROOM 100 0.5 FILL IN DAILY WORK LOG 5/18 - 7.5	5/19/2005 5/19/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
2247	Work In Progress MANNY LOZOYA PORTABLE 140 DOOR NEEDS CLOSURE AND PORTABLE 151 CORE IN HANDLE NEEDS TO BE CHECK OUT KEYS DO NOT WORK	5/24/2005 Medium	Ramiro Holguin Hector Lozoya		Berino ES
2273	Closed Work Orders 5/24/05 0.5 CHECK WITH JIMMY CLOSE GATES 1.5 CUT WEEDS ALONG WESTSIDE PONDING AREA ALSO PICKUP TRAS ALONG EASTSIDE OF BUILDING 2.0 CHECK OUT A/C ROOM 106 AND GYM A/C ON WESTSIDE ALSO REPLACE BELT ON COMPUTER LAB A/C 1.0 CHANGE OUT MARQUEE SIGN 2.5 MOW GRASS ON WESTSIDE OF PLAYGROUND ALSO AROUND PINE TREES 0.5 FILL IN DAILY WORK LOG 5/24 - 8	5/25/2005 5/24/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
2271	Closed Work Orders 5/20/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES 2.0 WATER EVERYTHING IN FRONT OF BUILDING ALSO CUT WEDS PICKUP TRASH 1.5 MOW COURTYARD AREA WATER LAWN AND MEXICAN ELDER TREES 1.0 CHANGE OUT A/C PUMP ROOM 124 AND P.1147 0.5 EMPTY TRASH CANS 1.0 INSTALL SOAP DESPENSERS IN ALL GIRLS RESTROOMS 1.0 CHANGE OUT ELECTRICAL BALLAST FRONT LOBBY 0.5 FILL IN DAILY WORK LOG 5/20 - 7	5/25/2005 5/20/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2267	Closed Work Orders 5/18/05 0.5 ROUTINE CHECK WITH JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 1.5 REMOVE ALL A/C AND MATERIAL FROM ROOF TOP HELP JAIME 0.5 PICKUP ALL OLD A/C AND PARTS 1.0 MEETING WITH MIKE, ALFERDO, MR. CHAVEZ ON PORTABLE TO BE MOVED 2.0 TRIM MEXICAN ELDER TREE AND PICKUP BRANCHES 1.0 ASSIST HUMFREYS PESTICIDE 0.5 HELP MIKE MEASURE PORTABLES AND GATES 0.5 FILL IN DAILY WORK LOG 5/18 - 8	5/25/2005 5/18/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
2405	Closed Work Orders 5/31/05 0.5 CHECK WITH JIMMY CLOSE GATES 2.0 WATER EVERYTHING IN FRONT OF THE BUILDING ALSO CUT WEEDS AROUND ROSE BUSHES 0.5 CHECK WITH DANNY ON PORTABLES TO BE WORKED ON DURING THE SUMMER BREAK 1.0 WATER PINE TREES ON WESTSIDE FENCE LINE ALSO EMPTY TRASH CANS 1.5 CUT WEEDS ON EASTSIDE OF PLAYGROUND ALSO TRIM MEXICAN ELDER TREE 0.5 GET WITH MIKE AND CORDONA ON PORTABLES TO BE TAKEN AWAY 5/31 - 6	6/1/2005 5/31/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
2378	Closed Work Orders 5/26/05 0.5 CHECK WITH JIMMY CLOSE GATES 1.0 CHECKING WITH TEACHERS ON ROOMS GETTING PAINTED 0.5 UNCLOG TIOLET ROOM 100 2.0 HELP RAUL CHECK MONITORING WELLS 1.0 CHANGE OUT ELECTRICAL BALLAST TEACHERS LOUNGE 0.5 REPAIR ELECTRICAL OUTLET IN GYM 1.5 CHECK ALL SPRINKLERS IN PLAYGROUND TO REPLACE THE ONES NOT WORKING AND FILL IN DAILY WORK LOG 5/26 - 7	5/31/2005 5/26/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
2379	Closed Work Orders 5/27/05 1.5 CAME IN TO CHECK POWER OUTAGE 1.0 CHECK EVERYTHING WENT POWER CAME BACK ON 1.5 PICKUP SUPPLIES AT P.P. 1.0 HELP MANNY WITH DOORS 2.0 REPAIR BROKEN SPRINKLERS 1.0 EMPTY TRASH CANS FILL OUT DAILY WORK LOG 5/27 - 8	5/31/2005 5/27/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2816	Work In Progress RUBEN RONQUILLO NEED DOOR WINDOW REPAIRED PORTABLE 139 ALSO WINDOW BAR WIRE REPLACE OR REPAIRED CASE# 05-05236	6/16/2005 Medium	Ramiro Holguin Ruben Ronquillo		Berino ES
2817	Work In Progress RUBEN RONQUILLO NEED WINDOW IN PORTABLE 136 REPLACE AND ALSO WINDOW WIRE. CASE# 05-05236	6/16/2005 Medium	Ramiro Holguin Ruben Ronquillo		Berino ES
2706	Complete BROKEN WINDOWS Damage to Violins and two guitars missing so far. Case# 05-04998 - Andy Luna #959	6/10/2005 6/10/2005 Medium	Ramiro Holguin Ruben Ronquillo		Berino ES
2652	Closed Work Orders 6/08/05 0.5 CHECK WITH JIMMY AND CORDONA ON PAINTING HIS OFFICE 2.0 WATER EVERYTHING IN FRONT OF BUILDING CUT WEEDS PICKUP TRASH 1.5 HELP JIMMY MOVE FURNITURE TO STORAGE SHED 1.0 MOW FRONT LAWN AND COURTYARD AREA 2.5 BOARD UP BROKEN WINDOW IN P.139 MAKE VANDALISM REPORT 0.5 FILL IN DAILY WORK LOG 6/8 - 8	6/9/2005 6/8/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
2650	Closed Work Orders 6/07/05 1.0 SEND IN DAILY WORK LOG FOR THE PAST 5 DAYS AND W.O. CHECK EMAIL 3.0 WORK ON HOOKING EVERYTHING BACK ON PORTABLES THAT WERE GOING TO BE REMOVED 2.5 HELP JAIME INSTALL A/C BACK ON PORTABLES 1.0 HELP DANNY REMOVE CARPET P. 142 0.5 FILL IN DAILY WORK LOG 6/7 - 8	6/9/2005 6/7/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
2568	Closed Work Orders 6/02/05 0.5 CHECK WITH JIMMY CLOSE GATES 1.5 EMPTY TRASH CANS CUTWEEDS IN PONDING AREA NEXT TO BUSES TURNAROUND 2.0 MOW GRASS ON WESTSIDE OF PLAYGROUND ALSO COURTYARD AREA 2.0 ATTEND SCHOOL BANQUET 6/2 - 6	6/7/2005 6/2/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2570	Closed Work Orders 6/03/05 1.5 WATER EVERYTING IN FRONT OF BUILDING 6.0 HELP REMOVE PORTABLES RAMPS STAIRS FENCE ETC. 0.5 FILL IN DAILY WORK LOG 6/3 - 8	6/7/2005 6/3/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
2574	Closed Work Orders 6/06/05 1.5 PICKUP TRASH CLEAN UP ROCKS AND BRICKS WERE PORTABLES WERE REMOVED 1.5 WATER EVERYTHING IN FRONT OF BUILDING 1.0 WENTTO ANTHONY ELEM. SO LUCKY COULD SHOW ME ALARM CODE FOR THAT SCHOOL 1.0 W.O.2554 1.5 HELP JAIVER AND CARLOS WITH MOTION DETECTORS ON WESTWING 6/6 - 5.5	6/7/2005 6/6/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
2550	Complete ENRIQUE SOTELO OVEN NEEDS TO BE CHECK OUT NO POWER TRANSFORMER IS BURN OUT change out lighting contactor for outlets.	6/6/2005 6/28/2005 Medium	Ramiro Holguin Enrique Sotelo		Berino ES
2551	Work In Progress 5/26/05 0.5 CHECK WITH JIMMY CLOSE GATES 1.0 CHECHING WITH TEACHERS ON ROOMS TO BE PAINTED 0.5 UNCLOG TIOLET ROOM 100 2.0 HELP RAUL CHECK WELLS 1.0 CHANGE OUT ELECTRICAL BALLAST TEACHERS LOUNGE 0.5 REPAIR BROKEN ELECTRICAL OUTLET IN GYM 1.5 CHECK ALL SPRINKLERS IN PLAYGROUND CHANGE OUT THE ONES NOT WORKING FILL OUT DAILY WORK LOG 5/26 - 7	6/6/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
2566	Closed Work Orders 6/01/05 0.5 CHECK WITH JIMMY CLOSE GATES 0.5 SEND IN DAILY WORK LOG AND W.O. CHECK EMAIL 3.0 IT WAS MOVING DAY FOR TEACHERS HELP JIMMY 1.5 EMPTY ALL TRASH CANS REPAIR BROKEN BOARD ON RAMP P.137 1.0 STARTED INSTALLING NEW TOWEL DESPENSOR IN MENS RESTROOM EASTWING 1.5 MONTHLY P.M. AND INSPECTION ON ALL MAINTENANCE LOGS FILL OUT DAILY WORK LOG 6/1 - 8	6/7/2005 6/1/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
3043	Closed Work Orders 6/27/05 1.5 WATER EVERYTHING IN FORNT OF BUILDING 5.0 2755 HELP DANNY 0.5 FILL IN DAILY WORK LOG 6/27 - 2	6/28/2005 6/27/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
3037	Closed Work Orders 6/21/05 0.5 CHECK WITH JIMMY MOVE MY PAINT STUFF TO NEXT ROOM 7.0 HOOKUP EXTENTION CORDS FOR P. 142 START INSTALLING NEW FLOOR 0.5 FILL IN DAILY WORK LOG 6/21 - 8	6/28/2005 6/21/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
3040	Closed Work Orders 6/22/05 1.5 WATER EVERYTHING IN FRONT OF BUILDING PICKUP TRASH 1.0 CUT WEEDS ALONG EAST FENCE LINE PICKUP TRASH 1.5 SPRAY ROUNDUP ON WEEDS AROUND PONDING AREA 3.5 PAINT PRINCIPAL OFFICE AND VICE P. TOO 0.5 FILL IN DIALY WORK LOG 6/22 - 8	6/28/2005 6/22/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
3041	Closed Work Orders 6/23/05 4.0 CHECK OUT SPRINKERS MAKE AJUSTMENTS ALSO REPLACE THE ONE NOT ROTATING ALSO SPRINKERS ON NORTH WALL HAD TO BE RISED UP 3.5 FINISH PAINTING ROOM 113 STARTED PREPARING ROOM 120 FOR PAINTING 0.5 FILL IN DAILY WORK LOG 6/23 - 8	6/28/2005 6/23/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
3045	Closed Work Orders 6/28/05 7.0 SWEEP FRONT PARKING LOTS AND BUSES TURNAROUND AND DRIVEWAYS WITH BOBCAT SWEEPER 1.0 SEND ALL MY DAILY WORK LOGS THE A HAD 6/28 - 8	6/28/2005 6/28/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
2901	Closed Work Orders 6/15/05 1.5 WATER EVERYTHING IN FRONT OF BUILDING MOW FRONT LAWN 1.0 STARTED MOWING WESTSIDE OF PLAYGROUND 1.0 HELP DANNY AND LORENZO LEVEL PORTABLE 4.0 W.O.2766 0.5 FILL OUT DAILY WORK LOG 6/15-8	6/20/2005 6/15/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2902	Closed Work Orders 6/16/05 1.5 CUT MORE WEEDS ALONG NORTH FENCE LINE 1.5 GO TO P.P. FUEL UP WORK TRUNK AND TAKE REPORT OF VANDALISM TO MIKE 1.0 STARTED MOW GRASS ON EASTSIDE OF PLAYGROUND 2.0 FINISH MOWING GRASS 1.0 BOARD UP BROKEN WINDOW IN P. 136 SECURE BAR WIRE ON WINDOW 1.0 TALK TOO MIKE AND CHAVEZ ON BREAK IN FILL OUT DAILY WORK LOG	6/20/2005 6/16/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
	6/16-8				
2903	Closed Work Orders 6/17/05 1.0 LOOK OVER BREAKIN WITH JIMMY AND SHERIFFS 1.5 WATER EVERYTHING IN FRONT OF BUILDING 1.5 REMOVE ALL TRASH FRONT UNDER PORTABLE 142 1.0 PICKUP TRASH FROM P.142 2.5 PUT GREASE ON POLES THAT RUN ALONG BUILDING ALSO PUT PLASTIC WRAP ON BROKEN SKY LIGHT ALSO PUT GREASE TOP OF WALK IN FREEZER 0.5 FILL IN DAILY WORK LOG	6/20/2005 6/17/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
	6/17-8				
2904	Closed Work Orders 6/20/05 1.5 WATER EVERYTHING IN FRONT OF BUILDING 6.0 PAINT ROOM 113 0.5 FILL IN DAILY WORK LOG	6/20/2005 6/20/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
	6/20-8				
2942	Closed Work Orders 6/21/05 0.5 CHECK WITH JIMMY ALSO SHOW CONTRACTOR THE PHONE ROOM IS AND UNIT WITH THE BACKUP BATTERYS 7.0 HELP DANNY START INSTALLING NEW FLOOR P.142 0.5 FILL IN DAILY WORK LOG	6/22/2005 6/21/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
	6/21 - 8				
2943	Work In Progress ANGEL G NEED BOBCAT TO REMOVE SOME SAND WERE PORTABLES WERE SETUP	6/22/2005 Medium	Ramiro Holguin Angel Gonzales		Berino ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2897	Closed Work Orders 6/09/05 1.5 CUT WEEDS INSIDE SWING SET INSIDE COURTYARD AREA 0.5 REMOVE BLACK BOARDS FROM P. 149 4.5 HELP REMOVE FLOOR P.142 1.0 HELP BETO WITH RAMPS FOR PORTABLES 0.5 FILL IN DIALY WORK LOG 6/9 8	6/20/2005 6/9/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
2898	Closed Work Orders 6/13/05 2.0 WATER EVERYTHING IN FRONT OF BUILDING CUT WEEDS PICKUP TRASH 1.0 CUT WEEDS ALONG NORTH FENCE LINE 4.5 W.O. 2766 0.5 FILL OUT DAILY WORK LOG 6/13-8	6/20/2005 6/13/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
2899	Closed Work Orders 6/14/05 4.0 W.O. 2766 1.5 PICKUP TRASH WERE PORTABLES WERE REMOVED AND BRINKS 1.0 PUT BACK FENCE WERE IT WAS REMOVED FOR PORTABLES BE TAKED OUT 1.5 CLEAN UP PORTABLE PICKUP EXTENSION CORDS FILL OUT DAILY WORK LOG 6/14-8	6/20/2005 6/14/2005 Medium	Ramiro Holguin Ramiro Holguin		Berino ES
2766	Closed Work Orders 6/14/05 6.5 Assisted at Berino Elementary on portable with repairing floor. 6/14 - 6.5	6/14/2005 6/14/2005 Medium	Lorenzo Solis Margret Villalobos		Berino ES
1208	Complete connect 4 mastercools CONNECT NEW 4 AC IN MAIN BUILDING CLASSROOMS	4/18/2005 4/18/2005 Medium	Jaime Gomez Enrique Sotelo	Classroom	Berino ES
777	Closed Work Orders 4-mover todo lo del salon 4 al salon 96 4- linpiar master cool en ch. desert t/	4/1/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
778	Closed Work Orders 03/31/05 4-mover todo lo del salon 4 al salon 96 4- linpiar master cool en ch. desert t/	4/1/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
933	Closed Work Orders 04/01/05 2-p. plant pick up suplays 6-work ordes 123269 4/1 - 8	4/7/2005 4/1/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
934	Closed Work Orders 04/06/05 8-work ordes 123569 4/6 - 8	4/7/2005 4/6/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
935	Closed Work Orders 04/07/05 8-work orders 123269 4/5 - 8	4/7/2005 4/5/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
936	Closed Work Orders 04/07/05 8-work orders 123269 4/4 - 8	4/7/2005 4/4/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
968	Closed Work Orders 04//07/05 8-123269 4/7 - 8	4/8/2005 4/7/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
969	Closed Work Orders 04/08/05 1-123269 painting 1-repair sprinkles 6- cut and remove weeds around the school 4/8 - 8	4/8/2005 4/8/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
970	Complete many losoya -need one kay for consecion stand door -A 31 cut key A31 and rekey pad lock for concession stand.	4/8/2005 4/13/2005 Medium	Juan Vargas Hector Lozoya		Chaparral ES
1189	Closed Work Orders 04/13/05 4-work on air conditions 4-recoger material y aser 6 art show tables 4/13 - 8	4/15/2005 4/13/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1190	Closed Work Orders 04/14/05 2-llebar art tables a g. m. school 6- work on air conditions 4/14 - 8	4/15/2005 4/14/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1191	Closed Work Orders 04/15/05 2- pick up suplays on p. plan 6- work on air conditions 4/15 - 8	4/15/2005 4/15/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1036	Closed Work Orders 04/11/05 8-work e, wing air acondionado 4/11/05 - 8	4/11/2005 4/11/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1033	Closed Work Orders 04/11/05 8-work on the e. wing service master coolings 4/11 - 8	4/11/2005 4/11/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1072	Complete 04/12/05 enrique sotelo rooms 63 60 62 61 need two speed disconnect INSTALLED FLEX AND DISCONNECTED FOR 4 AC. THAT WERE LIT UP TEMPORARILY	4/12/2005 4/14/2005 Medium	Juan Vargas Enrique Sotelo		Chaparral ES
1075	Work In Progress 04/12/05 enrique sotelo main bldg. need new timer for the outside lites	4/12/2005 Medium	Juan Vargas Enrique Sotelo		Chaparral ES
1079	Closed Work Orders 04/12/05 8-work air conditioning 4/12/05 - 8	4/12/2005 4/12/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2911	Closed Work Orders 06/16/05 8- repair floor room 81 6/16-8	6/21/2005 6/16/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2912	Closed Work Orders 06/17/05 2-work floor room 81 3- tomar informacion de los aires 1- fix air co. on m. school con joe ramirez 2- fix lighting rooms 129 128 130 131 and127 6/17-8	6/21/2005 6/17/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2913	Closed Work Orders 06/20/05 4- cortar sacate y llerva 1- fix sprinkler 2 -126597 1-126598 6/20-8	6/21/2005 6/20/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2829	Work In Progress 06/16/05 rooms 81 82 and 72 need window repair	6/16/2005 Medium	Juan Vargas Ruben Ronquillo		Chaparral ES
3038	Closed Work Orders 06/23/05 8-fix and painting walls room 81 6/23 - 8	6/28/2005 6/23/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
3039	Closed Work Orders 06/24/05 6-fix and painting walls room 46 2- p.plant 6/24 - 8	6/28/2005 6/24/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
3036	Closed Work Orders 06/21/05 4-fix e. wing roof 2- put round up 2- 126599 6/21 - 8	6/28/2005 6/21/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
3065	Closed Work Orders 06/27/05 4- 124067 4- repair floor room 81 6/27 - 8	6/29/2005 6/27/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
3066	Closed Work Orders 06/28/05 4- fix and replace sprinklers 4- cut weeds and. grass 6/28 - 8	6/29/2005 6/28/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2792	Closed Work Orders 06/14/05 8-work con ruben ronquillo 6/14 - 8	6/15/2005 6/14/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2793	Closed Work Orders 06/15/05 8- repair floor room 81 6/15 - 8	6/15/2005 6/15/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2760	Work In Progress SECURE STORAGE	6/14/2005 Medium	Juan Vargas Hector Lozoya		Chaparral ES
2735	Closed Work Orders 06/09/05 4- paint ceiling walls and door gym. 2- regar arboles 2- paint moulding and doors rooms 101 and 102 6/9 - 8	6/13/2005 6/9/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2736	Closed Work Orders 06/10/05 4-p. plant pick up materials 1- fix air co, on maint office 2- fix outside water faunting 1-` enparejar con el scraiper 6/10 - 8	6/13/2005 6/10/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2737	Closed Work Orders 06/13/05 8- cortar sacate y llerva round the school 6/13 - 8	6/13/2005 6/13/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2738	Work In Progress 06/13/05 mike munos need to clean the parking	6/13/2005 Medium	Juan Vargas		Chaparral ES
2733	Closed Work Orders 6/08/05 2- paint hallway 6-fix ceiling and walls on gym. 6/8 - 8	6/13/2005 6/8/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2612	Closed Work Orders 06/06/05 8 -fix hallway walls and paint 6/6 - 8	6/8/2005 6/6/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2613	Closed Work Orders 06/07/05 8-fix hallway walls and paint 6/7 - 8	6/8/2005 6/7/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2598	Closed Work Orders 06/02/05 1-service air co. room 60 and 61 4- cut weeds 2- put round up round the school 1- fix window and blind. room 72 6/2 - 8	6/7/2005 6/2/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2531	Void Front Office - Teachers can not call up to office, intercom does not work. THIS IS A TECHNOLOGY WORK ORDER. - MKV 126620	6/6/2005 Medium	Jennifer Corral Margret Villalobos	Office	Chaparral ES
2536	Work In Progress Meza lost keys:He did pay to replace the ones he lost. Meza is room # 130. Rosalinda Mendez would like keys to her filing cabinet. She never got any keys, she has been having to borrow the keys in the office. Mendez is in room #122. Manuela Ledesma needs keys for her room. She never received any. She is room # 114.	6/6/2005 Medium	Jennifer Corral Hector Lozoya	Classroom	Chaparral ES
206	Complete Room 54 - Door will not open afraid of students getting locked in there as per Mr. See. (informed Danny Miranda)-mkv replace locks 2 rooms and rekey old cores.	3/9/2005 3/14/2005 Medium	Margret Villalobos Danny Miranda	Classroom	Chaparral ES
2316	Work In Progress E-WING - FINISH REPAIRING THE PORCH.	5/26/2005 Medium	Michael Munoz Juan Vargas		Chaparral ES
771	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. COMPLETED PER DANIEL RAMIREZ	4/1/2005 4/14/2005 Medium	Aida Salcedo Daniel Ramirez		Chaparral ES
2311	Work In Progress Room 81 need a price quote for new carpet and cove base.	5/26/2005 Medium	Michael Munoz	Classroom	Chaparral ES
2356	Work In Progress P{lease replace cove base thru out site where needed.	5/27/2005 Medium	Juan Vargas		Chaparral ES
1080	Work In Progress START ON WOOD FLOORS E-WING	4/12/2005 Medium	Danny Miranda Danny Miranda		Chaparral ES

7/1/2005 10:40:45 AM

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1823	Complete jimmy/carbajal/need/repairs/for/vaccum/roller/bearings/broken/ REPLACED PARTS (ISSUED THRU ACT 1000) AND ALSO DID A P.M. AS PER JIMMY.	5/11/2005 6/1/2005 Medium	Daniel Ramirez Jimmy Carbajal		Chaparral ES
1824	Complete 05/11/05 manuel lozoya room 129 the loock not open need fix	5/11/2005 5/17/2005 Medium	Juan Vargas Hector Lozoya		Chaparral ES
1773	Closed Work Orders 05/06/05 4- cortar sacate 1- servicio main northside door 3- enparejar con la sraiper 5/6 - 8	5/10/2005 5/6/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1774	Closed Work Orders 05/09/05 2- regar los arboles 4- ayudar a lorenzo solis tomar informasion de los aires 2-pintar oficina 5/9 - 8	5/10/2005 5/9/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1769	Complete 05/10/05 enrique nesesito un outlet en la oficina INSTALL OUTLETS FOR COMPUTER FOR BLDG MECHANIC	5/10/2005 5/24/2005 Medium	Juan Vargas Enrique Sotelo		Chaparral ES
1771	Closed Work Orders 05/05/05/ 1-put aluminium blind on room 2 3- cortar cemento y poner sign 1-cambiar ceilingtile room 129 1-servisio aire co. room 124 5/5 - 6	5/10/2005 5/5/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1767	Work In Progress 05/10/05 lorenzo hernandez nesesito que enparege con el tractor a round the school	5/10/2005 Medium	Juan Vargas Lorenzo Hernandez		Chaparral ES
1871	Work In Progress 05/11/05/ jaime gomes cafeteria need new air conditioning	5/12/2005 Medium	Juan Vargas Jaime Gomez	Cafeteria	Chaparral ES
1906	Closed Work Orders 05/10/05 1-help johnny a. put new wood on ramp 1-fix water key on room 133 4-paint fix walls on cafeteria ofice 1- service air conditionig room 117 1-service air conditionig room 129 5/10 - 8	5/12/2005 5/10/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1908	Closed Work Orders 05/11/05 1-fix water leks room 134 4-help johnny a. fix ramp on desert t. school 1-change air 2-servisio electrico aire de la cafeteria 5/11 - 8	5/12/2005 5/11/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1909	Closed Work Orders 05/12/05 2-cortar llerva 3- servicio a los sprinklers 1- fix door room 96 2-ayudar a beto sacar tierra de los colunpios 5/12 - 8	5/12/2005 5/12/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1707	Complete 05/06/06 door need to be repair at norhtside entrence assoon asposible not locking repair panic bar	5/6/2005 5/6/2005 Medium	Juan Vargas Hector Lozoya		Chaparral ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1653	Closed Work Orders 05/04/05 4- put new air condition on gym 2- electric sevice air condition room 114 1- regar arboles 1-cambiar balastra y luces en lan cosina 5/4 - 8	5/4/2005 5/4/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1648	Complete 05/04/05 enrique sotelo need help on air condition room 114 ARREGALAR CORTO IN A/C	5/4/2005 5/19/2005 Medium	Juan Vargas Enrique Sotelo		Chaparral ES
1649	Closed Work Orders 04/29/05 2-lebantar suplays p. plant 4-cortar llerva con la rastra 2- cambiar balastras y luces en la cafeteria 4/29 - 8	5/4/2005 4/29/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1650	Closed Work Orders 05/02/05 2- regar arboles 4- fix play grouns sprinklers 2- troable shoting on air condition room 114 5/2 - 8	5/4/2005 5/2/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1651	Closed Work Orders 05/03/05 4- move storage gabinet and books shelves and asanbley especial maters on room 55 4- work fix ramp put new wood on desert t. school 5/3 - 8	5/4/2005 5/3/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1491	Closed Work Orders 04/20/05 8-work on air conditions 4/20 - 8	4/28/2005 4/20/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1492	Closed Work Orders 04/21/05 8- cortar sacate y recoger sacate cortado 4/21 - 8	4/28/2005 4/21/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1493	Closed Work Orders 04/22/05 4- fence repair 4-cortar llerva con la rastra 4/22-8	4/28/2005 4/22/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1494	Closed Work Orders 04/25/05 4- 125851 1- canviar balastras on boys restrooms 3-cortar llerva 4/25 - 8	4/28/2005 4/25/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1495	Closed Work Orders 04/26/05 2-cambiar balastras y luces room 125 1- cambiar ceilintile on library 1.5 destapar bano en e. wing 4/26 - 4.5	4/28/2005 4/26/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1496	Closed Work Orders 04/27/05 4-work on fix sprinklers 2- 125849 2- 125850 4/27 - 8	4/28/2005 4/27/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1497	Closed Work Orders 04/28/05 1-servisio air condition room 96 1- poner rejilla de air condition room 96 and 57 6- cortar sacate y llerva round the school 4/28 - 8	4/28/2005 4/28/2005 Medium	Juan Vargas Margret Villalobos		Chaparral ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1422	Work In Progress 04/26/05/jaime gomes library need 3 new master cools	4/26/2005 Medium	Juan Vargas Jaime Gomez		Chaparral ES
1423	Closed Work Orders 04/18/05 8-work air conditions 4/18 - 8	4/26/2005 4/18/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1424	Closed Work Orders 04/19/05 8- work on air conditios 4/19 - 8	4/26/2005 4/19/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1369	Work In Progress Automobile ran thru about 70ft of fence and 1 gate. Fence is located between DT and CHE Northend of Mc Combs. Case # 2005-03486 Deputy Williams	4/22/2005 Medium	Juan Vargas Michael Munoz		Chaparral ES
2314	Work In Progress 05/26/05 lorenzo nesesito ayada para ubicar los sprinklers	5/26/2005 Medium	Juan Vargas Lorenzo Hernandez		Chaparral ES
2483	Closed Work Orders 05/25/05 2- cortar llerva 1- fix water fountain 2- 126299 1-126300 --2 service air co. on librerary 5/25 - 8	6/3/2005 5/25/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2484	Closed Work Orders 5/26/05 2-servisio air con. on miusic room. 2- 133601 3- change sprinkler on norht playground 1-service e. wing boys restrooms 5/26 - 8	6/3/2005 5/26/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2485	Closed Work Orders 05/27/05 2-p. plat pick up suplays 2- cortar llerva 1- fix playgroun swing 1-fix water foutain 1-service air co. on room 63 1- change lights and balastra room 117 5/27-8	6/3/2005 5/27/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2486	Work In Progress 05/31/05 2- put round up round the school 4- linpiar los techos 2- regar los arboles 5/31-8	6/3/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2490	Closed Work Orders 06/01/05 4- cortar sacate 2- fix leaks change ceilingtile on library 1-change lights and balastra room 124 1-fix door room 124 6/1-8	6/3/2005 6/1/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2076	Void 05/08/05 the play ground have scorpions emergency please AS PER LESTER HUMPHREY THERE IS NOT MUCH THAT CAN BE DONE FOR A SCORPION OUTSIDE ON THE PLAYGROUNDS. IT WOULD NOT BE FEASIBLE OR COST EFFECTIVE TO TRY TO TREAT THE ENTRIE PLAYGROUND. VOID AS PER A. HOLGUIN. 5/31/05 - MKV	5/18/2005 Medium	Juan Vargas Margret Villalobos		Chaparral ES
2121	Work In Progress Air condition on cosesion stand need new motor 2 peed	5/19/2005 Medium	Juan Vargas Jaime Gomez		Chaparral ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2122	Closed Work Orders 05/18/05 1- servicio aire room 2 7--125618 5/18 - 8	5/19/2005 5/18/2005 Medium	Juan Vargas		Chaparral ES
2133	Closed Work Orders 05/19/05 8- fix holes painting on the cafeteria walls 5/19 - 8	5/19/2005 5/19/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2134	Duplicate Request 05/19/05 8- fix holes painting on the cafeteria walls 5/19 -8	5/19/2005 5/20/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2131	Closed Work Orders 05/19/05 8- fix holes painting on the cafeteria walls 5/19 - 8	5/19/2005 5/19/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2216	Closed Work Orders 05/22/05 2-poner molduras on rooms 101 and 102 1- servicio aire room 256 5- monhly inspections 5/22 - 8	5/23/2005 5/22/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2218	Closed Work Orders 05/23/05 2-servisio air on librerary 4- air condition service rooms 72 70 80 57 and music room 2-monthly inspections 5/23 - 8	5/23/2005 5/23/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2046	Closed Work Orders 05/17/05 2- regar los arboles 1-servisio aire room 62 5- put new ceilingtile fix walls holes change lites on cafeteria 5/17 - 8	5/17/2005 5/17/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
2043	Complete 05/17/05 fred need fix water valve bejain the barracks REPAIR LEAK ON WATER LINE AND INSTALLED 3/4 HOSE BIB	5/17/2005 5/17/2005 Medium	Juan Vargas Fred Appenzoller		Chaparral ES
1963	Closed Work Orders 05/13/05 2- p. plant pick up suplays 1- servicio aire room 117 4- enparejar con la troca 1- canviar luzes y balastra room 82 5/13 -8	5/16/2005 5/13/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1964	Closed Work Orders 05/16/05 2- desparramar arena en los columpios 6- cortar sacate y llerva al rededor de la school 5/16 - 8	5/16/2005 5/16/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
580	Closed Work Orders 3/22/05 4-safety training 2-cambiar luzes ybalastras fn new wing hallway 2-cortar llerva	3/23/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
582	Closed Work Orders 03/23/05 5-cortar sacate y llerva on ruond the school 3- 125617 fire ext. insp.	3/23/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
568	Closed Work Orders 03/14/05 checking electric panel on main bldg. 1-put caution tape round cements workers 6- repair floor room 96	3/22/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
569	Closed Work Orders 2-regar los arboles -6-repair floor room 96	3/22/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
570	Closed Work Orders 03/16/05 8-repair floor room 96	3/22/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
571	Closed Work Orders 03/18/05/ 8-repair floor room 96	3/22/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
572	Closed Work Orders 03/18/05 2-pickup suplays p. plant 6-painting room 96 and cleaning floor	3/22/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
660	Closed Work Orders 3/24/05 2-125615 2-125616 4-cambiar balastras luzes y ceilingtile on hallway and rooms 117 34 87 28 31	3/29/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
661	Closed Work Orders 3/29/05 8- removed 2 green boards shells and paint nurse room	3/29/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
662	Closed Work Orders 3/29/05 8- removed 2 green boards shells and paint nurse room	3/29/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
663	Closed Work Orders 3/29/05 8- removed 2 green boards shells and paint nurse room	3/29/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
468	Closed Work Orders 03/11/05 1- fix playgruond acuitmen 1-service door room 54 2-painting bus lines	3/16/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
469	Closed Work Orders 03/12/05 4-open gates cements workers on cambiar balastras y luzes	3/16/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
459	Complete door have problem to open on room 31 REKEY CORE AT RPP, 31 AND CLEAN LOCKSET.	3/16/2005 3/23/2005 Medium	Juan Vargas Hector Lozoya		Chaparral ES
460	Closed Work Orders 03/08/05 4-painting bus rodway line 2-service heater on librery 1-instaled new balastra and lamps on cafeteria 1-repair floor room 96	3/16/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
461	Closed Work Orders 2-painting bus lines 1-service door room 54 5- repair sub floor on room 96	3/16/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
437	Closed Work Orders 03/07/05/ 2-repair sub floor room 96 2-check gas leack on librery 1-service boys restrooms 3-paiting parkig lines	3/16/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
464	Closed Work Orders 3-working on playgruond sprinkler 2-repair floor room 96 1-intaled safety hasp room 47 2-help johnny a. serap water fountain	3/16/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
428	Closed Work Orders 2/25/05 5-cut weeds on around the school 1-help johnny on ch. desert t.	3/16/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
429	Closed Work Orders 2/26/05 2-abrir las puertas a trabajadores	3/16/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
430	Closed Work Orders 2/28/05 1-work on heater room 54 1-fix our toilet and room 127 6- sprayer roundup round on school fences	3/16/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
432	Closed Work Orders 3/01/05 4-cortar sacate north playgruond 1-service door room 256 3-remove green bord and istaled new bord	3/16/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
433	Closed Work Orders 03/02/05 replased outlet on room 63 1-serviced door rooms r1 and r2 6-painting parking lines	3/16/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
434	Closed Work Orders 03/03/05 3-work on electric outside safety lighting 1-remove shells and instaled new shells 2-service playgruons sprinclen 1-cut weebson bus drop roadway	3/16/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
435	Closed Work Orders 03/04/05/ 2-pickup suplays on p. plant 6-repair floor room 96	3/16/2005 Medium	Juan Vargas Juan Vargas		Chaparral ES
1407	Complete SMALL LEAK UNDER DISHWASHER. ALICE ESCALANTE SNP MGR 824-0048 REMOVED OLD DRAIN INSTALLED NEW DRAIN ON DISHWASHER	4/25/2005 5/3/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	Chaparral ES
2647	Work In Progress conectar portables	6/9/2005 Medium	Enrique Sotelo Enrique Sotelo	Portables	Chaparral MS
889	Complete DP 781 Monitoring data is due in this office before April 28, 2005 PREPARE DATA FOR D.P 781 AND TURN INTO OFFICE	4/6/2005 4/25/2005 Medium	Alfredo Holguin Ricardo Jacquez		Chaparral MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1854	Work In Progress Joe please order paint from Ruben so when portables arrive you can start painting them. Please call Mike	5/11/2005 Medium	Joe Ramirez	Portables	Chaparral MS
1454	Complete please cut weed in and around pressure tanks. CUT WEEDS AND CLEAN AROUND TANK.	4/27/2005 5/27/2005 Medium	Ricardo Jacquez		Chaparral MS
772	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. COMPLETED PER ROBERT GONZALEZ	4/1/2005 4/22/2005 Medium	Aida Salcedo Robert Gonzalez		Chaparral MS
2482	Complete walk-in at 60 degrees CHECKED WALK-IN ADJUSTED TIMER TIGHTENED LOOSE CONNECTION WORKING FINE	6/3/2005 6/8/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Chaparral MS
1129	Complete Keys - Need to issue keys to Joe Ramirez transferring from PPD to CHMID. Mike Mc Dermott will be turning in his keys. (April 29, 2005 - Payday) issued keys to new schools	4/14/2005 4/29/2005 Medium	Michael Munoz Hector Lozoya		Chaparral MS
831	Complete need to repair and replace motor box and gear box for back board. Gear box is stripped. R & R INSTALLED NEW MOTOR AND GEAR TO BB BACKBOARD	4/4/2005 4/20/2005 Medium	Michael Munoz Michael Munoz	Auditorium	Chaparral MS
1272	Closed Work Orders 4-18-5 8-HOURS GROUNDS MAINT. 4/18 - 8	4/20/2005 4/18/2005 Medium	Michael Mc Dermott Michael Mc Dermott		Chaparral MS GROUNDS
1273	Closed Work Orders 4-19-5 8-HOURS GROUNDS MAINT. 4/19 - 8	4/20/2005 4/19/2005 Medium	Michael Mc Dermott Michael Mc Dermott		Chaparral MS
1274	Closed Work Orders 4-20-5 8-HOURS A/C START UP CAFETERIA AND GYM. 4/20 - 8	4/20/2005 4/20/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Cafeteria	Chaparral MS A/C
1205	Closed Work Orders 4-13-5 8-HOURS A/C START UP. 4/13 - 8	4/18/2005 4/13/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Classroom	Chaparral MS 200 RMS
1206	Closed Work Orders 4-14-5 4-HOURS SET UP DISPLAYS FOR ART SHOW. 4-HOURS - GROUNDS MAINT. 4/14 - 8	4/18/2005 4/14/2005 Medium	Michael Mc Dermott Michael Mc Dermott		Chaparral MS ART SHOW
1207	Closed Work Orders 4-15-5 8-HOURS A/C START UP. 4/15 - 8	4/18/2005 4/15/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Classroom	Chaparral MS GYM AND LOCKER RMS.

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1052	Closed Work Orders 4-12-5 8-HOURS- BUILD 4 4X8 DISPLAY PEG BOARDS FOR ART SHOW. 4/12/05 - 8	4/12/2005 4/12/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Office	Chaparral MS ART ROOM
1003	Closed Work Orders 4-6-5 8-HOURS A/C START UP. 4/6 - 8	4/11/2005 4/6/2005 Medium	Michael Mc Dermott	Classroom	Chaparral MS 300 ROOMS
1004	Closed Work Orders 4-7-5 8-HOURS A/C START UP. 4/7 - 8	4/11/2005 4/7/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Classroom	Chaparral MS 200 ROOMS
1005	Closed Work Orders 4-8-5 8-HOURS START UP REFG. UNIT RM 205. 4/8 - 8	4/11/2005 4/8/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Classroom	Chaparral MS ROOM 205
1006	Closed Work Orders 4-11-5 8-HOURS GROUNDS MAINT. 4/11 - 8	4/11/2005 4/11/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Athletic Field	Chaparral MS GROUNDS
843	Closed Work Orders 4-4-5 8-HOURS A/C START UP. 4/4-8	4/5/2005 4/4/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Classroom	Chaparral MS 200 WING
844	Closed Work Orders 4-5-5 8-HOURS A/C START UP. 4/5 - 8	4/5/2005 4/5/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Classroom	Chaparral MS 200 WING
731	Closed Work Orders 3-22-5 4-HOURS CONTRACTOR CHANGING SPRINKLERS. 4-HOURS CONTRACTOR FIXING BASKETBALL GOALS.	3/31/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Hallway/Corridor	Chaparral MS 300
732	Closed Work Orders 3-23-5 8-HOURS A/C INSTALLATIONS.	3/31/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Classroom	Chaparral MS 100
733	Closed Work Orders 3-24-5 8-HOURS A/C INSTALATIONS.	3/31/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Classroom	Chaparral MS 100
734	Closed Work Orders 3-29-5 8-HOURS GROUNDS MAINT.	3/31/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Athletic Field	Chaparral MS GROUNDS
735	Closed Work Orders 3-30-5 8-HOURS- PAINTING HALLWAY.	3/31/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Hallway/Corridor	Chaparral MS 200
736	Closed Work Orders 3-31-5 8-HOURS A/C START UP.	3/31/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Classroom	Chaparral MS 300, 400
737	Closed Work Orders 4-1-5 8-HOURS A/C START UP.	3/31/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Classroom	Chaparral MS 400, 200
729	Closed Work Orders 3-21-5 8-HOURS GROUNDS MAINT.	3/31/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Athletic Field	Chaparral MS GROUNDS
382	Closed Work Orders 3-7-5- 8 HOURS GROUNDS MAINT.	3/15/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Classroom	Chaparral MS
510	Closed Work Orders 3-17-5 8-HOURS- WIRE NEW A/C 100 WING,	3/18/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Electrical Room	Chaparral MS 100 A/C

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
480	Closed Work Orders 3-16-5 8-HOURS INSTALLING NEW A/C.	3/17/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Mechanical Room	Chaparral MS 100 WING A/C
543	Complete Need to emergency lighting fixtures as per pm 125544.	3/18/2005 4/21/2005 Medium	Michael Mc Dermott Enrique Sotelo		Chaparral MS
384	Closed Work Orders 3-8-5- 8 HOURS REPAIR LEAK AT POND.	3/15/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Athletic Field	Chaparral MS POND AREA
385	Closed Work Orders FILL POND WITH WATER AND WATER PINE TREES AT POND.	3/15/2005 3/15/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Athletic Field	Chaparral MS POND AREA.
386	Closed Work Orders 3-10-5- 8 HOURS PAINTING HALLWAY PANELS.	3/15/2005 3/16/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Hallway/Corridor	Chaparral MS 300
387	Closed Work Orders 3-11-5 8- HOURS SET UP GYM FOR BB GAME. ALSO OFFICIATE GAME. 8TH GRADE VS FACULTY.	3/15/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Athletic Field	Chaparral MS GYM
388	Closed Work Orders 3-15-5- 8- HOURS INSTALL NEW AC UNITS 100 WING.	3/15/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Classroom	Chaparral MS 100 AC.
1513	Closed Work Orders 4-25-5 8-HOURS GROUNDS MAINT. 4/25 - 8	4/29/2005 4/25/2005 Medium	Michael Mc Dermott		Chaparral MS GROUNDS
1514	Closed Work Orders 4-26-5 8-HOURS PICK UP STAGING FROM UTEP AND INSTALL FOR FASHION SHOW. 4/26 - 8	4/29/2005 4/26/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Classroom	Chaparral MS
1515	Closed Work Orders 4-27-5 8-HOURS PAINT 100 HALLWAY . 4/27 - 8	4/29/2005 4/27/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Hallway/Corridor	Chaparral MS 100 HALL
1516	Closed Work Orders 4-28-5 4-HOURS TAKE DOWN STAGING AND RETURN TO UTEP. 4- HOURS CLEAN OUT SHED. 4/28 - 8	4/29/2005 4/28/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Computer Lab	Chaparral MS
1517	Closed Work Orders 4-29-5 8-HOURS MOVE MY SUPPLYS TO LOMA LINDA. 4/29 - 8	4/29/2005 4/29/2005 Medium	Michael Mc Dermott Michael Mc Dermott		Chaparral MS
1385	Closed Work Orders 4-2105 8-HOURS- A/C START UP 4/21 - 8	4/25/2005 4/21/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Electrical Room	Chaparral MS
1386	Closed Work Orders 4-22-5 8-HOURS GROUNDS MAINT. 4/22 - 8	4/25/2005 4/22/2005 Medium	Michael Mc Dermott Michael Mc Dermott		Chaparral MS GROUNDS
551	Complete 100, 200 & CAFETERIA - WIRING FOR REPLACEMENT MASTER COOLS. CONNECT 14 NEW A/C'S MAIN BLDG	3/18/2005 4/8/2005 Medium	Jaime Gomez Enrique Sotelo		Chaparral MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2919	Work In Progress 6/21/05. need to replace s.e. corner a/c gym area.	6/21/2005 Medium	Joe Ramirez Jaime Gomez		Chaparral MS
2873	Closed Work Orders 6/10/05. .5 building walk thru. 2.5 painting portable. 3.0 physical plant for supplies and misc. 1.5 continue painting. .5 clean up. 6/10-8	6/20/2005 6/10/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
2874	Closed Work Orders 6/13/05. .5 building walk thru. 6.5 painting portable rm. 143. .5 clean up. 6/13-7.5	6/20/2005 6/13/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
2875	Closed Work Orders 6/14/05. .5 building walk thru. 2.0 dismantle book shelves. 5.0 prepping and painting rm.144. .5 clean up. 6/14-8	6/20/2005 6/14/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
2876	Closed Work Orders 6/15/05. .5 building walk thru. 2.0 painting portable. 5.5 demolishing floor at C.H.E. 6/15-8	6/20/2005 6/15/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
2877	Closed Work Orders 6/17/05. .5 building walk thru. 1.5 trouble shooting a/c in office area installed new motor and switch. 6.0 painting portable. 6/17-8	6/20/2005 6/17/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
3019	Closed Work Orders 6/20/05. 3.0 applying round up and chopping and clearing weeds. 2.0 prepping and patching portable rm.12 2.0 fixing tables rm.103. 1.0 putting daily work log into system. 6/20 -8	6/28/2005 6/20/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
3021	Closed Work Orders 6/21/05. 4.5 cleaning and starting up a/c's gym area. 1.5 replacing lightbulbs. 2.0 replacing several door stops. 6/21 - 8	6/28/2005 6/21/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
3022	Closed Work Orders 6/22/05. 3.5 painting portable rm.12. 2.0 painting rm#'s on portable doors. 2.5 disassemble book shelves for storage. 6/22 - 8	6/28/2005 6/22/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
3023	Closed Work Orders 6/23/05. 5.0 finishing painting rm. 12. 2.5 replacing lightbulbs. .5 clean up. 6/23 - 8	6/28/2005 6/23/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
3024	Closed Work Orders 6/24/05. 2.0 watering trees. 2.0 p.p.d. for supplies. 1.0 finish touch-up rm. 12. 2.5 digging hole for post. .5 clean up. 6/24 - 8	6/28/2005 6/24/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
2661	Closed Work Orders 6/8/05. .5 building walk thru. 1.0 relocate dry erase board from rm.102 to 302. 6.0 painting portables. .5 clean up. 6/8 - 8	6/9/2005 6/8/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
2662	Closed Work Orders 6/9/05. .5 building walk thru. 1.0 spraying round up, court yard area. 1.0 fixing a/c rm. 202. 2.5 testing fire system with DIMAR inspectors. 2.5 painting portables. .5 clean up. 6/9 - 8	6/9/2005 6/9/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
2526	Closed Work Orders 5/31/05. .5 building walk thru. 6.5 secure area where portables are to be located and mark. tear down 2 fence lines. 1.0 put fence back up for security reason. 5/31 - 8	6/6/2005 5/31/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
2527	Closed Work Orders 6/2/05. .5 building walk thru. 2.5 trouble shooting a/c above cafeteria, cleaning up weeds in front of building. 2.5 watering pine trees. 1.0 putting line back up. 1.5 dragging ground behind building. 6/2 - 8	6/6/2005 6/2/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2528	Closed Work Orders 6/3/05. .5 building walk thru. 1.5 repair a/c above cafeteria stage. 4.0 dismantle stage, load up trailer and deliver back to N.M.S.U.,go to plant to drop off trailer & refuel. 2.0 comp-time taken. 6/3 - 8	6/6/2005 6/3/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
2589	Closed Work Orders 6/6/05. .5 building walk thru. 2.5 watering pine trees. 4.5 servicing refrig. units new portables. .5 clean up. 6/6 - 8	6/7/2005 6/6/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
2590	Closed Work Orders 6/7/05. .5 building walk thru. 1.5 cutting grass. 2.5 trouble shooting refrig. unit computer lab. 3.5 painting portables. 6/7 - 8	6/7/2005 6/7/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
1585	Closed Work Orders 4/22/05 .5 building walk thru. 4.5 edging along fence and building. 3.0 installing splash guard at old cafeteria. 4/22 - 8	5/3/2005 4/22/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
1586	Closed Work Orders 4/25/05 .5 building walk thru. .5 adjusting float on ac at ac/dc. 6.0 c.h.m. familiarizing myself with building. 1.0 lining soccer field. 4/25 - 8	5/3/2005 4/25/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
1587	Closed Work Orders 4/26/05. .5 building walk thru. 5.5 went to UTEP with mike to pick up runway for fashion show at C.M.S. stayed to continue to familiarize with building. 2.0 headed back to A.E. mote weed cutting. 4/26 - 8	5/3/2005 4/26/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1588	Closed Work Orders 4/27/05. all the below mentioned work done at A.E. .5 building walk thru. 1.0 watering trees. 2.0 cutting grass in front of old main building. .5 replacing lightbulbs at drug safe building. 1.0 working on boys urinal main building. 1.0 went to G.H.S. to pick up paint to line field. 1.5 lining soccer field. .5 pick up water hose and sprinkler.	5/3/2005 4/27/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
	4/27 - 8				
1590	Closed Work Orders 4/29/05. .5 building walk thru. 5.5 went to P.P.D. office to turn over keys, loaded trailer with furniture to take to C.M.S., went back to P.P.D. to turn in receipt paper. 1.0 went back to C.M.S. to drop off truck. 1.0 paper work and clear my belongings.	5/3/2005 4/29/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
	4/29 - 8				
1591	Closed Work Orders 5/2/05. .5 building walk thru. 4.5 cleaning storage building. 3.0 working on starting up several ac's.	5/3/2005 5/2/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
	5/2 - 8				
1981	Work In Progress 5/17/05. I NEED FOR ENRIQUE TO REPLACE A BATTERY IN ONE OF THE EMERGENCY LIGHT FIXTURES ,ALSO ONE OF THE LIGHTS IN THE GYM KEEPS COMING ON EVEN AFTER THE LIGHT SWITCH HAS BEEN TURNED OFF. THANK YOU.	5/17/2005 Medium	Joe Ramirez Enrique Sotelo		Chaparral MS
1912	Closed Work Orders 5/11/05. .5 building walk thru. 3.0 watering pine trees and locating meter boxes and trying to repair. 2.5 finish cleaning storage shed. 2.0 cutting plywood for coach Y. for activity day (friday).	5/12/2005 5/11/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
	5/11 - 8				
1913	Closed Work Orders 5/12/05. .5 building walk thru. 3.5 assemble audio-video carts for library. 1.5 working on water pump (fish pond). 2.5 installin new flush valves girls R.R. 300 wing.	5/12/2005 5/12/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
	5/12 - 8				

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1943	Closed Work Orders 5/13/05. .5 building walk thru. 1.5 set up for carnival. 2.0 warehouse to pick up material. 2.0 unclog drain rm. 307. odds and during carnival,example repair wire on softball throw.etc. 5/13 - 6	5/16/2005 5/13/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
1945	Complete 5/16/05. need for ENRIQUE to run power to storage shed so that I can plug in chargers PLEASE. . install tubing underground for 3 outlets for storage.	5/16/2005 5/24/2005 Medium	Joe Ramirez Enrique Sotelo		Chaparral MS
2025	Complete 5/17/05. need sensor replaced , wash basin 200 wing REPLACED SENSOR ON 200 WING MIDDLE RR.	5/17/2005 5/17/2005 Medium	Joe Ramirez Fred Appelzoller		Chaparral MS
2045	Void 5/17/05. margret need to reroute w.o.#1888 to enrique.	5/17/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
2028	Closed Work Orders 5/17/05. .5 building wLK THRU. 1.0 changing lightbulbsrm202 and boys locker rm. 3.0 fire extinguisher and exit sign inspection. 2.0 replcing lightbulbs and ballast in south hallway. 1.5 repair sprinkler heads. 5/17 - 8	5/17/2005 5/17/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
2182	Closed Work Orders 5/20/05. .5 building walk thru. 2.5 watering pine trees west side of football field. 2.0 digging trench to run power to storage shed. 2.0 repairing a/c . 1.0 entering week's work orders. 5/20 - 8	5/20/2005 5/20/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
2215	Closed Work Orders 5/23/05. .5 building walk thru. 2.5 continue trenching. 1.0 sunrise elem. to pick up music stands for band teacher. 1.5 working on 2 a/c's boys locker room. 1.0 repair keyboard shelf library. 1.5 watering trees west side of building. 5/23 8	5/23/2005 5/23/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2178	Closed Work Orders 5/18/05. .5 building walk thru. 1.5 cuttin grass and watering. 2.0 replacing lightbulbs in hallway. 1.5 repairing sprinklers on pine trees. 1.0 hanging banner in gym. 1.5 watering pine trees south end of football field.	5/20/2005 5/18/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
	5/18 - 8				
2180	Closed Work Orders 5/19/05. .5 building walk thru. 2.0 dragging the ground around north end of building. 2.5 cleaning front entrance. 1.0 replacing fire extinguisher cover girls locker room. 1.0 work on a/c unit portable 179.	5/20/2005 5/19/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
	5/19 - 7				
2173	Closed Work Orders 5/17/05. .5 building walk thru. 1.0 replacing lightbulbs rms. 202,178. 1.0 replace a/c water pump and clean unit (library). 2.0 repairing several sprinkler heads. 1.0 installing new fire extinguisher cover hallway and boys locker room. 2.5 cutting weeds and pine trees.	5/20/2005 5/17/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
	5/17 - 8				
2169	Closed Work Orders 5/16/05. .5 building walk thru. 1.0 changing lightbulbs rm. 202, and boys locker room. 3.0 fire extinguisher and exit sign inspection. 2.0 replacing lightbulb and ballast in hallway. 1.5 repairing sprinkler heads.	5/20/2005 5/16/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
	5/16 - 8				
2115	Work In Progress As per Mr.Diggs we are requesting the back-hoe to clean up around the pond so that new liner can be put in THANK YOU.	5/19/2005 Medium	Joe Ramirez Lorenzo Hernandez		Chaparral MS
2361	Closed Work Orders 5/24/05. .5 building walk thru. 1.0 dragging ground at bus turn around. 2.0 watering trees westside of football field. 3.0 helping ENRIQUE run power to shed. 1.0 locating and finding water line to pond and shed. .5 connecting water supply line to shed for a/c.	5/27/2005 5/24/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
	5/24 - 8				

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2362	Closed Work Orders 5/25/05. .5 building walk thru. 2.5 trenching alongside pond to bury conduit. 2.0 trouble shooting a/c/ malfunctions cafeteria. 2.0 working on a/c/ nurse's office. 1.0 installing new fire extinguisher cover (gym).	5/27/2005 5/25/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
	5/25 - 8				
2364	Closed Work Orders 5/26/05. .5 building walk thru. 2.5 continue trenching around pond. 4.0 repairing side panel on a/c office installing float on a/c stage area. .5 chopping weeds. .5 clean up.	5/27/2005 5/26/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
	5/26 - 8				
2429	Closed Work Orders 5/31/05. .5 building walk thru. 6.5 secure area where portable goes, mark area, tear down 2 fence lines. 1.0 put fence back up for security reasons.	6/2/2005 5/31/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
	5/31 - 8				
2430	Closed Work Orders 6/1/05. .5 building walk thru. 1.5 repair a/c rm. 307. 6.0 NMSU to pick up stage and set up.	6/2/2005 6/1/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
	6/1 - 8				
2366	Closed Work Orders 5/27/05. 4.0 locating repairing leaks on roof especially rm. 312. 2.0 warehouse to pick up supplies. 2.0 clean and start up a/c/ cafeteria.	5/27/2005 5/27/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
	5/27 - 8				
1910	Closed Work Orders 5/10/05 .5 building walk thru. 1.5 cutting grass and watering. 1.0 applying round up around building and cutting weeds. 1.5 unclogging several urinals boys R.R. 300 wing. 2.5 cleaning and start up of several a/cs that were not serviced. 1.0 entering daily log and clean up.	5/12/2005 5/10/2005 Medium	Joe Ramirez Margret Villalobos		Chaparral MS
	5/10 - 8				

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1752	Closed Work Orders 5/3/05 .5 building walk thru. .5 cutting weeds. 3.0 went to A.E. animal extraction, also replace lightbulbs & t.p dispenser at A/C D/C. 2.0 cleaning storage shed. 2.0 cleaning roof top. 5/3 - 8	5/9/2005 5/3/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
1754	Closed Work Orders 5/4/05. .5 building walk thru. 1.0 cutting boards for P.E. coach. 1.0 putting letters up on the marquis. 1.0 cutting off lock and staightening bracket boys locker room. 2.5 cutting weeds along fence. 2.0 continue cleaning shed. 5/4 - 8	5/9/2005 5/4/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
1756	Closed Work Orders 5/5/05. .5 building walk thru. 3.5 helping out at D.T. & then cutting weeds. 4.0 nnuual leave. 5/5 - 4	5/9/2005 5/5/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
1757	Closed Work Orders 5/6/05 .5 building walk thru. .5 went to SUNRISE E. to pick up scraper. 5.0 with lorenzo to take inventory of a/c's and heaters. 2.0 running errand for ms. MUELA ASST. PRINCIPAL. 5/6 - 8	5/9/2005 5/6/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
1758	Closed Work Orders 5/9/05. .5 building walk thru. 4.0 dragging along fence line and bus turn around. 1.0 applying round up. 2.5 installing new flush valves boys restroom. 5/9 - 8	5/9/2005 5/9/2005 Medium	Joe Ramirez Joe Ramirez		Chaparral MS
3025	Work In Progress ONE OF OUR BURNISHER STOPS WORKING ONCE WE USE IT FOR A WHILE. THANK YOU ROBERT	6/28/2005 Medium	Robert Gonzalez Jimmy Carbajal		Chaparral MS
2971	Work In Progress WE NEED THE LOCKS GOING INTO THE GYM CHANGED WHILE WE DO THE GYM. IN ORDER TO KEEP ANYONE FROM GOING IN. THANK YOU ROBERT	6/24/2005 Medium	Robert Gonzalez Hector Lozoya		Chaparral MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2799	Work In Progress I NEED IF POSSIBLE 2 MORE 2 WHEEL DOLLIES. EVERY BREAK WE HAVE ESPECIALLY THE SUMMER BREAK. WE HAVE TEACHERS MOVING FROM ONE ROOM TO ANOTHER AND SOME OF THEM BORROW THE DOLLIES. IT MAKES HARD FOR US BECAUSE WE"RE MOVING FURNITURE OR BOOKS AND OTHER THINGS. THANK YOU ROBERT	6/15/2005 Medium	Robert Gonzalez Aida Salcedo		Chaparral MS
2818	Work In Progress WE NEED 3 CHAIR DOLLIES. WE HAVE ALOT OF SPECIAL EVENTS IN WHICH WE HAVE TO TAKE ANY WHERE FROM 200 TO 400 CHAIRS TO THE GYM FROM THE CAFETERIA AND CLASSROOMS. THIS YEAR WITH THE 9TH GRADERS WE"LL HAVE EVEN MORE SET UPS TO DO . WE NEED THE DOLLIES TO BE LIKE THE TWO THAT WE HAVE NOW, TALL WE CAN CARRY TEN CHAIRS AT A TIME. THANK YOU ROBERT	6/16/2005 Medium	Robert Gonzalez Aida Salcedo		Chaparral MS
2009	Complete NEED THE KEY TO MY OFFICE TO BE CHANGED. SOMEONE HAS A COPY AND IS GOING INTO MY OFFICE AFTER I LEAVE FOR THE DAY. THANK YOU ROBERT REKEY OFFICE TO OFF MASTER AND REKEY NEW PORTABLES.	5/17/2005 6/14/2005 Medium	Robert Gonzalez Hector Lozoya		Chaparral MS
1779	Complete WE NEED A SIX FOOT LADDER , TO HAVE HERE PERMANENTLY. WE ALWAYS NEED ONE AND WE HAVE TO BE LOOKING FOR OUR MAINTENANCE MAN TO BORROW HIS. ISSUED & DELIVERED LADDER ON 5-13-05. COPY IN EQUIPMENT INVENTORY	5/10/2005 5/24/2005 Medium	Robert Gonzalez Sal Acuna		Chaparral MS
1316	Work In Progress ONE OF OUR SHOWER SCRUBBERS HAD A HARD TIME WORKING LAST SUMMER WHEN WE WERE USING A GRIT SCREENS IN THE GYM. MAY BE THE BRUSHES	4/21/2005 Medium	Robert Gonzalez Jimmy Carbajal		Chaparral MS
1314	Complete ONE OF OUR BURNISHER IS NOT WORKING RIGHT.IT PULLS TO ONE SIDE. REPLACED REAR WHEEL AXLE	4/21/2005 4/26/2005 Medium	Robert Gonzalez Jimmy Carbajal		Chaparral MS
1137	Complete two westside doors exit from gym. need to be repaired. Will not unlock from outside.Need to be fixed as soon as possible. repair door frames and repair panic bars at westside doors.	4/14/2005 4/14/2005 Medium	Robert Gonzalez Hector Lozoya		Chaparral MS
1139	Complete NEED TWO NAME TAGS. ASST. MANAGER JUANITA MONTELONGO HEAD CUSTODIAN ROBERT GONZALEZ MAKE NAME PLATES	4/14/2005 4/15/2005 Medium	Robert Gonzalez Hector Lozoya		Chaparral MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1131	Duplicate Request NEED SOME KIND OF LOCK INSTALLED ON MY FILING CABINET. HAVE CONFIDENTIAL FILES AND PAPERS.SECOND REQUEST. THANK YOU 1132	4/14/2005 4/18/2005 Medium	Robert Gonzalez Hector Lozoya	Stairway	Chaparral MS
1132	Complete NEED SOME KIND OF LOCK INSTALLED ON MY FILING CABINET. HAVE CONFIDENTIAL FILES AND PAPERS.SECOND REQUEST. THANK YOU repair file cabinet and replace lock.	4/14/2005 4/14/2005 Medium	Robert Gonzalez Hector Lozoya	Office	Chaparral MS
559	Complete I NEED 5 BELTS FOR OUR ROYAL VACUUM CLEANERS. NEED THIS REQUEST TO GO TO CUSTODIAL. DEPARTMENT. THANK YOU ROBERT DELIVERED 3 BELTS, REMOVED FROM ACT 100 INVENTORY	3/21/2005 3/29/2005 Medium	Robert Gonzalez Jimmy Carbajal		Chaparral MS
2822	Work In Progress rekey file cabinets--about 8 or 9	6/16/2005 Medium	Vickie Reed Hector Lozoya	Custodial	Chaparral MS
2823	Work In Progress need to key stage cabinets to open w/ only one key.	6/16/2005 Medium	Vickie Reed Hector Lozoya		Chaparral MS
724	Work In Progress REPAIR BROKEN 3" WATER LINE ON WEST SIDE OF SCHOOL.	3/31/2005 Medium	Vickie Reed Lorenzo Hernandez		Chaparral MS west side of school
1020	Work In Progress WEST DOOR TO FOOTBALL LOCKER ROOM NEED TO BE REPAIRED.	4/11/2005 Medium	Vickie Reed Danny Miranda		Chaparral MS FOOTBALL LOCKER ROOM
1095	Complete REPAIR DOOR HANDLE. replace handle and rekey core at room 105	4/13/2005 4/14/2005 Medium	Vickie Reed Hector Lozoya	Classroom	Chaparral MS 105
1096	Complete DOOR WILL NOT LOCK. rekey core at principals office	4/13/2005 4/14/2005 Medium	Vickie Reed Hector Lozoya	Office	Chaparral MS PRINCIPAL'S OFFICE
248	Complete Need to replace gate valve that supplies pond. DUG TRENCH AND RAN WATER LINE.	3/10/2005 4/15/2005 Medium	Vickie Reed Fred Appelzoller		Chaparral MS Pond area
209	Complete TIMER FAUCET IS BROKEN. NEED TO REPLACE. replace both lav. faucets	3/9/2005 3/17/2005 Medium	Vickie Reed Fred Appelzoller	Restroom (Boys)	Chaparral MS LOBBY
108	Complete DOOR LOCK NEEDS REPAIRED. TAKES ABOUT 5 MINUTES TO OPEN. REKEY CORE AT ROOM 107 AND CLEAN LOCKSET	3/7/2005 3/23/2005 Medium	Vickie Reed Hector Lozoya	Classroom	Chaparral MS 107
456	Complete NEED FLUSH VALVE FOR COMMODE. ASAP. REPLACE 12 FLUSHVALVES WITH 12 ZURN FLS VALVES	3/16/2005 5/17/2005 Medium	Vickie Reed Fred Appelzoller	Restroom (Boys)	Chaparral MS 300 wing (faculty)
415	Complete URINAL NEED TO BE REPAIRED. rebuilt flush valves on urinals.	3/15/2005 4/13/2005 Medium	Vickie Reed Fred Appelzoller	Restroom (Boys)	Chaparral MS MAIN HALLWAY

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2487	Work In Progress need extra key for rm 405a	6/3/2005 Medium	Vickie Reed Hector Lozoya	Classroom	Chaparral MS 405a
2488	Work In Progress need extra key for rm 405b	6/3/2005 Medium	Vickie Reed Hector Lozoya	Classroom	Chaparral MS 405b
2489	Work In Progress need to rekey storage rm in 100 hall to open only w/ A82	6/3/2005 6/3/2005 Medium	Vickie Reed Hector Lozoya	Office	Chaparral MS storage rm
1566	Complete NEED A-KEY TO BE ISSUED TO MICHELLE BALLARD. duplicate A Master	5/2/2005 5/6/2005 Medium	Vickie Reed Hector Lozoya		Chaparral MS
1708	Work In Progress NEED TO CHANGE STORAGE ROOM LOCK TO OPEN WITH KEY A-82 ONLY. ALSO DOOR MUST REMAIN LOCKED AT ALL TIMES.	5/6/2005 Medium	Vickie Reed Hector Lozoya	Hallway/Corridor	Chaparral MS 100 STORAGE
1888	Complete NEED BURY ELECTRICAL LINE FROM FILTER TO POND. install pvc wire for outlet to pond.	5/12/2005 5/31/2005 Medium	Vickie Reed Enrique Sotelo		Chaparral MS POND
361	Duplicate Request 2nd building. Please see Mr.Y and install a gutter where needed. SEE WO 1068	3/14/2005 5/11/2005 Medium	Michael Munoz Danny Miranda		Desert Pride
773	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. COMPLETED PER DAVID ACOSTA	4/1/2005 4/22/2005 Medium	Aida Salcedo David Acosta		Desert Pride
1068	Complete NEED TO PUT IN GUTTER SECOND BUILDING TWO DOORS TOTAL PUT GUTTER ON THREE SIDES OF BLDG.	4/12/2005 5/11/2005 Medium	Danny Miranda Danny Miranda		Desert Pride
1380	Work In Progress need to paint new frame @ varnish door to lounge	4/25/2005 Medium	Danny Miranda David Acosta		Desert Pride
1381	Complete need core for new door to lounge	4/25/2005 4/25/2005 Medium	Danny Miranda Hector Lozoya		Desert Pride
1244	Complete Principal is having a little trouble with his key unlocking lock to front entrance gate to staff parking lot. repair padlock	4/19/2005 4/20/2005 Medium	David Acosta Hector Lozoya		Desert Pride

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1108	Work In Progress need to replace the pump for a toilet (front office)	4/13/2005 Medium	David Acosta David Villalobos	Office	Desert Pride
1053	Forwarded Front Office -winds have blown roof tiles off the roof.	4/12/2005 Medium	David Acosta David Boyd	Office	Desert Pride
210	Complete need golfer traps	3/9/2005 6/13/2005 Medium	David Acosta Ruben Ronquillo		Desert Pride
1751	Work In Progress need new flapper for toilet	5/9/2005 Medium	David Acosta David Villalobos	Classroom	Desert Pride #8
1675	Forwarded storage bldg. the rubber roof is coming unglued on some parts around the edges and corners	5/5/2005 Medium	David Acosta David Boyd		Desert Pride
1612	Work In Progress restroom in lounge area- when flushed, water is pushes back up and smell like sewer	5/3/2005 Medium	David Acosta David Villalobos	Office	Desert Pride
1834	Work In Progress need two plastic name plates for front office doors-(ALL VISITORS MUST SIGN IN AT FRONT OFFICE)	5/11/2005 Medium	David Acosta Hector Lozoya	Office	Desert Pride
1410	Work In Progress need seven locks for doors to front offices. (in counslor, social workers area.)	4/25/2005 Medium	David Acosta Hector Lozoya	Office	Desert Pride
1391	Complete molding on the new door frame is coming unglued COMPLETED BY CONTRACTOR	4/25/2005 5/17/2005 Medium	David Acosta Danny Miranda	Office	Desert Pride
1388	Complete new door that was installed is lock on the inside. need to have door open. (asap) rekey core to new doors.	4/25/2005 4/26/2005 Medium	David Acosta Hector Lozoya	Office	Desert Pride
2606	Work In Progress need one key for classroom for new teacher	6/7/2005 Medium	David Acosta Hector Lozoya	Classroom	Desert Pride 5
3064	Work In Progress Att: Sal Acuna-requesting for a desk mover and red flat truck.	6/29/2005 Medium	David Acosta Sal Acuna	Football Field	Desert Pride
2910	Work In Progress need two light switches installed for iep room and custodian office (no light switches in rooms.)	6/21/2005 Medium	David Acosta Carlos Castillo	Office	Desert Pride
2765	Duplicate Request Ice machine is not making ice patricia cisneros - snp manager 824-3822 duplicate work order#2999	6/14/2005 6/15/2005 Medium	Alma Terrell Danny Orozco	Desert Trail Intermediate Cafeteria	

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
3120	Work In Progress ROOM 110 - NEED ELECTRICAL POLES FOR THE LAB AT DT (PLEASE CALL JAVIER GUTIERREZ WILL ASSIST IN QUESTIONS 882-6277	7/1/2005 Medium	Cora Ramirez Enrique Sotelo		Desert Trail Intermediate
3121	Work In Progress ROOM 207 - NEED ELECTRICAL POLES FOR THE LAB AT DT (PLEASE CALL JAVIER GUTIERREZ WILL ASSIST IN QUESTIONS 882-6277	7/1/2005 Medium	Cora Ramirez Enrique Sotelo		Desert Trail Intermediate
1374	Complete FAUCET AT THREE COMPARTMENT SINK DOES NOT SHUT OFF REMOVED FAUCET INSTALLED NEW RUBBER SEALS PUT FAUCET BACK ON	4/22/2005 4/22/2005 Medium	Danny Orozco Danny Orozco	Desert Trail Intermediate Cafeteria	
774	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. COMPLETED AS PER SALVADOR GONZALEZ	4/1/2005 5/23/2005 Medium	Aida Salcedo Salvador Gonzalez		Desert Trail Intermediate
2203	Duplicate Request ICE MACHINE NOT MAKING ICE - MACHINE KEEPS ON SHUTTING OFF PATRICIA CISNEROS - SNP MANAGER 505-824-3822 DUPLICATE WORK ORDER #2117	5/23/2005 5/26/2005 Medium	Alma Terrell Danny Orozco	Desert Trail Intermediate Cafeteria	
888	Complete DP 1020 monitoring data is due in this office before April 28,2005 prepare data and turn into office.	4/6/2005 5/24/2005 Scheduled	Ricardo Jacquez		Desert Trail Intermediate
931	Complete The vent from the over head exhaust over the stove fell. Pat Cisneros - SNP Mgr 824-3822 removed cover vent, bolted inside vent register to outer vent cover and installed.	4/7/2005 4/15/2005 Medium	Jacqueline Aguilar Danny Orozco	Desert Trail Intermediate Cafeteria	
192	Complete Garbage Disposal - Shakes alot and water is coming out from the bottom. 3/9/05 TIGHTENED LEGS ON GARBAGE DISPOSAL 4/26/05 INSTALLED NEW VACUUM BREAKER	3/8/2005 5/13/2005 Medium	Jacqueline Aguilar Danny Orozco	Desert Trail Intermediate Cafeteria	
703	Complete GARBAGE DISPOSAL - DOESN'T TURN ON WHEN SWITCH IS TURN ON. PATRICIA CISNEROS - 824-3822 had to get out utensil that was jammed in disposal.	3/30/2005 4/1/2005 Medium	Jacqueline Aguilar Danny Orozco	Desert Trail Intermediate Cafeteria	

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
704	Work In Progress GLASS TO SERVING LINE IS CRACKED. PATRICIA CISNEROS 824-3822	3/30/2005 Medium	Jacqueline Aguilar Danny Orozco		Desert Trail Intermediate
3113	Work In Progress WALK - IN REFREG. TEMP AT 50. NOT COOLING. PAT CISNEROS SNP MGR 824-3822	6/30/2005 Medium	Jacqueline Aguilar Danny Orozco		Desert Trail Intermediate Cafeteria
2999	Work In Progress ice machine not working. Pat Cisneros snp mgr 824-3822	6/27/2005 Medium	Jacqueline Aguilar Danny Orozco		Desert Trail Intermediate Cafeteria
1614	Complete HOSE TO WASHER HAS A HOLE. LEAKING WATER. PATRICIA CISNEROS - SNP MGR 824-3822 REMOVED BAD DRAIN HOSE FROM WASHER INSTALLED NEW DRAIN HOSE	5/3/2005 5/13/2005 Medium	Jacqueline Aguilar Danny Orozco		Desert Trail Intermediate Cafeteria
2322	Work In Progress PLEASE SEND EXTERMINATOR OR MOUSE TRAPS TO RM.#116(MRS. DOMINGUEZ) MOUSE INSIDE CLASSROOM.	5/26/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
2298	Work In Progress 5/25/05 .5-CHECK LIFT STATION .5-REPLACE MISSING INTERCOM BUTTONS TO CLASSROOMS. 2.0-FIX LIGHT FIXTURES TO CLASSROOM RESTROOMS. .5-REPLACE PENCIL SHARPENERS TO ROOMS. #102 AND 406. 1.5-TROUBLESHOOT AND FIX A/C TO ROOM #209. 3.0-CUT WEEDS. 5/25 - 8	5/25/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
2289	Work In Progress NEED A SCREW EXTRACTOR FOR CLASSROOM #112 SINK HANDLE. (VALVE)	5/25/2005 Medium	Johnny Acuna Fred Appelzoller		Desert Trail Intermediate
2290	Work In Progress NEED NEW LOCKS AND KEYS FOR CABINET/CLOSET AND THE TEACHER'S DESK. MAIN BLDG. RM. #115.	5/25/2005 Medium	Johnny Acuna Hector Lozoya		Desert Trail Intermediate
2228	Closed Work Orders .5-CHECK LIFT STATION 1.0-RE-ATTACH CARPET MOLDING TO CLASSROOM #406 6.5-CHECK MONTHLY MAINTENANCE PLAN - CLASSROOMS. 5/23 - 8	5/23/2005 5/23/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2238	Work In Progress PLEASE SEND PEST CONTROL OR MOUSE TRAPS FOR ROOM #119 INSIDE THE MAIN BUILDING. (MOUSE INSIDE CLASSROOM)	5/24/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
2425	Work In Progress NEED TO REPLACE A LOST KEY FOR ROOM #201: MARIA RONGEL	6/1/2005 Medium	Johnny Acuna Hector Lozoya		Desert Trail Intermediate
2376	Work In Progress NEED TO REPLACE DOOR FRAME TO PORTABLE #411. (MAIN DOOR).	5/31/2005 Medium	Johnny Acuna Danny Miranda		Desert Trail Intermediate
2377	Duplicate Request ICE MAKER IS NOT WORKING. DUPLICATE WORK ORDER #2117	5/31/2005 6/1/2005 Medium	Johnny Acuna Danny Orozco		Desert Trail Intermediate
2402	Work In Progress NEED TO REPAIR SEVERAL FENCE SITUATIONS: *REPLACE BENT POST AND REPAIR FENCE TO CAGE BEHIND PLAYGROUND BACKSTOP, *WEST FENCE IS MISSING A CENTER RE-ENFORCEMENT POLE NEXT TO GATE, *NEED TO REPLACE GUIDING WHEEL TO SOUTH GATE IN BUS TURN AROUND, *SOUTHEAST FENCE NEEDS REPAIR IN TWO PLACES.	6/1/2005 Medium	Johnny Acuna Michael Munoz		Desert Trail Intermediate
2403	Work In Progress NEED A LOCK FOR SOUTHWEST GATE NEXT TO LISA ST.	6/1/2005 Medium	Johnny Acuna Hector Lozoya		Desert Trail Intermediate
1974	Closed Work Orders 5/16/05 .5-CHECK LIFT STATION 2.5-MOW GRASS AREA 1.5-HELP JOE FIX LIGHT FIXTURES AT CH. MID 2.5-USED SCRAPER IN FRONT AND IN THE BACK OF SCHOOL GROUNDS 1.0-CUT WEEDS. 5/16 - 8	5/17/2005 5/16/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
1941	Complete CONTACTOR TO COMMERCIAL A/C IN THE KITCHEN AREA IS MAKING NOISE. (MASTERCOOL) revisar y cambiar lighting contactor en controls de a/c en cafeteria.	5/13/2005 5/19/2005 Medium	Johnny Acuna Enrique Sotelo		Desert Trail Intermediate
1920	Closed Work Orders .5-CHECK LIFT STATION 5.0-MOW GRASS AREA 1.0-FIX LIGHT FIXTURES IN KITCHEN AREA 1.5-FIX LIGHT FIXTURES IN RM. #110 8	5/12/2005 5/12/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
2061	Work In Progress NEED TO REPLACE CONDENSATION PUMP TO THE REFRIGERATION UNIT LOCATED INSIDE THE SERVER ROOM.	5/18/2005 Medium	Johnny Acuna Jaime Gomez		Desert Trail Intermediate

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2062	Closed Work Orders 5/18/05 .5-CHECK LIFT STATION 1.0-REPLACE WINDOW BLINDS TO RM. 212 .5-CUT OUT TOPS TO BARRELS TO BE USED AS TRASH CANS. 2.0-CHECK AND REPLACE ALL TORN WINDOW SCREENS TO MAIN BLDG. 2.0-CUT WEEDS 2.0-FIX ICE-MACHINE INSIDE KITCHEN. 5/18 - 8	5/18/2005 5/18/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
2207	Complete NEED (2-3) BOXES OF 2-PIN 26 WATT PUSH IN LIGHT BULBS FOR CLASSROOM RESTROOMS. THANK YOU !!!!! left lamps with Johnny 26 watts	5/23/2005 5/24/2005 Medium	Johnny Acuna Enrique Sotelo		Desert Trail Intermediate
2148	Complete PRINCIPAL REQUESTING THE COST, THE LABOR, AND THE SHIPPING FEES OF A HOLLOW DOOR THAT WAS INSTALLED IN PORTABLE #412 GIRLS REST ROOM. A STUDENT MADE A HOLE IN THE DOOR. FAXED PRICES TO PRINCIPAL 5/23/05	5/20/2005 5/23/2005 Medium	Johnny Acuna Danny Miranda		Desert Trail Intermediate
2210	Work In Progress NEED A NEW SINK CABINET FOR PORTABLE #413 GIRL'S RESTROOM. SIZE: 36" WIDE (FRONT) X 23" LONG X 2' 6" TALL	5/23/2005 Medium	Johnny Acuna Danny Miranda		Desert Trail Intermediate
2211	Work In Progress NEED A NEW REPLACEMENT HOLLOW DOOR FOR CLASSROOM # 411 GIRL'S RESTROOM. DOOR SIZE: 32 1/2" WIDE X 80" LONG. ALSO NEED (2) DOOR KNOBS. ONE (ROUND) FOR HALLWAY DOOR, AND ONE (LEVER) FOR BOY'S RESTROOM DOOR. THANK YOU !!!!!	5/23/2005 Medium	Johnny Acuna Danny Miranda		Desert Trail Intermediate
2212	Work In Progress (STUDENT RECORDS) NEED TO REPAIR BROKEN FILE CABINET LOCK, ALSO NEED A KEY TO BE ABLE TO LOCK CABINETS. BOTH STUDENT RECORD CABINETS ARE THE SAME KEY. (LOCATED INSIDE THE VAULT IN THE MAIN OFFICE)	5/23/2005 Medium	Johnny Acuna Hector Lozoya		Desert Trail Intermediate
2213	Complete NEED TO REPLACE (2) FLOURECENT LIGHT FIXTURE COVERS THAT ARE CRACKED INSIDE CLASSROOMS. INSTALL 3 LENS LAYIN	5/23/2005 5/25/2005 Medium	Johnny Acuna Enrique Sotelo		Desert Trail Intermediate
2214	Work In Progress NEED (4) STICKERS FOR MAIN ENTRANCE DOORS TO MAIN BUILDING. ACCORDING TO THE LAW: FOR THE SAFETY OF ALL STUDENTS, ALL VISITORS REPORT TO THE OFFICE. LA LEY REQUIERE PARA LA SEGURIDAD DE TODOS LOS ALUMNOS TODOS VISITANTES DEBEN REPORTARSE A LA OFICINA.	5/23/2005 Medium	Johnny Acuna Ruben Ronquillo		Desert Trail Intermediate

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2190	Complete NEED (14) PLASTIC INSERTS FOR REFRIGERATION WATERFOUNTAINS. (THE ONES THAT HOLD THE PUSH BAR)	5/23/2005 5/27/2005 Medium	Johnny Acuna Fred Appelzoller		Desert Trail Intermediate
	DROP OFF PARTS TO JOHNNY				
2141	Closed Work Orders .5-CHECK LIFT STATION 1.0-FIX LIGHT FIXTURES IN NW HALL RESTROOMS. 2.0-TROUBLESHOOT ICE MACHINE IN KITCHEN. 2.0-HELP FIX SERVER ROOM AIR CONDITIONER 2.5-CUT WEEDS. 5/19 - 8	5/19/2005 5/19/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
2117	Complete ICE MACHINE NOT WORKING. NEED TO REPLACE HOT GAS VALVE. ICE MACHINE MAKES ICE, BUT STAYS IN THE HARVEST MODE, THEN TRIPS THE HIGH PRESSURE SWITCH. (ICE-O-MATIC : MODEL #EC200FAPB1) HOT GAS VALVE: M.O.P.D. (300), COIL:(R235), BODY: (B), TYPE: (RS314) REMOVED BAD HOT GAS VALVE AND INSTALLED NEW ONE, VACUUMED SYSTEM CHARGED CHECKED FOR LEAKS WORKING FINE	5/19/2005 6/8/2005 Medium	Johnny Acuna Danny Orozco		Desert Trail Intermediate
1337	Closed Work Orders 4/21/05 .5-CHECK LIFT STATION 4.0- USED SCRAPER IN FRONT SCHOOL AND AROUND FENCELINES. 3.5-CUT WEEDS. 4/21 - 8	4/22/2005 4/21/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
1376	Closed Work Orders 4/22/05 .5-check lift station 2.0-pick up torn down fence and secure area. ch. elem. 1.0- nurse's office: fix light fixture to office and restroom. 4.5-fix outdoor playground sprinkler system. 4/22 - 8	4/22/2005 4/22/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
1443	Closed Work Orders 4/26/05 .5-CHECK LIFT STATION 4.5-MOW PLAYGROUND GRASS AREA 3.0-MAKE WATER WELLS AND WATER ALL TREES IN BACK OF SCHOOL. (PLAYGROUND) 4/26 - 8	4/26/2005 4/26/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
1418	Closed Work Orders 4/25/05 .5-check lift station 1.0-air up tires to television cart and assemble (3) shelves for library. 6.5- cut weeds east of main building and in back of school grounds. 4/25 - 8	4/25/2005 4/25/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1556	Work In Progress PORTABLE #411: NEED A NEW DOORKNOB (LEVER TYPE) FOR BOYS RR, AND ALSO NEED TO RE-WELD DOOR HINGE TO MAIN CLASSROOM DOOR. FALLEN DOOR HARD TO CLOSE.	5/2/2005 Medium	Johnny Acuna Hector Lozoya		Desert Trail Intermediate
1607	Complete NEED TO REPLACE EXIT SIGN/EMERGENCY LIGHT TO CAFETERIA. (NORTH SIGN) CHANGE OUT BATTERY ON EXIT SIGN AND LIGHT.	5/3/2005 5/4/2005 Medium	Johnny Acuna Enrique Sotelo		Desert Trail Intermediate
1604	Complete NEED TO REPLACE GASKETS TO KITCHEN SINK DRAIN.(THREE SECTION SINK). REMOVED ROTARY DRAIN AND INSTALLED NEW GASKET 3-COMP SINK	5/3/2005 5/13/2005 Medium	Johnny Acuna Danny Orozco		Desert Trail Intermediate
1605	Duplicate Request NEED A NEW WATER DRAIN HOSE FOR LAUNDRY WASHER. OLD HOSE HAS A PIN HOLE ON IT. DUPLICATE WORK ORDER #1614	5/3/2005 5/13/2005 Medium	Johnny Acuna Danny Orozco		Desert Trail Intermediate
1476	Complete PORTABLE #403: EVAP. A/C, NEED (2) 3/4" HIGH RISE BEARINGS. THANK YOU !!!! gave johnny 2 bearings	4/27/2005 4/29/2005 Medium	Johnny Acuna Jaime Gomez		Desert Trail Intermediate
1477	Closed Work Orders 4/27/05 .5-CHECK LIFT STATION 1.0-WATER TREES IN BACK OF SCHOOL .5-RAKE UP WEEDS AND DISPOSE. INSIDE LIFT STATION .5-TROUBLESHOOT AND REMOVE BEARINGS TO A/C. PORTABLE #403. 5.5-CUT WEEDS IN BACK OF SCHOOL GROUNDS, ALSO USED SCRAPER. 4/27 - 8	4/27/2005 4/27/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
1512	Closed Work Orders 4/28/05 .5-check lift station 1.0-paint shelf 1.0-check and fix a/c to art portable 5.5-cut weeds and spray round up on fencelines and school grounds. 4/28 - 8	4/28/2005 4/28/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
1659	Closed Work Orders 5/4/05 .5-CHECK LIFT STATION .5-FIX WATERFOUNTAIN SW HALL. .5-FIX STUDENT DESK IN ROOM #110 1.0-FIX A/C TO ROOM #111 .5-INSTALL DOOR SWEEP AND DOOR STOP TO PORTABLE #404 1.0-LUBRICATE WINDOW FRAMES TO MAIN BUILDING. 4.0-INSTALL A/C AT CHAPARRAL ELEMENTARY/ P.E. ROOM 5/4 - 8	5/4/2005 5/4/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1628	Closed Work Orders 5/3/05 .5-CHECK LIFT STATION 2.0-CHECK MONTHLY FIRE EXTINGUISHERS 1.0-CHECK MONTHLY EXIT SIGNS .5-LUBRICATE SOME WINDOW FRAMES TO MAIN BUILDING 4.0-REPLACE WOOD TO PORTABLE #404 OUTDOOR RAMP 5/3 - 8	5/3/2005 5/3/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
1807	Work In Progress NEED SCRAPER TO CLEAN OUTSIDE AND INSIDE OF FENCELINES. THANK YOU !!!!	5/10/2005 Medium	Johnny Acuna Lorenzo Hernandez		Desert Trail Intermediate
1808	Closed Work Orders 5/10/05 .5-CHECK LIFT STATION 7.5-CUT WOOD AND REPLACE SOME WOOD ON PORTABLE #413 RAMP. ALSO REMOVE OLD WOOD AND BOLTS FROM RAMP. 5/10 - 8	5/10/2005 5/10/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
1861	Closed Work Orders 5/11/05 .5-CHECK LIFT STATION 4.0-CUT AND REPLACE WOOD TO PORTABLE #413 RAMP. 1.5-SPREAD OUT PRIMARY SCREENING IN FRONT OF PORTABLES. 2.0-HELP BETO SPREAD OUT PLAYGROUND SAND INSIDE SWINGS AREA. 5/11- 8	5/11/2005 5/11/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
753	Closed Work Orders 3/31/05 .5-CHECK LIFT STATION 7.5-CLEAN AND SERVICE A/C'S.	3/31/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
715	Closed Work Orders 3/30/05 .5-CHECK LIFT STATION 7.5-CLEAN AND SERVICE A/C'S.	3/30/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
1298	Complete TEACHER IN ROOM #205. MR. HOLMES IS REQUESTING TO REPLACE COMODE TO A FLUSHMATE COMODE. REMOVE OLD W/C AND INSTALLED NEW ONE.	4/21/2005 5/24/2005 Medium	Johnny Acuna Fred Appenzoller		Desert Trail Intermediate
1264	Closed Work Orders 4/19/05 .5-CHECK LIFT STATION 7.5-CH. ELEM. HELP JUAN CARLOS WITH A/C'S. 4/19 - 8	4/19/2005 4/19/2005 Medium	Johnny Acuna Juan Acosta		Desert Trail Intermediate
1234	Closed Work Orders 4/18/05 .5-check lift station 6.0-cut weeds in front of main building. 1.5-use scraper in back of school grounds. 4/18 - 8	4/19/2005 4/18/2005 Medium	Johnny Acuna Juan Acosta		Desert Trail Intermediate

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1192	Work In Progress RM. #112 GUTIERREZ . NEED TO FIX AND MAKE A KEY FOR FILING CABINET INSIDE CLASSROOM..THANK YOU.....	4/15/2005 Medium	Johnny Acuna Hector Lozoya		Desert Trail Intermediate
1211	Work In Progress need irrigation backflow preventer to be installed for irrigation to front trees. (irrigation line has been installed).	4/18/2005 Medium	Johnny Acuna Lorenzo Hernandez		Desert Trail Intermediate
1119	Closed Work Orders 4/13/05 .5-check lift station 1.5- principal request: deliver art stands to gadsden middle school. 6.0-mow grass area. playground 4/13 - 8	4/13/2005 4/13/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
1041	Work In Progress NEED A HALL AND CLOSET NON-LOCKING DOOR SET FOR PORTABLE #412 INSIDE DOOR.	4/11/2005 Medium	Johnny Acuna Hector Lozoya		Desert Trail Intermediate
1042	Complete NEED (2) HIGH RISE 3/4" MASTERCOOL A/C BEARINGS. gave johnny 2 bearings	4/11/2005 4/12/2005 Medium	Johnny Acuna Jaime Gomez		Desert Trail Intermediate
1037	Closed Work Orders 4/11/05 .5-CHECK LIFT STATION 7.5-CH.ELEM. HELP JUAN CLEAN AND SERVICE A/C'S. 4/11/05 - 8	4/11/2005 4/11/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
509	Closed Work Orders 3/17/05 .5-CHECK LIFT STATION .5-CHECK BOILER HEATING SYSTEM 7.0-WORKED ON CLASSROOM FLOOR. CH.ELEM.	3/18/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
470	Closed Work Orders 3/16/05 .5-CHECK LIFT STATION .5-CHECK BOILER HEATING SYSTEM 7.0-WORKED ON CLASSROOM FLOOR. (CH. ELEM)	3/16/2005 Medium	Johnny Acuna Juan Acosta		Desert Trail Intermediate
421	Closed Work Orders 3/15/05 .5-check lift station .5-check boiler heating system 7.0-ch. elem: worked on classroom floor.	3/15/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
592	Closed Work Orders 3/22/05 .5-CHECK LIFT STATION .5-PAINT FRAME FOR KINDERGARDEN WATERFOUNTAIN .5-PAINT SPRINKLER TIMER CASE. 2.5-WATER OUTDOOR TREES. 4.0-ATTEND SAFETY MEETING AT S.T. MIDDLE SCHOOL	3/23/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
593	Closed Work Orders 3/23/05 .5-CHECK LIFT STATION 7.5-BUILD SHELVES, AND CLEAN STORAGE SHED.	3/23/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
564	Closed Work Orders 3/21/05 .5-CHECK LIFT STATION 7.5-CLEAN AND SERVICE A/C'S	3/21/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
680	Closed Work Orders 3/29/05 .5-CHECK LIFT STATION .5-USED SCRAPER ON THE EAST SIDE OF THE MAIN BUILDING. 7.0-CLEAN AND SERVICE A/C SYSTEMS.	3/29/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
702	Complete NEED HELP WITH AN ELECTRICAL SHORT INSIDE THE DISCONNECT BOX TO THE NORTH SIDE (OUTDOOR COMMERCIAL MASTERCOOL) A/C FOR THE CAFETERIA. THANK YOU..... realambar alambres quemados del corto circuito dentro de tubo.	3/30/2005 4/4/2005 Medium	Johnny Acuna Enrique Sotelo		Desert Trail Intermediate Cafeteria
668	Complete BROKEN: MAIN ELECTRICAL PVC LINE UNDERNEATH PORTABLE #408. repair electrica pvc	3/29/2005 4/4/2005 Medium	Johnny Acuna Enrique Sotelo		Desert Trail Intermediate
231	Complete need a couple of (chicago faucets) gaskets for custodial closet sink faucets. Thank You..... replace washer on faucet.	3/10/2005 4/12/2005 Medium	Johnny Acuna Fred Appelzoller		Desert Trail Intermediate
360	Work In Progress PLEASE REPAIR PARKING LOT SECURITY LIGHT FIXTURE LOCATED IN THE PARKING LOT ENTRANCE/EXIT GATE.	3/14/2005 Medium	Johnny Acuna Enrique Sotelo		Desert Trail Intermediate
369	Closed Work Orders 3/14/05 .5-CHECK LIFT STATION .5-CHECK B0ILER HEATING SYSTEM 2.0-CUT WEEDS AROUND PORTABLES AND FENCELINES 5.0-CH. ELEM: WORKED ON PORTABLE FLOOR.	3/14/2005 3/14/2005 Medium	Johnny Acuna Margret Villalobos		Desert Trail Intermediate

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
3050	Closed Work Orders .5-check lift station .5-check sunrise elem. and lift station 7.0-paint student restrooms at desert trail. 6/28 - 8	6/28/2005 6/28/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
2872	Work In Progress NEED HELP WITH (2) LIGHT FIXTURES TO CHANGE OUT BALLASTS IN THE LIBRARY. LIGHT FIXTURES ARE EMERGENCY LIGHT FIXTURES.	6/20/2005 Medium	Johnny Acuna Enrique Sotelo		Desert Trail Intermediate
2805	Closed Work Orders 6/13/05 .5-check lift station 7.5-fix light fixtures to classrooms. 6/13 - 8	6/15/2005 6/13/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
2807	Closed Work Orders 6/14/05 .5-check lift station 7.5-help Ruben clean and move computers, furniture, etc. in the Barracks. physical plant 6/14 - 8	6/15/2005 6/14/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
2808	Closed Work Orders 6/15/05 .5-check lift station 7.5-move computers, furniture, etc. to the Barracks at the Physical Plant. 6/15 - 8	6/15/2005 6/15/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
2758	Duplicate Request ICE-MACHINE NOT WORKING IN THE KITCHEN. 2999	6/14/2005 Medium	Johnny Acuna Danny Orozco		Desert Trail Intermediate
2695	Work In Progress PLEASE FIND LOCATION OF ELECTRICAL LINE IN THE WALL WHERE A NEW DOOR WILL BE INSTALLED. (LOCATION: MIDDLE HALLWAY GOING OUTSIDE TO THE PORTABLES / THE LOCATION IS WHERE THE FIRE EXTINGUISHER IS).	6/10/2005 Medium	Johnny Acuna Enrique Sotelo		Desert Trail Intermediate
2641	Closed Work Orders 6/8/05 .5-check lift station 4.0-help move books, disassemble shelves, move shelves to another classroom, and assemble shelves back together. (from Rm. 304 to portable #405) 3.5-fix light fixtures to classrooms. replace bulbs or ballasts as needed. 6/8 - 8	6/8/2005 6/8/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
2594	Closed Work Orders 6/6/05 .5-check lift station 7.5-fix light fixtures in classrooms/ replace bulbs or ballasts as needed. 6/6 - 8	6/7/2005 6/6/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2595	Closed Work Orders 6/7/05 .5-check lift station 7.5-help move books, take apart shelves, move shelves to another classroom, and reassemble shelves to new classroom. FROM MAIN BUILDING TO PORTABLE #405. 6/7 - 8	6/7/2005 6/7/2005 Medium	Johnny Acuna Johnny Acuna		Desert Trail Intermediate
2585	Work In Progress (DANNY MIRANDA) NEED TO SEE IF FRAME AND DOOR COULD BE MOVED TO THE OTHER SIDE OF THE WALL TOWARDS HALLWAY AND CLOSE OFF WALL WHERE DOOR AND FRAME USED TO BE. *LOCATION: SPEECH ROOM*	6/7/2005 Medium	Johnny Acuna Danny Miranda		Desert Trail Intermediate
1592	Work In Progress PUMP ROOM - REPAIR LEAKING FILTERS.	5/3/2005 Medium	Ricardo Jacquez Ricardo Jacquez		Desert Trail Intermediate
2669	Complete I HAVE ANEXTRACTOR TO BE FIXED. MAY I HAVE A LOANER JIMMY ????? CLEANED NAZZLE ASSY AS PER JIMMY	6/9/2005 6/13/2005 Medium	Salvador Gonzalez Jimmy Carbajal		Desert Trail Intermediate
1182	Complete PORTABLE 409 IS INFESTED OF TINY BUGS (EMERGENCY ASAP) STUDENTS WERE TAKEN OUT OF CLASSROOM Lester Humphrey went out on 4/15/05 mkv	4/15/2005 4/18/2005 Medium	Salvador Gonzalez Margret Villalobos		Desert Trail Intermediate 409
1279	Complete BURNISHING MACHINE IS BROKEN REPLACED REAR WHEEL AXLE	4/20/2005 4/26/2005 Medium	Salvador Gonzalez Jimmy Carbajal		Desert Trail Intermediate
1280	Complete BACK PACK IS NOT WORKING WELL REMOVED 7 CLEANED OUT ALL FILTERS. ALSO REMOVED DUCT TAPE (IT WASN'T GETTING ANY AIR INTAKE)	4/20/2005 4/28/2005 Medium	Salvador Gonzalez Jimmy Carbajal		Desert Trail Intermediate
1281	Void REPLACE STAINLESS STEEL SOAP DISPENSERS WINDOW ARE BROKEN (two) SALL WILL ORDER FORM SITE NET INVENTORY.	4/20/2005 Medium	Salvador Gonzalez Jimmy Carbajal		Desert Trail Intermediate
1282	Complete WETBACK IS NOT WORKIN WELL REPLACED PARTS , ALONG W/ GASKET AND ALSO DID P.M.	4/20/2005 4/27/2005 Medium	Salvador Gonzalez Jimmy Carbajal		Desert Trail Intermediate
545	Complete I HAVE A BROKEN VACCUM CLEANER REPLACED PARTS (THRU SITE NET) AND DID P.M. AS PER JIMMY CARBAJAL	3/18/2005 3/29/2005 Medium	Salvador Gonzalez Jimmy Carbajal		Desert Trail Intermediate
1231	Complete NEED TO HAVE BROKEN KEY REPLACED, BP691 FOR UTILITY BOX. MARY SITTERS HAS A KEY. make keys for Mary Sitters	4/18/2005 4/20/2005 Medium	Maria Sitters Hector Lozoya		Desert View ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1017	Complete THREE COMPARTMENT SINK IS CLOGGED. MARTHA FLORES - SNP MGR 589-2425 RAN SNAKE, DRAINED GREASE TRAP UNCLOGGED OUTLET AND ADDED BOTTLE OF LIQUID DRAIN OPENER	4/11/2005 4/22/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	Desert View ES
1212	Complete NEED TO REPAIR A VACUUM REPLACED ABOVE PARTS AND ALSO DID P.M.	4/18/2005 5/20/2005 Medium	Jimmy Carbajal Jimmy Carbajal		Desert View ES
2287	Work In Progress NEED TO HAVE MAINTENANCE DONE ON AN EXTRACTOR PLEASE ITS BEEN OUT OF SERVICE FOR A LONG TIME. THANK YOU.	5/25/2005 Medium	Jimmy Carbajal Jimmy Carbajal	Classroom	Desert View ES
2288	Complete COULD YOU PLEASE REPAIR THE UPPER HANDLE ASSY. ON A VACUUM PLEASE ASAP. THANK YOU. REPLACED PARTS (ISSUED THRU ACT 1000) AND ALSO DID P.M. AS PER JIMMY CARBAJAL	5/25/2005 5/31/2005 Medium	Jimmy Carbajal Jimmy Carbajal	Classroom	Desert View ES
1533	Work In Progress Please use auger and assist with installation of marquee.	4/29/2005 Medium	Lorenzo Hernandez		Desert View ES
1275	Complete Please fabricate iron stand for new marquee. FABRICATE STAND FOR NEW MARQUEE FOR DV	4/20/2005 5/18/2005 Medium	Angel Gonzales		Desert View ES
1276	Work In Progress please install fabricated iron supports for new marquee. Please see mike before installation.	4/20/2005 Medium	Lorenzo Hernandez		Desert View ES
1944	Work In Progress PLEASE SUPPORT WITH THE INSTALLATION OF THE MARQUEE	5/16/2005 Medium	Lorenzo Hernandez	Parking Lot	Desert View ES
1858	Work In Progress New Marquee is going to be installed at site. Will need to run power to it. Please Make arrangements to install next week when Marquee is istalled. Thanks	5/11/2005 Medium	Carlos Castillo		Desert View ES
2496	Work In Progress NEED TO PICK UP SHARPS CONTAINERS FROM NURGES OFFICE ON NEXT TRIP OVERTHERE.	6/3/2005 Medium			Desert View ES
2109	Complete drains are clogged up again, (dishwasher area and serving line area) martha flores - snp manager 505-589-2425 RAN SNAKE DOWN FLOOR SINK UNCLOGGED DRAIN	5/19/2005 6/8/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Desert View ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1249	Duplicate Request ALL DRAINS ARE PLUGGED UP (SERVING LINE DRAINS, DISHMACHINE DRAIN AND SINK DRAINS, ETC.) DUPLICATE WORK ORDER #1017	4/19/2005 4/25/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Desert View ES
1635	Complete 1. CLOGGED DRAIN TO DISHMACHINE 2. (RESTROOM) FLUSHING VALVE IS LEAKING MARTHA FLORES - MANAGER - 589-2425 5/5 RAN SNAKE DOWN FLOOR SINK UNDER DISHWASHER UNCLOGGED 5/6 REMOVED TOILET AND INSTALLED NEW WAX RING AND BOLTS REPLACED TOILET	5/4/2005 5/13/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Desert View ES
775	Void NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005.	4/1/2005 Medium	Aida Salcedo Maria Sitters		Desert View ES
1183	Work In Progress NEED TO REPLACE HOSE SPIGOTS IN PATIOS. LOOSING WATER PRESSURE AND HANDLES ARE BROKEN. NO HEAD CUSTODIAN AT SCHOOL SITE. IF YOU NEED ANY INFORMATION, CONTACT JIMMY CARBAJAL @ THE CUSTODIAL WAREHOUSE	4/15/2005 Medium	Aida Salcedo David Villalobos		Desert View ES
804	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. AS PER JIMMY CARBAJAL	4/1/2005 5/27/2005 Medium	Aida Salcedo Oscar Estrada		Desert View ES
2522	Complete Disconnect power to double metal portable remove power to portable to be moved.	6/6/2005 6/6/2005 Medium	Carlos Castillo Carlos Castillo		Desert View ES
716	Complete N. Roof - need to replace temp gauges. As per Boiler Inspector. WAS REPLACING BAD T-STAT BUT HAD TO REPLACE WELLS BECAUSE OF THE THREADED, TATH WAY ALL WILL BE THE SAME SIZE NOT ORDERING DIFF. KIND OF THERMOMETERS.	3/30/2005 5/3/2005 Medium	Michael Munoz Jose Ambriz		Desert View ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2392	Closed Work Orders 5/27/05 6hr remove sand drive way 2hr maint office 5/27 - 8	5/31/2005 5/27/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2393	Closed Work Orders 5/31/05 1hr play ground ck 6hr remove sand walk way-parkings 1hr work log 5/31 - 8	5/31/2005 5/31/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2421	Closed Work Orders 6/1/05 7hr paint trim-door-ramp port #3 1hr worl log 6/1 - 8	6/1/2005 6/1/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2509	Closed Work Orders 6/3/05 5hr paint trim-doors-trim port #1 2hr help plumber desconnet port to be moved 1hr work log 6/3 - 8	6/3/2005 6/3/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2448	Work In Progress pat aguilar locksmith frount door to building need repair door closures need replacement door handdels need replacement	6/2/2005 Medium	Patricio Aguilar Hector Lozoya		Desert View ES
2460	Closed Work Orders 6/2/05 7hr paint trim-doors-ramps 1hr work log 6/2 - 8	6/2/2005 6/2/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2226	Closed Work Orders 5/23/05 1hr play ground ck 1hr trash cans 1hr ac invetory 4hr set up marqee 1hr work log 5/23 - 8	5/23/2005 5/23/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2262	Closed Work Orders 5/23/05 1hr ac gym 6hr replace sprinkers -remove sand 1hr work log 5/23 - 8	5/24/2005 5/23/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2297	Closed Work Orders 5/25/05 7hr replace sprinkler-remove sand-dig out 4 dead trees 1hr work log 5/25 - 8	5/25/2005 5/25/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2336	Closed Work Orders 5/27/05 7hr replace sprinkers-remove sand 1hr work log 5/27 - 8	5/26/2005 5/27/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1968	Work In Progress pat aguilar - asper principal to replace ac in port #2 room 3&4 with refrigrated air conditioning	5/16/2005 Medium	Patricio Aguilar Jose Ambriz		Desert View ES
1969	Work In Progress pat aguilar move sand away from rock wall move sand back up hill	5/16/2005 Medium	Patricio Aguilar Lorenzo Hernandez		Desert View ES
1965	Closed Work Orders 5/16/05 1hr play ground ck 2hr trash pick up grounds 1hr trash cans 1hr replace water pump #21 2hr scrap weeds grounds- cut weeds 1hr work log 5/16 - 8	5/16/2005 5/16/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1918	Closed Work Orders 5/12/05 3hr replace water drips-adj sprinkers 1hr round up on weeds 3hr building inspetion reports 1hr work log 5/12 - 8	5/12/2005 5/12/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1916	Closed Work Orders 5/12/05 3hr replace water drips-adj sprinkers 1hr round up on weeds 3hr building inspetion reports 1hr work log 5/12 - 8	5/12/2005 5/12/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2127	Closed Work Orders 1/13/05 1hr reset timmer sprinkers 2hr repair office chair 2hr clean out stroe room 1hr clean out truck 2hr maint office 5/13 - 8	5/19/2005 5/13/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2130	Closed Work Orders 5/17/05 8hr help install rain gutters sp 5/17 - 8	5/19/2005 5/17/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2136	Closed Work Orders 5/19/05 1hr paint roses 1hr clean out water lines 2hr paint marquee stand 1hr repair water fountain hall way 2hr clean up around front door 1hr work log 5/19 - 8	5/19/2005 5/19/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2102	Closed Work Orders 5/18/05 1hr repair ac #10 1hr marquee 1hr remove sand drive way 3hr stand marquee 1hr rest ac #76 1hr work log 5/18 - 8	5/18/2005 5/18/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2186	Closed Work Orders 5/20/05 4hr clean out mechanical rooms 3hr water trees 1hr work log 5/20 - 8	5/20/2005 5/20/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1860	Work In Progress pat aguilar grounds need grass seed & fertilizer need 10 trees	5/11/2005 Medium	Patricio Aguilar Lorenzo Hernandez		Desert View ES
1851	Work In Progress pat aguilar elect lower class rest room need emergency light replaced	5/11/2005 Medium	Patricio Aguilar Carlos Castillo		Desert View ES
1848	Closed Work Orders 5/11/05 3hr round up on weeds 1hr help set up ac port 3 1hr emergency light insp 1hr exit signs insp 1hr fire extin insp 1hr work log 5/11 - 8	5/11/2005 5/11/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1855	Complete pat aguilar elect kitchen hall need a transformer for lights	5/11/2005 6/24/2005 Medium	Patricio Aguilar Carlos Castillo		Desert View ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1763	Closed Work Orders 5/9/05 1hr play ground ck 1hr line out soccer grounds 2hr trash pick up grounds 1/2hr ac cont. port 3 1hr trash cans 1hr mow gress 1/2hr replace sprinkler head 1hr work log 5/9 - 8	5/9/2005 5/9/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1723	Closed Work Orders 2hr mow grass 3hr help install new ac port 3 2hr stms repair studen disks 1hr work log 5/6 - 8	5/6/2005 5/6/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1694	Closed Work Orders 5/5/05 2hr trash pick up yard 1hr repair ac #34 1hr replace fire ex 3hr stms ac kitch- broken glass gym door- ceiling tiles office 1hr work log 5/5 - 7	5/5/2005 5/5/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1658	Closed Work Orders 5/4/05 1hr marquee 1hr lights kitchen 1hr sprinkler vale would not close 1/2hr out side door #23 1/2hr play ground water fountin 3hr stms remove sand side walk-drive way-elect bracker gym 1hr work log 5/4 - 8	5/4/2005 5/4/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1627	Closed Work Orders 5/3/05 1/2hr light at office 5hr paint wall at stms 1/2hr help move stage 1hr clean paint tools 1hr work log 5/3 - 8	5/3/2005 5/3/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1441	Closed Work Orders 4/26/05 5hr replace belts ac 2hr sevice ac dinning room 1hr work log 4/26 - 8	4/26/2005 4/26/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1417	Closed Work Orders 4/25/05 1hr play ground ck 3hr replace belts ac 3hr water fountin stms 1hr work log 4/25 - 8	4/25/2005 4/25/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1373	Closed Work Orders 4/22/05 3hr repair 3 water fountins stms need to repair part for 4th water fountin 1hr help at rs service ac 1hr elect office rest rooms 2hr service water fountins 1hr work log 4/22 - 8	4/22/2005 4/22/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1326	Closed Work Orders 2/21/05 2hr repair ac water line 5hr service port ac- class rooms 1hr work log	4/21/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1330	Closed Work Orders 4/15/05 5hr cut weeds frount gate- rack 1hr weeds to dump 2hr maint office 4/15 - 8	4/21/2005 4/15/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1574	Closed Work Orders 5/2/05 1hr play ground ck 1hr marqee 1hr trash pick up grounds 1/2hr lights office rest room 1hr water heater sp 1hr move sand way from doors 1 1/2hr get wall set for paintting 1hr work log 5/2 - 8	5/2/2005 5/2/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1575	Closed Work Orders 5/2/05 1hr play ground ck 1hr marqee 1hr trash pick up grounds 1/2hr lights office rest room 1hr water heater sp 1hr move sand way from doors 1 1/2hr get wall set for paintting 1hr work log 5/2 - 8	5/2/2005 5/2/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1570	Closed Work Orders 4/29/05 1/2hr roof insp. 1hr fire extin insp. 1hr exit light insp. 1/2hr repace bus only parking 1hr repair ac part #2 1hr clean out truck 2hr maint office 4/29 - 7	5/2/2005 4/29/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1473	Closed Work Orders 4/27/05 3 1/2hr water trees 1/2hr paint to rs 1hr cabinet lock #32 2hr service ac gym 1hr work log 4/27 - 8	4/27/2005 4/27/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1474	Complete pat aguilar locksmith need anther lock for file cabinet #32	4/27/2005 5/5/2005 Medium	Patricio Aguilar Hector Lozoya		Desert View ES
1510	Closed Work Orders 4/28/05 1hr repair ac port #5 3hr help at sp with cable for shade 3hr replaced ac filters comp-lib-ast prin-offi-port 1hr work log 4/28 - 8	4/28/2005 4/28/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1165	Closed Work Orders 4/14/05 1hr trash pick up back yard 3hr remove sand side walk 2hr mow grass 1hr clean patios 1hr work log 4/14 - 8	4/14/2005 4/14/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1263	Closed Work Orders 4/19/05 1hr clean big toy play ground 1/2hr pick up trash back yard 5hr service ac class rooms 1/2hr boilers off 1hr work log 4/19 - 8	4/19/2005 4/19/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1294	Closed Work Orders 4/20/05 7hr service ac class rooms 1hr work log 4/20 - 8	4/20/2005 4/20/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1023	Closed Work Orders 3/29/05 1hr play ground ck 1hr clean graffiti off trash cans 2hr trash pick up grounds 4hr sand blsat rock wall	4/11/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1024	Closed Work Orders 3/30/05 2hr sand blast rock wall 1hr remove ole map -hange new map 4hr inspection report 1hr work log	4/11/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1032	Closed Work Orders 4/6/05 4hr remove sand fount walk way 3hr stms water fountin -lib shilfs -rest room cover wires 1hr clean out truck 4/6/05 - 8	4/11/2005 4/6/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1026	Closed Work Orders 4hr water trees 3hr repair water lines 1hr work log	4/11/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1027	Closed Work Orders 4/1/05 4hr weed eater 2hr help havc tech 2hr maint office 4/1 - 8	4/11/2005 4/1/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1028	Closed Work Orders 4/5/05 1hr marqee 6hr mow grass-rack up 1hr work log 4/5 - 8	4/11/2005 4/5/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1074	Closed Work Orders 4/8/05 4hr work on water lines with contractors 1hr marqee 1hr move map #32 1hr out side door #23 1hr work log 4/8 - 8	4/12/2005 4/8/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1071	Closed Work Orders 4/7/05 4hr remove sand walk way- drive way 3hr stms water fountin -cover wires -stair way lights-repair hole on floor 1hr worl log 4/7- 8	4/12/2005 4/7/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1081	Closed Work Orders 4/11/05 1hr play ground ck 1hr trash cans 3hr stms door stops cafit -remove shilfs nurse office 2hr help elect tech trouble shot lights gym 1hr work log 4/11 - 8	4/12/2005 4/11/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
1110	Closed Work Orders 4/12/05 1hr work bord #30 5 1/2hr remove sand drive way 1/2hr help calit tech with grees trap 1hr work log 4/12 - 8	4/13/2005 4/12/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1111	Closed Work Orders 1/13/05 1hr trash cans 4hr remove sand drive way 2hr paint fire lane work log 4/13 - 7	4/13/2005 4/13/2005 Medium	Patricio Aguilar Margret Villalobos		Desert View ES
976	Closed Work Orders 3/2/05 1hr sweep drive way lower grades 2hr trim trees 1hr to dump trims 3hr mow & rack yard 1hr work log	4/8/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
978	Closed Work Orders 3/3/05 1hr repair scale nurse 2hr trim trees 1hr to dump trims 2hr mow grass & rack 1hr install screen #10 1hr work log	4/8/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
979	Closed Work Orders 3/4/05 4hr trim roses- clean around frount door 1hr clean out truck 1hr clean out store room 2hr maint office	4/8/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
980	Closed Work Orders 3/7/05 1hr play ground ck 2hr pick up trash grounds 1hr trash cans 3hr dig out shrups 1hr work log	4/8/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
981	Closed Work Orders 3/8/05 2hr repair food cart cafet 2hr clean pine trees 1/2hr hang fram #19 1 1/2hr dig out shrups 1hr water timer s.p. 1hr work log	4/8/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
982	Closed Work Orders 3/9/05 1hr trash to dump 3hr clean under pine trees 3hr dig out shrups 1hr work log	4/8/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
983	Closed Work Orders 3/10/05 1hr to dump 3hr clean undr pine trees 3hr remove durt- file up holes from shrups 1hr work log	4/8/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
985	Closed Work Orders 3/11/05 1hr pick up trash back yard 3hr clean under pine trees 1hr marquee 1/2hr look for gass smile #15 1 1/2hr trash to dump 1hr work log	4/8/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
986	Closed Work Orders 3/14/05 1hr play ground ck 1/2hr gym light switch 2 1/2hr trash pick up grounds 2 1/2hr remove durt tree bed 1/2hr repair water founten 1hr work log	4/8/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
987	Closed Work Orders 1hr repair tables port #2 4hr repair sprinkler water liones 1hr emergency lighting 1hr exit sign 1hr fire exting 1hr work log	4/8/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
988	Closed Work Orders 3/16/05 3hr repair sprinkler water line replace sprinkers 1hr pot plaint	4/8/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
990	Closed Work Orders 3/17/05 6 1/2hr repair water lines replace sprinkers 1/2hr fire alarm 1hr work log	4/8/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
991	Closed Work Orders 3/18/05 5hr sprinkers - water lines 1hr set up water timmer 2hr maint office	4/8/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
859	Closed Work Orders 2/25/05 1hr marquee 1/2hr hang frame office 2 1/2hr install new bords bleachers 3hr paint bleachers 1hr work log	4/5/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
866	Closed Work Orders 3/1/05 1hr reset heater comp lab 3hr trim trees 1hr trims to dump 3hr inspection report	4/5/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
864	Closed Work Orders 2/28/05 1hr help pick up gate s.p. 1hr marquee 1/2hr light in freezer 2 1/2hr pick up trash grounds 1hr play ground ck 1hr move bleachers 1hr work log	4/5/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2740	Closed Work Orders 6/10/05 2hr paint nurse office -rest room 4hr maint office 2hr clean tools paint 6/10 - 8	6/13/2005 6/10/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2741	Closed Work Orders 6/134/05 7hr paint hall way -rest room hall 1hr work log 6/13 - 8	6/13/2005 6/13/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2675	Closed Work Orders 6/9/05 5hr paint teachers lunch room-paint office inter- paint class rooms 2hr help havc ac port #3-ac comp lab 1hr work log 6/9 - 8	6/9/2005 6/9/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2772	Closed Work Orders 6/13/05 7hr paint hall ways 1hr work log 6/13 - 8	6/14/2005 6/13/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2554	Closed Work Orders 6/6/05 1hr play ground ck 1/2hr ck out side lights with cont. 1hr trash pick up grounds 1 1/2hr help elect desconnet port 3hr mow grass 1hr work log 6/6 - 8	6/6/2005 6/6/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2639	Closed Work Orders 6/8/05 1hr pick up trash were port was moved 6hr paint hall ways 1hr work log 6/8 - 8	6/8/2005 6/8/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
3034	Closed Work Orders 6/24/05 7hr paint sp/ed room 1hr worklog 6/24 - 8	6/28/2005 6/24/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
3035	Closed Work Orders 6/27/05 1hr play ground ck 6hr paint office door-paint princ door-paint rest room doors 1hr work log 6/27 - 8	6/28/2005 6/27/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
3110	Closed Work Orders 6/30/05 7hr paint rest rooms upper grade 1hr work log 6/30 - 8	6/30/2005 6/30/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
3081	Closed Work Orders 6/27/05 2hr emerg light insp 1hr exit signs insp 1hr fire exing insp 3hr build mechanic insp 1hr work log 6/27-8	6/29/2005 6/27/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
3047	Closed Work Orders 6/28/05 7hr paint frount build doors 1hr work log 6/28 - 8	6/28/2005 6/28/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2837	Closed Work Orders 6/16/05 7hr paint class rooms-teachers rest room 1hr work log 6/16 - 8	6/16/2005 6/16/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2834	Closed Work Orders 6/16/05 7hr paint class rooms 1hr work log 6/16 - 8	6/16/2005 6/16/2005 Medium	Patricio Aguilar Patricio Aguilar		Desert View ES
2359	Complete Need water solution tank for floor machine, Note:request is for machine at Desert View Elementary. SOLUTION TANK ISSUED PER JIMMY'	5/27/2005 6/3/2005 Medium	Miguel Aguilar Jimmy Carbajal		Desert View ES
2577	Complete Exterior water fountain broken lower grade playground, water shut off and now exterior portable (6&7) does not have water access in restroom. This portable is being used during intersession. Note: Work order is for Desert View not RS. FOUND VALVE TO DRINKING FTN ONLY AND SUPPLIED WATER TO PORTABLES.	6/7/2005 6/7/2005 Medium	Miguel Aguilar David Villalobos		Desert View ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2542	Work In Progress Need urinal repaired in south side, lower grade restrooms. Note: work order is for Desert View Elementary.	6/6/2005 Medium	Miguel Aguilar David Villalobos		Desert View ES
2543	Complete (4) flush valves leaking, girls restroom south side, lower grade restrooms. Note: Work order is for Desert View Elementary, not RS. MATERIAL SUPPLIED FOR THIS WO GIVEN TO PAT AGUILAR WHO WILL REPAIR.	6/6/2005 6/30/2005 Medium	Miguel Aguilar David Villalobos		Desert View ES
2544	Complete Custodial sink south side is clogged, near lower grade restrooms. Note: Work order is for Desert View Elementary, not RS. cable out sink and unclog	6/6/2005 6/7/2005 Medium	Miguel Aguilar David Villalobos		Desert View ES
2545	Complete Boys north side restrooms (3) flush valves leaking and Girls restroom north side (4) flush valves leaking. Note: Work order is for Desert View Elementary, not RS. MATERIAL FOR THIS WO WAS GIVEN TO PAT AGUILAR , WHOM WILL FIX WHEN FINISHED PAITING.	6/6/2005 6/30/2005 Medium	Miguel Aguilar David Villalobos		Desert View ES
2546	Work In Progress Faucets in both patio areas need repair. Note: Work order is for Desert View Elementary, not RS.	6/6/2005 Medium	Miguel Aguilar David Villalobos		Desert View ES
2730	Work In Progress Requesting pressure washer to clean exterior walkways and patios, large problem with pigeon waste.	6/13/2005 Medium	Miguel Aguilar Jimmy Carbajal		Desert View ES
2731	Complete Requesting new roto block for floor machine, old roto bristles are falling off. Will also be requesting 2nd roto block for carpets like issued at RS. ROTO BLOCK DEL AS PER JIMMY	6/13/2005 6/16/2005 Medium	Miguel Aguilar Jimmy Carbajal		Desert View ES
2732	Complete Roto block for carpets, long bristle, similiar to one issued at RS. DELIVERED ROTO BLOCK WITH SAL TO D.V. AS PER JIMMY	6/13/2005 6/16/2005 Medium	Miguel Aguilar Jimmy Carbajal		Desert View ES
1746	Work In Progress AS PER CORA, SHE NEEDS A MASTER KEY FOR THE CONTRACTORS TO WORK AT DV. (DV-MASTER KEY)	5/9/2005 Medium	Mary Garcia Hector Lozoya	Office	Desert View ES DV SCHOOL
2240	Complete MR. MENDOZA LARRY, TEACHER AT D.V. IS PAYING FOR KEY#RA-11 WITH CHECK #4227. PLEASE REPLACE KEY ASAP FOR 2005-2006 SCHOOL YEAR. CHECK AND COPY OF WORK ORDER SENT TO ANNIE DE LOS SANTOS ON 5/25/05 TOTAL COST 21.00	5/24/2005 5/25/2005 Medium	Margarita Terrazas Hector Lozoya	Classroom	Desert View ES 505-5891189

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
270	Complete as per custodian substitute Mr. Gonzalez, vacuum cleaner is jammed/broken. vacuum cleaner is located in portable #9 near the student restrooms. If you could please fix it or replace it? Thank you! REPLACED WHEEL, RETAINERS, BELTS 7 DID P.M.	3/10/2005 3/18/2005 Medium	Margarita Terrazas Jimmy Carbajal	Classroom	Desert View ES
740	Work In Progress MIKE, THE SCHOOL SIGN THAT MRS. YTURRALDE REQUESTED IT'S ALREADY AT THE WAREHOUSE. LARRY TOLD ME TO LET YOU KNOW SO YOU CAN PICK IT UP AND INSTALL IT. THANK YOU VERY MUCH FOR YOUR HELP! THANK YOU, MARGARET :)	3/31/2005 Medium	Margarita Terrazas Michael Munoz		Desert View ES
828	Complete As per Enrique (construction gentleman), needs for Manny Lozoya to secure the Pre-K building. Manny already talked with Mr. Enrique on this.work on cores and cylinders at main doors and secure outside doors.	4/4/2005 4/5/2005 Medium	Mary Garcia Hector Lozoya	Classroom	GAC
826	Complete As per Becky Acuna-over in the computer lab a bar that was subdividing the lab room, which is located on the wall between the window, needs to be removed. This way window blinds can be installed correctly. Manny already took care of this.	4/4/2005 4/14/2005 Medium	Mary Garcia Manuel Prospero	Computer Lab	GAC
849	Complete As per Manny Prospero's request: Talked with David Villalobos and if can get toilet seats with covers to replace the old ones in the mens and womens bathrooms in A-Wing. supplied Manny with comode seats	4/5/2005 4/7/2005 Medium	Mary Garcia David Villalobos	Restroom (Girls)	GAC
850	Work In Progress As per Manny Prospero: Needs weeds to be cut if can have ground come out to help.	4/5/2005 Medium	Mary Garcia Lorenzo Hernandez		GAC
928	Complete As per Rafa-needs for the mop sink to be replaced with a new mop sink in the custodial closet. Old sink is cracked and leaking water into the wall. replaced cracked mop sink	4/7/2005 4/11/2005 Medium	Mary Garcia David Villalobos	Custodial	GAC
929	Complete As per Rafa-mop holder needs to be replaced with a new mop holder. Old one does not hold items in place. DELIVERED 15 MOP HOLDERS AS PER SAL	4/7/2005 6/16/2005 Medium	Mary Garcia Jimmy Carbajal	Custodial	GAC
1142	Complete ELVA MUNOZ A-WING- NEEDS AIR CONDITIONER TO BE CHECKED, NOT WORKING AT ALL MANNY ALREADY LOOKED AT IT, AND IS NOT WORKING AT ALL. As per Jose troubleshoot unit had a loose connection in 120v line contactor, connected back - working ok.	4/14/2005 4/15/2005 Medium	Mary Garcia Jose Ambriz	Office	GAC

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1021	Complete As per Jose Ambriz, needs Cali to come in and check power in the A-Wing Offices and Conference Room #1, across from Computer Lab in order for him to install cooling & heating unit. Please refer back to work order # 1368.	4/11/2005 6/24/2005 Medium	Mary Garcia Carlos Castillo	Office	GAC
1018	Complete As per Liz Ramirez, would like for Manny Prospero to help her take out a kidney table from the box that was delivered. (note: already assembled)	4/11/2005 4/12/2005 Medium	Mary Garcia Manuel Prospero	Classroom	GAC
1012	Complete As per Ms. Shela Raihl, would like for Michael Vega with Technogoly to have a key issued out for C-Wing Conference Room #1 recut A37 key and rekey core at conf. room.	4/11/2005 4/12/2005 Medium	Mary Garcia Hector Lozoya	Classroom	GAC
1057	Complete As per Manny Prospero, needs Manny Lozoya to lubercate all door knobs in the portables at the point.	4/12/2005 4/12/2005 Medium	Mary Garcia Hector Lozoya	Classroom	GAC Point-across the street
1058	Complete As per Manny Prospero-the portable at the point needs to have the ceiling tiles replaced. (due to wind that moved them)	4/12/2005 4/12/2005 Medium	Mary Garcia Manuel Prospero		GAC Point-across the street
1059	Complete As per Manny Prospero, the Main Office Portable needs the old instalation replaced. (due to the dust and wind)	4/12/2005 4/29/2005 Medium	Mary Garcia Manuel Prospero	Office	GAC Point-across the street
1043	Complete Weather stripping needs to be put around Blanca Rivera's door in C-Wing. She gets about an inch of dust her office.	4/11/2005 4/15/2005 Medium	Mary Garcia Manuel Prospero	Office	GAC
1243	Complete AS PER MANNY PROSPERO-A WING AIR CONDITIONER UNIT NEEDS TO BE CHECKED, NOT COOLING. MANNY ALREADY TALKED WITH JOSE AMBRIZ, AND SEEMS TO KNOW WHAT THE PROBLEM IS. There was a leak in condensor lines, braced, vacuum , charge had to troubleshoot t-stat wiring, was not runing unit off, both compressors working .	4/19/2005 4/27/2005 Medium	Mary Garcia Jose Ambriz	Office	GAC
1246	Complete AS PER MARTHA GALLEGOS-NEEDS MANNY PROSPERO TO CUT WEEDS, CLEAN SIDEWALKS AND COVER HOLES AROUND THE TRAILER.	4/19/2005 4/20/2005 Medium	Mary Garcia Manuel Prospero		GAC POINT
1216	Complete As per Socorro McCrum-A Wing-Computer Lab needs some tiles to be replaced and reposition properly.	4/18/2005 4/18/2005 Medium	Mary Garcia Manuel Prospero	Computer Lab	GAC

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1217	Complete As per Socorro McCrum-A Wing Computer Lab- old curtains need to be removed	4/18/2005 4/18/2005 Medium	Mary Garcia Manuel Prospero	Computer Lab	GAC
1218	Complete As per Socorro McCrum-A Wing-Computer Lab needs to be dusted after replacing ceiling tiles.	4/18/2005 4/18/2005 Medium	Mary Garcia Ralph Lara	Computer Lab	GAC
212	Void As per Manny Prospero & Danny Miranda- The new bathrooms - partions in both women & men's need to be replaced. (A-Wing)	3/9/2005 3/18/2005 Medium	Mary Garcia Danny Miranda	Restroom (Boys)	GAC
219	Complete Jim Amacher needs a (closet) door to be removed from his office. remove door and put in new plate covers.	3/9/2005 3/11/2005 Medium	Mary Garcia Manuel Prospero	Office	GAC
204	Complete GOING DOWN THE WALK PATH THERE IS AN AREA THAT THE CEMENT IS NOT EVEN AND WOULD LIKE TO KNOW IF SOMETHING CAN BE DONE BEFORE SOMEONE HAS AN ACCIDENT. THIS AREA IS SOME WHAT IN FRONT OF THE POOL AREA. (MAYBE A TAPE OR SOME CEMENT TO LEVEL IT OUT OR SOMENTING OF THAT SORT. 1438	3/9/2005 3/18/2005 Medium	Mary Garcia Manuel Prospero		GAC
144	Work In Progress IN A-WING SPECIAL ED, ACROSS COMPUTER LAB; ROOMS HAVE NO COOLING AND HEATING. NEED TO TALK W/SYLIVIA MORENO.	3/8/2005 Medium	Mary Garcia Jose Ambriz	Office	GAC
692	Complete Elva Munoz-A Wing; broke her desk key and needs a replacement key. change lock at cafeteria for contractor repair camlock elva desks.	3/30/2005 3/30/2005 Medium	Mary Garcia Hector Lozoya	Office	GAC
381	Complete Bathroom behind reception area in C-Wing needs for the exhaust fan to be replaced. (as per Jose Ambriz & Manny P.) Jose Ambriz already replaced it, but needs to account for the exhaust fan. Removed old burned exh replaced it with new.	3/15/2005 3/15/2005 Medium	Mary Garcia Jose Ambriz	Restroom (Boys)	GAC
443	Complete NEEDS A DOOR STOPPER IN FILE ROOM IN A- WING (ELVA MUNOZ) change door stopper in file room.	3/16/2005 3/31/2005 Medium	Mary Garcia Manuel Prospero	Office	GAC
2107	Complete BETEL B-WING NEEDS A FILING CABINET TO BE ASSEMBLED	5/19/2005 5/19/2005 Medium	Mary Garcia Manuel Prospero	Office	GAC
2189	Complete NEED KEYS FOR MS. AGUEDA MORA - AB63 (OFFICE ONLY) DUPLICATE HB63 FOR MS. MORA	5/20/2005 5/25/2005 Medium	Mary Garcia Hector Lozoya	Office	GAC

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1934	Complete AS PER DINO FACIO-LIGHTS OUT OVER THE HR & FINANCE RECEPTION AREA. MANNY AWARE OF IT.	5/13/2005 5/17/2005 Medium	Mary Garcia Manuel Prospero	Office	GAC
1554	Complete AS PER MR. GIOVAS, GESSICA BASQUEZ NEEDS A KEY F9S FOR THE CAFETERIA TO BE ISSUED TO HER.	5/2/2005 5/3/2005 Medium	Mary Garcia Hector Lozoya	Cafeteria	GAC
1457	Complete As per Mr. Giovas - Need to replace locks and rekey to off-master. (Only 2 Keys) rekey new cafeteria to off master.	4/27/2005 5/3/2005 Medium	Mary Garcia Hector Lozoya	Cafeteria	GAC
1460	Complete As per Liz Ramirez-Point, there is a water leak between office portable and portable #3. David Villalobos is the one that needs to take care of this. As per Manny Prospero, he already looked at this, and needs for David to take care of this. As per David Manny did not dig up as requested, hose bib was eliminated there was a shutoff vlave directly under hosebib. currently plugged, if they need hosebibb, Manny has hosebibb and viser to put back on, besides looking Many needs to attempt at finding the problem.	4/27/2005 4/29/2005 Medium	Mary Garcia David Villalobos	Office	GAC Point
1366	Complete MS. BROWDER'S OFFICE-B WING, NEEDS FOR THERMASTATE TO BE WIRED. AS PER MANNY PROSPERO, CALI WAS ALREADY AWARE TO CONNECT WIRES, BUT HAS NOT BEEN DONE FOR OVER 1 YEAR. run circuit for wall mt unit.	4/22/2005 5/17/2005 Medium	Mary Garcia Carlos Castillo	Office	GAC
1351	Complete YOLI JACQUEZ-C-WING, NEEDS A CABINET TO BE ASSEMBLED. (VERY LAGRGE CABINET). BOXES ARE IN HER OFFICE.	4/22/2005 4/25/2005 Medium	Mary Garcia Manuel Prospero	Office	GAC
1352	Complete MARY GACIA'S OFFICE-A WING, OUR SUPPLY CABINET DOOR NEEDS TO BE REPAIRED. DOES NOT LOCK. MANNY WAS AWARE OF THIS ON 05/21/05.	4/22/2005 4/25/2005 Medium	Mary Garcia Manuel Prospero	Office	GAC
1806	Complete LIZ RAMIREZ-POINT NEEDS 3 DESK TO BE ASSEMBLED.	5/10/2005 5/16/2005 Medium	Mary Garcia Manuel Prospero	Office	GAC POINT
1609	Complete AS PER MR. RICHARD CHAVEZ, NEEDS A KITCHEN KEY ISSUED TO HIM. KEY #AB5. duplicate AB5 Key	5/3/2005 5/5/2005 Medium	Mary Garcia Hector Lozoya	Cafeteria	GAC kitchen
1610	Complete ELVA MUNOZ LOST OFFICE KEY #AB46. NEEDS EITHER A NEW KEY OR A REPLACEMENT KEY. replace cores and recut keys	5/3/2005 5/5/2005 Medium	Mary Garcia Hector Lozoya	Office	GAC

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1611	Complete AS PER MANNY PROSPERO, DOOR LOCK IN THE ELECTRICAL ROOM IN KITCHEN ENTRANCE DOES NOT LOCK. MANNY LOZOYA IS ALREADY AWARE OF PROBLEM	5/3/2005 5/5/2005 Medium	Mary Garcia Hector Lozoya	Mechanical Room	GAC CAFETERIA
2786	Complete AS PER MANNY PROSPERO, 2ND REQUEST- NEEDS A KEY FOR THE BOILER ROOM. (THIS ROOM IS OFF MASTER) 1 KEY FOR MANNY P. FOR BOILER	6/15/2005 6/15/2005 Medium	Mary Garcia Hector Lozoya	Mechanical Room	GAC BOILER ROOM
2768	Complete MARTHA GALLEGOS-POINT; NEEDS HER OFFICE TO BE PAINTED AND PATCH HOLES.	6/14/2005 6/16/2005 Medium	Mary Garcia Manuel Prospero	Office	GAC POINT
2755	Work In Progress AS PER LAURA GARCIA-WOULD LIKE TO CLOSE OFF OFFICE DOOR TOTALLY & HAVE A DOOR MADE THROUGH ANNIE'S OFFICE, GOING INTO HER OFFICE. (PLEASE CHECK W/LAURA BEFORE DOING ANYTING.)	6/13/2005 Medium	Mary Garcia Danny Miranda	Office	GAC
2756	Work In Progress AS PER MR. GIOVAS NEEDS AN ELECTRICAL OUTLET TO CONNECT THE COKE MACHINES, OUT IN THE PATIO PORCH. PLEASE SEE MR. GIOVAS OR MARY BEFORE INSTALLING	6/13/2005 Medium	Mary Garcia Carlos Castillo		GAC PATIO AREA
2548	Work In Progress AS PER CORA W/TECHNOLOGY, SHE NEEDS A KEYS TO BE ISSUE TO LYNCO ELECTRIC AND SOUND & SINGNAL FOR GHS AND LU (FOR THE WHOLE SCHOOL)	6/6/2005 Medium	Mary Garcia Hector Lozoya	Classroom	GAC
2587	Complete RAY LARA LOST A KEY TO HIS OFFICE C-WING (#A34) REKEY OFFICE C-WING A34 TO A42XC: Eloisa invoice05-73	6/7/2005 6/15/2005 Medium	Mary Garcia Hector Lozoya	Office	GAC
2588	Work In Progress AS PER MR. RICHARD G. CHAVEZ, CRUSHED GRAVEL NEEDED FOR ROAD GOING DOWN TO MANNY PROSPERO'S MOBILE HOME. SCHOOL CARS WILL BE PARKED TEMPORARY THERE. (NOTE: CARS WILL START PARKING ON FRIDAY, 10TH) PLEASE SEE MARY GARCIA OR MR. CHAVEZ BEFORE THROWING GRAVEL.	6/7/2005 Medium	Mary Garcia Lorenzo Hernandez	Parking Lot	GAC
2654	Complete EAST OF C-WING, TILE IS BROKEN AND NEEDS TO BE REPLACED WITH A NEW PIECE. (SAFETY ISSUE)	6/9/2005 6/9/2005 Medium	Mary Garcia Manuel Prospero	Hallway/Corridor	GAC

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2658	Work In Progress RAY LARA-C WING; NEEDS FURNITURE TO BE MOVED FROM CORINA & DEBBIE'S OFFICE INTO THE CONFERENCE ROOM. (WIRE SHELVE WILL BE PLACED IN MR. LARA'S OFFICE). NOTE: THIS MUST BE DONE BY 6/15/05 AS PER MS. STEINHOFF.	6/9/2005 Medium	Mary Garcia Manuel Prospero	Office	GAC
2659	Work In Progress AS PER ALL B-WING, AIR CONDITIONING WINDOW UNITS NEED TO BE CLEANED OUT. (TO MUCH DUST WHEN TURNING ON UNIT)	6/9/2005 Medium	Mary Garcia Manuel Prospero	Office	GAC
2660	Work In Progress AS PER CARLOS VIGIL-NEEDS 6 PAD LOCKS FOR GHS MASTER. (FOR THIS TO OPEN WITH BEST LOCK MASTER KEY) APPROVED BY MR. CHAVEZ	6/9/2005 Medium	Mary Garcia Hector Lozoya	Classroom	GAC
2879	Complete AS PER ELVA PEREZ-AIR CONDITIONER NEEDS FILTER TO BE CLEANED OUT. use blower and install new filter.	6/20/2005 6/22/2005 Medium	Mary Garcia Manuel Prospero	Office	GAC
2973	Complete NEED TO PICKUP LM KEYS FROM MARY GARCIA THEY WERE DELIVERED TO HER. WORK ON NEW LOCKS FOR NEW BLDG AND PICKUP KEYS FROM LM SCHOOL.	6/24/2005 6/27/2005 Medium	Mary Garcia Hector Lozoya		GAC
2909	Work In Progress AS PER TINA B-WING, OUTLET IN THE FILE ROOM DOES NOT WORK. (NEED TO PLUG A FAN IN ORDER TO WORK IN THAT ROOM TO HOT.) Need Electrician's assistance, checked for power, breaker and no power. routed to Cali 6/27/05.	6/21/2005 Medium	Mary Garcia Carlos Castillo	Office	GAC FILE ROOM
2938	Work In Progress AS PER ELVA MUNOZ-IF BATHROOM ACROSS COMPUTER LAB CAN BE PAINTED.	6/22/2005 Medium	Mary Garcia Manuel Prospero	Restroom (Girls)	GAC ACROSS COMPUTER LAB
2939	Work In Progress AS PER ELVA MUNOZ-IF LIGHTS IN THE BATHROOM ACROSS COMPUTER LAB CAN HAVE BETTER LIGHTING. (TO DARK)	6/22/2005 Medium	Mary Garcia Manuel Prospero	Restroom (Girls)	GAC ACROSS COMPUTER LAB
3013	Work In Progress As per Norma Alvarado-A Wing, needs 3 ceiling tiles to be replaced in her office	6/27/2005 Medium	Mary Garcia Manuel Prospero	Office	GAC Norma's Office
3095	Work In Progress AS PER ALFREDO, MANNY LOZOYA NEEDS TO CHANGE THE MECHANICAL ROOM DOOR TO THE MASTER KEY FOR GAC	6/30/2005 Medium	Mary Garcia Hector Lozoya	Mechanical Room	GAC
3096	Work In Progress AS PER TINA GALLEGOS -STORAGE AREA WHERE NETWORK PRINTERS ARE LOCATED NEED COOL AIR IN ORDER TO RUN PROPERLY.	6/30/2005 Medium	Mary Garcia Jose Ambriz	Office	GAC B WING

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
3097	Work In Progress AS PER MARGARET VILLALOBOS- A WING - AIR CONDITIONERS IN MS. LEADAU'S OFFICE AND ALL OTHER OFFICES IN THAT AREA ARE NOT WORKING AT ALL. As per Mary Garcia this may be a duplicate	6/30/2005 Medium	Mary Garcia Jose Ambriz	Office	GAC A WING
3072	Work In Progress AS PER ALFREDO HOLGUIN-NEEDS 2 GRAND MASTER KEYS MADE FOR GAC. THIS WILL BE ISSUED OUT TO ONE PERSON IN HVAC, PLUMBER AND ELECTRICIAN. THIS KEYS NEED TO BE GIVEN TO MARY GARCIA-TO KEEP TRACK OF GAC KEYS BEFORE ISSUING TO ANY STAFF MEMBER.	6/29/2005 Medium	Mary Garcia Hector Lozoya	Mechanical Room	GAC GAC
3073	Work In Progress AS PER DINO FACIO-A HOLE IS DEVELOPING ON ONE OF THE FLOOR TILES AND WILL CAUSE OTHER TILES TO BREAK DE TO BUMPS ON THE FLOOR.	6/29/2005 Medium	Mary Garcia Manuel Prospero	Office	GAC PURCHASING OFFICE
3067	Work In Progress AS PER ELISA SAENZ-NEEDS A NAME PLATE FOR MS. MORA TO READ AS FOLLOWS: (AGUEDA MORA, ACTING SUPERINTENDENT)	6/29/2005 Medium	Mary Garcia Hector Lozoya	Office	GAC
3068	Work In Progress AS PER ELISA SAENZ-NEEDS A NAME PLATES, THAT READS AS FOLLOWS: (ELISA SAENZ) ONE ONLY	6/29/2005 Medium	Mary Garcia Hector Lozoya	Office	GAC
2265	Work In Progress Repair the sprinkler system at the GAC in the front.	5/25/2005 Medium	Michael Munoz Lorenzo Hernandez		GAC
2384	Complete WATER OUTAGE CK'D WITH CONTRACTORS ON WATER OUTAGE, CKD PRESSURE INSIDE BLDG AND FLUSHVALVES.	5/31/2005 5/31/2005 Medium	Michael Munoz David Villalobos		GAC
1464	Closed Work Orders 4/27/05 7HRS HELP JOSE AMBRIZ TOFIX A WING A/C. 1HR HELP JOSE AMBRIZ TO INSTALL HEAD PRESSURE CONTROL IN TECNOLOGY A/C/. 4/27 - 8	4/27/2005 4/27/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1541	Closed Work Orders 4/29/05 2HRS CHANGED LIHTS VULVS AND BALLAST IN CONFERENCE ROOM. 4HRS W.O.1059 2HRS I WENT TO PYSICAL PLANT TO PIKIN SOM MATERIALES. 4/29 - 4	4/29/2005 4/29/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1577	Closed Work Orders 5/02/05 1HR INSTALL TEMPERATURE METER IN KITCHEN.2HRS WORKING IN ELECTRIC DOOR IN C WING. 1HRS INSTALL HUNGER IN C WING AREA. 1HRS INSTALL 3 DOOR SWEEPS IN KITCHEN AREA. 3HRS SPRAGING WEEDS POISON IN THE FRONT ENTRANCE. 5/2 - 8	5/2/2005 5/2/2005 Medium	Manuel Prospero Manuel Prospero		GAC

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1322	Closed Work Orders 4/21/05 2HRS.W.O.#1243 CHARGED THE ONLY ONE COMPRESOR IS WORKING, WE NEED CHANGED 2 BAD COMPRESORS. 6HRS RECHARGED AND CHECK HALL A/C UNID IN THE BUILDING. 4/21 - 6	4/21/2005 4/21/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1371	Closed Work Orders 4/22/05 5HRS HELP TO MOVE HALL FURNITURE AND COMPUTER TO MS.MYRA CASTILLO [ALLIANCE PORTABLE]. 1HRS REMOVE LIGHTS BULV IN 'C' WING. 2HRS HELP JOSE AMBRIZ AND JAIME GOMEZ IN C WING A/C/ UNID. 4/22 - 8	4/22/2005 4/22/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1419	Closed Work Orders 4/25/05 4HRSW.O. 1351 1HR W.O.1352. 2HRS HELP TO SET UP BOR ROOM FOR MEETIN. 1HRS CHECK THERMOSTAT IN B WING. 4/25 - 3	4/25/2005 4/25/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1436	Closed Work Orders 4/26/05 4HRS HELP JOSE AMBRIZ TO FIX A LEACK ON TOP UNID AND RECHARGE. 1HRS INSTALL DOOR STOPPER IN ANNE DE LOS SANTOS OFFICE. 2HRS CHANGED LIGHTS BULB IN C WING HALL. 1HRS CHANGED CEILIN TILES IN CAFETERIA. 4/26 - 8	4/26/2005 4/26/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1616	Closed Work Orders 5/3/05 2HRS REPLACES DIAPHRAGM IN A WING MAN RESTROOM 2HRS WORKING IN C WING COOLING. 3 HRS HEL MANY LOZOYA TO FIX DOOR IN ELECTICO ROOM A WING AND WAKING DOORS IN KITCHEN. 1HRS CHECK BERTA RUIZ WEEL CHAER. 5/3 - 8	5/3/2005 5/3/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1654	Closed Work Orders 5/4/05 2HRS CAT WEEDS IN FRONT ENTRANCE 2HRS CHANGED LIGHTS BULBS AND BALLAST IN KITCHEN. 2HRS HELP TO SET UP SOME STAFF IN KITCHEN. 2HRS INSTALL CEILIN TILES IN CAFETERIA. 5/4 - 8	5/4/2005 5/4/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1691	Closed Work Orders 5/5/05 2HRS CAT WEEDS IN PARKING LOT 2HRS REMARK LINES IN PARKING LOT. 2HRS MOVE FILE CABINETS IN YOLY JAQUEZ STORAGE AN INSTALL NEW CABINET. 2HRS ASEMBLE A CAR FOR T.V.FOR MS.CUBILETE. 5/5 - 8	5/5/2005 5/5/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1717	Closed Work Orders 5/6/05 3HRS WORKING IN JOSE REYEZ REFRIGERATION UNID.2HRS REPLACE DIAPHRAGM IN LEADIES RESTROOM 'A' WING 2HRS FINISH REMARK LINES IN PARKING LOT.1HRS FINISH CHANGED CEILIN TILES IN KITCHEN 5/6 - 8	5/6/2005 5/6/2005 Medium	Manuel Prospero Manuel Prospero		GAC

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1802	Closed Work Orders 5/10/05 6HRS CAT WEEDS AND CLEAN THE PATIO. 2HRS INSTALL MOP SENC IN CUSTODIAN CLOUSET A WING. 5/10 - 8	5/10/2005 5/10/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1768	Closed Work Orders 5/9/05 2HRS HELP TO SET UP ITEM IN KITCHEN. 1HRS WO 126254 1HR 126255.2HRS ASSEMBLE AND INSTALL RACK MAGAZINE IN YOLI JAQUEZ OFFICE. 2HRS ASSEMBLE FLAT BED DOLLY. 5/9 - 8	5/10/2005 5/9/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1864	Closed Work Orders 5/11/05 6HRS I DELIVERED CHAIRS TO DIFFERENT CLASSROOMS AND ASSEMBLE PARTICION FOR A CLASSROOM IN ALLIANCE PORTABLES. 2 HRS WORKING IN A/C JOSE REYEZ OFFICE. 5/11 - 8	5/11/2005 5/11/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1838	Complete AS PER JOSE AMBRIZ-STATES THAT HE NEEDS TO CHANGE THE CONDENSER FAN MOTOR FOR A WINDOW UNIT IN JOSE REYES'S OFFICE. JOSE AMBRIZ IS ALREADY AWARE OF THIS. HAD A BAD CONDENSOR, PTAC UNIT IN BACKUP I REPLACED BAD COMPRESSOR, WILL ORDER PART TO REPLACE BAD ONE.	5/11/2005 5/12/2005 Medium	Manuel Prospero Jose Ambriz	Office	GAC
1907	Closed Work Orders 5/12/05 4HRS MAINTAINED FRONT GRAUNDS [SIDEWALKS] CAT WEEDS AND REMOVED ALL ENTRANCE DIRT. 2HRS HELP JOSE AMBRIZ TO CHANGED WINDOW UNID IN JOSE REYEZ OFFICE. 2HRS HELP DANY MIRANDA TO FIGURAT CONSTRUCTION IN C WING. 5/12 - 8	5/12/2005 5/12/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2451	Closed Work Orders 6/2/05 2HRS IRRIGATION OUT SIDE 2HRSINSTALL CLOCS AN MOVED FURNITURE C WING 4HRS WORKING IN A WING A/C WIHT JOSE AMBRIZ. 6/2 - 8	6/2/2005 6/2/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2504	Closed Work Orders 6/3/05 1hr irrigation out side. 2hrs check thermostat and a/c in c wing area.2hrs changed ceilin tiles in main hall. 1hrs help jose ambriz to fix a/c in a wing. 2hrs working in a wing a/c one mor time. 6/3-8	6/3/2005 6/3/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2406	Closed Work Orders 5/31/05 2HRS MOVE FUNITURE AND BAXES SOCORROMC CRUM TO COMFERECE ROOM NUM 3. 2.5 HRSW.O.2384. 3.5HRS CHANGED CEILIN TILES IN C WING. 5/31 - 5.5	6/1/2005 5/31/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2426	Closed Work Orders 6/1/05 6HRS MAINTAINER FRONT GRAUNDS [SIDE WALKS] CUT WEEDS AND REMOVED ALL ENTRANCE DIRT. 2HRS CHANGED CEILIN TILES. 6/1 - 8	6/1/2005 6/1/2005 Medium	Manuel Prospero Manuel Prospero		GAC

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2250	Closed Work Orders 5/24/05 4HRS MAINTAINED FRONT GRAUNDS [SIDE WALKS] CUT WEEDS AND ALL ENTRANCE DIRT. 2HRS VISIT MIKE SORIA ABOUT PORTABLE SPRINCKLER 2HRS MOVE FURNITURE IN SOCORRO;S OFFICE. 5/24 - 8	5/24/2005 5/24/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2224	Closed Work Orders 5/23/05 3HRS ASSEMBLE 2 TABLE CADDY AND 4 CHAIR CADDY. 5/23 - 3	5/23/2005 5/23/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2373	Closed Work Orders 5/27/005 2HRS CHECK FOR GAS LEAK IN KITCHEN. 2HRS HELP DANY MIRANDA TO FIX A RESTROOM PARTITION. 2HRS HELP DAVID VILLALOBOS IN RESTROMS. 2HRS I WEN TO PHISYCAL PLANT TO PICK UP SOME MATERIALES . 5/27 - 8	5/27/2005 5/27/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2162	Closed Work Orders 5/20/05 7HRS CHANGED CEILIN TILES IN C WING HALL, COMPUTER LAB AND RECEPTION AREA. 1HRS WORKIN IN NURSES OFFICE A/C. 5/20 - 8	5/20/2005 5/20/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2163	Work In Progress 5/20/05 WE NEED TO CHANGED LOCKS AT NEW HANDICAP RESTROOMS. TO PRIMUS LOCKS. THIS IN FOR MANNY LOZOYA	5/20/2005 Medium	Manuel Prospero Hector Lozoya		GAC
2090	Closed Work Orders 5/18/05 2HRS ASSEMBLE A TV CAR. 2HRS WORKIN IN MS.BROWRER A/C. 2HRSASSISTING MANY LOZOYA. 2HRS FIX A DOOR CLOUSED IN C WING HALL. 5/18 - 8	5/18/2005 5/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2091	Closed Work Orders 5/18/05 2HRS ASSEMBLE A TV CAR. 2HRS WORKIN IN MS.BROWRER A/C. 2HRSASSISTING MANY LOZOYA. 2HRS FIX A DOOR CLOUSED IN C WING HALL. 5/18 - 8	5/18/2005 5/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2123	Closed Work Orders 5/19/05 1HRS WO 2107. 3HRS WORKING IN CHERYL COYLE A/C. 2HRS CHECK CAROLYN LINDAU A/C/. 2HRS WORKING WIHT JOSE AMBRIZ IN MS.BROWRER A/C. 5/19 - 7	5/19/2005 5/19/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2125	Closed Work Orders 5/19/05 1HRS WO 2107. 3HRS WORKING IN CHERYL COYLE A/C. 2HRS CHECK CAROLYN LINDAU A/C/. 2HRS WORKING WIHT JOSE AMBRIZ IN MS.BROWRER A/C. 5/19 -8	5/19/2005 5/19/2005 Medium	Manuel Prospero Manuel Prospero		GAC

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1940	Closed Work Orders 5/13/05 2HRS WO 1934 1HRS ASSEMBLE A PRINTER STAND. 2HRS MOVE FURNITURE IN CISSY ANDREAS OFFICE C WING.2HRS CHANGED LIGHTS BULVES AND BALLAST IN TINA GALLEGOS OFFICE. 1HR PAPER WORK. 5/13 - 6	5/13/2005 5/13/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1956	Closed Work Orders 5/16/05 4HRS CHANGED CEILIN TILES IN MAIN ENTRANCE HALL. 2HRS WORKING WIHT DENY MIRANDA. 2HRS W.O.1806. 5/16 - 6	5/16/2005 5/16/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1980	Work In Progress AS PER MANY LOZOYA WE NEED 4 KEY FOR RESETE FIRE ALARM.	5/17/2005 Medium	Manuel Prospero Hector Lozoya		GAC
2047	Closed Work Orders 5/17/05 2HRS W.O.1934 2HRS CHANGED LIHTS BULBS AND BALLAST IN A WING RESTROOM. 4HRS.CHANGED SEILIN TILES IN COMPUTER LAB AND CONFERENCE ROOM NUM 2. 5/17 - 6	5/17/2005 5/17/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1227	Closed Work Orders 4/18/05 2HRS OPEN VENTSIN IRMA SUAREZ ,CARMEN MORRISETE AND COPY ROOM PLACES. 2HRS W.O.1216. 2HRS W.O.1217. 1HR W.O.1218.. 1HRS HELP RAFAEL LARA TO SET UP BORN ROOM FOR MEETIN. 4/18 - 3	4/18/2005 4/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1200	Closed Work Orders 4/15/05 4HRS W.O. 1142 1HR W.O.1043 2HRS I WENT TO PYSICAL PLANT TO PIKING SOME MATERIALES AND CHECK THA TRUACK. 1HR CLINING MAY STORAGE. 4/15 - 3	4/15/2005 4/15/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1171	Closed Work Orders 4/14/05 4/HRS W.O # 826. 2HRS W.O.#125797 2HRS W.O #125798. 4/14 - 4	4/14/2005 4/14/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1285	Closed Work Orders 4/20/05 8HRS W.O.1246 1246	4/20/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1252	Closed Work Orders 4/19/05 2HRS AJUST DOORS IN TEGNOLOGY DEP. 2HRS CHANGED LIGHTS VULBS AND BALLAST IN ELECTRIC ROOM C WING. 2HELP IN FIRE TEST IN KITCHEN AREA. 2HRS I WENT TO SANTA TERESA M SCHOOL TO PIK UP SOME TABLES FOR A MEETIN AND TACK BACK. 4/19 - 8	4/19/2005 4/19/2005 Medium	Manuel Prospero Manuel Prospero		GAC
1120	Closed Work Orders 4/13/05 6HRS CUTING WEEDS FRONT TO THE BUILDING AND CLINING SIDE WALKS 2HRS COVER HOLE IN KITCHEN. 4/13 - 8	4/13/2005 4/13/2005 Medium	Manuel Prospero Manuel Prospero		GAC

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1088	Closed Work Orders 4/12/05 2HRSW.O.I.D. 1058 W.O.I.D. 2HRS 1057. 2HRS WO.ID. 1018. 2HRS FIX WATER LEACK IN LEADIES RESROOM [MAIN ENTRANCE]. 4/12 - 4	4/12/2005 4/12/2005 Medium	Manuel Prospero Manuel Prospero		GAC
966	Closed Work Orders 4/8/05. 3hrs clining sidewalks and catting weeds/picking trash in parking lot. 2hrs remove mop basin in custodian room. 3hrs remove old toilet sit and install 5 new in main entrance. 4/8/05 - 8	4/8/2005 4/8/2005 Medium	Manuel Prospero Manuel Prospero		GAC
848	Closed Work Orders 4/5/05 2HRS HELP RAFAEL LARA TO SET UP BOR ROOM FOR MEETIN. 2HRS FIX A DOOR IN CONFERENCE ROOM #1 'C' WING 4/5 - 4	4/5/2005 4/5/2005 Medium	Manuel Prospero Manuel Prospero		GAC
956	Closed Work Orders 4/6/05 4hrs maintained front grounds side walks cut weeds and removed all entrance dirt. 4hrs working in the back yard. 4/6 - 8	4/8/2005 4/6/2005 Medium	Manuel Prospero Manuel Prospero		GAC
807	Closed Work Orders 4/1/05 2hrs changed ceilin tiles in jaky aguilar office. 2hrs cut weeds in back to the building. 4hrs made paper work wen to physical plant wash truak, chek oil level, pick materiales.	4/1/2005 4/1/2005 Medium	Manuel Prospero Manuel Prospero		GAC
838	Closed Work Orders 4/4/05 4HRS ID#826 2HRS CHANGED BALLAST IN 'C' WING RESTROOM. 2HRS CUT WEEDS IN PATIO. 04/05/05 - 4	4/5/2005 4/5/2005 Medium	Manuel Prospero Manuel Prospero		GAC
839	Closed Work Orders 4/4/05 4HRS ID#826 2HRS CHANGED BALLAST IN 'C' WING RESTROOM. 2HRS CUT WEEDS IN PATIO. 4/4/05 - 4	4/5/2005 4/4/2005 Medium	Manuel Prospero Manuel Prospero		GAC
712	Closed Work Orders 4HRS CHANGED CEILIN TILES IN CAFETERIA. 2HRS CHANGED LIGHTS BULBS AND BALLAST IN LITTLE ROOM IN KITCHEN. 2HRS WORKING IN 'B' WING HEATER.	3/30/2005 Medium	Manuel Prospero Manuel Prospero		GAC
620	Closed Work Orders 4HRS PICK UP TRAS END CLEAN FRONT TO THE BUILDIN. 2HRS FINISH INSTALL 5MINUTES PARKING ONLY SINGS .2HRS HELP CUSTODIAN TO SETUP BOR ROOM .	3/24/2005 Medium	Manuel Prospero Manuel Prospero		GAC
594	Closed Work Orders 8HRS INSTALL 15 SIGNS '30 MINUTES PARKING ONLI IN FRONT TO BUILDING.	3/23/2005 Medium	Manuel Prospero Manuel Prospero		GAC

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
595	Closed Work Orders 8HRS INSTALL 15 SIGNS '30 MINUTES PARKING ONLI IN FRONT TO BUILDING.	3/23/2005 Medium	Manuel Prospero Manuel Prospero		GAC
574	Closed Work Orders 3HRS I WENT TO SAFETY MIRIN IN S.T.M.S. 1HR I WEN TO DO IT BEST TO PICK UP SOME CEMNT. 4HRS HELP LUPE ONTIVEROS TO PICK UP ROCAS.	3/22/2005 Medium	Manuel Prospero Manuel Prospero		GAC
575	Closed Work Orders 3HRS I WENT TO SAFETY MIRIN IN S.T.M.S. 1HR I WEN TO DO IT BEST TO PICK UP SOME CEMNT. 4HRS HELP LUPE ONTIVEROS TO PICK UP ROCAS.	3/22/2005 Medium	Manuel Prospero Manuel Prospero		GAC
565	Closed Work Orders 2HRS CHANGED LIGHTING BULBS IN KITCHEN. 6HRS HELP LUPE ONTIVEROS TO PICK UP ROCKS IN PARKING LOT.	3/21/2005 Medium	Manuel Prospero Manuel Prospero		GAC
566	Closed Work Orders 3/21/05 2HRS CHANGED LIGHTING BULBS IN KITCHEN. 6HRS HELP LUPE ONTIVEROS TO PICK UP ROCKS IN PARKING LOT.	3/21/2005 Medium	Manuel Prospero Manuel Prospero		GAC
670	Closed Work Orders 2HRS CHANGED 2 PISSES OF TILES IN THE FRONT ENTRANCE. 2HRS CHANGED AIR FILTER RETURN IN DATA ROOM. 2HRS HELP JOSE AMBRIZ TO INSTALL A HEAD PRESSURE CONTROL. 2HRS HELP DENY MIRANDA TO FIX A DOOR.	3/29/2005 Medium	Manuel Prospero Manuel Prospero		GAC
544	Closed Work Orders 3/18/05 2HRS MADE PAPER WORK. 3 HRS WO#204. 2HRS PICK UP MATERIALES IN PHYSICAL PLANT. 1HR CHEK THERMOSTAT IN B WING.	3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
520	Closed Work Orders 3/3/05 2HRS ASSEMBLE AND INSTALL SCALE IN ELBA MUNOZ OFFICE.2HRS PREPAR BOR ROOM DOOR FOR PAINTING. 2HRS AJUST AND INSTALL DOOR CLOSET ELBA MUNOZ OFFICE 2HRS FIX A DESK DOOR IN BERTA RUIZ OFFICE	3/18/2005 3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
526	Closed Work Orders 3/8/05 3HRS PAINTIN BOR ROOM DOOR.2HRS CHANGED LIGHT BULBS AND BALLAST IN A WING RESTROOM. 3HRS WORKING IN ESPETIAL ED DEPARMENT.	3/18/2005 3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
528	Closed Work Orders 3/9/05 6HRS CHANGED CEILIN TILES IN CAFETERIA.2HRS FIX EXOST FAN IN C WING AREA.	3/18/2005 3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
517	Closed Work Orders 3/1/05 8HRS CHANGED CEILIN TILES IN MAIN HALWAY AND COM LAB C WING	3/18/2005 3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
523	Closed Work Orders 3/4/05 4HRS W O #1404. 2HRS I WENT TO PHYSICAL PLANT TO PICK UP SOME MATERIAL. 2HRS HELP TO FINE AC. BRAKES IN KITCHEN AREA.	3/18/2005 3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
524	Closed Work Orders 3/7/05 2HRS WO#1404 3HRS HELP KALI IN KITCHEN AREA. 1HRS FIX FLAT TIRES ON FLAT DALLY FOR LULU EZPARZA. 2HRS CHANGED LIGHTS BULBS IN CAFETERIA AREA.	3/18/2005 3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
508	Closed Work Orders 2/28/05 6 HRS REMARK LINES IN PARKIN LINE 2HRS CUT WEEDSIN FRONT ENTRANCE.	3/17/2005 3/18/2005 Medium	Manuel Prospero Margret Villalobos		GAC
530	Closed Work Orders 3/10/05 8HRS CUT WEEDS AND CLEAN FRONT ENTRANCE	3/18/2005 3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
531	Closed Work Orders 3/11/05 2HRS WO# 219 2HRS REMOVED CLOSET DOOR IN JIM AMACHER OFFICE. 2HRS FIX A DOOR IN ROSALINDA REYES OFFICE. 2HRS HELP JOSE AMBRIZ TO CHANGED EXOST FAN IN C WING AREA.	3/18/2005 3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
532	Closed Work Orders 3/14/05 2HRS CUT WEEDS IN THE PATIO. 2HRS PAINTING BLUE LINES IN PATIO AREA. 4HRS CHANGED CEILIN TILES IN C WING.	3/18/2005 3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
533	Closed Work Orders 3/15/05 2HRS WO#125561 2HRS WO#125562 2HRS I WENT TO PHYSICAL PLANT FOR EVALUATION WIHT MIKE MUNOZ 2HRS HELP DAVID BILLALOBOS TO FIX FLOOR RAIN IN MAIN ENTRANCE RESTROOM.	3/18/2005 3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
534	Closed Work Orders 3/16/05 3HRS INSTALL SOME PICES OF BASE BOR IN CAFETERIA AND MAIN ENTRANCE.3HRS PAINTIN SOME SPAT IN CAFETERIA WALL. 2HRS HELP MAANY LOZOYA TO FIX A DOOR.	3/18/2005 3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
535	Closed Work Orders 3/16/05 3HRS INSTALL PICES OF BASE BOR IN CAFETERIA AND MAIN ENTRANCE. 3HRS PAINTING SOME SPAT IN CAFETERIA WALL. 2HRS HELP MAANY LOZOYA TO FIX A DOOR IN CAFETERIA AREA.	3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
536	Closed Work Orders 3/16/05 3HRS INSTALL PICES OF BASE BOR IN CAFETERIA AND MAIN ENTRANCE. 3HRS PAINTING SOME SPAT IN CAFETERIA WALL. 2HRS HELP MAANY LOZOYA TO FIX A DOOR IN CAFETERIA AREA.	3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
537	Closed Work Orders 3/16/05 3HRS INSTALL PICES OF BASE BOR IN CAFETERIA AND MAIN ENTRANCE. 3HRS PAINTING SOME SPAT IN CAFETERIA WALL. 2HRS HELP MAANY LOZOYA TO FIX A DOOR IN CAFETERIA AREA.	3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
538	Closed Work Orders 3/16/05 3HRS INSTALL PICES OF BASE BOR IN CAFETERIA AND MAIN ENTRANCE. 3HRS PAINTING SOME SPAT IN CAFETERIA WALL. 2HRS HELP MAANY LOZOYA TO FIX A DOOR IN CAFETERIA AREA.	3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
539	Closed Work Orders 3/17/05 2HRS CUT WEEDS BACK TO THE BUILDING. 1HR WO#443 2HRS FIX TINA GALLEGOS DESK 3HRS WORKING IN B WING ELECTRIC PANEL.	3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
540	Closed Work Orders 3/17/05 2HRS CUT WEEDS BACK TO THE BUILDING. 1HR WO#443 2HRS FIX TINA GALLEGOS DESK 3HRS WORKING IN B WING ELECTRIC PANEL.	3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
541	Closed Work Orders 3/17/05 2HRS CUT WEEDS BACK TO THE BUILDING. 1HR WO#443 2HRS FIX TINA GALLEGOS DESK 3HRS WORKING IN B WING ELECTRIC PANEL.	3/18/2005 Medium	Manuel Prospero Manuel Prospero		GAC
119	Complete Change light bulbs in hallways changed 10 light bulbs in the hallways	3/7/2005 3/2/2005 Medium	Manuel Prospero Manuel Prospero	Hallway/Corridor	GAC
145	Closed Work Orders 3/2/05 2HRS FIX FILE CABINET IN ELISA SAENZ OFFICE. 2HRS FIX A DESK IN ELVA PEREZ OFFICE. 4HRS CHANGE CEILIN TILES IN B WIN AREA.	3/8/2005 3/8/2005 Medium	Manuel Prospero Manuel Prospero	Office	GAC
2771	Closed Work Orders 6/14/05 8HRS MAINTAINED FRONT GRAUNDS SIDE WALKS CUT WEEDS AND REMOVED ALL ENTRANCE DIRT. 6/14 - 8	6/14/2005 6/14/2005 Medium	Manuel Prospero Manuel Prospero		GAC

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2802	Closed Work Orders 6/15/05 2HRS CHANGED SEILIN TILES IN COMP LAB. 2HRS FIX DOOR CLOSER IN CAFETERIA EXIT. 2HRS INSTALL NEW FIRE EXTINGUISHER IN DATA ROOM AND CORA OFFICE. 2HRS CHANGED LAIHTING BULBS IN CAFETERIA AND MAN RESTROOM. 6/15 - 8	6/15/2005 6/15/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2742	Closed Work Orders 6/13/05 2HRS CHANGED HALOGEN FLOODLIGHT IN RECEPTION AREA AND ENTRANCE TO CAFETERIA. 2HRS HELP DANY MIRANDA IN C WING PROYEC. 2HRS HELPJOSE AMBRIZ TO SET UP THERMOSTAT IN HALL BUILDING. 2HRS CHANGED SEILIN TILES IN CONFERENCE ROOM A WING. 6/13 - 8	6/13/2005 6/13/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2739	Work In Progress 6/13/05 NEED TO ORDER 6 T-STAT METAL COVERS FOR JOSE AMBRIZ.	6/13/2005 Medium	Manuel Prospero Jose Ambriz		GAC
2674	Closed Work Orders 6/9/05 2HRS HELP TO ELECTIC MAN TO FINE KITCHEN BRAKES. 2HRS W.O.2654.3HRS HELP WALTER SITTERS TO TRANSPORT BACK AND FOR WARD FRON S.T.M. 7 VEHICLES TO GAC. 1HR I WENT TO THE LAND FILE WITH LORENZO SOLIS. 6/9 - 6	6/9/2005 6/9/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2704	Closed Work Orders 6/10/05 2HRS IRRIGATION OUT SIDE.2HRS CHANGED LIGHTING BULBS AND BALLAST IN TINA GALLEGOS OFFICE. C WING.3HRS I WENT TO PHYSICAL PLANT. 1HRS CHECK THERMOSTAT. 6/10 - 8	6/10/2005 6/10/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2646	Closed Work Orders 6/8/05 2HRS I WENT TOTHE LAND FILE WITH LORENZO SOLIS. 3 HRS MARKING PARKING LINES IN MANNY PROSPERO'S MOBILE HOME AREA. 3HRS HELP MANNY LOZOYA TO INSTALL NEW KIS IN ADITION. 6/8 - 8	6/8/2005 6/8/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2607	Closed Work Orders 6/7/05 2HR I WENT TO THE LAND FILE WITH LORENZO SOLIS. 2HRS PAINT MR. CHAVEZ'S OFFICE WERE NEEDED. 2HRS FIX PARTITION IN LEADIES RESTROOM [A] WING. 2HRS WORKING IN A WING A/C. 6/7 - 8	6/7/2005 6/7/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2558	Closed Work Orders 6/6/05 2HRS CHANGED AIR FILTERS AND LIGHTING BULBS IN DATA ROOM [TEGNOLOGY]. 1HR WO 126550. 1HR 126551. 4HRS CHANGED CEILIN TILES C WING. 6/6 - 8	6/7/2005 6/6/2005 Medium	Manuel Prospero Manuel Prospero		GAC

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2946	Closed Work Orders 6/22/05 1HR W.O. 2879 1HRS INSTALL NEW CLOK IN CAFETERIA AND KITCHEN. 6HRS CLINING AND INSTALL NEW AIR FILTERS IN C WING. 6/22 - 7	6/22/2005 6/22/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2961	Closed Work Orders 6/23/05 2HRS ASSISTING THE ROOF COMPANY IN CHECKING THE ROOF. 1HR ASSISTING IN SETING UP A PARTICITION DOOR IN THE KINDER BUILDING.5HRS CLINING AND REPLACED AIR FILTERS IN WINDOW UNITS. C WING. 6/23- 8	6/23/2005 6/23/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2936	Closed Work Orders 6/21/05 6 HRS W.O.2659 2HRS CHECKFOR POWER IN OUTLET IN FILE ROOM.B WING. 6/21-8	6/21/2005 6/21/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2900	Closed Work Orders 6/20/05 3HRS MAINTAINED FRONT GRAUNDS SIDE WALKS AND ALL ENTRANCE DIRT. 2HRS UNPLUGGED THE SINK AND BATHROOM IN THE SPECIAL EDUCATION DEPART. 3HRS REPLACED THE ROPE ON THE FLAG POLE AND PUT UP THE FLAGS. 6/20-8	6/20/2005 6/20/2005 Medium	Manuel Prospero Manuel Prospero		GAC
2841	Closed Work Orders 6/16/05 6HRS W.O.2768 2HRS REMARK PARKING LINES. 6/16-2	6/16/2005 6/16/2005 Medium	Manuel Prospero Manuel Prospero		GAC
3051	Closed Work Orders 6/28/05 6HRS WO 3008. 2HRS FIX PARTITION DOOR IN A WING RESTROOM. 6/28 -2	6/29/2005 6/28/2005 Medium	Manuel Prospero Manuel Prospero		GAC
3074	Closed Work Orders 6/29/05 1HR WORKIN IN LUPITA CHAVEZ A/C. 4HRS WO 3008 2HRS WORKING IN SPECIAL EDUCATION A/C. 1HR WORKING IN FRONT DOOR . 6/29 - 4	6/29/2005 6/29/2005 Medium	Manuel Prospero Manuel Prospero		GAC
3011	Closed Work Orders 6/27/05 2HRS WORKING IN DATE ROOM A/C. B WING. 2HRS CHARGED FREON IN A WING A/C. 2HRS WORKING WIHT MANY LOZOYA IN NEW BUILDING. 2HRS FIX PARTITION DOOR IN LEADIS RESTROOM A WING. 6/27 - 8	6/27/2005 6/27/2005 Medium	Manuel Prospero Manuel Prospero		GAC
3008	Work In Progress AS PER MANY PROSPERO WE NEED REMPLACE 2 COMPRESORS ON A WING UNITS.	6/27/2005 Medium	Manuel Prospero Jose Ambriz		GAC
2988	Closed Work Orders 6/24/05 4HRS WORKING IN A/C A WING.2HRS I WENT TO PHYSICAL PLANT. 2HRS HELP JOSE AMBRIZ IN DATA ROOM TO INSTALL NEW DIFUSOR. 6/24 - 8	6/24/2005 6/24/2005 Medium	Manuel Prospero Manuel Prospero		GAC

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2576	Complete Locate underground lines for Grounds DEPT.at swimming pool area locate lines for grounds dept.	6/7/2005 6/16/2005 Medium	Carlos Castillo Carlos Castillo		GAC
1674	Work In Progress NEED 2FT.BY2FT. CONCRETE BASE TO INTALL LIGHT FIXTURES ON BOTH SIDES OF ENTRANCE SIGN TO THE GAC.	5/5/2005 Medium	Carlos Castillo Michael Munoz		GAC
2518	Complete Gac C Wing remove electrical from walls to be demolished.	6/6/2005 6/24/2005 Medium	Carlos Castillo Carlos Castillo		GAC
2367	Complete need to repair restroom partitions mens g.a.c. REPAIRED RR PARTITIONS	5/27/2005 5/26/2005 Medium	Danny Miranda Danny Miranda		GAC
320	Complete Need key cylinder to be installed to SNP Cafeteria Storage Room (Dining Area) Thanks.	3/11/2005 3/31/2005 Medium	Alma Terrell Hector Lozoya	Cafeteria	GAC
1060	Forwarded FILL HOLES TO TILED KITCHEN WALLS AND REPAIR LIGHT FIXTURE AND CEILING TO DISHWASHING AREA As per David Boyd all repairs will be made by contractor. - Danny Orozco 4/15/05	4/12/2005 4/13/2005 Medium	Alma Terrell David Boyd		GAC
2202	Complete MICE PROBLEMS - PLEASE SEND EXTERMINATOR ASAP LEFT MESSAGE WITH ROSIE ON 5/23/05 AT 9:30 A.M. GESSICA BLAZQUEZ-SNP MANAGER 505-882- 6784 No charge as per Lester Humphrey - will be treated on 5/26/05-mkv	5/23/2005 5/24/2005 Medium	Alma Terrell Margret Villalobos	Cafeteria	GAC
790	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. COMLETED	4/1/2005 4/12/2005 Medium	Aida Salcedo Ralph Lara		GAC
3094	Work In Progress Install fencing on north property line for site security.	6/30/2005 6/30/2005 Medium	Alfredo Holguin Michael Munoz		GAC
1645	Complete NEED TO CHECK SCOOTER (ELECTRICAL CART) FOR BERTHA RUIZ. REPLACED 2 12V BATTERIES	5/4/2005 5/10/2005 Medium	Alfredo Holguin Angel Gonzales		GAC

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2083	Work In Progress C-WING, PLEASE HAVE DIMAR GIVE US A PRICE QUOTE FOR LOWERING OF SPRINKLERS IN DEMO AREA. PLEASE SEE MIKE	5/18/2005 Medium	Danny Orozco		GAC
408	Complete Please have Manny Lozoya make the following name plates. See if we can have them for March 24th, if not then no later than April 14th. Gregg Martinez Dino Anastasia	3/15/2005 4/7/2005 Medium	Hector Lozoya		GAC Cruz Drake
155	Complete "Psych Room - File cabinet in office difficulty geetin into file cabinet. Need 3 keys made 149E and 106E for Doug, Pablo and Ruth" wo 1359 repair doors and cabinet duplcte 6 keys.	3/8/2005 3/16/2005 Medium	Hector Lozoya		GAC
861	Complete NEED TO INSTALL 3 SOAP DISP & 3 ROLL TOWEL DISP. IN CAFETERIA AS PER MIKE. WILL INSTALL 3 STAINLESS STEEL SOAP DISP. AS PER MIKE. COMPLETED AS PER JIMMY CARBAJAL.	4/5/2005 4/6/2005 Medium	Jimmy Carbajal Jimmy Carbajal	Cafeteria	GAC
3026	Work In Progress A-WING WOMEN'S RR - HANDICAP COMMODE THAT WAS INSTALLED BY CONTRACTOR IS DEFECTIVE, NEEDS TO BE REPLACED A/S/A/P.	6/28/2005 Medium	David Villalobos David Boyd		GAC
776	Closed Work Orders 03/30/05 4-cleaning master cools on ch/desert t. 1-servise restroom on room 128 3-painting new doors rooms 96 57 and54	4/1/2005 Medium	Juan Vargas Margret Villalobos		GAC
3027	Work In Progress SUPERINTENDENTS OFFICE - NEEDS TO BE SPRAYED FOR ANTS. (OPEN PO)	6/28/2005 Medium	Norma Alvarado Margret Villalobos		GAC
1313	Complete Auto Shop - Disconnect airline to compressor. DISCONNECTED AIRLINE TO COMPRESSOR, OK FOR LEAKS	4/21/2005 4/25/2005 Medium	Michael Munoz David Villalobos		Gadsden HS
2385	Work In Progress SWIMMING POOL (PUMP ROOM) - AS PER NM ENVIRONMENT DEPT. POOL REGULATIONS, PUBLIC POOLS AND GENERAL USE POOLS WILL HAVE AN EMERGENCY SHUT OF SWITCH INSTALLED TO TURN OFF RECIRCULATING PUMP IN CASE OF AN EMERGENCY.	5/31/2005 Medium	Raul Sanchez Michael Mc Dermott		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1498	Complete Swimming Pool - Need an electrician (Mike Mc Dermott as per Mike) to install/connect new circulating pump and run conduit for new booster pump.	4/28/2005 5/9/2005 Medium	Raul Sanchez Michael Mc Dermott		Gadsden HS
1499	Work In Progress Irrigation Wells - Need Grounds to pick up old well column piping and dispose of it properly.	4/28/2005 Medium	Raul Sanchez Lorenzo Hernandez		Gadsden HS
1827	Complete Requested by Mr. S. Alvarado Rm. 141 Old English Building-Our A.C. does not work right, it blows hot air. The entire bottom south side of the Old English Building is not cooling. ALL OLD ENG UNITS ARE WORKING OK, MOTOR, PUMPS ALL THAT AREA A/C ARE ON. I MADE SURE THAT ALL THIS EQUIP IS WORKING PROPERLY.	5/11/2005 5/18/2005 Medium	Velia Alarcon Jose Ambriz		Gadsden HS
1829	Complete Requested by Mr. Carrasco Rm. 580 Auto Shop- Light gray paint for shop floor enough for 700 sq. ft., 4 paint rollers and trays, 2 gal. paint thinner, 4 4" paint brushes. If he could get these items quickly, he could do the job with the students.	5/11/2005 5/19/2005 Medium	Velia Alarcon Ruben Ronquillo		Gadsden HS
1835	Complete Requested by Velia Rm. 205 North Building-Door will not lock (Teacher's Lounge).	5/11/2005 5/17/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
1804	Work In Progress Requested by Mr. Wallis Rm. 609 Volleyball Courts-Spread new sand donated by Maintenance, on to the sandy volleyball court next to the Soccer Fields. Attn: Speedy	5/10/2005 Medium	Velia Alarcon Lorenzo Hernandez		Gadsden HS
1805	Complete Requested by Mr. Whitner Rm. 563 Ag. Shop-The A.C. stops putting out cool air after a short while, and then throws out hot air. CK THIS A/C , FERNIE HAS ALREADY TAKEN CARE OF IT.	5/10/2005 5/17/2005 Medium	Velia Alarcon Jose Ambriz		Gadsden HS
1782	Complete Requested by Julio Alcantar Security-Need keys to all building for Security Officers for safety reasons. 6 keys made of HG1 duplicate 6 H61	5/10/2005 5/16/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
1786	Complete Requested by Julio Alcantar Security-Need keys to all building for Security Officers for safety reasons. 6 keys of HF1 duplicate k6 HF1 for security guards	5/10/2005 5/16/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
1788	Complete Requested by Julio Alcantar Security-Need keys to all building for Security Officers for safety reasons. 8 keys made of HH1 8 keys for sec. guards	5/10/2005 5/16/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1789	Complete Requested by Julio Alcantar Security-Need keys to all buildings for Security Officers for safety reasons. 6 keys made of HJ1. made 6 HJ1 for officers	5/10/2005 5/16/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
1792	Complete Requested by Julio Alcantar Security-Need keys to Weight Room for security reasons. 2 keys needed of HE200.	5/10/2005 5/16/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
1795	Complete Requested by Ms. Littlefield Rm. 226 North Building-Need to prepare for the Sept. 3rd Kick Off Celebration. Need 2 keys made of HK6, one for Ms. Littlefield, and one for key box.	5/10/2005 5/16/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
1663	Complete Requested by Ms. Thornley-Ms. Thornley lost or miss placed the key to Rosa Quezada'a office and concession stand. Locks need to be re-keyed for Rosa's office and concession stand, 4 keys will be needed. rekey 4 cores off master for concession stand and Rosa's Office. xc: Eloisa 5/10/05 - Randy Thornley	5/4/2005 5/9/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
1679	Void Requested by Mr. Chambers Rm. 238 Varsity Gym-Cover all windows in Varsity Gym with 1/8" steel sheeting-(measurements to be provided by Mario)-while painting Varsity Gym this summer. Will put drawing or sign of a Panther on steel sheeting. VOID THIS IS CONTRACT WORK - THE OUTSIDE NEEDS TO BE PREPARED FOR PLASTER, AND PAINT, THE INSIDE NEEDS TO BE PREPARED FOR PLYWOOD FINISH TO BE PAINTED AFTER THE WINDOWS ARE SOLERED AND SEALED SHUT. WE WILL ATTEMPT TO DO THIS UNDER THE HVAC PROJECT AT THIS SITE SCHEDULED FOR FULL IF PROJECT ALLOWED. - AS PER ALFREDO HOLGUIN 5/16/05	5/5/2005 Medium	Velia Alarcon Michael Munoz		Gadsden HS
1680	Work In Progress Requested by Mr. Chambers Rm. 317 Academic Building-Install a combination lock in the mail room in the Academic Building.	5/5/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
1681	Complete Requested by Ms. Papitto Rm. 216 North Building- Re-key black storage cabinet to store my computers for the summer.	5/5/2005 5/17/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
1682	Complete Requested by Mrs. Rojas Boys Gym-HE1 key doesn't work in locker room door, need the outside door fixed with new lock. rekey 2 deadbolt locks and repair panic bar and replace stricker.	5/5/2005 5/9/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1683	Complete Requested by Ms. Trevizo Rm. 314 Academic Building- Re-key her classroom door, two cabinets, and one desk. Her keys were lost or stolen. change core #HE118 to HE2 - Total Cost 21.00 XC: ELOISIA 5/20/05 INVOICE 05-66	5/5/2005 5/18/2005 Medium	Velia Alarcon Hector Lozoya	Classroom	Gadsden HS
1636	Complete Requested by Jenny Gonzalez Computer Lab- Change filters (AC) in lab. Mario already replace filters in computer 2ab 5/4/05	5/4/2005 5/5/2005 Medium	Velia Alarcon Jose Ambriz	Computer Lab	Gadsden HS
1637	Complete Requested by Ms. Infante Rm. 750 Barracks- Cooler smells awful when turned on, sometimes water flows through and cools and other times it doesn't. all crew in GHS Replaced media filters that was causing the smells for a few days, I already ck for proper operation.	5/4/2005 5/5/2005 Medium	Velia Alarcon Jose Ambriz	Classroom	Gadsden HS
1638	Work In Progress Requested by Ms. Jordan Rm. 320 Academic Building-Lights blown out.	5/4/2005 Medium	Velia Alarcon Fernando Moncayo	Classroom	Gadsden HS
1639	Complete Requested by Ms. Jordan Rm. Academic Building- Air conditioning not cooling. Fernie has already replace pump in aerocoll that pads were not getting wet.	5/4/2005 5/5/2005 Medium	Velia Alarcon Jose Ambriz	Classroom	Gadsden HS
1640	Work In Progress Requested by Mr. Whitener Rm. 563 Ag. Shop- Needed: one 25 foot extension cord made for the arc welding machines. Also, repair the female ends on 3 existing extension cords.	5/4/2005 Medium	Velia Alarcon Michael Mc Dermott		Gadsden HS
1641	Work In Progress Requested by Mr. Whitener Rm. 566 Ag. Shop- The oil pressure gauge on the air compressor is broken and drips crankcase oil onto the floor. It also has an air leak on the small copper tubing on the compressor which causes it to turn on frequently.	5/4/2005 Medium	Velia Alarcon Joe Ontiveros		Gadsden HS
1642	Work In Progress Requested by Mr. Whitener Rm. 566 Ag. Shop- The door lock on the south shop door (emergency exit) is very difficult to lock and unlock.	5/4/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
1486	Complete Requested by Velia Alarcon Rm. 112 Main Building-We need 3 sets of the following keys made: D master, H master, M master, and N master. duplicate 3 set of each Masters.	4/28/2005 5/4/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1487	Complete Requested by Mr. Fensch Rm. 334 Academic Building-Storage cabinet to the left inside the door, needs to be re-keyed.	4/28/2005 5/17/2005 Medium	Velia Alarcon Hector Lozoya	Classroom	Gadsden HS
1488	Duplicate Request Requested by Mr. Donaldson Rm. 554 Wood Shop-Replace broken glass, large broken glass panel separating tool room from shop area. SAME AS 1483	4/28/2005 Medium	Velia Alarcon Ruben Ronquillo	Classroom	Gadsden HS
1489	Work In Progress Requested by Mr. Donaldson Rm. 554 Wood Shop-Replace broken ceiling tile and install plank roof over office and storeroom.	4/28/2005 Medium	Velia Alarcon Joe Ontiveros	Classroom	Gadsden HS
1490	Work In Progress Requested by Mr. Villa Rm. 510 Annex Building (Band Room)-Need replacement bulbs in main band room and office.	4/28/2005 Medium	Velia Alarcon Fernando Moncayo		Gadsden HS
1524	Complete Requested by Mr. Rios Varsity Gym-Key is stuck in cylinder. Cylinder is in Velia's office. (Outside door to Girls Locker Room) rekey core at v-gym girls lockerroom outside door.	4/29/2005 5/4/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
1525	Complete Requested by Maricruz Carrasco Rm. 343 Academic Building-Faculty restroom on south hallway cylinder came out, needs to be replaced. rekey core at faculty rr south hallway.	4/29/2005 5/4/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
1526	Complete Requested by Mrs. Pena Rm. 208 North Building-Clogged kitchen sink, 1st sink to the left as you enter from classroom. UNCLOGGED BY MARIO	4/29/2005 5/4/2005 Medium	Velia Alarcon Mario Apodaca	Classroom	Gadsden HS
1527	Work In Progress Requested by Mr. A. Perez Rm. 550 Wood Shop Building-Paint entry door; in order to avoid tagging. Adjust gap between door.	4/29/2005 Medium	Velia Alarcon Joe Ontiveros		Gadsden HS
1569	Work In Progress Requested by Fernando Moncayo Varsity Gym-Broken glass in basketball locker room.	5/2/2005 Medium	Velia Alarcon Ruben Ronquillo		Gadsden HS
1425	Complete Requested by Mr. Chambers Rm. 100 Mailroom-Change combination as soon as possible. change new combination at mail room.	4/26/2005 5/4/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
1426	Complete Requested by Mr. Chambers Rm. 275d Library-Make 5 additional HG7 keys for Adminstrators. (Library Storage Room)	4/26/2005 5/3/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1384	Complete Concession Stand - Bookkeeper Key is not working. (Informed Manny) REPAIR DOOR HANDLE AND RECONE CYLINDER	4/25/2005 4/25/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
1389	Complete Requested by Ms. Thornely Concession Stand- Problem with the door, we can not open it and please fix or replace deadbolt. REKEY DEADBOLT AND REPLACE CUM LOCK INSIDE DEAD BOLT	4/25/2005 4/25/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
1396	Complete Requested by Ms. Trich Rm 275d Library-For security of large influx of new media equipment, please re-key the storage room. Keys should be issues only to Administrators, library personnel, and one key to the building mechanic, per Mr. Chambers. Please note that this involves one interior and one exterior door. REKEY 2 LOCKSET AT LIBRARY TO HG7 OFF MASTER	4/25/2005 4/25/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
1392	Complete Requested by Luis Saucedo Rm 507 Annex Building-One of the urinals the water keep running and does not stop. CLEANED OUT DEBRIS FROM FLUSHVALVE AND ALL OTHER FLUSHVALVES.	4/25/2005 4/26/2005 Medium	Velia Alarcon David Villalobos	Restroom (Boys)	Gadsden HS
2464	Complete Requested by Velia Front Office-Five L wrenches are needed. 5 L WRENCHES FOR PANIC BARS.	6/2/2005 6/7/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
2461	Complete Requested by Marie Acosta Rm. 802 Counseling Center-Turn on A.C. in old Counseling Center. MASTERCOOL , FERNIE WILL START IT UP THIS NO WATER UNTIL THEY REPLACE LINE, AND FERNIE WILL SHUT IT.	6/2/2005 6/6/2005 Medium	Velia Alarcon Jose Ambriz		Gadsden HS
2462	Work In Progress Requested by Marie Acosta Counseling Center-Grounds keeping is needed between portable and old Counseling Center building.	6/2/2005 Medium	Velia Alarcon Lorenzo Hernandez		Gadsden HS
2471	Work In Progress Requested by Ms. Lopez Rm. 805 Counseling Center-Re-Key room 805 (both doors) to a D106, two keys are needed.	6/2/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
2472	Complete Requested by Ms. Lopez Counseling Center-Place chain and padlock on south gate of Counseling Center between portable and old Counseling Center. Padlock should have same cylinder as rooms 804-809.	6/2/2005 6/7/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
2473	Complete Requested by Ms. Lopez old Counseling Center-Four HE134 keys are needed. RECUT 4 HE134 KEYS	6/2/2005 6/7/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2466	Complete Requested by Velia Front Office-We have 20 keys that need to be re-keyed to HE157 (Gate Key). They currently do not open the gates. RECUT 20 HE157 keys	6/2/2005 6/7/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
2467	Work In Progress Requested by Velia Front Office-Five additional keys needed of the M master key.	6/2/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
2468	Complete Requested by Ms. Anderson Rm. 233a Panther Hut-Pastry refrigerator is having condensation problems, and is making a mess. HAD THE REF. ON THEN CAME BACK TO CK PRESSURES FOUND OUT CONDENSOR DIRTY, BLOW IT RECK AND WORKING FINE.	6/2/2005 6/7/2005 Medium	Velia Alarcon Jose Ambriz		Gadsden HS
2469	Work In Progress Requested by Ms. Lopez Counseling Center-1. Re-key rooms 804, 806, 808, 809 (room 809 has two doors, both doors need to be re-keyed) to an off master key. Needed to store testing materials and is a security issue. Four keys are needed.	6/2/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
2441	Work In Progress Requested by Ms. Lopez Rooms 802-809 Counseling Center-Remove carpet from all rooms. As per Mike route to Bldg Mechanic 6/10/05 - mkv	6/2/2005 Medium	Velia Alarcon Joe Ontiveros		Gadsden HS
2442	Work In Progress Requested by Ms. Lopez Business Building-Remove bulletin board strips from hallway outside of room 611 and put them up in main building hallway outside of room 122.	6/2/2005 Medium	Velia Alarcon Mario Apodaca		Gadsden HS
2435	Complete Requested by Mr. Grubaugh Cafeteria-Please re-key (need 5 sets) the sound booth at the back of the cafeteria. Items disappear from that room on a regular basis. REKEY CORE TO H67	6/2/2005 6/6/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
2436	Work In Progress Requested by Maria Perez Rm. 228 North Building-Have the small brown filing cabinet re-keyed. 3 keys are needed.	6/2/2005 Medium	Velia Alarcon Hector Lozoya	Office	Gadsden HS
2437	Work In Progress Requested by Cathy Rm. 115 Front Office-Need 3 name plates with Cathryn Cano	6/2/2005 Medium	Velia Alarcon Hector Lozoya	Office	Gadsden HS
2438	Work In Progress Requested by Ms. Wiley Rm. 820 & 821 Career Center- Have several flourescant light bulbs replaced.	6/2/2005 Medium	Velia Alarcon Fernando Moncayo		Gadsden HS
2284	Complete Requested by Mr. Chambers for Auto Shop, main door-Master Key stuck on door lock-Emergency!	5/25/2005 5/25/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2360	Complete Requested by Velia Old English Building-Four classroom are getting new doors and need to be re-keyed. rekey 4 classrooms and make keys	5/27/2005 6/1/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
2027	Complete Requested by Mr. Torres (Security Officer) Rm. 509 Annex Building-Door to girl's restroom will not lock. Door does not fit properly onto door frame, causing it not to go inot door frame notch. ADJ DOOR AND DEADBOLT	5/17/2005 5/24/2005 Medium	Velia Alarcon Danny Miranda	Restroom (Girls)	Gadsden HS
2035	Complete Requested by Mr. Whitener Rm. 566 Ag. Shop- The east A.C. on the shop will not turn on. AS PER FERNIE HE ALREADY REPLACED 1/4"COPPER LINE. CK'D A/C WORKING OK, THEY HAD IT OFF DUE TO LINE REPAIR.	5/17/2005 5/18/2005 Medium	Velia Alarcon Jose Ambriz		Gadsden HS
2036	Work In Progress Requested by Mr. Whitener Rm. 566 Ag. Shop- The light directly above the shop sink is burned out.	5/17/2005 Medium	Velia Alarcon Mario Apodaca		Gadsden HS
450	Work In Progress Requested by Mr. D. Martinez main hallway in North Building-Move the snack machines from the main hallway to the shaded area outside, once the electrical outlets have been placed.	3/16/2005 Medium	Velia Alarcon Mario Apodaca		Gadsden HS
451	Complete Requested by Ms. Vermillion Rm 754 Barracks- Have file and storage cabinets re-keyed. repair locks at 2 file cabinets	3/16/2005 4/20/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
445	Complete Rm 158 Concession Stand-need to connect power to new exhaust fan.	3/16/2005 6/24/2005 Medium	Velia Alarcon Carlos Castillo		Gadsden HS
446	Complete Rm 112-Have a HJ5 key made for key box. recut key H75	3/16/2005 4/20/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
447	Work In Progress Requested by Mr. D. Martinez Rm 227C North Building-Replace windows in the Assistant Principal's Office. The windows that are there currently are painted shut.	3/16/2005 Medium	Velia Alarcon Fernando Moncayo		Gadsden HS
448	Work In Progress Requested by Mr. D. Martinez Outside of North Building-Have electrical outlets placed outside the North Building in the shaded area for the candy/snack machines.	3/16/2005 Medium	Velia Alarcon Carlos Castillo		Gadsden HS
689	Complete Classrooms above Varsity Gym-Due to the power outage a few weeks ago, several outlet have no electricity.	3/30/2005 6/24/2005 Medium	Velia Alarcon Carlos Castillo	Classroom	Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
185	Work In Progress Requested by Mr. Martin, Rm 551 Wood Shop- Broken Window	3/8/2005 Medium	Velia Alarcon Ruben Ronquillo		Gadsden HS
186	Complete Requested by Mr. Whitener Rm Ag. Shop- 3 sets of keys made of HK4 (Store Room) duplicate keys	3/8/2005 4/7/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
176	Complete Rm 112 Velia's Office-1 HH2 key made for Key Box (Opens room # 132 recut 1 HH2 key for keybox and put lock on new door at n. bldg.	3/8/2005 3/15/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
177	Complete Rm 110 (Requested by Mr. Chambers)-4 keys made of F3 (Security Pad Lock Key) duplicat 4 - F3 for guard house.	3/8/2005 3/15/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
178	Work In Progress Requested by Ms. M. Gonzalez, Rm 140 Old English Building-The window on the far left side will not stay open. We have to hold it up with a book. Mario looked at it and he states that the Window Company needs to come in and fix all windows in building	3/8/2005 Medium	Velia Alarcon Ruben Ronquillo		Gadsden HS
179	Work In Progress Requested by Ms. M. Gonzalez, Rm 140 Old English Building-Third Request-The blinds in my room are broken and do not work properly. This will help keep the sun out in the afternoon when the roon gets "very hot". Mario took a look at them, class will need 4 set of blinds measurements 44 X 90	3/8/2005 Medium	Velia Alarcon Ruben Ronquillo	Classroom	Gadsden HS
181	Complete Requested by Ms. Lam, Rm 104 Main Building-A heavy duty doorstop for the south door to help the air flow. Classroom does not have windows that can be opened.	3/8/2005 3/29/2005 Medium	Velia Alarcon Fernando Moncayo	Classroom	Gadsden HS
183	Complete Requested by Mr. Martin, Rm 551 Wood Shop- Hall door does not open. This is a problem with getting wheel chairs into the building, where my classroom is located. REPAIR DOORS	3/8/2005 3/8/2005 Medium	Velia Alarcon Danny Miranda		Gadsden HS
345	Work In Progress The gate on the south side of the school was hit over the weekend. We're unable to close gate, we need this repaired as soon as possible.	3/14/2005 Medium	Velia Alarcon Joe Ontiveros		Gadsden HS
337	Complete Coke machines by Academic Building, Cafeteria, and Auto Shop no power to Coke machines. Mario checked out the problem, they seem to be working correctly now. Completed by Fernando	3/11/2005 5/18/2005 Medium	Velia Alarcon Fernando Moncayo		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
313	Complete Requested by Ms. Green-Wall Rm 505 Annex Building-Keys were lost or stolen, we need this classroom re-keyed and re-key teacher's desk. HK11-Classroom Key 035-Desk Key rekey hk11 to hk14 and cut 2 hk14 keys. Invoice # 05-48	3/11/2005 3/15/2005 Medium	Velia Alarcon Hector Lozoya	Classroom	Gadsden HS
314	Complete 3rd Request for Welder power cord and power end connections. GET QUOTE, MAKE REQUESTS AND MAKE CORD AND DELIVER.	3/11/2005 4/13/2005 Medium	Velia Alarcon Carlos Castillo	Classroom	Gadsden HS
315	Work In Progress Requested by Mr. Donaldson Rm 554 Wood Shop- Install exhaust system (hook up pipe, tubes, etc.) for Jointer/Planer	3/11/2005 Medium	Velia Alarcon Carlos Castillo	Classroom	Gadsden HS
316	Work In Progress Requested by Mr. Donaldson Rm 554 Wood Shop- 1. Install heavier electric circuit for operation of drum sander. 2. Re-route machine wiring (belt/disc., sander, etc.) through safety kill switch.	3/11/2005 Medium	Velia Alarcon Carlos Castillo	Classroom	Gadsden HS
317	Work In Progress Requested by Mr. Donaldson Rm 554 Wood Shop- Install mirror on office wall, next to bathroom door and wash/clean-up station (between 554e and 554d)	3/11/2005 Medium	Velia Alarcon Ruben Ronquillo	Classroom	Gadsden HS
318	Complete Requested by Mr. Donaldson Rm 554 Wood Shop- Repair/replace toilet flush mechanism in 554 bathroom. supplied fernando with tank lever, has been repaired.	3/11/2005 4/7/2005 Medium	Velia Alarcon David Villalobos	Classroom	Gadsden HS
319	Complete Requested by Ms. Foote Academic Building-The lock on the teacher's restroom next to the Math Lounge is broken. (Restroom in room # 342) The keys won't open the door, so the restroom is unusable. REKEY CYLINDER AT RR IN ROOM 342	3/11/2005 3/21/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
321	Work In Progress Requested by Mr. J. Gonzales Rm 300 Academic Building-No power on south wall of classroom. as per BM reset breaker after power outage.	3/11/2005 5/18/2005 Medium	Velia Alarcon Fernando Moncayo	Classroom	Gadsden HS
322	Complete Requested by Luis Saucedo-Weight Room, room # 502 One of the sink faucets is broken. supplied Mario with faucet has been repaired.	3/11/2005 4/7/2005 Medium	Velia Alarcon David Villalobos		Gadsden HS
323	Complete Requested by Mr. Whitener- Main Building Mail Room, room # 100. The light switch is malfunctioning and only works part of the time. Mario replaced switch on 3/11/05 at 9:30 a.m.	3/11/2005 3/11/2005 Medium	Velia Alarcon Mario Apodaca		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1179	Work In Progress Requested by Velia Rm 113 & 114 Main Building (Front Office)-We need the windows replaced in the men and women bathrooms, we're unable to open or close windows properly.	4/15/2005 Medium	Velia Alarcon Ruben Ronquillo		Gadsden HS PATIO
1180	Complete Requested by Velia Rm. 120 Main Building (Front Office)-The key cylinder to the front door spins all the way around and does not allow us to lock or open door. repair cylinder and repair panic bar.	4/15/2005 4/18/2005 Medium	Velia Alarcon Hector Lozoya	Office	Gadsden HS
1181	Complete Requested by Ms. Trich Rm. 275 Library-The gate (book-theft detection system) has stopped working. It may have blown a relay. Please R & R at your earliest convenience to save our materials from walking out the door. TROUBLESHOOT AND FIX GATE SYSTEM.	4/15/2005 4/22/2005 Medium	Velia Alarcon Mario Apodaca		Gadsden HS
1167	Complete Requested by Ms. Hamilton Rm 562 Ag. Building-Classroom, front door, and office key broke. Key# HK3 duplicate key for Ms. Hamilton.	4/14/2005 4/15/2005 Medium	Velia Alarcon Hector Lozoya	Classroom	Gadsden HS
1169	Complete Requested by Luis Saucedo for Rm 510 Annex Building-Band room the door knob is broken. The key turns all the way around and does not lock door. repair panic bar and replace cylinder	4/14/2005 4/20/2005 Medium	Velia Alarcon Hector Lozoya	Classroom	Gadsden HS
1163	Complete Requested by Ms. M. Garcia Rm 752 Barracks-Name plate for door. Ms. M. Garcia make name tag for Ms. Garcia	4/14/2005 4/15/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
1159	Work In Progress Requested by Ms. M. Garcia Rm 752 Barracks-Blinds needed on one window (45 x 60). Fire hazard, covered with paper. Special Ed. classroom	4/14/2005 Medium	Velia Alarcon Ruben Ronquillo	Classroom	Gadsden HS
1215	Complete Requested by Mr. Fensch Rm 334 Academic Building-Inside door handle is loose-handle jams and is getting worse. Entire door handle may fall apart soon.	4/18/2005 4/19/2005 Medium	Velia Alarcon Hector Lozoya	Classroom	Gadsden HS
1019	Work In Progress Requested by Ms. Moreno Rm. 126 Main Building-Put blinds on the windows.	4/11/2005 Medium	Velia Alarcon Ruben Ronquillo	Classroom	Gadsden HS
1056	Void Requested by Mr. D. Martinez North Building Hallway-Convert the North Building Hallway with Lockers into offices. Please refer to the attached memorandum. This project requires CMT Approval and Funding. - Alfredo Holguin 4/13/05-mkv	4/12/2005 Medium	Velia Alarcon Michael Munoz	Hallway/Corridor	Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1054	Complete Requested by Ms. Thornley Rm. 660 Business Building-Lost room key, we need to have lock re-keyed. REKEY 2 LOCKSET AT ROOM 660 HJ	4/12/2005 4/25/2005 Medium	Velia Alarcon Hector Lozoya	Classroom	Gadsden HS
962	Complete Requested by Marie Acosta Rm 800 Counseling Center-Need locks on file cabinets placed-Cum. Folder Cabinets. This is the third work order placed. rekey 7 file cabinets and repair office cabinet.	4/8/2005 4/12/2005 Medium	Velia Alarcon Hector Lozoya	Office	Gadsden HS
963	Complete Requested by Jesus Estrada Varsity Gym-Girls locker room, sink has been pulled off the wall. contractors upgrading sinks to hicap.	4/8/2005 4/11/2005 Medium	Velia Alarcon David Villalobos	Restroom (Girls)	Gadsden HS
893	Work In Progress Requested by Mr. Contaldo Rm 103-Paint outside of observatory using white oil-based paint.	4/6/2005 Medium	Velia Alarcon Joe Ontiveros		Gadsden HS
730	Complete Requested by Ms. Wiley, Rm 820 & 821 Career Center-Door lock isn't working properly at times, unable to lock or unlock. repair lockset and repair hinges.	3/31/2005 4/4/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
725	Complete Requested by Mr. S. Alvarado, Rm 141 Old English building-Door is about ready to fall off it's hinges.	3/31/2005 6/9/2005 Medium	Velia Alarcon Danny Miranda	Classroom	Gadsden HS
726	Complete Requested by Mr. S. Alvarado, Rm 141 Old English Building-Room needs to be painted. PAINT ROOM	3/31/2005 5/23/2005 Medium	Velia Alarcon Joe Ontiveros	Classroom	Gadsden HS
727	Work In Progress Requested by Mr. Haack, Rm 127 Main Building-Window was broken on 3/30/05.	3/31/2005 Medium	Velia Alarcon Ruben Ronquillo	Classroom	Gadsden HS
728	Complete Requested by Ms. Holguin, Rm 125 Main Building-Requesting a dead bolt lock installed in store room in classroom. Would like to to store new computers and new equipment over the summer to avoid vandalism. rekey lockset and recut keys.	3/31/2005 4/4/2005 Medium	Velia Alarcon Hector Lozoya	Classroom	Gadsden HS
2578	Work In Progress Requested by Velia Rm. 112 Front Office-We need two additional keys of HH6, downstairs Social Workers Office in Old English Building.	6/7/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
2579	Work In Progress Requested by Velia Rm. 112 Front Office-We need three additional keys of HE200 (Weight Room).	6/7/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
2580	Work In Progress Requested by Velia Rm. 112 Front Office-We need three additional keys of HE131 (my office).	6/7/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2581	Work In Progress Requested by Velia Rm. 112 Front Office-We need five additional keys of DC17 (Swimming Pool).	6/7/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
2582	Work In Progress Requested by Velia Rm. 112 Front Office- We need two additional keys of HH9, upstairs Social Workers Office in Old English Building.	6/7/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
2583	Work In Progress Requested by Velia Rm. 112 Front Office-We need one additional key of HH7, for I.A. in Ms. Axtell's classroom.	6/7/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
2584	Work In Progress Requested by Isela Rm. 800 Counseling Center- Paint office and doors.	6/7/2005 Medium	Velia Alarcon Joe Ontiveros		Gadsden HS
2530	Work In Progress Requested by Mr. Chambers Rm. 110 Front Office-Need a 6 and 7 point keys to open classrooms, storerooms, etc. for construction people at G.H.S., one key of each.	6/6/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
2698	Work In Progress Requested by Marie Acosta Rm. 803 Old Counseling Center-Re-key vault in Old Counseling Center. Needs to be off master, 5 keys are needed.	6/10/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
2699	Work In Progress Requested by Velia Rm. 112 Front Office-Fix or re-place light bulbs on posts where Juan Diaz' mobile home is located. Where D.P.A. was located on our campus before, extremely dark at night.	6/10/2005 Medium	Velia Alarcon Michael Mc Dermott		Gadsden HS
2700	Work In Progress Requested by Velia Rm. 112 Front Office-Have one HE200 re-cut, key does not open room. (Weight Room)	6/10/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
2701	Work In Progress Requested by Velia Rm. 112 Front Office-Have three HE87 re-cut, keys do not open room. (Training Room)	6/10/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
2745	Work In Progress Requested by Velia-In room 505 of the Annex Building there's a storage room that the contractors of Lynco Electric need access to. We do not have a key for the deadbolt on that door, needs to be opened as soon as possible for them.	6/13/2005 Medium	Velia Alarcon Hector Lozoya		Gadsden HS
2478	Work In Progress CONNECT UTILITIES TO PORTABLES.	6/3/2005 Medium	David Villalobos David Villalobos		Gadsden HS PORTABLES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2831	Closed Work Orders 06/09/05 8-Worked in VARSITY GYM(preparing to paint) 6/9 - 8	6/16/2005 6/9/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
2835	Closed Work Orders 06/10/05 1-Ckd water leak in top of PANTHER HUT 1-Assisted outside CONTRACTORS ,with opening of bldgs 2-Report to PPD 4-Assisted LORENZO SOLIS with a/c log information 6/10 - 8	6/16/2005 6/10/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
2836	Closed Work Orders 06/13/05 8-Worked in VARSITY GYM(preparing to paint) 6/13 - 8	6/16/2005 6/13/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
2838	Closed Work Orders 06/14/05 8-Worked in VARSITY GYM(painting) 6/14 - 8	6/16/2005 6/14/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
2839	Closed Work Orders 06/15/05 Worked in VARSITY GYM(painting) 6/15 - 8	6/16/2005 6/15/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
2840	Closed Work Orders 06/16/05 8-Worked in VARSITY GYM(painting) 6/16 - 8	6/16/2005 6/16/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
2630	Work In Progress 06/08/05 Atnn;MANNY LATOYA , need to change the lock cilinders to restrict the access to the VARSITY GYM due to been paint thank you!	6/8/2005 Medium	Fernando Moncayo Hector Lozoya		Gadsden HS
2640	Closed Work Orders 06/06/05 2-Cleaned and varnished new doors for NORTH BLDG 2-Ckd and patched roof in PANTHER HUT 4-Worked in VARSITY GYM 6/6 - 8	6/8/2005 6/6/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
2642	Closed Work Orders 06/07/05 3-2468 5-Assisted LORENZO SOLIZ with a/c's information log 6/7 - 5	6/8/2005 6/7/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2643	Closed Work Orders 06/08/05 7-Worked in VARSITY GYM 1-Log on reports	6/8/2005 6/8/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
	6/8 - 8				
1730	Closed Work Orders 05/02/05 1-Worked on CAFETERIA a/c's 1-REpaired a/c water line at AG SHOP 2-Ckd AG SHOP air compressor 3-1565? 1-Broken windowat BOY'SBASKET BALL locker room	5/8/2005 5/2/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
	5/2 - 5				
1731	Closed Work Orders 05/03/05 7-1067? 1-Assisted RAUL with SWIMMING POOL pump	5/8/2005 5/3/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
	5/3 - 1				
1732	Closed Work Orders 05/04/05 1-Prepared STAGE ligths for PRE-SCHOOL graduation 1-Replaced a/c mtr in ACADEMIC room 312 1-Assisted LOCKSMITH with gate locks 3.5Worked on a/c's 1.5-Assisted PEST CONTROL TECH.	5/8/2005 5/4/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
	5/4 - 8				
1733	Closed Work Orders 05/05/05 5-125077 1-AG SHOP air compressor coil replacement 2-STAGE ligths training	5/8/2005 5/5/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
	5/5 - 8				
1850	Work In Progress Attention; MR AMBRIZ, need to order a new mtr starter coil for AG SHOP air compressor.Also need an air gauge and a oil gauge for same machine. Coil is FURNAS brand, air gauge is 1/4npt 0-150psi, oil gauge is 1/8npt 0-15psi thank you!	5/11/2005 Medium	Fernando Moncayo Jose Ambriz		Gadsden HS
1845	Closed Work Orders 05/11/05 1-Ckd with VELIA ALARCON on w/o's 2-Assisted CLASSIC CONSTRUCTION with power and marks for underground utilities 1-ACADEMIC bldg room 326 a/c selector switch 1-Clean up roof and fixed water leak in NORTH bldg VARSITY GYM 2-Worked on a/c's 1-Log on reports	5/11/2005 5/11/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
	5/11 - 8				

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1837	Closed Work Orders 05/06/05 1.5-Called for it, and installed ptble a/c's in CAFETERIA, for assebly 1.5-a/c in room 320,is not working 3-By passed electrical controls to a/c's on CAFETERIA 1-Removed ptble a/c's from CAFETERIA 1-Prepared AUTO SHOP pressure washer to use it on SWIMMING POOL	5/11/2005 5/6/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
	5/6- 8				
1839	Closed Work Orders 05/07/05 8-SWIMMING POOL start up clean up and repairs	5/11/2005 5/11/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
	5/7 -8				
1840	Closed Work Orders 05/09/05 2-Assisted LYNCO ELECTRIC and NATIONAL RESTAURANT TECHS. 2-Troubleshooted a/c's in OLD ENGLISH bldg 4-Worked on a/c's at ANNEX bldg	5/11/2005 5/9/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
	5/9 - 8				
1841	Closed Work Orders 05/10/05 2.5-Ckd and balanced air flow in room 504 1-Replaced cooler pump in room 315 1-Repaired water leak in room 106 1-Ckd trash compactor 2.5-Worked on a/c's	5/11/2005 5/10/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
	5/10 - 8				
1856	Work In Progress Attention, MR AMBRIZ;Need a new a/c for the GROUNDS SHOP	5/11/2005 Medium	Fernando Moncayo Jose Ambriz		Gadsden HS
1583	Closed Work Orders 04/28/05 2-Repaired hole on south fance,as per MIKE MUNOZ 1-Assisted glass repair people to WOODSHOP tool room 1-PRESCHOOL restroom exhaust fan 1-Blower motor in BUSINESS bldg room 611 2-Worked on a/c's on ANNEX bldg 1-Troubleshooted and reseted refrig. a/c unit at CAREER CTR	5/2/2005 4/28/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
	4/28 - 8				

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1584	Closed Work Orders 04/29/05 2.5-Report to PPD;Pick up materials,serviced truck etc. 1.5-Ckd refrig. air a/c unit in NORTH bldg room 233 4-Cleaned and serviced refrig. air a/c units in COMPUTER LAB 4/29 - 8	5/2/2005 4/29/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
1565	Complete Need to remove cabinets and counter top to relocate ice machine in PANTHER HUT HOME C ROOM remove cabinet and top	5/2/2005 5/4/2005 Medium	Fernando Moncayo Danny Miranda		Gadsden HS
1329	Duplicate Request Need assistance with electrical problems;There is no power on a/cs.After ckd them out I think the 3ph conntactor is bad thank you see wo 1307	4/21/2005 Medium	Fernando Moncayo Carlos Castillo	Custodial	Gadsden HS
1341	Closed Work Orders 04/18/05 1-Repaired office door at FLOWER SHOP 3-Worked on air conditioners at WOOD SHOP 4-Worked on ACADEMIC BLDG air conditioners 4/18 - 8	4/22/2005 4/18/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
1342	Complete Refrig. air unit in room 611 at BUSINESS BLDG is not working HAD A BURNED OUT MOTOR, USED, SMALLER BLOWER MOTOR UNTIL RECEIVED NEW 3/4 THAT HAS ALREADY BEEN INSTALLED BY MARIO AND FERNIE, THEY TOOK CARE OF IT, WORKING OK.	4/22/2005 5/3/2005 Medium	Fernando Moncayo Jose Ambriz		Gadsden HS
1343	Closed Work Orders 04/19/05 1-Assisted HVAC TECH. with NORTH bldg refrig. air units 2-Replaced spider bearings on ACADEMIC LOUNGE a/c 5-Worked on CAFETERIA air cond. 4/19 - 8	4/22/2005 4/19/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
1344	Closed Work Orders 04/20/05 3-Set up barricade at FOOTBALL blaechers 5-Worked on CAFETERIA air cond. 4/20 - 8	4/22/2005 4/20/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1345	Closed Work Orders 04/21/05 2-Report to PPD warehouse to pick up a/c's materials 1.5Troubleshooted refrig. air a/c unit at BUSINESS room 611 2.5-Removed and installed wet section media on large a/c unit at NURSE'S bldg 2-Troubleshooted a/c's at CAFETERIA 4/21 - 8	4/22/2005 4/21/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
1972	Closed Work Orders 05/12/05 1-Assisted CLASSIC CONSTR.with doors and water hook up 1.5-Unclogged sink in ACADEMIC TEACHER'S LOUNGE 2-Ckd and cleaned door lock cilinder in NORTH BLDG LOUNGE 2-Troubleshooted refrig.air a/c unit in CAREER CTR. LAB 1.5-Repaired south gate 5/12 - 8	5/16/2005 5/12/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
1973	Work In Progress Need to rerun conduit and wires to kitchen exhaust in PANTHER HUT HOMEC ROOM	5/16/2005 Medium	Fernando Moncayo Michael Mc Dermott		Gadsden HS
2129	Closed Work Orders 05/17/05 5-125097 1-1490 2-MAIN BLDG WESTwing a/c ,burned out the pump connecting plug 5/17- 7	5/19/2005 5/17/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
2120	Closed Work Orders 05/16/05 1-Ckd and replaced water pump in LIBRARY a/c 2-125077 1.5-125110 2.5-Worked on classroom storage cabinets 1-Log on reports 5/16 -8	5/19/2005 5/16/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
2220	Closed Work Orders 05/19/05 6-Monthly inspections 1-Ckd girls restroom in MAIN BLDG ,water leak 1-Log on reports 5/19 - 8	5/23/2005 5/19/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2217	Closed Work Orders 05/18/05 2-Troubleshooted refrig. air a/c unit in room 208 1.5-Assisted LOCKSMITH with storage cabinets locks 1.5-Water leak in new sink in PANTHER HUT HOMECE. 1-Ckd and replaced cooler pump in BARRACKS room 754 2-Worked on CONCESSION STAND 5/18 - 8	5/23/2005 5/18/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
2223	Closed Work Orders 05/20/05 2-LIBRARY a/c no power to unit 2-OLD ENGLISH 1st floor south a/c not working properly 3-1376 1-Ckd OLD ENGLISH restrooms ,that need to be paint 5/20 -5	5/23/2005 5/20/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
2225	Work In Progress Need to order vinyl panels ,adhesive and trim for restrooms As per Mike - Route back to Fernando and have him order material thru Ruben.	5/23/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
2248	Void Now that the STUDENT'S are out ,need to spray all bldg to control inccets and bugs.thank you! LESTER HUMPHREY - NEED PRICE QUOTE. Void - As per A. Holguin 5/26/05 - mkv	5/24/2005 Medium	Fernando Moncayo Margret Villalobos		Gadsden HS
2419	Closed Work Orders 05/25/05 8-Ckd and cleaned roofs,roof gutters and roof drains for maintenance site inspections 5/25 - 8	6/1/2005 5/25/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
2422	Closed Work Orders 05/26/05 6-Repaired and repainted walls in OLD ENGLISH HALLS 1-Met with SAMCON on new restroom swer line 1-Ckd a/c in FLOWER SHOP office 5/26 - 8	6/1/2005 5/26/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
2423	Closed Work Orders 05/27/05 1-Gathered paper work for PPD 2-Ckd bldgs for rain leaks 1-Assisted ARQITECTAL PDCTS on new doors 4-Prepared and painted new exterior doors in NORTH BLDG 5/27 - 8	6/1/2005 5/27/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2417	Closed Work Orders 05/24/05 2-Ckd a/c's on BARRACKS for SPED working during summer 6-Worked on maintenance plan inspections 5/24 - 8	6/1/2005 5/24/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
2415	Closed Work Orders 05/23/05 4-Monthly maintenance plan inspections 1-ckd FLOWER SHOP and AG. SHOP a/c's 2-Ckd OLD ENGLISH a/c's for SOCIAL WORKERS office 1-Log on reports 5/23 - 8	6/1/2005 5/23/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
2453	Closed Work Orders 05/31/05 1-Ckd new doors at OLD ENGLISH ,with MANNY L. and DANNY M. 7-Prepared VARSITY GYM to paint 5/31 - 8	6/2/2005 5/31/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
2458	Closed Work Orders 06/02/05 7-Worked on VARSITY GYM;Painting proyect 1-No water in NURSE'S BLDG 6/2- 8	6/2/2005 6/2/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
2459	Work In Progress Attn. MANNY LOCKSMITH; Need to ck. storage cabinet in room 226 not locking 6/2/2005	6/2/2005 Medium	Fernando Moncayo Hector Lozoya		Gadsden HS
2456	Closed Work Orders 06/01/05 8-Worked in VARSITY GYM; Painting proyect 6/1 - 8	6/2/2005 6/1/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
681	Closed Work Orders 03/21/05 2-125102 6-125103	3/29/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
682	Closed Work Orders 03/22/05 3-125102 5-Safety training at STMS	3/29/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
683	Closed Work Orders 03/23/05 8-Prepared and painted new entrance doors at NORTH bldg	3/29/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
684	Closed Work Orders 03/24/05 4-Repaired and painted holes on walls in NORTH bldg halls 2-Removed,cleaned and reglued, stairs rubber covering 1-Provided water hose, to ROTC CAMP OFFICIALS 1-Removed tape and overpaint from doors	3/29/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
554	Closed Work Orders 03/16/05 1-Daily ck of heating boilers 1-Assisted RAUL SANCHEZ with chemicals 1-BARRACKS boys rr overflowing 4-Replaced lighth ballast and tubes at NORTH bldg halls	3/19/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
555	Closed Work Orders 03/17/05 1-Heating boiler daily ck 5-Monthly maint. inspections 2-ACADEMIC bldg north entrance; broken window and door closer	3/19/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
556	Closed Work Orders 03/18/05 1-Daily heating units ck 3-Report to PPD 1 VARSITY gym VOLLEYBALL locker room door lock,coming off 3-Replaced ballast and lighth tubes in rooms on top of VARSITY gym	3/19/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
417	Closed Work Orders 03/14/05 1-Daily heating boilers ck 1-Skunk control;ck up traps,set up traps etc. 6-Worked on air conditioner clean up	3/15/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
550	Closed Work Orders 03/15/05 1-Daily ck of heating boilers 1-Replaced hinges on MAIL RM. door 2-Assisted LOCKSMITH with several w/o 1-Replaced lighth ballast in top of VARSITY gym 2-Reinstalled ctr. pole on westside doors at WEIGHT room,also adjusted panic bar mechanism 1-Log on reports	3/18/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
277	Closed Work Orders 03/09/05 1-Daily heating boilers ck 4-Replaced bad ballast,tubes and switches at ACADEMIC bldg staff resrooms,teachers lounge and janitors room 1-122929 .5-190 1.5-Exhaust fan mtr. replacement;In front office restrooms	3/10/2005 3/10/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
278	Closed Work Orders 03/10/05 1-Daily heating ck 1-ROTC hall ballast and tubes replacemnt 2-Evaluation at PPD 2-OLD ENGLISH heating system;Adjusted temp set point etc 2-125077	3/10/2005 3/10/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
340	Closed Work Orders 03/11/05 1-Daily boiler ck 1-Skunk control 3-125077 1-NORTH BLDG girls restroom overflowing 2-Ckd and replaced bad lighth ballast and tubes at ROTC corridor	3/11/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
141	Closed Work Orders 02/24/05;1-Daily ck of heating boilers 2-Ckd roof leaks in MAIN west wing 1-Cks and repaired wall power strip in DAY CARE 1-Worked on VARSITY gym heaters 3-Removed new door locks to secured doors	3/7/2005 3/8/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
142	Closed Work Orders 02/25/05 1-Routine ck of heating boilers 1-BARRACKS girls restroom clogged 1-Ckd and cleaned football conssecion stand ice machine 1-MAIN staff restrm exhaust fan 1-Door stopper/holder on new doors 2-Troublrshooted and gathered info needed on elect.board 1-Log on reports	3/7/2005 3/8/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
147	Work In Progress Rm 112-varnish new door waiting on materials	3/8/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
194	Closed Work Orders 02/28/05 1-Daily ck of heating equipment 2-Installed new locks on new doors 2-Secured doors at PRESS BOX 1-WEIGHT rm broken window 2-Repaired broken cabinet shelves	3/8/2005 3/9/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
195	Closed Work Orders 03/01/05 1-Ckd heating boilers 2-Pickup old doors;Installed door locks on new doors 1-Ckd and reseted power at PRESCHOOL 1-Installed new door stopper/holder on new doors 2-BUSINESS girls restroom leaking under sinks 1-Ckd electrical panel for a buzzing noise	3/8/2005 3/9/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
196	Closed Work Orders 03/02/05 1-Ckd heating units 2-Removed old doors;Installed door locks on new doors 1-Repaired door dead bolt and adjusted door closer at ANNEX 1-Secured door at old DESERT PRIDE restrms 1-Installed new door stopper/holder on new doors 1-Washed and cleaned work truck 1-MAIN BLDG staff restroom,removed exhaust fan 4-On call by MS LOPEZ on power outage	3/8/2005 3/9/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
197	Closed Work Orders 03/03/05 8-174 Worked on power outage related problems	3/8/2005 3/9/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
198	Closed Work Orders 03/04/05 1-Daily ck of heating boilers 1-Ckd and troubleshoted air compressor at AUTO SHOP 2-Report to PPD	3/8/2005 3/9/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
199	Closed Work Orders 03/07/05 1-Heating boilers daily ck 2-183 5-Replaced and ckd bad ballast and light tubes at ACADEMIC bldg	3/8/2005 3/9/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
200	Closed Work Orders 03/08/05 1-Heating units daily ck 1-Skunk control traps etc. 6-Replaced and ckd bad ballast and lighth tubes at ACADEMIC restrooms and halls;Also replaced lighth switch	3/8/2005 3/9/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
1070	Complete Need two 6 in. heavy duty barrel bolt, to secure doors from inside, in WEIGTH ROOM asap please	4/12/2005 4/15/2005 Medium	Fernando Moncayo Hector Lozoya		Gadsden HS
1094	Complete Need an exhaust fan motor, for DAY CARE restroom no info in old motor, will match it with BROAN motor ck exhaust fan mtor w/blade for correct size, fernie will install and replace it.	4/13/2005 6/7/2005 Medium	Fernando Moncayo Jose Ambriz		Gadsden HS
1097	Work In Progress Need to connect electrical power to new exhaust fan in COUNCELING CTR	4/13/2005 Medium	Fernando Moncayo Carlos Castillo		Gadsden HS
1076	Closed Work Orders 04/11/05 1-Log on reports 6-Worked on ACADEMIC BLDG air conditioners 1-Assisted LOCKSMITH with file cabinets locks, in COUNCELING CTR 4/11 - 8	4/12/2005 4/11/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
1146	Complete Please rekey pad lock in BOYS GYM NW entrance, thank you mandula! repair and rekey pad lock at boys gym.	4/14/2005 4/14/2005 Medium	Fernando Moncayo Hector Lozoya		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1198	Closed Work Orders 04/14/05 5-Assisted JOSE AMBRIZ troubleshooting refrg.air units,at NB 1-Worked on ACADEMIC BLDG air conditioners 1-Responded to fire alarm in ACADEMIC BLDG;Cleared bldg for MRS LOPEZ 1-Assisted LOCKSMITH on BOYS GYM w/os 4/14 - 8	4/15/2005 4/14/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
1193	Closed Work Orders 04/12/05 7-Worked on ACADEMIC BLDG air conditioners 1-Log on reports 4/12 - 8	4/15/2005 4/12/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
1195	Closed Work Orders 04/13/05 1-Ckd room 336 for burning smell and smoke 1-Replaced lighth ballast in same room 5-Worked on ACADEMIC BLDG air conditioners 1-Ckd and reseted fire alarm,cleared bldg for MRS LOPEZ 4/13 - 8	4/15/2005 4/13/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
1153	Work In Progress All restrooms and plumbing chases need to be sprayed to control roaches, thankyou! Faxed PO on 5/3/05 45012450	4/14/2005 Medium	Fernando Moncayo Margret Villalobos	Restroom (Boys)	Gadsden HS
1262	Closed Work Orders 04/15/05 2.5-Reported to PPD,pick up materials,serviced truck etc 1-Worked on air cond. for MR PEREZ at ART ROOM 1.5-Repaired door at BOYS GYM EAST entrance 3-Worked on air conditioners 4/15 - 8	4/19/2005 4/15/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
824	Closed Work Orders 03/29/05 1-Ckd all bldgs after spring break 2-Removed north parking entrance steel sign 1-181 1-Disposed of old wood doors 3-Repaired MAIN bldg n.w doors,damaged by wind 3/29 - 7	4/4/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
827	Closed Work Orders 03/30/05 1-Open stuck door in rm 141 1-Painted book shelves 2-Made barricade of rebar and " caution" tape in parking lot 2.5-Adjusted all entrance doors at CAFETERIA .5-Unloaded wood doors at WOODSHOP 1-Log on reports 3/30 - 8	4/4/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
829	Closed Work Orders 03/31/05 1-Assisted LOCKSMITH with several w/o 2-Unclogged urinal, replaced p trap & tail piece at AUTOSHOP .5Removed pad lock from locker at GIRL'S GYM 4.5-Fire on storages under bleachers in FOOTBALL STADIUM 3/31 - 8	4/4/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
830	Closed Work Orders 04/01/05 1-Ckd FOOTBALL bleachers and storages 3-Report to PPD,pick up materials,serviced truck etc 2-Ckd and fixed food disposer at PANTHER HUT 2-Repaired security lights in north side 4/1 - 8	4/4/2005 4/1/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
760	Complete Room 141 in 1st floor of OLD ENGLISH needed to be rekeyed due to; No keys found for that room change 2 lockset in rm 141 and rekey to a5 - 3keys	4/1/2005 3/31/2005 Medium	Fernando Moncayo Hector Lozoya	Classroom	Gadsden HS
996	Closed Work Orders 04/04/05 3-Assisted LOCKSMITH with several w/o 1-108420 1-Rehung and repaired door in MAIN bldg NW entrance 1-Ckd ANNEX BLDG boys restroom for graffitti touch up 1-Replaced toilet flushing handle in WOODSHOP resroom 1-Log on reports 4/4 - 8	4/10/2005 4/4/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
997	Closed Work Orders 04/05/05 1-108393 1-Ckd observatory for damage/vandalism 1-108385 2-Ckd MAIN BLDG staff restroom,for no hot water and clogged toilet 2-Troubleshooted refr. air unit in rm 244 1-Unclogged toilet at OLD ENGLISH SOCIAL WORKERS office 4/5 - 8	4/10/2005 4/5/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
998	Closed Work Orders 04/06/05 2-Assisted SECURITY with barricade for "EVERY 15 MINUTES program" 6-125569 4/6 - 8	4/10/2005 4/6/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
999	Closed Work Orders 04/07/05 2-"EVERY 15 MINUTES PRESENTATION" 2-Start up a/cs and shut down furnaces in MAIN BLDG 2-Secured vending machine, that was broken into 2-Urinal installation at AUTO SHOP 4/7 - 8	4/10/2005 4/7/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
1000	Closed Work Orders 04/08/05 5-Worked on CAFETERIA air conditioners 3-Low water pressure in KITCHEN area,ckd.restrooms and water tanks;Called water TECH. for assistance 4/8 - 8	4/10/2005 4/8/2005 Medium	Fernando Moncayo Fernando Moncayo		Gadsden HS
895	Work In Progress Need to order new fire extinguishers;10;10lb-5;5lb also need fire extinguisher locator stiker to identify extinguisher location asap please 100 stikers	4/6/2005 Medium	Fernando Moncayo Ruben Ronquillo		Gadsden HS
896	Complete PANTHER HUT; need to be sprayed for roaches As per Lester Humphrey - No charge this is part of the service 4/6/05	4/6/2005 4/8/2005 Medium	Fernando Moncayo Margret Villalobos		Gadsden HS
174	Complete check electrical systems after poweroutage TROUBLESHOOT AFFECTED AREA BY OUTAGE, ELIMINATE FIRE HAZZARD EMER. BALLAST, REPLACE BURNED BALLAST THRU OUT CAMPUS, DISCOVER BURNED LIGHTING CONTACTOR (CAFETERIA), MORE ELEC COMPONENTS ARE PROBALLY DAMAGED AND WILL NOT BE FOUND UNTIL PROBLEMS ARE REPORTED, FUTURE PROBLEMS PENDING.	3/8/2005 3/3/2005 Emergency	Carlos Castillo		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
182	Complete North Bldg Room 328 Pam Holguin - need to check outlet that comes from west wall where there is no electricity. as per BM reset breaker after power outage.	3/8/2005 5/18/2005 Medium	Mario Apodaca	Classroom	Gadsden HS 328
190	Complete Main Bldg Room 109 - Dead air not working. replace diffuser 24x24x8 that other was restricting to much air flow, ck 12" rigid pipe for enough air supply for duct main.	3/8/2005 6/8/2005 Medium	Jose Ambriz	Classroom	Gadsden HS 109
918	Closed Work Orders please assist with the movement of the bleachers from other sites to GHS. Please document all hrs, employees involved and equipment. Thanks(every 15 minutes)	4/7/2005 4/11/2005 Medium	Lorenzo Hernandez		Gadsden HS
1232	Work In Progress Please demo and cancell all plumbing as per Mr.Foster.	4/19/2005 Medium	David Villalobos		Gadsden HS
1608	Complete NEED TO PUT CHAIN & LOCK TO BE ABLE TO SECURE DOOR, GATE BY SOUTHWEST CORNER BY CONCESSION STAND WHERE WATER FOUNTAIN USED TO BE, FOOTBALL STADIUM. CHAIN & LOCK NEED TO BE WELDED TO GATE	5/3/2005 5/4/2005 Medium	Hector Lozoya		Gadsden HS
1544	Complete Please remove old sink an ice machine by 5-05-05 for new install TOOK OUT OLD SINK TO BE REPLACED BY ICE MACHINE ON 5/2, RETROFIT PLUMBING DRAIN AND WATER FOR ICE MAKER, CAP OFF WATER LINES.	4/29/2005 5/4/2005 Medium	David Villalobos		Gadsden HS
1548	Complete please reomove sink, dishwasher and ice machine for new install.panther hut REMOVED SINK, CONNECTIONS FOR DISHWASHER AND GARBAGE DISPOSAL.	4/29/2005 5/4/2005 Medium	David Villalobos		Gadsden HS
1581	Work In Progress curtains that where purchased thru the site need to have altering done to them by Rodriquez upholster.	5/2/2005 Medium	Michael Munoz		Gadsden HS
2827	Work In Progress AS PER MR. BOYD, STORM PUMP IN LIFT STATION IS RUNNING CONTINUOUSLEY. IS DESIGNED TO RUN ONLY DURING A STORM. NEED TO HAVE IT CHECKED OUT. MR. BOYD IS AT SCHOOL SITE AND IF HE SEE'S MARIO, HE WILL LET HIM KNOW ABOUT IT.	6/16/2005 Medium	Raul Sanchez		Gadsden HS
2315	Work In Progress Please paint inside and out of both guard shacks and repair what is damaged before school starts this year.	5/26/2005 Medium	Mario Apodaca		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2815	Complete CHARLES MARTINEZ, SAMCON NEEDS ANOTHER MASTER KEY FOR GHS (open all bldgs & classrooms). HAD TO GIVE OTHER KEY TO PLUMBER BECAUSE HE COMES IN AT 6:00 AM. - FELIPE	6/16/2005 6/16/2005 Medium	Alfredo Holguin Hector Lozoya		Gadsden HS
3031	Work In Progress RUBEN, PLEASE PREPARE WATER TANK FOR DELIVERY TO GADSDEN HIGH ON JULY 5, 2005. THERE WILL BE A POWER OUTAGE ON THE 6TH, 7TH & 8TH OF JULY.	6/28/2005 Medium	Aida Salcedo Ruben Ronquillo		Gadsden HS
3032	Work In Progress NEED TO DELIVER 5 WATER COOLERS, WATER BOTTLES AND HAND SANITIZER TO GADSDEN HIGH ON JULY 5TH. THERE WILL BE A POWER OUTAGE ON THE 6TH, 7TH & 8TH OF JULY. PLEASE CHECK TO SEE IF ANY OF THE WATER COOLERS ARE ELECTRICAL AND WORKING TO DISPENSE COLD WATER.	6/28/2005 Medium	Aida Salcedo Guillermo Hernandez		Gadsden HS
3033	Work In Progress NEED TO POWER WASH FRONT OF BUILDING BEFORE THE END OF THE SUMMER BREAK. ESPECIALLY ABOVE FRONT DOORS.	6/28/2005 Medium	Aida Salcedo Jesus Estrada		Gadsden HS
791	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. COMPLETED PER JESUS ESTRADA	4/1/2005 4/21/2005 Medium	Aida Salcedo Jesus Estrada		Gadsden HS
107	Work In Progress need to varnish 4 new doors in rooms #109,134,147,1542	3/7/2005 Medium	Danny Miranda Fernando Moncayo		Gadsden HS
1686	Complete Need to replace contactor after the power outage on 4/29/05.	5/5/2005 6/24/2005 Medium	Carlos Castillo Carlos Castillo		Gadsden HS
1307	Complete Replace damaged steamer contactor troubleshoot system and trace down burned contactor and replace burned contactor.	4/21/2005 6/6/2005 Medium	Carlos Castillo Carlos Castillo	Electrical Room	Gadsden HS
2762	Work In Progress need to varnish 15 new doors	6/14/2005 Medium	Danny Miranda Joe Ontiveros		Gadsden HS
1552	Work In Progress Emergency Call-no power to treatment plant.Hi voltage circuit breaker is tripping.	5/2/2005 5/3/2005 Medium	Carlos Castillo Carlos Castillo		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1353	Duplicate Request replace burned contactor 1307	4/22/2005 Medium	Carlos Castillo	Electrical Room	Gadsden HS
2814	Complete Locate underground lines for plumpbers at relocated portable area., locate underground lines for plumbers	6/16/2005 6/17/2005 Medium	Carlos Castillo Carlos Castillo	Portables	Gadsden HS
2656	Work In Progress connect power to portable	6/9/2005 Medium	Carlos Castillo Carlos Castillo	Portables	Gadsden HS
1677	Complete Concession Stand - Need to locate utilities for new toilet facilities. locate utilities	5/5/2005 5/24/2005 Medium	David Boyd David Villalobos		Gadsden HS
1678	Complete Concession Stand - Need to locate utilities for new toilet facilities. locate and mark underground lines for contractors.	5/5/2005 5/10/2005 Medium	David Boyd Carlos Castillo		Gadsden HS
2306	Complete walk-in refrigerator not cooling DIRTY COIL- REMOVED ALL SIX COVERS AND FANS FROM EVAPORATOR DROPPED CONDENSATE DRAIN PAN CLEANED COIL, FANS AND COVERS, PUT IT ALL BACK TOGETHER, CLEANED UP	5/26/2005 5/31/2005 Medium	Danny Orozco Danny Orozco	Cafeteria	Gadsden HS
816	Complete REACH-IN REFRIGERATOR NOT WORKING. REMOVED BAD COMPRESSOR AND FILTER DRYER INSTALLED NEW COMPRESSOR AND DRIER VACUUMED SYSTEM CHECKED FOR LEAKS CHARGED SYSTEM R-134 CHECKED TEMP 38 DEGREES CLEANED UP	4/4/2005 5/20/2005 Medium	Danny Orozco Danny Orozco	Cafeteria	Gadsden HS
1067	Complete G.H.S. NEED TO REMOVE SINK @ COUNTER TOP remove cabinets and tops	4/12/2005 5/4/2005 Medium	Danny Miranda Danny Miranda		Gadsden HS
1696	Complete need to repair walls at panther hut REPAIR WALLS	5/5/2005 5/12/2005 Medium	Danny Miranda Danny Miranda		Gadsden HS
898	Work In Progress BUS BLDG 611- REMOVE AND INSTALL COVEBASE. (Please call Mike before you start on this work order) - Thanks mkv	4/6/2005 Medium	Michael Munoz Mario Apodaca	Classroom	Gadsden HS
1831	Closed Work Orders 5-9-5 5-HOURS WO 1498 3- HOURS WO 1662 5/9	5/11/2005 5/9/2005 Medium	Michael Mc Dermott Michael Mc Dermott		Gadsden HS PUMP HOUSE POOL..
2350	Closed Work Orders 5-25-5 4-HOURS REMOVE FLOOR OUTLETS RM 660. 4-HOURS RE DO ELECTRICAL CONDUITS OUTSIDE RM 233. 5/25 - 8	5/27/2005 5/25/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Classroom	Gadsden HS ROOM 660

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2078	Closed Work Orders 5-18-5 3-hours look over work orders for high school. 5/18 - 3	5/18/2005 5/18/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Gym	Gadsden HS
3089	Closed Work Orders 6-27-05 1.5-INPUT TO SCHOOL DUDE 6.5-WORK AT V-GYM 6/27 - 8	6/30/2005 6/27/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
3090	Closed Work Orders 6-28-05 2-WENT TO CK E/COOLER AT ROOM 551,700 6-WORK AT V-GYM 6/28 - 8	6/30/2005 6/28/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
3093	Closed Work Orders 6-29-05 8-WORK AT V-GYM 6/29 - 8	6/30/2005 6/29/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
2995	Closed Work Orders 6-22-05 1-CK BLDG POWER GOING OUT 6-WORK AT V-GYM 1-CK E/COOLER AT RM 751 6/22 - 8	6/27/2005 6/22/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
2996	Closed Work Orders 6-23-05 .8-WORK AT V-GYM 6/23 - 8	6/27/2005 6/23/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
2990	Closed Work Orders 6-20-05 1.5-IN PUT TO SCHOOL DUDE 6.5-WORK AT V-GYM 6/20 - 8	6/27/2005 6/20/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
2991	Closed Work Orders 6-21-05 1-WENT TO CK AND FIX TOILET AT POOL 7-WORK AT V-GYM 6/21 - 8	6/27/2005 6/21/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
2869	Closed Work Orders 6-13-05 6-14-05 6-15-05 6-16-05 32-WORK AT V-GYM PANTING ALL WALLS 6/13,14,15,16 32	6/20/2005 6/16/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
2563	Closed Work Orders 5-31-05 1.5-IN PUT TO SCHOOL DUDE 6.5-AT V-GYMCORING -UP FOR PANTING 5/31 - 8	6/7/2005 5/31/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2564	Closed Work Orders 6-1-05 6-AT V-GYM COVRING -UP FOR PANTING 2-CIOSING WATER TO POOL AND OPENING CONTRACTORS HIT WATER LINE 6/1 - 8	6/7/2005 6/1/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
2565	Closed Work Orders 6-02-05 8-V-GYM COVRING FOR PANTING 6/2 - 8	6/7/2005 6/2/2005 Medium	Mario Apodaca		Gadsden HS
2721	Closed Work Orders 6-07-05 1.5-IN PUT TO SCHOOL DUDE 6.5-WORK AT V-GYM PUTING -UP PLASTIC DROP CLOTH 6/7 - 8	6/13/2005 6/7/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
2724	Closed Work Orders 6-08-05 6-09-05 3-OPENING DOORES FOR CONTRACTRS 13-WORK AT V-GYM PUTING UP PLASTIC DROP CLOTH AND PATCH UP WALLS 6/8, 9 - 16	6/13/2005 6/9/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
953	Closed Work Orders 4-6-05 2-REMOVE TOILET TO GET TO BLACKAGE AND REMOVE IT AT M/OFFICE RESTROOM 1-FIX WINDOW AT ROOM 127WOOD NOT CLOSE 1-CK ALL BLDE AND HEATING UNIT 2-PINT DOOR AT ROOM 802 1-IN PUT TO SCHOOL DUDE 1-WORK ON CLEANING UP VEHICLES #95 4/6 - 8	4/8/2005 4/6/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
954	Closed Work Orders 1-CK IN TO OFFICE W/MR FOSTRE 4-HELP PICK UP CHAIRS AND PUT UP FENCE AT NORTH SIDE THIS WAS FOR EVERY 15 MINUTES 3-WORK ON E/COOLER AT ACADEMIC	4/8/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
903	Closed Work Orders 4-05-05 1.5-IN PUT TO SCHOOL DUDE 3-WORK ON CURTAIN AND TRACK DOING ADJUST TO OPEN AND CLOSING AT ROOM 331 2-AT FOOTBOLL W/CLAIMS SPECIAIST AND SERVPRO TO CK DEMAGE ON BLDG AND FOOTBALL EQUIPMENT 1.5-WENT TO CK ROOF TOP ALL LOOK GOOD BUT A WATER LEAK IS THER W/O 124706 4/5 - 8	4/6/2005 4/5/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
789	Complete NEED TO DISCONNECT POWER TO BURNING STORAGE AS PER FIRE DEPT. (BLEACHER AREA) eliminate electrical hazard for fire dept.	4/1/2005 3/31/2005 Emergency	Mario Apodaca Carlos Castillo	Athletic Field	Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
770	Closed Work Orders 3-31-05 1.5-WENT TO RM 342 TO FIX DOOR .5-W/O 125105 NEED OVERHEAD SCREEN TO PUT UP NEED TO ORDER 1-WENT TO PUT A NEW PORCELAN LAMPHOLDER RM V GYM 1-CK IN AT OFFICE W/FOSTER 4-FIRE AT FOOTBALL FIELD WENT TO PUT OUT	4/1/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
767	Closed Work Orders 3-29-05 2-IN PUT TO SCHOOL DUDE 2-WENT TO CK FOR LOW WATER AND RUNING TOLET 1.5-PUT UP SING AT ROOM 227,900 2.5-WENT TO REMOVE SING AT NORTH SIDE	4/1/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
768	Closed Work Orders 3-30-05 8-CK EXIT SING W/O 124400 RED NEED TOBE WORK ON GREEN IS OK	4/1/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
837	Closed Work Orders 8-AT ROOM 331 PUTING UP A TRACK SYSTEM FOR CURTAIN 8	4/5/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
834	Closed Work Orders 4-1-05 2-WENT TO CK DAMAGE TO BLDG AT FOOTBALL FILED 1.5-IN PUT TO SCHOOLDUDE 1.5-PUT UP ORANGE BARRICAE AT FOOT BALL FIELD 3-AT ROOM 331 PUTING UP A TRACK SYSTEM 4/1 - 8	4/5/2005 4/1/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1202	Closed Work Orders 4-14-05 4-WORK ON E/COOLER AT V-GYM 4-AT ROOM 611 REMOVE ALL VINY WALL BASE AND SPRAY BLEACH A MIX OF 1TO 10 4/14 - 8	4/15/2005 4/14/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1203	Closed Work Orders 4-13-05 1-IN PUT TO SCHOOL DUED 3-FIX WATRE LEAK ON E/COOLER ON SHOP BLDG 2-TRAUBLE SHOOT A/C UNIT AT ROOM 244,245 AND AT ROOM 222-226 CALL LUPE TO HELP FIX 2-WORK ON E/COOLER AT V-GYM 4/13 - 8	4/15/2005 4/13/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1204	Work In Progress NEED A OIL PRESSUREFOR AIR COMPRESSOR AT AG SHOP	4/15/2005 Medium	Mario Apodaca Jose Ambriz		Gadsden HS
1269	Closed Work Orders 4-15-05 1-IN PUT TO SCHOOL DUDE 2-WENT TO MR FOSTER OFFICE TO CK IN ON WORK ORDER 1-RESPRAY AT ROOM 611 BUS BLDG 4-WORK ON E/COOLER AT ACADEMIC BLDG 4/15 - 8	4/20/2005 4/15/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1270	Closed Work Orders 4-18/19-05 16-WORK ON E/COOLER AT ACADEMIC BLDG AND FIX WATER LINE 4/18,19 -16	4/20/2005 4/19/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1122	Complete A/C UNIT IS DOWN AT N/BLDG ROOM 222,223,224,226 NEED TO BE FIX ASAP replace 2hp motor - 1725 rpm - 3ph, had to reverse compressor was lock, working ok with blower, rerun that was single phasing, disconnet blades one was not touching. working ok.	4/13/2005 4/14/2005 Medium	Mario Apodaca Jose Ambriz	Classroom	Gadsden HS
1123	Closed Work Orders 4-12-05 1-IN PUT TO SCHOOL DUDE 7-WORK ON E/COOLER AT ACADEMIC BLDG 4/12 - 8	4/13/2005 4/12/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1084	Closed Work Orders 4-08-05 1.5-in put to school dude 4.5work on e/cooler 2-help joe on computer for school dude 4/8 - 8	4/12/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1087	Closed Work Orders 4-11-05 8-work on e/cooler at academic bldg 4/11 - 8	4/12/2005 4/11/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
131	Closed Work Orders 3-02-05 -1.5-INPUT TO SCHOOLDUDE 5.5-AT COUNS CENTER ON BAD ODOR CAMMING FRAM SEWAGE LINE 1-WENT TO PUT NEW LAMP AT ROOM 230	3/7/2005 3/8/2005 Medium	Mario Apodaca Mario Apodaca	Classroom	Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
132	Closed Work Orders 3-03-05 5.5-HELP RUN HOT WATER TO MAIN OFFICE RESTROOM W/O 97333 1.5-CK BOILER AND HEATING UNIT 1-CK IN AT OFFICE W/MR FOSTER	3/7/2005 3/8/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
133	Work In Progress NEED NEW STAIR VINYL STRIP FOR MAIN GOING UP TO OLD/ENG	3/7/2005 Medium	Mario Apodaca Michael Munoz	Stairway	Gadsden HS
134	Work In Progress NEED TO REWELD TRAY RAILING AT LINE #2	3/7/2005 Medium	Mario Apodaca Danny Orozco	Cafeteria	Gadsden HS
113	Closed Work Orders "2-25-05 1-CK BOILER AND HEATING UNIT 1.5- FIX BOY RESTROOM PARTITLONS AT N-BLDG 1.5-GIRLS RESTROOM FIX TOILET FLUSH VALVE 1.5-PUT NEW CEILING TILE AT ROOM 653 1-WENT TO FIX DOOR CENTER POST AT N- BLDG 1.5-IN PUT TO SITENET "	3/7/2005 3/16/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
110	Closed Work Orders 3-01-05 1-CK BOILER AND HEATING UNIT 2- HELP UNPLUGGED FLOOR SINK AT CAFETERIA AND FIX DRAIN 5-WORK ON MAINTENANCE PIAN	3/7/2005 3/16/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
111	Closed Work Orders "2-28-05 1-CK BOILER AND HEATING UNIT 1.5- AT ACADDEMIC BLDG CK TOW ROOM WAS GETING TOO HAT INSIDE THERMOSTATIC SET TOO HI 5.5WORK ON MAINTENANCE PIAN "	3/7/2005 3/16/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
217	Closed Work Orders 3-07-05 1-CK BOILER AND HEATING UNIT 1-WENT TO CK CXOUNS CENTER FOR ODOR AT BLDG 1.5WENT TO PUT A NEW VACUUM BREAKER AT C/STAND 1.5-PUT NEW LAMP AT AG SHOP 1-5-WENT TO PUT NEW COVE ON OUTLET AT ROOM 220 1.5-IN PUT TO SCHOOLDUDE	3/9/2005 3/9/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
218	Closed Work Orders 1-CK BOILER AND HEATING UNI 1-WENT TO ROOM 140 TO CK WINDOW AND HEATING UNIT 2-PUT UP SING AT LIBRARY AND CAFETERIA 1-CK IN TO MS LOPEZ OFFICE 1-AT COUNS CENTER FOR ODOR 2-PUT NEW BALLAST AT ROOM 239	3/9/2005 3/9/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
191	Complete NEED TO REKEY THE EAST WING AT THE CAFETERIA FOR THE COUNS CENTER ARE MOVEING IN TO THE E-WING AND NEED 12 NEW KEY	3/8/2005 3/8/2005 Medium	Mario Apodaca Hector Lozoya	Cafeteria	Gadsden HS
261	Complete NEED NEW WOOD DOOR AT OLD ENG BLDG ROOM #140,135,134,132,128,129,153,150,148. REPLACED DOORS	3/10/2005 6/9/2005 Medium	Mario Apodaca Danny Miranda	Classroom	Gadsden HS
263	Complete NEED NEW WOOD DOOR AT N-BLDG AT ROOM # 224,230,211,232,233 replace 5 doors and frames	3/10/2005 6/13/2005 Medium	Mario Apodaca Danny Miranda		Gadsden HS
264	Work In Progress NEED A METAL DOOR FOR BOY RESTROOM AT N-BLDG - ONE DOOR	3/10/2005 Medium	Mario Apodaca Danny Miranda	Restroom (Boys)	Gadsden HS
265	Closed Work Orders 3-09-05 1-CK BOILER AND HEATING UNIT 2.5-WORK ON E/COOLER AT OLD ENG BLDG 1.5-IN PUT TO SCHOOL DUDE 3-MOVE OFFICE FURNITURE OUT AND IN TO THE EAST WING FOR COUNSEL	3/10/2005 3/10/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
267	Complete NEED TO REPAIR GLASS AT ACADEMIC BLDG BY OFFICE 48X48	3/10/2005 3/11/2005 Medium	Mario Apodaca Ruben Ronquillo	Hallway/Corridor	Gadsden HS
332	Work In Progress DOOR AT ACADEMIC BLDG NEED TO BE FIX HINGES ARE LOSS FRAM BY ROOM 344	3/11/2005 Medium	Mario Apodaca Danny Miranda	Office	Gadsden HS
333	Work In Progress NEED NEW DOOR AT MAIN BLDG GOING OUT TO COMPUTER LAB WEST WING	3/11/2005 Medium	Mario Apodaca Danny Miranda	Hallway/Corridor	Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
334	Closed Work Orders 3-10-05 1-CK BOILER AND HEATING UNIT 6-WORK ON E-COOIER AT OLD ENG 1-IN PUT TO SCHOOL DUDE	3/11/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
425	Closed Work Orders 3-10-05 1-CK BOILER AND HEATING UNIT 6-WORK ON E-COOLER AT OLD/ENG BLDG 1-IN PUT TO SCHOOL DUDE	3/15/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
426	Closed Work Orders 3-11-05 1-CK BOILER AND HEATING UNIT 2- W/DANNY M CKING DOOR AT NEED TOBE REPLACES 5-WORK ON E/COOLER AT MAIN BLDG	3/15/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
427	Closed Work Orders 3-14-05 1-CK BOILER AND HEATING UNIT 7-WORK ON E/COOLER AT WOOD,AG SHOP	3/15/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
652	Work In Progress NEED TO ORDER THE WET SIED FOR E/COOLER AT ACADEMIC BLDG W/NEW COOLING MEDIA	3/29/2005 Medium	Mario Apodaca Jose Ambriz		Gadsden HS
653	Complete NEED TO REMOVE AND REINSTALL SAFETY SWITCH BOXES FOR E/COOLER AT WEIGHT ROOM AND ACADEMIC BLDG SO WE CAN PUT NEW WET SIDE above work order performed by Mario.	3/29/2005 5/18/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
654	Complete NEED A NEW SWITCH W/PILOT LIGHT FOR WALK IN COOLER ASAP COMPLETED BY DANNY OROZCO AS PER MARIO.	3/29/2005 5/18/2005 Medium	Mario Apodaca Danny Orozco		Gadsden HS
647	Closed Work Orders 3-16-05 1-CK BOILER AND HEATING UNIT 6-WORK ON E/COOLER AT AG AND AUTO SHOP 1-AT CAFETERIA HELP DAVID RUN SEWER SNAKE	3/29/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
648	Closed Work Orders 3-17-05 1-CK BOILER AND HEATING UNIT 7-WORK ON E/COOLER ACADEMIC	3/29/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
649	Closed Work Orders 3-22-05 5-WENT TO STMS FOR SAFETY MEETING 3-PAINT AT ROOM 227	3/29/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
650	Closed Work Orders 3-23/24-05 8-WORK ON E/COOLER AT ACADEMIC BLDG	3/29/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
645	Closed Work Orders 3-15-05 1-CK BOILER AND HEATING UNIT 2-WORK AT ROOM 610 PUTING SHELIVING 2-HELP CK SEWER LINES W/VIDEO AT COUNS CENTER 3-WORK ON E/COOLER AT BARRACKS	3/29/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1935	Closed Work Orders 5-11-05 2-CK E/COOLER AND A/C UNIT 1.5-WENT TO REMOVE OUTLET FOR SENIOR PARTY 1-IN PUT TO SCHOOL DUDE 1-FIX AIR LEAK W/O 1641 3-WORK ON E/COOLER 5/11 - 5	5/13/2005 5/11/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1936	Closed Work Orders 5-12-05 6-WORK ON ROOFING INFOR 1-WENT TO CK E/COOLER AT RM 700 NEW PUMP 1-CK E COOLER AT RM 311 BALT 5/12 - 8	5/13/2005 5/12/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1958	Closed Work Orders 5-13-05 1.5WENT TO SHOP/WHs AND GAS UP 2-CK E/COOLER AND A/C UNIT AND FIX ONE UNIT 1-FIX E/COOLER AT ROOM 563 2-FIX SCREEN AT CAFE NOT MOVEING UP AND DOWN 1.5-IN PUT TRO SCHOOL DUDE. 5/13 - 8	5/16/2005 5/13/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2066	Closed Work Orders 5-16-05 1.5-CK ALL BLDG AND A/C UNIT AND E/COOLER 5.5-REMOVE ALL OLD PAD FOAM ROOF TOP 1-IN PUT TO SCHOOL DUDE 5/16 -8	5/18/2005 5/16/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
2067	Closed Work Orders 5-17-15 1.5-REMOVE OLD PAD FROM OLD ENG BLDG 1.5-PUT NEW FILTER AT BUS BLDG 1-PUT NEW BALLAST AT G/SHOP 4-WORK ON EXIT SIGN W/O 12621 5/17 - 8	5/18/2005 5/17/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
2068	Work In Progress NEED TO CALL ELECTRIC CO. TO SERVICE OUTSIDED LAMPS	5/18/2005 Medium	Mario Apodaca Michael Munoz		Gadsden HS
2192	Closed Work Orders 5-18-05 4-WENT TO PUT -UP DRY BOARDS AT REM 410 AND 411 3-WORK ON EXIT SIGN W/O 126261 1-WENT TO CK C/COOLER AT RM 330 NEED BEARINGS 1-INPUT TO SCHOOL DUDE 5/18 - 8	5/23/2005 5/18/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
2197	Closed Work Orders 5-19-05 7-WORK ON MAINTENANCE PLAN INSPECTION 5/19 - 7	5/23/2005 5/19/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
2089	Complete NEED NEW BEARINGS FOR E/COOLER AT ACADEMIC BLDG had bad bearings, spiders on acad. bldg for aero cool, ordered some and Fernie will replace them.	5/18/2005 6/13/2005 Medium	Mario Apodaca Jose Ambriz		Gadsden HS
2281	Closed Work Orders 5-23-05 1-IN PUT TO SCHOOL DUDE 6-WORK ON PSFA INSPECTIONS 1-WENT TO CK A/C UNIT AT RMJ 227 5/23 - 8	5/25/2005 5/23/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
2282	Closed Work Orders 5-24-05 8-WORK ON PSFA INSPECTIONHS 5/24 - 8	5/25/2005 5/24/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
2279	Work In Progress NEED SCISSOR LIFT FOR V-GYM BY 5-31-05	5/25/2005 Medium	Mario Apodaca Ruben Ronquillo	Gym	Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2380	Closed Work Orders 5-25-05 4-VARATHANE DOOR FOR OLD ENG 4-WORK ON PSFA INSPECTIONS 5/25 - 8	5/31/2005 5/25/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
2381	Closed Work Orders 5-26-05 3-REVARATHANE DOORS FOR OLD ENG 3- WORK ON PSFA INSPECTIONS 2-WENT TO CK AND FIX 2 E/COOLER AT RM 754,752 5/26 - 8	5/31/2005 5/26/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1664	Closed Work Orders 5-3-05 7-HELP OUT CARLOC C. AT TRANSFOMER W/O 1552 1-PUT A NEW PHOTOELECTRIC SWITCH AT CAFE BLDG 5/3 - 1	5/4/2005 5/3/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1662	Complete NEED 2 # NEW TIMERS FOR OUT DOOR LIGHT AT V-GYM AND COMPUTER LAB	5/4/2005 5/9/2005 Medium	Mario Apodaca Michael Mc Dermott		Gadsden HS
1655	Work In Progress NEED TO COVER ALL WALL AT CONCCSSION STAND W/WHITE WALL LINER PANEL AND END CAPS NEED 20 # MORE SHEETS	5/4/2005 Medium	Mario Apodaca Danny Miranda		Gadsden HS
1656	Complete BOY GYM GLASS 15X46 BROKEN WINDOW	5/4/2005 5/9/2005 Medium	Mario Apodaca Ruben Ronquillo		Gadsden HS
1702	Complete NEED TO REKEY THE STORAGE AT V-GYM W/KEY FROM RM 331 rekey storage off master to HE 248	5/5/2005 5/6/2005 Medium	Mario Apodaca Hector Lozoya		Gadsden HS
1703	Closed Work Orders 5-04-05 1-PUT NEW WATRE FLOUT FOR E/COOER AT RM 563 1.5-WENT TO REMOVE BLACKAGES FRAM SINK AT RM 216 1.5-PUT NEW FILTER AT CAMP LAB 1-HELP REMOVE OLD SINK AT RM 233 1-IN PUT TO SCHOOL DUDE 1-WENT TO TROUBLE SHOOT A/C UNIT AT RM 244 5/4 - 7	5/5/2005 5/4/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1729	Closed Work Orders 5-05-05 2.5-TRAINING FOR STAGE LIGHTING AT V-GYM BY LYNCO ELECTRIC 2.5-W/RODRIGUES AT V-GYM CURTAIN FOR STAGE 1-CK E/COOLER AT RM 334 PUMP 2- PUT NEW FILTER ALL A/C UNIT FOR N-BLDG 5/5 - 8	5/6/2005 5/5/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1818	Closed Work Orders 5/10/05 1.5-CK ALL E/COOLER AND BLDG 1.5 WENT TO SET UP OUTLETS FOR SENIOR PARTY 2-CK AND FIX E/COOLER AT RM 315,155 1-FIX OUTLET AT RM 223 2-TROBLE SHOOT A/C UNIT AT RM 220 5/10 - 8	5/11/2005 5/10/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1816	Closed Work Orders 5-06-05 3-CK E/COOLER AND FIX COOLER AT RM 275,554 1-WENT TO CK FIX DOOR AT RM 331 DOOR HAND 1.5-TRAUBIE SHOOT A/C UNIT AT RM 227 2.5-WENT TO CK IN W/MR CAREY AND MR FARTER ON W/ORDER FOR GYM 5/6 - 8	5/11/2005 5/6/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1356	Closed Work Orders 4-20-05 1.5-IN PUT TO SCHOOL DUDE 3-FOOTBALL FIELD PUTING UP ORANGE BARRERA 3.5-WORK ON E/COOLER AT CAFETERIA 4/20 - 8	4/22/2005 4/20/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1357	Closed Work Orders 4-21-05 1.5-PUT NEW VINY WALL BASE ATROOM 611 3-TROBLE SHOOT A/C UNIT TA BUS BLDG 2.5-PUT NEW PAD MEDIA AT ROOM 900 BLDG 1-WENT TO FIX DOOR AT ROOM 137 4/21 - 8	4/22/2005 4/21/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1461	Closed Work Orders 4-22-05 1-IN PUT TO SCHOOL DUDE 2-PUT A NEW MOTORON A/C UNIT AT BUS BLDG .2-WORK ON LIBRARY GATE AND FIX W/O 1181 1-WENT TO CK E/COOLER AT ROOM 334 PUT NEW PUMP 2-WORK ON E/COOLER AT ACADEMIC 4/22 - 6	4/27/2005 4/22/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1462	Closed Work Orders 4-26-05 8-WORK ON E/COOLER AT CAFETERIA 4/26 - 8	4/27/2005 4/26/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1483	Complete NEED TO PUT NEW GLASS AT WOOD SHOP 69"X 49" AT TOOL ROOM	4/28/2005 4/28/2005 Medium	Mario Apodaca Ruben Ronquillo		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1484	Closed Work Orders 4-27-05 1- IN PUT TO SCHOOL DUDE 7-WORK ON E/COOLER AT CAFETERIA & ROOM 500 4/27 - 8	4/28/2005 4/27/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1501	Work In Progress NEED 2 # NEW SINKS AND FAUCETS FOR THE CONCESSION STAND	4/28/2005 Medium	Mario Apodaca David Villalobos		Gadsden HS
1579	Closed Work Orders 4-28-05 1-IN PUT TO SCHOOL DUDE 3-AT CAFE HELP PUT A NEW ELECTRICAL CONTRAL FOR E/COOLER 2-PUT ANEW MOTOR ON A/C UNIT FOR ROOM 611 2-WORK ON E/COOLER 4/28 - 8	5/2/2005 4/28/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1580	Closed Work Orders 4-29-05 1-WENT TO CK IN W/MS LOPEZ 2-TROUBLE SHOOT A/C UNIT AT ROOM 244 5-WORK ON E/COOLER AT BOY GYM 4/29 - 8	5/2/2005 4/29/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1582	Closed Work Orders 5-02-05 1.5-MEETING AT MS LOPEZ OFFICE FOR ADA 4-WORK AND HELPING OUT CARLOS ON ELECTRIC CONTROS FOR WALL NAD E/COOLER 1.5-IN PUT TO SCHOOL DUDE 1-AT V-GYM W/RODRIGUEZ UPHOLSTERY FOR PUTING UP CURTAIN 5/2 - 8	5/2/2005 5/2/2005 Medium	Mario Apodaca Mario Apodaca		Gadsden HS
1522	Complete Need Grand Masters 6 & 7 for Bobby Aldaz. issued 6 & 7 pin master	4/29/2005 4/29/2005 Medium	Lorenzo Hernandez Hector Lozoya		Gadsden HS
1393	Work In Progress BASEBALL & SOFTBALL DUGOUT AREA - NEED (3) HOLLOW METAL DOORS WITH HOLLOW METAL FRAMES (3'0" X 6'8") FOR STORAGE ROOMS.	4/25/2005 Medium	Lorenzo Hernandez Danny Miranda	Athletic Field	Gadsden HS
1394	Work In Progress GROUNDS SHOP - NEED TO RESTOCK FIRST AID KIT.	4/25/2005 Medium	Lorenzo Hernandez Ruben Ronquillo		Gadsden HS
2625	Complete I have two chair dolly's (cafeteria) that have broken wheels. I have one inflatable wheel dolly that is flat. REPLACED CAHIR DOLLY WHEELS AS PER JIMMY	6/8/2005 6/13/2005 Medium	Jesus Estrada Sal Acuna		Gadsden HS
615	Complete I have an Advance burnisher #1178815 that has a broken handle. REPLACED ABOVE PARTS AND DID P.M.	3/24/2005 5/20/2005 Medium	Jesus Estrada Jimmy Carbajal		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2491	Complete Advance burnisher #1238139 pad holder is stuck and streaks tile. NSS wet/dry #080808A is not picking up water. FIXED PAD HOLDER ON BURNISHER. WET-N-DRY HAD A CLOG IN VACUUM TUBE AND ALSO REPLACED SQUEEZY(ISSUED THRU ACT 1000).	6/3/2005 6/9/2005 Medium	Jesus Estrada Jimmy Carbajal		Gadsden HS
2386	Complete Nss Roto GISD tag 000395 has a short in cord. FIXED SHORT IN PLUG AS PER JIMMY	5/31/2005 6/3/2005 Medium	Jesus Estrada Jimmy Carbajal	Athletic Field	Gadsden HS
1354	Work In Progress need casters on tables fixed. I counted 14 that need replacement.	4/22/2005 Medium	Jesus Estrada Guillermo Hernandez	Cafeteria	Gadsden HS
2773	Closed Work Orders 6-10-05 4HRS Went to PPD -4- Supply 4HRS Varsity GYM 6/10 - 8	6/14/2005 6/10/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2774	Closed Work Orders 6-13-05 8HRS Varsity GYM 6/13 - 8	6/14/2005 6/13/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2775	Closed Work Orders 8HRS Paint GYM 6/14 - 8	6/14/2005 6/14/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2697	Closed Work Orders 6-9-05 8HRS Varsity GYM 6/9 - 8	6/10/2005 6/9/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2632	Closed Work Orders 6-6-05 2HRS Paint New doors on North BLDG 4HRS Varsity GYM 2 HRS Patch Roof top on North BLDG 6/6 - 8	6/8/2005 6/6/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2633	Closed Work Orders 6-7-05 2HRS Weed Control 7HRS Varsity GYM 6/7 - 8	6/8/2005 6/7/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2634	Closed Work Orders 6-8-05 7HRS Worked on Varsity GYM 6/8 - 7	6/8/2005 6/8/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
3055	Closed Work Orders 6-27-05 1HR Weed Control 1HR Clean Shop 6HRS Varsity GYM Installed Basket ball Court 6/27 - 8	6/29/2005 6/27/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
3056	Closed Work Orders 6-28-05 8HRS Varsity GYM Put up Banners 6/28 - 8	6/29/2005 6/28/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
3015	Closed Work Orders 6-27-05 1HR Clean Basement 1HR Weed Control 6HRS Varsity GYM Install Basket ball Court 6/27 - 8	6/27/2005 6/27/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2962	Closed Work Orders 6-22-05 7HRS Varsity GYM Clean up 1HRS Weed Control 6/22 - 8	6/23/2005 6/22/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2963	Closed Work Orders 6-23-05 2HRS Weed Control 2HRS Paint Electrical Pipe 4HRS Varsity GYM 6/23 - 8	6/23/2005 6/23/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2986	Closed Work Orders 6-24-05 2HRS Went to PPD Fill up Gas -N-to take time sheet 2HRS Weed Control 4HRS Varsity GYM 6/24 - 8	6/24/2005 6/24/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
3106	Closed Work Orders 6-29-05 2HR Weed Control 6HRS Finishing up Varsity GYM 6/29 - 8	6/30/2005 6/29/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
3107	Closed Work Orders 6-30-05 1HR Remove old doors from old English BLDG 2HRS Weed Control 5HRS Patching Holes in BLDG Halls 6/30 - 8	6/30/2005 6/30/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2862	Closed Work Orders 6-17-05 8HRS Varsity GYM 6/17 - 8	6/17/2005 6/17/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2842	Closed Work Orders 6-15-05 8HRS Varsity GYM 6/16 - 8	6/16/2005 6/16/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2843	Closed Work Orders 6-16-05 8HRS Varsity GYM 6/16 - 8	6/16/2005 6/16/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2932	Closed Work Orders 6-20-05 8HRS Varsity GYM 6/20-8	6/21/2005 6/20/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2933	Closed Work Orders 6-21-05 2HRS Weed Control 6 HRS Varsity GYM 6/21-8	6/21/2005 6/21/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2069	Closed Work Orders 5-17-05 1.5HRS Replaces air filters Refre uniteds 2.5HRS Pick up old Cooler pads on Bldgs 1HR Weed Control 2HRS Relace water pump main bldg -N- Change plug devices 1HR Recived -N- deliver paint to Auto Shop 5/17 - 8	5/18/2005 5/17/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2097	Closed Work Orders 5-18-05 1HR Install soap despenser at wood shop 4HRS Work boys Gym Installing dry board RM 410-n-411 1HR Install door stop at swimming pool 2HRS Replaces water Flow at Main BLDG 5/18 - 8	5/18/2005 5/18/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2177	Closed Work Orders 5-19-05 1HR CK A/C Cafeteria 6HRS Paper Work -N- CKING BLDG 1HR Weed Control 5/19 - 8	5/20/2005 5/19/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2181	Closed Work Orders 1.5HRS Fixed screen at social Work Office 5HRS Paint New Doors with Polyerthane 1.5HRS Ajust E-Cooler motor old English bldg 5/20 - 8	5/20/2005 5/20/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1979	Closed Work Orders 5-10-05 5.5HRS Clean up old E-Cooler pads on Roof top 2.5HRS Weed Control -N- Replaces Cooler Flows 5/10 - 8	5/17/2005 5/10/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1921	Closed Work Orders 5-12-05 1HR CK A/C at the Barracks 1HR Replace water pump on E-Cooler in Cafeteria 1HR Ajust Front South Gate 3HRS Weed Control 1HR RM 205 Teacher Lounge Key door problem did not open 1HR CK Light in Band RM 5/12 - 8	5/12/2005 5/12/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2404	Closed Work Orders 5-31-05 1HR Pick up trash around BLDG 1HR Went to PPD to fill gas -N- Pick up Varsity Paint 6HRS Worked on Varsity Gym 5/31 - 8	6/1/2005 5/31/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2396	Closed Work Orders 5-27-05 2HRS Went to ppd -4- Supplies -N- Services Truck 4HRS Paint North BLDG doors 2HRS Weed Control 5/27 - 8	5/31/2005 5/27/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2428	Closed Work Orders 6-1-05 2HRS Borken Water Line Help Closing -N- Opening Shut off Valves 6HRS Worked on GYM 6/1 - 8	6/2/2005 6/1/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2492	Closed Work Orders 6-2-05 8HRS Varsity GYM 6/2 - 8	6/3/2005 6/2/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2493	Closed Work Orders 6-3-05 8HRS Worked on Varsity GYM 6/3 - 8	6/3/2005 6/3/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2333	Closed Work Orders 5-26-05 4HRS Paint Hallway wall on Old English BLDG 3HRS Paint 2# Coat New Doors 1HR CK A/C on Agricul Shop 5/26 - 8	5/26/2005 5/26/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2291	Closed Work Orders 8HRS OnPublic School Facilities Authority Maintenance Plan Site Inspection (PSFA) 5/24 - 8	5/25/2005 5/24/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2292	Closed Work Orders 5-25-05 4HRS Work on (PSFA) Inspections 4HRS Paint New Doors 5/25 - 8	5/25/2005 5/25/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
2234	Closed Work Orders 5-23-05 8HRS W/O ID # 726 RM 141 old English Painted 5/23	5/24/2005 5/24/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1470	Closed Work Orders 4/26/05 1.5 HRS Fixed Lav at Main Office no water 4HRS Work in Cafeteria Coolers 1.5HRS Install new 1/2in water Ball Valve for Cooler in main BLDG 1HR Weed Control 4/26 - 8	4/27/2005 4/26/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1509	Closed Work Orders 4-28-05 3HRS Work on Coolers in Cafeteria 1HR Replace Electic out Let in RM 229 2HRS Remove and stall motor in Business Bldg 2HRS Weed Control 4/28 - 8	4/28/2005 4/28/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1600	Closed Work Orders 5-2-05 1HR Weed Control 1HR Fixed water Leak in Academic BLDG 1HR Taped Broken Window in Varsity gym 2HRS Remove Cabinets 1HR Fixed water Leak in Arricultural bldg 2HRS IN stalling -n- Replace Fire Extinguishers 5/2 - 8	5/3/2005 5/2/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1596	Closed Work Orders 4-30-05 4HRS Electical Power out Work on pool 4/30 - 4	5/3/2005 4/30/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1555	Closed Work Orders 4-29-05 2HRS Went to PPD to take paper work-N-get Supply for Coolers 1HR Unclough urinal inVarsity gym 1HR Work on Boys gym on Coolers 1HR Clean Basemant 1HR Fixed Electical box at the Barracks 2HRS Replacing Fire Extinguishers 4/29 - 8	5/2/2005 4/29/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1378	Closed Work Orders 4/22/05 1HR Fixed book detactor in Library 1HR Installed New Cooler Pats at the Barracks Bldg 1HR unclough urinal in the Acadmic Bldg 2HRS Installed motor on Refer united in Bussiness Bldg 2HRS unclough sink in Main Bldg RM 123 1HR Weed Control 4/22 - 8	4/22/2005 4/22/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1332	Closed Work Orders 4/21/05 1HR Fixed water Leak in Academic Bldg 1.5HRS Installing baseborde in RM 611 2HRS PPD Material for E-Coolers 3.5HRS Installing Side Cooler panel in Nurse Office 4/21 - 8	4/21/2005 4/21/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1878	Closed Work Orders 5-11-05 3HRS Work E-Cooler boys Gym 2HRS Fixed Leak-N-Clean Roof trash in VarsityBLDG 1HR Fixed Servics Sink in RM 124 1HR w/o ID # 1641 Fix air Leak in Compressor in Agricul Shop 1HR Install E-Cooler Control Switch 5/11 - 7	5/12/2005 5/11/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1764	Closed Work Orders 5-7-05 8HRS Work on Pool 5/7 - 8	5/9/2005 5/7/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1765	Closed Work Orders 5-9-05 1HR Replace Fire Extinghisher in Old English 6HRS Work on E-Coolers Band BLDG 1HR CK Old English E-Cooler were off 5/9 - 8	5/9/2005 5/9/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1809	Closed Work Orders 5-9-05 1HR Replacing Fire Extinghisher around BLDG 6HRS Work E-Coolers in Band BLDG 1HR CK Old English E- Cooler Not Running 5/9 - 8	5/10/2005 5/9/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1810	Closed Work Orders 5-10-05 2.5HRS Weed Control 2HRS WorK on E-Cooler in Grils gym 1.5 Ajust motor in AcademicBldg making Loud Noise 1HR Sofe Ball Field no power for Disco teck 1HR Cafeteria truch Compactor not Working Electical Problem 5/10 - 8	5/10/2005 5/10/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1625	Closed Work Orders 5-3-05 6HRS Work Order # 1067 Remove Cabines in Counseing Center 1HR Ajust door in Old English-N- Install door stop 1HR Help on High power Electical Short 5/3 - 2	5/3/2005 5/3/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1695	Closed Work Orders 1HR Install E-Cooler motor in Academic BLDG RM 312 2HRS Spread dirt in Business BLDG 1HR Work on E-Cooler in band RM 1HR Help weld chain in consalacion stand 1HR CK E-Cooler in RM 551 1HR Take gate door to grow yard 1HR Throw away old Cabinet in home ec 5/5 - 8	5/5/2005 5/5/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1720	Closed Work Orders 2HRS Work Order # 125077 Help Remove E- Cooler 6HRS Remove old plumbing drain -N-in stall new drain in RM 233 5/6 - 8	5/6/2005 5/6/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1721	Void 5-6-05	5/6/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1722	Closed Work Orders 5-6-05 1HR Install water flow in Cafeteria 2HRS Remove -N- Install Lav Faulset in Old English Bldg 1HR Patch Holes in wall north Bldg 4HRS Help install Ice Maker in RM 233 5/6 - 8	5/6/2005 5/6/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1030	Closed Work Orders 4-11-05 1HR work on toilet in main Bldg 1HR Remove Lav in Varsity Gym 6HR Clean E-Coolers in Academic Bldg Fixed water Leaks 4/11 - 8	4/11/2005 4/11/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1065	Closed Work Orders 4/11/05 1HR Weed Control 7HR Clean E-Coolers 4/11/05 - 8	4/12/2005 4/11/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
965	Closed Work Orders 4/7/05 2-cut weeds around bldg 2hrs Loading chair and taking them to Cafeteria 2hrs put up Fence 2hrsDrilling holesto Install urinal in Auto Shop 4/7 - 8	4/8/2005 4/7/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
967	Closed Work Orders 4/6/05 2HRS Replaces Fire Extinguishers w/o 125571 2HRS Remove toilet in main office and put new wax, screws 3HRS Remove urinal and drain pipes in Auto Shop 1HR Remove Exust Fan in day care center 4/6 - 8	4/8/2005 4/6/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1115	Closed Work Orders 4/13/05 8HRS Worked on E-Cooler 4/13 - 8	4/13/2005 4/13/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1141	Closed Work Orders 4/14/05 5.5HRS Work on E-Coolers in Varsity Gym 2.5HRS Removed tiles -N-baseborde in RM 611 4/14 - 8	4/14/2005 4/14/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1228	Closed Work Orders 4/15/05 1HR weed control 1HR unclough toilet in wood shop 3.5HR CK E- Coolers -N- Replaceing water pumps 2.5HRS Went to ppd to take paperwork -N- filled gas 4/15 - 8	4/18/2005 4/15/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1229	Closed Work Orders 4/18/05 2.5HRS weed Control 5.5HRS Removing E- Coolers Side Panels 4/18 - 8	4/18/2005 4/18/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
1268	Closed Work Orders 4/19/05 1HR Spray Amonia in RM 610 1HR Weed Control 1HR Fixed Desk in Attendance Office 5HRS Work on E-Coolers 4/19 -8	4/19/2005 4/19/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1297	Closed Work Orders 4/20/05 3HRS Installing orange Fens at burn arrea 5HRS worked in Cafeteria on E-Coolers Replaced 4 1\2in Ball Valves 4/20- 8	4/20/2005 4/20/2005 Medium	Joe Ontiveros Joe Ontiveros		Gadsden HS
892	Complete Need to replace compressor contactor in heatpumps in CAREEER CTR PTBLE,both are burned GAVE FERNIE 2 CONTACTOR 220 THAT WER NOT ENERGIZING, FERNIE WILL REPLACE.	4/6/2005 4/5/2005 Medium	Joe Ontiveros Jose Ambriz		Gadsden HS
240	Complete SMALL GATE BY THE CANAL NEEDS TO BE PAD LOCKED. replace padlock and welded to gate.	3/10/2005 4/6/2005 Medium	Juliet Parra Hector Lozoya	Athletic Field	Gadsden MS
117	Work In Progress Softball Field Concession Stand need to run power to it.	3/7/2005 Medium	Mario Apodaca Carlos Castillo	Athletic Field	Gadsden MS
2954	Work In Progress Please install new sprinkler by picnic area where sprinkler was broken and run a new line for additional sprinkler by the south east door by cafeteria for proper coverage of irrigation. As per Rudy need to route to Fred Appelzoller. - mkv	6/23/2005 Medium	Michael Munoz Fred Appelzoller		Gadsden MS GROUNDS
1240	Complete Athletics - Check a/c unit, it works for a short time then shuts off for atleast 1 or 2 hours then turns back on again for a short time. ck a/c	4/19/2005 4/19/2005 Medium	Margret Villalobos Rudy Arreola		Gadsden MS Terry Alvarado
1578	Complete Room 140 - Unit is not working properly. CHILLERS WERE OFF DUE TO POWER OUTAGE. RESET WATER PUMPS.	5/2/2005 5/3/2005 Medium	Margret Villalobos Jaime Gomez		Gadsden MS
1223	Complete Rudy could you please cut the weeds around the trash dumpster ans surrounding area. cut weeds	4/18/2005 4/19/2005 Medium	Michael Munoz Rudy Arreola	Cafeteria	Gadsden MS
2221	Work In Progress Weeds are growing out on the new tennis courts. Please cut and apply a none coloring chemical to prevent weeds from coming out thru concrete and damaging the courts. Also please cut the weeds around tennis court. THanks	5/23/2005 Medium	Michael Munoz Lorenzo Hernandez	Athletic Field	Gadsden MS
2470	Work In Progress GATE BY DITCH NEEDS TO BE REPLACED. IT'S ONLY LOCKED BY A SMALL CHAIN THAT CAN EASILY BE BROKEN (PER YOLIE JACQUEZ). ROUTE TO MANNY LOZOYA AS PER MIKE MUNOZ.	6/2/2005 Medium	Michael Munoz Hector Lozoya		Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1429	Complete B-Wing - Please paint new doors that were installed. PAINTED DOORS	4/26/2005 5/24/2005 Medium	Michael Munoz Rudy Arreola	Classroom	Gadsden MS
1432	Complete please cut weeds and clean up debris inside the fenced area at the boiler rooms. cut weeds and picked up trash.	4/26/2005 4/27/2005 Medium	Michael Munoz Rudy Arreola	Mechanical Room	Gadsden MS
713	Complete Gym- replace relief valve. As per Boiler Inspector. strapped down relief valve drain line	3/30/2005 4/13/2005 Medium	Michael Munoz Jaime Gomez		Gadsden MS
600	Work In Progress need new breakers to be installed on wwp. pulled old breakers and install new breakers	3/24/2005 4/7/2005 Medium	Michael Munoz Ricardo Jacquez		Gadsden MS
917	Closed Work Orders .50 Ck in with office. 1.0 Replaced ballast cleaned light fixture also new lamps. .50 Pulled out dead tree C-WING. 2.0 Cleaned up tagging in gym lobby. 4.0 Cutting weeds also mowed front of school and C-WING.	4/7/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
913	Closed Work Orders 4*01*05 .50 Ck in with office. 1.5 .125812. .50 Ck doors for Danny M. 1.5 Changed out 8 lamps in teachers lounge B-WING. 1.0 Cleaned up tumble weeds by fences. .50 .125792. .50 Helped set up for ROTC assembly. 2.0 .125814. 4/1 - 8	4/7/2005 4/1/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
914	Closed Work Orders 4*04*05 .50 Ck in with office. .50 Did paperwork. 5.0 Cleaned A/Cs and serviced in VOC BLDG. 2.0 .125813. 4/4 - 8	4/7/2005 4/4/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
915	Closed Work Orders 4*05*05 .50 Ck in with office. 3.5 Cleaned units in ANNEX BLDG changed filters. 1.0 Helped Juan throw trash from cafeteria. .50 Set up for assembly .50 .125796. .50 Toilet clogged in C-WING. 1.5 Ck glue traps in MAIN GYM AREA. 4/5 - 8	4/7/2005 4/5/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
756	Closed Work Orders 3*30*05 .50 Ck in with office. 2.0 Prunning palm trees and pulling weeds. 1.0 .125575. .50 Opened cabinet for Mr.Avalos. 2.5 Cutting weeds around VOC BLDG. 1.5 Cleaned up tagging in gym lobby.	4/1/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
757	Closed Work Orders 3*31*05 .50 Ck in with office. 2.0 .125605. 1.5 Adjusting more temp in classrooms. 1.0 Removed banner for main office and put up in C-WING. 1.5 Watering trees in front of school. .50 Clogged toilet girls rr. 1.0 Did paperwork.	4/1/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
779	Closed Work Orders 03/30/05 4-cleaning master cools on ch/ desert t. 1-serve restroom on room 128 3- painting new doors rooms 96 57 and54	4/1/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
851	Work In Progress Fence by the football feild is getting knocked down by students when they are running.	4/5/2005 Medium	Rudy Arreola Michael Munoz		Gadsden MS
852	Work In Progress We are having problems with mice in the gym area. Boys and girls lockerrooms and coaches offices. Faxed PO on 4/14/05 - mkv	4/5/2005 Medium	Rudy Arreola Margret Villalobos		Gadsden MS
1250	Complete All uninals and backing up in B-WING boys RR tried to unlcoged with urnial snake. uncloged urinals with mini roter	4/19/2005 4/21/2005 Medium	Rudy Arreola David Villalobos	Restroom (Boys)	Gadsden MS
1251	Closed Work Orders .50 Ck in with office. 2.0 Helped unclong unload displays for art festival. 1.5 Walk school with Mrs Q for ada standards. 2.0 Helping unload more displays. .50 Did paper work. 1.5 Cleaned up trash by baseball field. 4/13 -8	4/19/2005 4/13/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
1253	Closed Work Orders .50 Ck in with office. 1.0 Helped fred with toilets that were clogged 5.5 Helped unload more displays. 1.0 Turned on A/Cs for main gym. 4/14 -8	4/19/2005 4/24/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
1254	Closed Work Orders .50 Ck in with office. 3.5 Helped with setup in gym 4.0 Sevicig A/Cs in custodial and purchasing warehouse. 4/15 -8	4/19/2005 4/15/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1255	Closed Work Orders .50 Ck in with office. 4.5 Helped load art displays. 3.0 Servicing A/C Vocational bldg. 4/18-8	4/19/2005 4/18/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
1128	Complete Room 320 key was stuck in cylinder couldnt get key out.	4/14/2005 4/13/2005 Medium	Rudy Arreola Hector Lozoya		Gadsden MS
1101	Work In Progress We are going have a new student in a wheelchair the only concern is we need a walkway where the new fence was put up to connect to the side of the bandroom.	4/13/2005 Medium	Rudy Arreola Michael Munoz		Gadsden MS
1102	Work In Progress Some of the doors to the main entance have a little step the wheelchair may not be able to go up (Concerned the student may flip forward).	4/13/2005 Medium	Rudy Arreola Michael Munoz		Gadsden MS
1105	Work In Progress Sidewalk on eastside of annex bldg is to steep for wheelchair need sidewalk raised.	4/13/2005 Medium	Rudy Arreola Michael Munoz		Gadsden MS
1106	Closed Work Orders 4*11*05 .50 Ck in with office. 3.5 Was shoveling sand from sidewalks in courtyard. 4.0 Cleaning A/Cs in cafeteria. 4/11 - 8	4/13/2005 4/11/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
1107	Closed Work Orders 4*12*05 .50 Ck in with office. 1.0 Picking up trash around bus turnaround also courtyard. 6.5 Removing lockers from boys lockerroom. 4/12 - 8	4/13/2005 4/12/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
637	Closed Work Orders 3*21*05 8.0 Painting doors in main gym.	3/29/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
638	Closed Work Orders 3*22*05 4.0 Continued painting doors 4.0 Meeintg at STMS.	3/29/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
639	Closed Work Orders 3*23*05 4.0 touching up doors in main bldg. 1.5 countinued toucing up doors in main bldg. 2.5 Went home early JOB#.13807.	3/29/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
640	Closed Work Orders 3*24*05 8.0 Painting doors also touching up doors throughout campus.	3/29/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
641	Closed Work Orders 3*18*05 .50 Ck in with office. 1.0 Shutting down boilers. 2.5 Cutting weeds front of school and C-WING. 4.0 Mowing grass front of school and C-WING.	3/29/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
686	Work In Progress Some of the sprinklers in the front of campus are watering on to the street need to them adjusted or replaced.	3/30/2005 Medium	Rudy Arreola Lorenzo Hernandez		Gadsden MS
696	Closed Work Orders 3*29*05 .50 Did paperwork. .50 Ck in with office. 2.0 Shutting down boilers and doing change over. 1.0 Helped load tests to vehicle to deliver to GAC. 3.5 Cutting weeds around campus and picking up trash. .50 Adjusting temperatures in classrooms by computer.	3/30/2005 4/13/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
512	Closed Work Orders 3*15*05 .50 Ck boiler RMS. .50 .125548. 1.5 .125549. 1.0 Moved shelves from library to RM 203. .50 Reset breaker in RM163. 2.0 Helped juan clena out storage room 1.5 .125550. .50 Set mouse traps in MAIN GYM.	3/18/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
516	Closed Work Orders 3*17*05 .50 Ck in with office. 1.0 Ck boiler RMS. 2.5 Cutting weeds front parking lot shoveling sand from curb. 2.5 Mowed front of school and also C-wing. .50 Cleaned up mower and put away. 1.0 Checking glue traps in girls and boys locker RMS also gym lobby.	3/18/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
514	Closed Work Orders .50 Ck in with office. 1.0 Ck boiler RMs. 2.0 .125604. .50 Rm 161 replaced 8 lamps and cleaned both fixtures. 2.0 Picking up trash around bus turnaround. 2.0 Edging sidewalks with weed eater front of school.	3/18/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
288	Closed Work Orders 3*03*05 .50 Ck in with office. 1.0 Ck boiler RMs. 2.5 Painted lobby in VOC BLDG. 4.0 Cutting weeds also spraying for weeds.	3/11/2005 3/11/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
289	Closed Work Orders 3*04*05 .50 Ck in with office. 1.0 Ck boiler RMs. 2.5 Spraying for weeds around fencelines also sidewalks. 4.0 Cutting weeds bus turnaround also front of school.	3/11/2005 3/11/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
291	Closed Work Orders 3*07*05 .50 Ck in with office. 1.0 Ck boiler RMs. 5.0 Cutting out window in front office also installing frame around window opening. 1.5 Installed last of the papertowel and soap dispensers.	3/11/2005 3/11/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
292	Closed Work Orders 3*08*05 .50 Ck in with office. 1.0 Ck boiler RMs. 2.5 Moved Bleachers for baseball games. 4.0 Painted dugouts and cleaned up trash.	3/11/2005 3/11/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
293	Closed Work Orders 3*08*05 .50 Ck in with office. 1.0 Ck boiler RMs. 2.5 Moved Bleachers for baseball games. 4.0 Painted dugouts and cleaned up trash.	3/11/2005 3/11/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
294	Closed Work Orders 3*10*05 .50 Ck in with office. 1.0 Ck boiler RMs. 2.5 Mowed weeds by football field also picking up trash. 1.5 .125576. .50 .125559. 1.5 .125601.	3/11/2005 3/11/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
312	Duplicate Request Need to have a metal frame to cover for new window just installed. 407	3/11/2005 Medium	Rudy Arreola Danny Miranda	Office	Gadsden MS
284	Closed Work Orders 2*28*05 .50 Ck in with office. 1.0 Ck Boiler RMs. 1.5 Touching up RR in MAIN BLDG. JOB #11183	3/11/2005 3/11/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
285	Closed Work Orders .50 Ck in with office. 1.0 Ck boiler RMs. 2.0 Removing old roll up doors in front office. .50 Picked up tools and cleaned up counter. 2.0 Installing soap dispensers. 2.0 Cutting weeds around campus.	3/11/2005 3/11/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
286	Closed Work Orders .50 Ck with office. 1.0 Ck boiler RMs. 2.0 Painting front office. 4.0 Helped Enrique with outlets in front office. .50 Picked up cleaned up.	3/11/2005 3/11/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
279	Closed Work Orders 2*23*05 .50 Ck in with office. 1.0 Ck boiler RMs. 1.5 Ck checked rooms that leak we had some rain. 1.0 Girls lockerroom door is getting stuck. 4.0 Cutting weeds.	3/11/2005 3/11/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
280	Closed Work Orders 2*24*05 .50 Ck in with office. 1.0 Ck boiler RMs. 2.5 Cleaing boiler RMs. 1.5 Walked with inspector. 2.5 Installing papertowel dispensers.	3/11/2005 3/11/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
281	Closed Work Orders 2*24*05 .50 Ck in with office. 1.0 Ck boiler RMs. 2.5 Cleaing boiler RMs. 1.5 Walked with inspector. 2.5 Installing papertowel dispensers.	3/11/2005 3/11/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
282	Closed Work Orders .50 Ck in with office. 1.0 Ck boiler RMs. .50 Clogged urinal mens RR. 2.0 Replaced motor on boiler B-WING. 3.0 Cutting weeds around Voc BLDG and Band RM. 1.0 Toilet keeps Running.	3/11/2005 3/11/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
268	Duplicate Request Urinals are backing up water goes slow. same as 208	3/10/2005 Medium	Rudy Arreola Fred Appelzoller	Restroom (Boys)	Gadsden MS
269	Work In Progress Broken window need to be replaced this window was replaced about 1 week ago and its broken again. 31 x 76 As per Mike Munoz cove it with a board, this window was replace on 2/28/05.	3/10/2005 Medium	Rudy Arreola Ruben Ronquillo	Hallway/Corridor	Gadsden MS
375	Forwarded We are still having problems with water leaks in the main bldg and the annex bldg {PM WORKORDER#125606}	3/15/2005 Medium	Rudy Arreola		Gadsden MS
376	Closed Work Orders 3*11*05 .50 Ck in with office. 1.0 Did paperwork. 1.0 Ck boiler RMs. 1.5 Helped Fred with urnials in B-WING boys RRs. 2.5 Cutting weeds around C-WING. 1.5 .125602.	3/15/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
377	Closed Work Orders .50 Ck in with office. 1.5 125605 2.0 125606 4.0 SCHOOL WAS ON LOCK DOWN.	3/15/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
1334	Closed Work Orders 4*20*05 .50 Ck in with office. 1.0 Water fountain clogged. 2.5 Moved filing cabinets to their rooms. 4/20 - 4	4/22/2005 4/20/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1335	Closed Work Orders 4*21*05 .50 Ck in with office. 3.5 Serviced A/C Portable 500/501. 1.0 Showed Danny Miranda for doors that need to be replaced. 3.0 Cutting weeds around campus also picking up trash. 4/21 - 8	4/22/2005 4/21/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
1535	Complete We have 5 broken windows on the west side of the MAIN GYM that need to be replaced. broken window	4/29/2005 5/6/2005 Medium	Rudy Arreola Ruben Ronquillo		Gadsden MS
1538	Closed Work Orders 4*28*05 .50 Did paperwork. .50 Ck in with office. 1.5 Went to check damage done to gym annex 1.5 Picked up broken teachers desk and removed replaced. 1.5 Cleaning out storage RM. 2.5 .125842. 4/28 - 8	4/29/2005 4/28/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
1465	Work In Progress We need metal frames around windows we several threw out the campus in main bldg. The moulding is missing.	4/27/2005 Medium	Rudy Arreola Ruben Ronquillo		Gadsden MS
1478	Closed Work Orders 4*22*05 .50 Ck in with office. 1.5 Urinal was overflowing and running ANNEX BLDG. 2.0 Cleaned out storage and stored chairs. 1.0 .125832. 2.5 Clean up tagging boys RR ANNEX BLDG. .50 Put painting supplies away. 4/22 - 8	4/28/2005 4/22/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
1479	Closed Work Orders 4*25*05 .50 Ck in with office. 3.5 Eding sidewalks and curbs. 4.0 Cleaning A/Cs in cafeteria. 4/25 - 8	4/28/2005 4/25/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
1480	Closed Work Orders 4*26*05 .50 Ck in with office. 3.5 Starting up A/Cs in portables. 4.0 Removing planks from ramps in the junk pile and replacing on ramps. 4/26 - 8	4/28/2005 4/26/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
1481	Closed Work Orders 4*27*05 .50 Ck in with office. 1.0 Removing more planks from ramps. 2.5 Finished replacing planks on ramps. 4.0 Cutting weeds in both A and B boiler RMs. 4/27 - 8	4/28/2005 4/27/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1897	Complete Drains are backing up from the teachers lounge to the nurses offices tried drain cleaner and plunger also removed P Traps. UNCLOG DRAIN W/MINI ROOTER	5/12/2005 5/13/2005 Medium	Rudy Arreola Fred Appelzoller		Gadsden MS
1898	Complete Water fountain is clogged removed p-trap and plunged but water wont go down. UNCLOG DRAIN W/MINI ROOTER	5/12/2005 5/16/2005 Medium	Rudy Arreola Fred Appelzoller		Gadsden MS
1781	Complete Window was broken need new one installed 23x34 on southside of the main blds. broken window	5/10/2005 5/10/2005 Medium	Rudy Arreola Ruben Ronquillo		Gadsden MS
1814	Closed Work Orders 5*9*05 .50 Ck in with office. .50 Did paperwork. 1.0 Breaker tripped in cafeteria. .50 A/C not working in portable 500. 1.5 Pick up scraper at STHS. 4.0 1537 5/9 - 4	5/11/2005 5/9/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
1815	Closed Work Orders 5*10*05 .50 Did papework. .50 Ck in with office. 2.5 Moved boxes for teacher into storage title one material. .50 Taped off broken window. 1.0 Cleaned tagging in hallways and drinking fountain. .50 .126253. .50 Making copies and filled out vanalism report. 2.0 Assisted Lorenzo with A/C 5/10 - 8	5/11/2005 5/10/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
1670	Closed Work Orders 5*03*05 .50 Ck in with office. 2.5 B-WING Boys RR was tagged. 1.0 Picked up fence by football field. 1.5 Picked up trash by courtyard fenceline. 1.5 Repairing water line for water fountain in VOC BLDG. 1.0 Clogged toilets in Girls Lockerrooms . 5/3 - 8	5/5/2005 5/3/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
1671	Closed Work Orders 5*04*05 .50 Ck in with office. 4.0 Helped Danny O with WASHER/DRYER removing taking out. 3.5 .1605. 5/4 -4.5	5/5/2005 5/4/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1667	Closed Work Orders 4*29*05 .50 Ck in with office. 1.5 Sink was leaking boys RR. 2.0 Cutting weeds around bus turnaround. 3.0 Putting tables together and throwing away cardboard. 1.0 Cutting weeds in C-WING. 4/29-8	5/5/2005 4/29/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
1706	Closed Work Orders 5*05*05 .50 Did paperwork. .50 Ck in with office. 2.0 .126288. 1.0. Basketball court was having trouble going up (GREASED) 2.0 .126290. 1.5 .126245. .50 Door in bandroom was not closing. 5/5 - 8	5/6/2005 5/5/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
1710	Void Speaker was knocked off the south side of the gym facing the baseball feild need it replaced. This wo needs to be routed to the Technology Dept.	5/6/2005 Medium	Rudy Arreola	Athletic Field	Gadsden MS
1735	Closed Work Orders 5*06*05 .50 Did paperwork. .50 Ck in with office. 1.5 .126246. 4.0 Mowing grass front of school and C-WING. .50 Cooling pumps went down had to reset. .50 Clean mower and put away. 5/6 - 7.5	5/9/2005 5/6/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2143	Closed Work Orders 5*18*05 .50 Ck in with office. .50 Did paperwork. 5.0 Did inspections. .50 Did workorders. 1.5 .126292. 5/18 - 8	5/20/2005 5/18/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2144	Closed Work Orders 5*19*05 .50 Ck in with office. .50 A/C at purchasing warehouse not cooling. 4.5 Helped fred with drain clogged. 2.5 Throwing away stuff that was no good. 5/19 - 8	5/20/2005 5/19/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2145	Work In Progress Broken window in RM#303 in the VOC/BLDG.	5/20/2005 Medium	Rudy Arreola Ruben Ronquillo		Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2155	Complete We need to have the connections for the internet and phone lines. Electrical poles need to be removed. completed by Rudy as per EnriqueRemoved poles , and Technology removed communications lines.	5/20/2005 5/25/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2156	Duplicate Request We need 3 electrical poles removed from front office. To clear up space for counter. completed by Rudy as per Enrique 2155	5/20/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2194	Work In Progress Need some help for knocking down some walls to make an extra classroom in C-WING old Calixto's office.	5/23/2005 Medium	Rudy Arreola Danny Miranda		Gadsden MS
1926	Closed Work Orders 5*11*05 .50 Ck in with office. .50 Did paperwork. 3.0 Tocuhing up concrete pilars in gym. 2.0 .126241. 2.0 Attened assembly. 5/11 - 8	5/13/2005 5/11/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
1927	Closed Work Orders 5*12*05 .50 Ck in with office. .50 Did paperwork. 1.5 Setting up for assembly. 1.5 126284 3.0 Clogged up drains in teachers lounge and nurses office. 1.0 Cleaning up water spills from drains and floors. 5/12 - 8	5/13/2005 5/12/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2029	Closed Work Orders 5*13*05 .50 Ck in with office. .50 Did paperwork. 3.0 Assisted Lorenzo with A/C inventory. 2.0 Set up for assemblies in cafeteria. 2.0 Cleaning up tagging in hallways and bathrooms. 5/13 - 8	5/17/2005 5/13/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2030	Closed Work Orders 5*16*05 .50 Ck in with office. .50 Did paperwork. 3.5 Cutting weeds bus turn around. 2.0 Water was backing up in nurses office and teachers lounge. 1.5 Looking for valve that would shut off kitchen area. 5/16 - 8	5/17/2005 5/16/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2031	Work In Progress 2 A/C in main gym need to be replaced.	5/17/2005 Medium	Rudy Arreola Jaime Gomez		Gadsden MS
2063	Closed Work Orders 5*17*05 .50 Ck in with office. .50 Did paperwork. 3.0 Spraying for weeds also cutting weeds VOC/BLDG. 1.0 Did walk threw of school for tagging. 2.0 Cleaning out straing unit not working. 1.5 Toilet was running also cleaned up water. 5/17 - 8	5/18/2005 5/17/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2064	Complete Filing cabinet had to opened to get some files out due to teacher was out sick and the filing cabinet needs to be secured for summer. repair file cabinet lock	5/18/2005 5/19/2005 Medium	Rudy Arreola Hector Lozoya		Gadsden MS
2065	Forwarded (WARRANTY WORK ORDER) Coil in room 178 is not cooling need to have it checked out. Alfredo - This is out of warranty can you take care of item or call me - D. Boyd 6/6/05 David Boyd - As per Rudy, Jaime (HVACR) and John Find. - M. Munoz 6/6/05	5/18/2005 Medium	Rudy Arreola David Boyd		Gadsden MS
2339	Closed Work Orders 5*25*05 .50 Throwing trash in dumpsters. 7.5 Painting rooms in annex bldg. 5/25 - 8	5/27/2005 5/25/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2340	Closed Work Orders 5*26*05 4.0 Cutting weeds also mowed front of school. 2.5 Finished painting annex bldg. 1.5 Began painting rooms in B-WING. 5/26 - 8	5/27/2005 5/26/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2341	Work In Progress Light fixture on eastside of cafeteria was damaged and needs to be replaced.	5/27/2005 Medium	Rudy Arreola Enrique Sotelo		Gadsden MS
2342	Work In Progress Light fixture on the westside of the A-WING boiler room was broken needs to be replaced.	5/27/2005 Medium	Rudy Arreola Enrique Sotelo		Gadsden MS
2253	Forwarded We need to replace the carpet in main office with tile the carpet is worn out and there are some runs. Also there are some patches were the old furniture used to be. Tile under carpet has asbestos. When carpet is removed tile will follow. Need to do an abatement before floor can be done. Route to Const. Dept - As per Mike Munoz 6/14/05	5/24/2005 Medium	Rudy Arreola David Boyd		Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2256	Closed Work Orders 5*23*05 .50 Autoshop A/C not working. 3.0 Unclogging the drain in nurses office also teachers. .50 talked to Mr.Hamel about summer projects. 3.0 Walking threw school to see what rooms are really bad as far as painting. 1.0 Doing paperwork. 5/23 - 8	5/24/2005 5/23/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2257	Closed Work Orders 5*23*05 .50 Ck in with office. 7.5 .1429. 5/23 - .5	5/24/2005 5/23/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2258	Closed Work Orders 5*24*05 7.5 .1429. 1.5 Helped Danny Miranda with core for new doors. 5/24 - 1.5	5/24/2005 5/24/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2259	Work In Progress Light fixture was broken on the southside of boiler room.	5/24/2005 Medium	Rudy Arreola Enrique Sotelo		Gadsden MS
2260	Work In Progress Light fixture was broken the west side of the gym.	5/24/2005 Medium	Rudy Arreola Enrique Sotelo		Gadsden MS
2242	Work In Progress MAIN BANDROOM. We need to remove 2 steps in bandroom to make more room.	5/24/2005 Medium	Rudy Arreola Michael Munoz		Gadsden MS
2243	Forwarded WARRANTY WORK ORDER A/C not cooling just blowing hot air need to have them checked out.	5/24/2005 Medium	Rudy Arreola David Boyd		Gadsden MS
2244	Work In Progress Room 140 handle was broken need to have it replaced.	5/24/2005 Medium	Rudy Arreola Hector Lozoya		Gadsden MS
2401	Complete Door handles on both A/B wing boiler RMs need to be replaced they have tried to get into them one handle is missing. replace 2 handles	6/1/2005 6/7/2005 Medium	Rudy Arreola Hector Lozoya		Gadsden MS
2420	Closed Work Orders 5*31*05 .50 Did paperwork. 3.5 Removing staples and papers from walls also throwing away. 4.0 Continued painting rooms in B-WING. 5/31 - 8	6/1/2005 5/31/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2418	Closed Work Orders 5*27*05 .50 Did paperwork. 7.5 Painting rooms in B-WING 5/27 - 8	6/1/2005 5/27/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2515	Void Wires are hanging off the side othe bldg and from the pole in old central office on the main entrance. Need wires secured. THIS WORK ORDER IS FOR TECHNOLOGY - AS PER ENRIQUE SOTELO. WO#126619	6/6/2005 Medium	Rudy Arreola Enrique Sotelo		Gadsden MS
2516	Duplicate Request Wires are hanging off the side othe bldg and from the pole in old central office on the main entrance. Need wires secured.	6/6/2005 Medium	Rudy Arreola Enrique Sotelo		Gadsden MS
2517	Closed Work Orders 6*01*05 7.5 Painting room in B-WING also removing staples and thumbtacks from walls. .50 Did paperwork. 6/1- 8	6/6/2005 6/1/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2521	Closed Work Orders 6*03*05 2.0 Picking up trash in courtyard. 2.0 Moved out storage bins from bandroom. 3.0 Continued painting hallways in B-WING. 1.0 Walked around with Rim Bert to show him where floor is warped. 6/3 - 8	6/6/2005 6/3/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2519	Closed Work Orders 4.0 Cutting weeds and spraying weeds bus turnaround. 4.0 Continued painting rooms in B-WING. 6/3 - 8	6/6/2005 6/3/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2719	Closed Work Orders 6*10*05 1.0 126587. .50 126549. 1.5 126588. .50 A/C not cooling in Room 157. 2.5 Was at meeting a custodial warehouse. 2.0 Started knocking down wall in Annex bldg. 6/10 - 8	6/13/2005 6/10/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2720	Work In Progress (((WARRANTY WORK ORDER))) The coils in RM#157/158 not cooling at all they came to check but still doing the same thing.	6/13/2005 Medium	Rudy Arreola David Boyd		Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2717	Closed Work Orders 6*08*05 1.5 .126542. 1.0 .126586. 1.5 Cleaning up front of school cutting weeds and picking up trash. 4.0 Painting hallways in B-WING. 6/8 - 8	6/13/2005 6/8/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2784	Work In Progress We need to have the sprinklers in front of school adjusted especially in the B-WING.	6/15/2005 Medium	Rudy Arreola Lorenzo Hernandez	Parking Lot	Gadsden MS
2785	Closed Work Orders 6*13*05 .50 Picked up paint with Ruben. .50 Did paperwork. .50 .126565. 2.0 Finished removing studs from walls the were removed in ANNEX BLDG-> 3.5 Mowed grass front of school and behing annex bldg. 1.0 Picking up trash around campus. 6/13 - 8	6/15/2005 6/13/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2560	Closed Work Orders 6*06*05 .50 Did paperwork. 7.5 Moving lockers from Anthony Elem to GMS. 6/6 - 8	6/7/2005 6/6/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2561	Forwarded (((WARRANTY WORK ORDER))) All Exhaust fans on Roof not working they all turned off.	6/7/2005 Medium	Rudy Arreola David Boyd		Gadsden MS
2618	Complete Wet'n'Dry is not working will need a loaner while the other one gets repaired. Thank you Juan Acosta REPLACED PARTS (ISSUED THRU ACT 1000) AS PER JIMMY	6/8/2005 6/9/2005 Medium	Rudy Arreola Jimmy Carbajal		Gadsden MS
2622	Closed Work Orders 6*07*05 .50 Did paperwork. 2.0 Cutting weeds bus turnaround. 1.5 Helped Manny with doors. 3.0 Mowing the front part of the school and C- WING. 1.0 Watered trees by the vocational Bldg. 6/7 - 8	6/8/2005 6/7/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
3000	Work In Progress We need change locks due to the floor getting a new coat of varnish and so one can go in.	6/27/2005 Medium	Rudy Arreola Hector Lozoya	Gym	Gadsden MS
3057	Closed Work Orders 6*24*05 7.0 Painting Rooms in A-WING. 1.0 Did paperwork. 6/24 - 8	6/29/2005 6/24/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
3058	Closed Work Orders 6*27*05 2.0 Cleaned up storage morgan bldg. 4.5 Mowed front of school and C-WING. 1.5 Throwing broken furniture and tables away in junk pile. 6/17 - 8	6/29/2005 6/17/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
3059	Closed Work Orders 6*28*05 .50 Set up sprinkler front of school. 6.0 Painting the last of the new doors that were installed RM 152 door had to sanded and repainted the teacher paint this door. 1.0 Cleaned up and put paints and tools away. .50 Did paperwork. 6/28 - 8	6/29/2005 6/28/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2974	Closed Work Orders 6*21*05 2.0 Cutting weeds around campus. .50 Removed A/C pads that were not being used Retured to Ruben R. 1.5 Pruined trees by ANNEX BLDG. 4.0 Painting new doors and metal frames that were just installed. 6/21 - 8	6/24/2005 6/21/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2975	Closed Work Orders 6*22*05 .50 Set up sprinklerls front of campus. 7.0 Painting doors that were just installed. .50 Capped off 1in irrigation line. 6/22 - 8	6/24/2005 6/22/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2976	Closed Work Orders 6*23*05 .50 Set up sprinkler front of school. 2.0 .2885. 1.5 .2884. 2.0 .2886. 1.0 .2887. 1.0 Did paperwork. 6/23 - 1.5	6/24/2005 6/23/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2907	Work In Progress Portable 501 they installed new doors and when they were banging on the frame the half of the ceiling came down including electrical and communication lines and light fixtures.	6/21/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2908	Closed Work Orders 6*20*05 .50 Did paperwork. 3.0 Painted new doors in portable 501. 4.5 Began painting new doors and frames in annex bldg. 6/20-8	6/21/2005 6/20/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2866	Closed Work Orders 6*17*05 .50 A/C leaking water at warehouse. 1.5 .126584. 1.0 Showing contractor the rooms that not cooling. 1.0 Meeting with Mike M. 2.5 Replaced exhaust fan in girls RR GYM LOBBY. .50 Did paperwork. 6/17-7	6/20/2005 6/17/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2854	Closed Work Orders 6*14*05 4.0 Cutting weeds around campus. 4.0 Touching up RMs. in B-WING. 6/14 - 8	6/17/2005 6/14/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2855	Closed Work Orders 6*15*05 .50 Talked to Mr. Hamel about DEOM. .50 Checked out toilet that was not working water shut off. 7.0 Countinued painting RMs in B-WING. 6/15 - 8	6/17/2005 6/15/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
2856	Closed Work Orders 6*16*05 2.0 Watering trees in parking lot also behind school. 2.0 Mowing filing cabinets to cafeteria. 4.0 Touching up RMS in VOC BLDG. 6/16 - 8	6/17/2005 6/16/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
1700	Work In Progress NEED OUTLETS INSTALLED FOR WASHER AND DRYER, 120V AND 230V.	5/5/2005 Medium	Danny Orozco Enrique Sotelo		Gadsden MS
815	Complete RANGE OVEN NOT WORKING. REPLACED BAD THERMOCOUPLE	4/4/2005 4/1/2005 Medium	Danny Orozco Danny Orozco	Cafeteria	Gadsden MS
1783	Complete repair broken file draw lock in a SPED file #99-0123 room 132 repair file cabinet key	5/10/2005 5/19/2005 Medium	Dana Hamel Hector Lozoya	Classroom	Gadsden MS
1433	Complete AIR CONDITIONERS NEED TO BE TURNED ON FOR ALL FOUR PORTABLES. turned on a/c's	4/26/2005 4/27/2005 Medium	Dana Hamel Rudy Arreola	Classroom	Gadsden MS
1463	Complete heater keeps going out in office replaced damper motor.	4/27/2005 4/28/2005 Medium	Dana Hamel Jaime Gomez	Cafeteria	Gadsden MS
2431	Complete Need a new "w" master. Mr. hamel gave his key to the district court people make a duplicate W Master	6/2/2005 6/6/2005 Medium	Dana Hamel Hector Lozoya		Gadsden MS
207	Complete need both doors on portable #500 repaired REMOVE OLD DOOR REPLACE WITH NEW DOORS.	3/9/2005 5/26/2005 Medium	Dana Hamel Danny Miranda	Classroom	Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
208	Complete B wing boys restrrom urinals are plugged unclogged urinals in B-Wing with mini rooter.	3/9/2005 3/11/2005 Medium	Dana Hamel Fred Appelzoller	Restroom (Boys)	Gadsden MS
154	Complete replace light in hallway 1360 wo replaced bulb and cleaned fixture.	3/8/2005 3/3/2005 Medium	Dana Hamel Rudy Arreola	Hallway/Corridor	Gadsden MS
407	Complete Complete the molding/trim around the new window in the rear office A wing PUT IN NEW DOOR FRAME FOR WINDOW.	3/15/2005 5/24/2005 Medium	Dana Hamel Rudy Arreola	Office	Gadsden MS
380	Void We have a problem with the fire alarm signal is from the band room #9	3/15/2005 Medium	Dana Hamel	Choral	Gadsden MS
657	Complete the door is cracked/broken. The teacher must lift the door to close it properly. Room 112 B Wing put in new door, frame and hardware	3/29/2005 5/24/2005 Medium	Dana Hamel Danny Miranda	Classroom	Gadsden MS
1064	Work In Progress Would like to take out an office wall and turn the old tech offices into one classroom. ROUTED BACK TO RUDY AS PER MIKE MUNOZ 5/31/05 - MKV	4/12/2005 Medium	Dana Hamel Rudy Arreola	Office	Gadsden MS
1278	Complete We need a dead bolt and a lock for the storage room across from the library. As per NM PED request. Please this needs to be done today. MR. HAMEL CALLED IN, CONTACTED MIKE MUNOZ. MANNY LOZOYA WILL BE THERE WITHIN 5 MINUTES. 12:35 PM/ M. SITTERS - Installed deadbolt at storage and replace lock at file cabinet in main office. - ML	4/20/2005 4/21/2005 Medium	Dana Hamel Hector Lozoya	Office	Gadsden MS
1184	Void hook up a bell system to the phone so the kitchen workers can hear the phone Need to route work order to Technology - Need to submit thru Sitenet. - Thanks mkv	4/15/2005 Medium	Dana Hamel	Office	Gadsden MS
1185	Complete The newly painted vocational building has been tagged SE corner. Clean ASAP painted	4/15/2005 4/18/2005 Medium	Dana Hamel Rudy Arreola		Gadsden MS
1186	Duplicate Request repair the outside door latch to the baseball field, won'y lock	4/15/2005 Medium	Dana Hamel	Hallway/Corridor	Gadsden MS
2928	Work In Progress repair and paint stairway up to equipment room, patch all walls and paint the area and closets for football. This money came into district as restitution by one student \$245.00	6/21/2005 Medium	Dana Hamel Rudy Arreola	Stairway	Gadsden MS
2929	Work In Progress Replace door into storage area and repair the frame to keep students from upstairs area	6/21/2005 Medium	Dana Hamel Danny Miranda	Stairway	Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2931	Work In Progress repair the stairs up into the choir class. They are falling away from the framing and you can see down into the crawl space. Unsafe condition. Replace the stairs if necessary	6/21/2005 Medium	Dana Hamel Rudy Arreola	Classroom	Gadsden MS
2926	Work In Progress Please paint all ceilings in all restrooms. I would prefer black to reduce the tagging. Also touch up all restrooms with black to cover the areas they have scratched out taggings.	6/21/2005 Medium	Dana Hamel Rudy Arreola	Restroom (Boys)	Gadsden MS
2881	Work In Progress fix exhaust fan in science room 150	6/20/2005 Medium	Dana Hamel Rudy Arreola	Classroom	Gadsden MS
2882	Work In Progress assemble file cabinet, drill flag pole into wall, hang fireextinguishers, shampoo carpets all in Library W.O. CALLS FOR CARPETS IN LIBRARY TO BE SHAMPOOED. FORWARDED INFORMATION TO JUAN ACOSTA AND HE WILL BE TAKING CARE OF IT. 6/21/05. MS.	6/20/2005 Medium	Dana Hamel Rudy Arreola		Gadsden MS
2883	Work In Progress move chalk boards up from present location, too low	6/20/2005 Medium	Dana Hamel Rudy Arreola	Classroom	Gadsden MS
2884	Complete repair window frames in classroom #112 cleaned webs and dirt applied silicone bronze color also clear to seal where dirt was coming in seal frames.	6/20/2005 6/23/2005 Medium	Dana Hamel Rudy Arreola	Classroom	Gadsden MS
2885	Work In Progress repair holes in wall roomc-207, paint	6/20/2005 Medium	Dana Hamel Rudy Arreola	Computer Lab	Gadsden MS
2886	Complete paint classroom room 188 These rooms just needed to be touched up also replace 8 lamps that were out.	6/20/2005 6/23/2005 Medium	Dana Hamel Rudy Arreola	Classroom	Gadsden MS
2887	Complete replace ceiling tile room 406 annex removed stained ceiling tiles total of 6. this room leaks really bad and has for the past 20 years.	6/20/2005 6/23/2005 Medium	Dana Hamel Rudy Arreola		Gadsden MS
2888	Work In Progress repair holes in ceiling by air conditioner, needs 4 new window blinds, secure fuse box, secure air conditioner switch, repair entry door to class and last can not use the high switch on air conditioner because it makes too much noise.	6/20/2005 Medium	Dana Hamel Rudy Arreola	Portables	Gadsden MS
2889	Work In Progress repair all the interior doors, jams and latches. Outside doors are not closing unless lifted by handles	6/20/2005 Medium	Dana Hamel Danny Miranda	Gym	Gadsden MS
2890	Work In Progress paint room 204 c to a single color	6/20/2005 Medium	Dana Hamel Rudy Arreola	Classroom	Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2572	Work In Progress need locks on desk draws and other security measures to ensure that data is not compromised. Gloria Hernandez office and Terry Villalobos data entry clerks in C wing. ASAP	6/7/2005 Medium	Dana Hamel Hector Lozoya	Office	Gadsden MS
2787	Void With the newly installed door frames, the threshold need to be repair in room 156 "D" level SPED Contractor installed the new threshold.	6/15/2005 Medium	Dana Hamel Rudy Arreola	Classroom	Gadsden MS
2788	Duplicate Request Complete the removal of the wall to make a full classroom out of technology offices SAME AS 1064	6/15/2005 Medium	Dana Hamel Rudy Arreola	Classroom	Gadsden MS
2789	Work In Progress check to ensure that the flushes are working in lobby bathroom. If they are, then request that custodial clean, clean, and clean again this area (stinks)	6/15/2005 Medium	Dana Hamel Fred Appenzoller	Restroom (Boys)	Gadsden MS
2790	Work In Progress Start to repaint all outside grey to cover up tagging. Request that outside stucco walls be repainted at least the front of school	6/15/2005 Medium	Dana Hamel Rudy Arreola		Gadsden MS
266	Work In Progress washing machine out of order Teresa Portillo - SNP Manager (505) 882-2824	3/10/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Gadsden MS
2763	Complete need to paint 7 new doors Painted all new doors in rm 152 tehacher had painted the door had to sand it down and paint door and frame.	6/14/2005 6/29/2005 Medium	Danny Miranda Rudy Arreola		Gadsden MS
792	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. COMPLETED AS PER JUAN ACOSTA	4/1/2005 4/27/2005 Medium	Aida Salcedo Juan Acosta		Gadsden MS
2708	Work In Progress please repair and tighten existing fence behind mobile home occupant.	6/10/2005 Medium	Michael Munoz	Football Field	Gadsden MS
2497	Complete NEED TO PICK UP SHARPS CONTAINERS FROM NURCES OFFICE ON NEXT TRIP OVERTHERE. PICKED SHARPS CONTAINER FROM NURSE AS PER JIMMY	6/3/2005 6/7/2005 Medium			Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2219	Complete The campus does look like it is getting watered, please run a trial and check timer programs. Also need to cut the grass and weed eat before applying chemical. Please do not apply chemical on walls they are yellow. The grass should be cut on a weekly bases. AB&C wing checked timers and sprinklers there are some that needed to be adjusted.	5/23/2005 5/23/2005 High	Rudy Arreola		Gadsden MS
1595	Complete grass is not getting watered,please check timer for proper operation. Also the same on the main campus. CK TIMERS	5/3/2005 5/3/2005 Medium	Rudy Arreola		Gadsden MS
1602	Complete please cut weeds and grass that are in parking lot, please remove dead trees also. cutting weeds and remove dead tree.	5/3/2005 5/4/2005 Medium	Rudy Arreola		Gadsden MS
1537	Complete please cut weeds and in and around bus turn around. mowed down areas that could do, Speedy is going to help w/tractor.	4/29/2005 5/10/2005 Medium	Rudy Arreola		Gadsden MS
1284	Complete BOYS & GILRS LOCKER ROOMS ARE FLOODING, AFTER TOILETS ARE FLUSHED. CONTACTED DAVID VILLALOBOS AS PER MIKE MUNOZ.	4/20/2005 4/20/2005 Medium	David Villalobos		Gadsden MS
159	Complete Main Bldg Boys RR - Lock is not opening (Boys stuck in restroom). 1357 - replace lockset and rekey cylinder.	3/8/2005 4/6/2005 Medium	Hector Lozoya	Restroom (Boys)	Gadsden MS
758	Complete DISHWASHER - WHEN TURNING ON WATER LEAKS ON THE BACK OF THE DISHWASHER AND NOT IN THE INSIDE OF THE WASHER. TERRY PORTILLO SNP MGR 882-4824 removed and replaced vacuum bracket kit.	4/1/2005 4/5/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	Gadsden MS
354	Work In Progress Need to installing emerg. lights in hallways and restrooms girls and boys as per pm 125602.	3/14/2005 Medium	Rudy Arreola Enrique Sotelo		Gadsden MS
326	Work In Progress We are having a problem with students in the cafeteria after hours we need to have dead bolts installed so we can secure cafeteria.	3/11/2005 Medium	Rudy Arreola Hector Lozoya	Cafeteria	Gadsden MS
327	Complete We have to toilets that the water drains real slow allready tried toilet auger and still going slow. They are wall hung toilets. remove w/c and ran snake thru drain , and re-installed w/c.	3/11/2005 3/16/2005 Medium	Rudy Arreola Fred Appelzoller	Restroom (Girls)	Gadsden MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
127	Complete Need to cut weeds, mow grass front of campus and patio area, also around bus turnaround, football field and surrounding areas. Apply chemical on weeds.(Need to schedule grounds work on a weekly basis) 1348 wo Spray and cut weeds, mow grass and also tried to drag.	3/7/2005 3/4/2005 Medium	Rudy Arreola Rudy Arreola		Gadsden MS
1520	Complete please pick-up and secure fence that is on the south side of the footballfield behind mobile home. PICKED UP FENCE	4/29/2005 5/3/2005 Medium	Michael Munoz Rudy Arreola	Athletic Field	Gadsden MS
1593	Complete WATER TANK - REPLACE SWITCH FOR COMPRESSOR. REWIRED PRESS. SWITCH ON LIFT ONLY	5/3/2005 5/10/2005 Medium	Ricardo Jacquez Ricardo Jacquez		Gadsden MS
930	Complete Treatment Plant - replace blower motor #1. PULL OUT BURNED MOTOR NEW MOTOR	4/7/2005 4/6/2005 Medium	Ricardo Jacquez Ricardo Jacquez		Gadsden MS
1819	Complete ATHLETIC DEPT - NEED AN EXTRA KEY WA152 FOR ATHLETIC OFFICE.	5/11/2005 5/17/2005 Medium	TERRY ALVARADO Hector Lozoya		Gadsden MS
1521	Complete Water Tank - Replace switch for compressor. REPAIR PROBLEM ON CTRL OF COMPRESSOR TO WATER TANK.	4/29/2005 4/28/2005 Medium	Ricardo Jacquez Enrique Sotelo		Gadsden MS
891	Complete 4/6/05 need ac belts for master cool ax 96 hvac gave pancho 2 belts a96	4/6/2005 4/12/2005 Medium	Frank Lara Jaime Gomez		La Mesa ES
905	Closed Work Orders 4/6/05 1 check in check boiler 3 servicing ac units 2 went to san miquel to replace leaking water lines 2 unclogged sink main building by restroom 4/6 - 8	4/6/2005 4/6/2005 Medium	Frank Lara Frank Lara		La Mesa ES
938	Closed Work Orders 4/7/05 1 check in check boiler 3 soldering copper lines for ac units 2 cutting branches by bus stop 1 repaired sprinkler in front yard 1 install belts for ac units 4/7 - 8	4/7/2005 4/7/2005 Medium	Frank Lara Frank Lara		La Mesa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
706	Closed Work Orders 3/30/05 1 check in check boiler 2 using weedeater in front main building 1 cutting branches by bus stop 2 using mower back of main building 1 fixed black board in caft area 1 unclogged sink in caft area	3/30/2005 Medium	Frank Lara Frank Lara		La Mesa ES
751	Closed Work Orders 3/31/05 1 check in check boiler 3 went to santa teresa high school to get bleachers 2 putting roundup in fence line 1 using weedeater by basketball courts 1 cleaning pump house	3/31/2005 Medium	Frank Lara Frank Lara		La Mesa ES
809	Closed Work Orders 4/1/05 1 check in check boiler 3 soldering copper lines for ac units 4 working on ac units service them	4/1/2005 4/1/2005 Medium	Frank Lara Frank Lara		La Mesa ES
825	Closed Work Orders 4/4/05 1 check in check boiler 3 servicing ac units 2 mowing behind building 2 using weedeater in campus 4/4 - 8	4/4/2005 4/4/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1261	Closed Work Orders 4/19/05 1 check in check boiler 6 went to mesquite to assist roma on ac units 1 install window screen back ofr building 4/19 - 8	4/19/2005 4/19/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1292	Closed Work Orders 4/20/05 1 check in check boiler 3 went to assist roma on ac units 2 using weedeater in fence line 1 repaired swing behind main building 1 cutting branches by bus stop 4/20 -8	4/20/2005 4/20/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1156	Closed Work Orders 4/14/05 1 check in check boiler 2 went to gadsden middle school to take boards for art exhibit 1 replace outlet for copier machine 2 using weedeater in campus 2 putting roundup behind main building 4/14 - 8	4/14/2005 4/14/2005 Medium	Frank Lara Frank Lara		La Mesa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1226	Closed Work Orders 4/18/05 1 check in check boiler 1 replace sprinkler in front of main building 2 went to gasden middle school to get boards from art exhibit 2 using mower in campus 2 servicing ac unit in rm 29 4/18 - 8	4/18/2005 4/18/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1197	Closed Work Orders 4/15/05 1 check in check boiler 2 went to shop to get material and service truck install map rack rm 23 2 using roundup in campus 1 unclogged sink in rm 4 1 put sprinklers in playground 4/15 - 7	4/15/2005 4/15/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1114	Closed Work Orders 4/13/05 1 check in check boiler 2 went to san miguel to service ac units caft area 1 replace ac motor rm 25 2 using weedeater in fence line 2 putting roundup in fence line 4/13 - 8	4/13/2005 4/13/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1109	Complete Need to replace ground receptacles main building for copier machine.	4/13/2005 4/14/2005 Medium	Frank Lara Enrique Sotelo		La Mesa ES
1069	Closed Work Orders 4/12/05 1 check in check boiler 1 replace ac belt main building 1 watering front yard 4 using mower in campus 1 cleaning building mechanic storage 4/12 - 8	4/12/2005 4/12/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1031	Closed Work Orders 4/11/05 1 check in check boiler 3 soldering copper lines in barracks 1 unclogging sink in kitchen area 1 replace float on ac unit rm 25 2 using weedeater in campus 4/11 - 8	4/11/2005 4/11/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1013	Complete 4/11/05 need to repair water lines at barracks need snake to unclogged sink in kitchen area SILVER SOLDER WATER LINE AND UNCLOGGED LAV IN KITCHEN.	4/11/2005 4/11/2005 Medium	Frank Lara Fred Appenzoller		La Mesa ES
1014	Complete 4/11/05 water leak in heating system repaired leak in principal's office	4/11/2005 4/11/2005 Medium	Frank Lara Jaime Gomez		La Mesa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
994	Closed Work Orders 4/8/05 1 check in check boiler 7 moving bleachers to school sites from gasd high school 4/8 - 8	4/8/2005 4/8/2005 Medium	Frank Lara Frank Lara		La Mesa ES
335	Closed Work Orders 3/11/05 1 check in check boiler 1 repaired swing in playground 2 using weedeater in playground 2 replace door closer and door hinge rm 17 2 painting wall in restroom special needs	3/11/2005 Medium	Frank Lara Frank Lara		La Mesa ES
368	Closed Work Orders 3/14/05 1 check in check boiler 1 unclogged sink in kitchen 2 mowing using weedeater in campus 3 using weedeater and mowing in campus 1 using blower in all sidewalks	3/14/2005 3/14/2005 Medium	Frank Lara Margret Villalobos		La Mesa ES
372	Void 3/14/05	3/15/2005 Medium	Frank Lara Frank Lara		La Mesa ES
373	Closed Work Orders 3/14/05 1 check in check boiler 2 mowing and using weedeater in campus 3 using weedeater and mowing in campus 1 using blower in all sidewalks	3/15/2005 Medium	Frank Lara Frank Lara		La Mesa ES
271	Closed Work Orders 3/10/05 1 check in check boiler 3 using weedeater in fence line 2 using mower back of building 2 soldering copper lines for ac units	3/10/2005 3/10/2005 Medium	Frank Lara Frank Lara		La Mesa ES
257	Closed Work Orders 3/4/05 1 check in check boiler 1 install office chairs for confrence rm 2 went to service truck get material 2 using weedeater in campus 1 replace screen window main building 1 replace florescent lamps in caft area	3/10/2005 3/10/2005 Medium	Frank Lara Frank Lara		La Mesa ES
258	Closed Work Orders 3/7/05 1 check in check boiler 1 fixed water fountain main building 2 using weedeater in campus 2 using mower in campus 1 installing axhaust fan caft area 1 replaced door closer in kitchen	3/10/2005 3/10/2005 Medium	Frank Lara Frank Lara		La Mesa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
259	Complete need to replace door knob nurses rm replace privacy lock	3/10/2005 3/14/2005 Medium	Frank Lara Hector Lozoya		La Mesa ES
260	Complete need to make key for nurse got lost rekey core F28 to F52 and duplicate 3 keys.	3/10/2005 3/14/2005 Medium	Frank Lara Hector Lozoya		La Mesa ES
255	Closed Work Orders 3/3/05 1 check in check boiler 2 using weedeater in campus 1 using weedeater in fence line 2 unclogged sink rm1 2 trimming bushes in front of main building	3/10/2005 3/10/2005 Medium	Frank Lara Frank Lara		La Mesa ES
250	Closed Work Orders 2/28/05 1 check in check boiler 2 installing new office chairs 1 using weedeater in campus 2 unclogged sink in kitchen 1 using weedeater in campus 1 install map rack rm16	3/10/2005 3/10/2005 Medium	Frank Lara Frank Lara		La Mesa ES
251	Duplicate Request 2/28/05 1 check in check boiler 2 installing new office chairs 1 using weedeater in campus 2 unclogged sink in kitchen 1 using weedeater in campus 1 install map rack rm16	3/10/2005 3/10/2005 Medium	Frank Lara Frank Lara		La Mesa ES
252	Closed Work Orders 3/1/05 1 check in check boiler 2 install new office chairs 2 mowing in campus 2 mowing in campus 2 using weedeater in campus	3/10/2005 3/10/2005 Medium	Frank Lara Frank Lara		La Mesa ES
253	Closed Work Orders 3/2/05 1 check in check boiler 1 fixed swing in playground replace chain 2 using weedeater in campus 2 putting roundup in front of main building 1 cleaning pump house 1 service water fountain main building	3/10/2005 3/10/2005 Medium	Frank Lara Frank Lara		La Mesa ES
503	Closed Work Orders 3/17/05 1 check in check boiler 2 using weedeater in campus 1 moved furniture to parent center 2 using weedeater in campus 1 replace flush valve main building 1 painting shelve for rm 22	3/17/2005 Medium	Frank Lara Frank Lara		La Mesa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
365	Closed Work Orders 3/14/05 1 check in check boiler 1 unclogged sink in kitchen 2 mowing using weedeater in campus 3 using weedeater and mowing in campus 1 using blower in all sidewalks	3/14/2005 3/14/2005 Medium	Frank Lara Margret Villalobos		La Mesa ES
422	Closed Work Orders 3/15/05 1 check in check boiler 1 service heater in rm a1 2 unclogged sink in kitchen area 1 went to mesquite to turn boiler on 1 install kidney table for parent center	3/15/2005 Medium	Frank Lara Frank Lara		La Mesa ES
599	Closed Work Orders 3/23/05 1 check in check boiler 2 using mower in campus 1 repaired swing in playground 4 started to service ac units	3/24/2005 Medium	Frank Lara Frank Lara		La Mesa ES
552	Closed Work Orders 3/18/05 1 check in check boiler 1 install mirror in boys restroom caft area 2 went to service truck get material 2 digging out sprinklers in playground 1 used blower in sidewalks in campus 1 install paper towel despencer main building	3/18/2005 Medium	Frank Lara Frank Lara		La Mesa ES
562	Closed Work Orders 3/21/05 1 check in check boiler 1 put sprinklers in playground 2 using weedeater in campus 3 using weedeater in campus 1 started putting roundup in fence line	3/21/2005 Medium	Frank Lara Frank Lara		La Mesa ES
577	Closed Work Orders 3/22/05 1 check in check boiler 3 painting wall in restroom caft area 4 went to meeting in santa teresa middle school	3/23/2005 Medium	Frank Lara Frank Lara		La Mesa ES
627	Closed Work Orders 3/24/05 1 check in check boiler putting sprinklers in campus 1 2 working on my ac units 4 working On ac units	3/24/2005 Medium	Frank Lara Frank Lara		La Mesa ES
671	Closed Work Orders 3/29/05 1 check in check boiler 7 went to high school to move bleachers	3/29/2005 Medium	Frank Lara Frank Lara		La Mesa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2514	Closed Work Orders 6/3/05 1 check in check boiler 3 went to san miquel to set portable 2 put fence up by road 2 moving furniture to barracks from main building 6/3 - 8	6/6/2005 6/3/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2474	Closed Work Orders 6/2/05 1 check in check boiler 3 mowing grass in campus 2 using weedeater in campus 2 moving furniture to barracks 6/2 - 8	6/3/2005 6/2/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2410	Closed Work Orders 5/31/05 1 check in check boiler 3mowing grass in playground 2 replace broken sprinkler in playground 2 moving furniture in truck to barracks 5/31 - 8	6/1/2005 5/31/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2427	Closed Work Orders 6/1/05 1 check in check boiler 3 mowing behind main building 2 using weedeater in campus 2 moving furniture to barracks 6/1- 8	6/2/2005 6/1/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2389	Closed Work Orders 5/27/05 1 check in check boiler 3 taking off ramps of portable 4 putting furniture in caft area 5/27 - 8	5/31/2005 5/27/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2301	Closed Work Orders 5/25/05 1 check in check boiler 3 still moving furniture to caft area 4 moving furniture with truck to caft area 5/25 - 8	5/26/2005 5/25/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2338	Closed Work Orders 5/26/05 1 check in check boiler 7 taking of fence for removal of portable to chaparral putting back fence up and cleaning area up, replace broken water line also 5/26 - 8	5/27/2005 5/26/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2264	Closed Work Orders 5/24/05 1 check in check boiler 3 started moving furniture inside main building 4 moving furniture from portables to caft 5/24 - 8	5/25/2005 5/24/2005 Medium	Frank Lara Frank Lara		La Mesa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2106	Closed Work Orders 5/18/05 1 check in check boiler 7setting up for celebration for school closer,also using truck for cleaning and throwing trash 5/18 - 8	5/19/2005 5/18/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2124	Closed Work Orders 1 check in check boiler 1 replace pump on ac unit rm16 2 using truck to move furniture to barracks 3 using truck to move furniture to barracks 1 replace broken sprinkler in playground 5/19 - 8	5/19/2005 5/19/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1939	Closed Work Orders 1 check in check boiler 1 cutting branches by basketball courts 2 went to shop for material service truck 3 went to mesquite to assist roma 1 putting shelves in barracks for storage 5/13 - 8	5/13/2005 5/13/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1914	Closed Work Orders 1 check in check boiler 3using mower in campus 2 moving furniture to barracks 1 cutting branches by caft area 1 replace flush valve in kitchen area 5/12 - 8	5/12/2005 5/12/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1985	Closed Work Orders 1 check in check boiler 3 mowing using weedeater in campus 4 cleaning the campus for school closing celebration 5/16 - 8	5/17/2005 5/16/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2052	Closed Work Orders 1 check in check boiler 3 cleaning school for celebration 1 servicing ac unit barracks rm25 3 using truck for moving furniture to barracks 5/17 - 8	5/17/2005 5/17/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1370	Closed Work Orders 1 check in check boiler 1 replace flush valve caft 2 using weedeater in campus 2 went to mesquite to assist roma on bulletin board 1 painted stall in boys restroom caft area 1 put sprinklers in play ground 4/22 - 8	4/22/2005 4/22/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1327	Closed Work Orders 1 check in check boiler 1 replace flush valve boys restroom main building 2 using weedeater in campus 2 trimming branches by parking lot 1 took off graffati behind barracks 1 using blower in campus 4/21 - 8	4/21/2005 4/21/2005 Medium	Frank Lara Frank Lara		La Mesa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1415	Closed Work Orders 4/25/05 1 check in check boiler 3 using mower in campus 2 brunning bushes in front of main building 1 unclogged sink in kitchen 1 straighten out fence by parking lot 4/25 - 8	4/25/2005 4/25/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1560	Forwarded mini split system for server, condenser fan motor, having problems to kick in.	5/2/2005 Medium	Frank Lara David Boyd		La Mesa ES
1543	Closed Work Orders 1 check in check boiler 1 replace door closer rm 17 2 went to shop for material service truck 2 replace pads on ac units 1 fixed swing in playground 1 put on sprinklers in playground 4/29 - 8	4/29/2005 4/29/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1572	Closed Work Orders 1 check in check boiler 3 assisting lorenzo on inventory on ac units 2 using weedeater in campus 1 straighten out stairs in portable 1 putting sprinklersin playground 5/2 - 8	5/2/2005 5/2/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1573	Duplicate Request 1 check in check boiler 3 assisting lorenzo on inventory on ac units 2 using weedeater in campus 1 straighten out stairs in portable 1 putting sprinklersin playground	5/2/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1508	Closed Work Orders 1 check in check boiler 2 replace broken copper line on barracks 1 took truck to get rack for truck 2 replace broken sprinkler in front of main building 1 replace broken legs for table 1 cleaned pump house and boiler 4/28 - 8	4/28/2005 4/28/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1472	Closed Work Orders 1 check in check boiler 2 using weedeater in campus 1 cut branches by parking lot 2 helping with inspection with fire distiquishers 2 putting roundup in fence line 4/27 - 8	4/27/2005 4/27/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1453	Work In Progress need to plow playground and seed	4/27/2005 Medium	Frank Lara Lorenzo Hernandez		La Mesa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1853	Closed Work Orders 1 check in check boiler 1 using blower in all sidewalks 2 replace broken sprinkler playground 2 went to mesquite to assist roma 1 took of graffati in caft area 1 replace window screen behind main building 5/11 - 8	5/11/2005 5/11/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1803	Closed Work Orders 1 check in check boiler 3 putting tar in pan of ac unit was leaking 1 replace float on ac unit rm 25 3 using truck to move shelves and boxes to rooms 5/10 - 8	5/10/2005 5/10/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1759	Closed Work Orders 1 check in check boiler 2 using weedeater in campus 1 trimming branches by parking lot 2 using truck to move furniture to rm30 1 prunning bushes in of main building 1 replace seat on swing north side 5/9 - 8	5/9/2005 5/9/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1719	Closed Work Orders 1 check in check boiler 3 trimming bushes in front of main building 2 using roundup in campus 2 install shelve for special needs 5/6 - 8	5/6/2005 5/6/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1689	Closed Work Orders 1 check in check boiler 2 trimming bushes in front of main building 1 using weedeater in fence line 2 service ac unit in rm 30 1replace seat on swing by playground 1 put sprinklers in playground 5/5 - 8	5/5/2005 5/5/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1623	Closed Work Orders 1 check in check boiler 2 using weedeater by parking lot 1 put up screen up by stage 2 servicing ac unit in portable 29 1 put up stall in boys restroom caft area 1 putting sprinklers in campus 5/3 - 8	5/3/2005 5/3/2005 Medium	Frank Lara Frank Lara		La Mesa ES
1665	Closed Work Orders 5/4/05 1 check in check boiler 3 using mower in campus 2 painted wall in boys restroom caft area 2 unclogged sink kitchen area 5/4 - 8	5/5/2005 5/4/2005 Medium	Frank Lara Frank Lara		La Mesa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2638	Closed Work Orders 6/8/05 1 check in check boiler 5 assisting danny vega moving furniture to san miquel 2 moving furniture to barracks with truck 6/8 - 8	6/8/2005 6/8/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2611	Closed Work Orders 6/7/05 1 check in check boiler 3 went to san miquel to assist danny vega 2 putting roundup in playground equitment 2 moving furniture to barracks with truck 6/7 - 8	6/8/2005 6/7/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2557	Closed Work Orders 6/7/05 1 check in check boiler 3 using weedeater in campus 2 using roundup in campus 2 moving furniture to barracks with truck 6/7 - 8	6/7/2005 6/7/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2813	Closed Work Orders 6/15/05 1 check in check boiler 3 working in warehouse cleaning barracks 4 working in warehouse cleaning barracks 6/15 - 8	6/16/2005 6/15/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2757	Closed Work Orders 6/13/04 1 check in check boiler 3 mowing grass in campus 4 mowing grass in campus using weedeater 6/13 - 8	6/14/2005 6/13/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2778	Closed Work Orders 6/14/05 8 working in phiscal plant at warhouse 6/14 - 8	6/15/2005 6/14/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2896	Closed Work Orders 6/20/05 1 check in check boiler 7 went to berino to assist danny miranda on barracks 6/20-8	6/20/2005 6/20/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2878	Closed Work Orders 6/16/05 1 check in check boiler 4 assisting roma in mesquite with yard 3 came back to la mesa and started painting hallway 6/16-8	6/20/2005 6/16/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2880	Closed Work Orders 6/17/05 1 check in check boiler 3 went to mesquite to assist roma in yard work 4 painting hallway in main building in la mesa 6/17-8	6/20/2005 6/17/2005 Medium	Frank Lara Frank Lara		La Mesa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2972	Closed Work Orders 6/21/05 1 check in check boiler 7 assisting danny miranda in berino 6/21 - 8	6/24/2005 6/21/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2977	Closed Work Orders 6/23/05 1 check in check boiler 5 assisting danny miranda in berino on floors 2 came back to la mesa and started painting hallway 6/23 - 8	6/24/2005 6/23/2005 Medium	Frank Lara Frank Lara		La Mesa ES
2984	Closed Work Orders 1 check in check boiler 2 went to shop to service truck and get material 5 painting hallway in main building 6/24 - 8	6/24/2005 6/24/2005 Medium	Frank Lara Frank Lara		La Mesa ES
3010	Closed Work Orders 1 check in check boiler 3 mowing playground in campus 4 finishing painting inside main building 6/27 - 8	6/27/2005 6/27/2005 Medium	Frank Lara Frank Lara		La Mesa ES
3082	Closed Work Orders 1 check in check boiler 2 using weedeater in campus 1 1 replace sprinklers in front of main building 4 moving furniture to barracks with truck 6/29 - 8	6/29/2005 6/29/2005 Medium	Frank Lara Frank Lara		La Mesa ES
3062	Closed Work Orders 6/28/05 1 check in check boiler 3 using weedeater in campus 4 moving furniture to barracks with truck 6/28 - 8	6/29/2005 6/28/2005 Medium	Frank Lara Frank Lara		La Mesa ES
3104	Closed Work Orders 1 check in check boiler 2 putting roundup in campus 1 install bulletin board in rm23 3 painting dinning area 1 trimmed branches in by bus stop 6/30 - 8	6/30/2005 6/30/2005 Medium	Frank Lara Frank Lara		La Mesa ES
3105	Work In Progress enrique need to replace outlet in caft area came of the wall	6/30/2005 Medium	Frank Lara Enrique Sotelo		La Mesa ES
2084	Work In Progress AZTEC FLOORING PLEASE PROVIDE A PRICE QUOTE FOR THE FOLLOWING ROOMS. VCT&COVEBASE RMS 28&29.	5/18/2005 Medium	Michael Munoz	Portables	La Mesa ES
1857	Work In Progress Aztec flooring. Need Price quotes on flooring on portables at La Mesa and portable at Deser-trail. Pleas call Mike before you go.	5/11/2005 Medium	Michael Munoz		La Mesa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1846	Complete Ruben please order and have available solid blocks and galletas for portable movement from La Mesa to San Miguel, and La Mesa to CHM. Desert trail to CHM. THanks	5/11/2005 5/13/2005 Medium	Ruben Ronquillo	Portables	La Mesa ES
1847	Complete Please disconnect electrical from portables as soon as school ends for portable re- locations. Also order material for installation. Please see Mike disconnect 3 portables that will be relocated.	5/11/2005 5/23/2005 Medium	Enrique Sotelo		La Mesa ES
1849	Complete please disconnect sewer and water from portables as soon as school ends. Please have material to re-install when they are re-located. Please see mike DISCONNECT UTILITIES FROM PORTABLES.	5/11/2005 5/23/2005 Medium	Fred Appelzoller		La Mesa ES
3102	Work In Progress ON JULY 5TH, SAL, JIMMY & GUILLERMO - NEED TO PICK UP SHELVES & WRAP FROM LA MESA CAFETERIA AND STORE IN MAINTENANCE BARRACK.	6/30/2005 Medium			La Mesa ES
3103	Work In Progress ON JULY 6 & 7, SAL & GUILLERMO - NEED TO REPORT TO LA MESA FOR HELP ON FINISHING FLOORS.	6/30/2005 Medium			La Mesa ES
3009	Work In Progress Mr. Suttmiller needs keys for all buildings at LM. (Master)	6/27/2005 Medium	Aida Salcedo Hector Lozoya		La Mesa ES
793	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. COMPLETED PER ARMANDO DIAZ	4/1/2005 4/29/2005 Medium	Aida Salcedo Armando Diaz		La Mesa ES
780	Void 03/30/05 4-cleaning master cools on ch/desert t. 1-servise restroom on room 128 3-painting new doors rooms 96 57 and54	4/1/2005 Medium	Aida Salcedo		La Mesa ES
1310	Complete need to repair vacumm cleaner asap REPLACED PARTS & DID P.M.	4/21/2005 4/25/2005 Medium	Armando Diaz Jimmy Carbajal		La Mesa ES
1136	Complete need x tractor fix leaking water asap WAS ORIGINALLY SUBMITTED TO VECHILE REPAIR/A. GONZALEZ. CHANGED TO CUSTODIAL EQUIPMENT REPAIR/J. CARBAJAL. 4-25-05. MS. REPLACED FLO JET VALVE AND DID P.M. AS PER JIMMY ON 4/25/05	4/14/2005 4/21/2005 Medium	Armando Diaz Jimmy Carbajal		La Mesa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
688	Duplicate Request need one new vacuum cleaner DUPLICATED, SEE W.O. #644	3/30/2005 Medium	Armando Diaz Jimmy Carbajal		La Mesa ES
644	Complete REQUESTING 1 NEW VACUUM CLEANER DELIVERED 1 NEW VACUUM AS PER AIDA, PER JIMMY CARBAJAL	3/29/2005 3/29/2005 Medium	Armando Diaz Jimmy Carbajal		La Mesa ES
781	Void 03/30/05 4-cleaning master cools on ch/ desert t. 1-serve restroom on room 128 3- painting new doors rooms 96 57 and 54	4/1/2005 Medium	Aida Salcedo		La Union ES
794	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. COMPLETED PER SANTOS GALINDO	4/1/2005 4/27/2005 Medium	Aida Salcedo Santos Galindo		La Union ES
184	Complete Alvarez Farms - need doorbells.	3/8/2005 3/10/2005 Medium	Carlos Castillo		La Union ES
885	Duplicate Request Alvarez farms. After May 17th washer and drier can be installed.	4/6/2005 Medium			La Union ES
886	Work In Progress Alvarez farms. washer and drier can be installed after May 17th. When David has completed the install please provide power. Might want to get with David.	4/6/2005 Medium	Carlos Castillo		La Union ES
1482	Complete alvarez farms -2 light fixtures over conference table are out. replace 2 ballast and lamps.	4/28/2005 4/27/2005 Medium	Carlos Castillo Carlos Castillo	Classroom	La Union ES
1613	Work In Progress Transformer for the high temp. alarm in the server rm. does not have 120v circuit only the 24v side was hooked up.	5/3/2005 Medium	Eddie Baeza Carlos Castillo		La Union ES
1748	Work In Progress A contactor is requested for a/c units. NEMA size 4. 8502SFO2S. Ser. 460/575V 60hz. 100HP. 3 phase	5/9/2005 Medium	Eddie Baeza Carlos Castillo		La Union ES
1739	Closed Work Orders 5-3-05 4 Assist with Mercado. 1 Assist sound and signal tech. 3 Cut weeds and cut grass at campus and playground, 5/3 - 8	5/9/2005 5/3/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1740	Closed Work Orders 5-4-05 4 Assist with Mecado. 4 Chop weeds and use weed-eater. 5/4 - 8	5/9/2005 5/4/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1741	Closed Work Orders 1 Check systems on campus. 5 Cut weeds and use weed-eater. 5/5 - 6	5/9/2005 5/5/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1742	Closed Work Orders 5-6-05 8 Assist with mercado. 5/6 - 8	5/9/2005 5/6/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1842	Closed Work Orders 5-10-05 4 Water trees. .5 Change out float valve rm. 306. 1 Level a/c unit at Main bldg. 1 Assist custodians, 1 Unclog camode at LUJTP. .5 Change a/c filter at LUJTP. 5/10 - 8	5/11/2005 5/10/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1843	Closed Work Orders 5-11-05 1.5 Check systems on campus. 6.5 WO#1068 Assist Danny at Panther Pride. 5/11 - 1. 5	5/11/2005 5/11/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1529	Closed Work Orders 4-25-05 4 Service a/c units. 4/25 - 4	4/29/2005 4/25/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1530	Closed Work Orders 4-26-05 8 Service a/c units. 4/26 - 8	4/29/2005 4/26/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1531	Closed Work Orders 4-27-05 2 Chop weeds on campus. 6 WO# 123921 Assist Caly at GAC. 4/27 - 8	4/29/2005 4/27/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1532	Closed Work Orders 4-28-05 4 Cut weeds on campus. 4 WO#123921 Assist Caly at GAC. 4/28 - 8	4/29/2005 4/28/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1567	Closed Work Orders 4-29-05 4 Perform maint. plan inspections. 2 Go to ppd. 2 Cut weeds on campus. 4/29 - 8	5/2/2005 4/29/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1568	Closed Work Orders 1.5 Check systems on campus. 2 Assist Jaime with mini split system in server rm. 1 Assist Carlos with PA system. 3.5 Cut weeds on campus. 8	5/2/2005 5/2/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1331	Complete (2) 4L260 V-belts are requested for the exhaust fans at the kitchen. REMOVED AND REPLACED BAD FAN BELTS ON KITCHEN EXHAUSTS	4/21/2005 5/31/2005 Medium	Eddie Baeza Danny Orozco		La Union ES
1358	Closed Work Orders 1.5 Check systems on campus. 6.5 Service a/c units at STMS. 4/22 - 8	4/22/2005 4/22/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1359	Closed Work Orders 2.5 Service a/c units at STMS. 5.5 Service a/c units at LUE. 4/21 - 8	4/22/2005 4/21/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1360	Closed Work Orders 1 Change out marquee. 4 Chop weeds on campus. 3 Mow grass on campus and at leach fld. 4/20 - 8	4/22/2005 4/20/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2449	Closed Work Orders 6-2-05 2 Cut weeds on campus. 5 assist david at LUJTP. 1 Assemble table at LUJTP. 6/2 - 8	6/2/2005 6/2/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2445	Closed Work Orders 5-31-05 1 Check systems on campus. 3 Cut weeds. 4 Prepare walls for painting rms.100,101,102, teachers lounge. 5/31 - 8	6/2/2005 5/31/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2446	Closed Work Orders 6-1-05 8 Paint walls rms. 100,101,102, teachers lounge. 6/1 - 8	6/2/2005 6/1/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2249	Closed Work Orders 5-23-05 Remove lockers from rms. 100,101,102, and teachers lounge. 5/23 - 8	5/24/2005 5/23/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2233	Work In Progress A 16' trailer and 2 men are requested to take lockers which were removed from the Main bldg. to the PPD.	5/24/2005 Medium	Eddie Baeza Margret Villalobos		La Union ES
2334	Closed Work Orders 5-26-05 5 Cut grass on campus and at leach fld. 2 Service 935 lawnmower. 1 Wash dist. pickup. 5/26 - 8	5/26/2005 5/26/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2331	Closed Work Orders 5-25-05 8 Remove lockers from classrms. Install tile in rooms 102,103. 5/25 - 8	5/26/2005 5/25/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2328	Closed Work Orders 5-23-05 8 Remove lockers from rooms 100, 101, 102, and teachers lounge. 5/23 - 8	5/26/2005 5/23/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2329	Closed Work Orders 5-24-05 6 Remove lockers rooms 100, 101, 102, and teachers lounge. 2 Assist David at LUJTP. 5/24 - 8	5/26/2005 5/24/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2138	Closed Work Orders 5-18-05 2 Water trees. 2.5 Change ballasts in hallways. 1 WO# 126273 Extinguishers. 1 WO# 126272 Exit signs. 1.5 WO# 126271 Emergency lights. 5/18 - 8	5/19/2005 5/18/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2174	Closed Work Orders 5-20-05 1 Check systems on campus. 1 Adjust floats on a/c units (2) 4 Begin removing lockers rm 102. 2 Water playground. 5/20 - 8	5/20/2005 5/20/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2205	Work In Progress Remodel areas where lockers were removed in four classrooms, with shelving.	5/23/2005 Medium	Eddie Baeza Danny Miranda		La Union ES
2081	Closed Work Orders 5-16-05 1 Check systems on campus. 3 Assist Lorenzo with a/c inventory. 3 Cut grass on campus. 1 Assist sound and signal tech. 5/16 - 8	5/18/2005 5/16/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2082	Closed Work Orders 5-17 05 1 Check systems on campus. 5 WO#1366 Assist Caly at GAC. .5 Replace a/c cooler float at Main bldg. 5/17 - 1.5	5/18/2005 5/17/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1930	Closed Work Orders 5-12-05 2.5 Cut grass @ leach fld. 2 Go to Wal-Mart as per Ms. Tutor. 2 Cut grass on campus. 1.5 Check a/c units at Main bldg. change out float valve. 5/12 - 8	5/13/2005 5/12/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1931	Closed Work Orders 5-13-05 5 Make wells around trees, fertilize, and water. 1 Repair dish washer at kitchen. .5 repair ice machine. 1.5 Go to PPD. 5/13 - 8	5/13/2005 5/13/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1932	Work In Progress A bubbler system is requested for the trees at the playground.	5/13/2005 Medium	Eddie Baeza Lorenzo Hernandez		La Union ES
1933	Closed Work Orders 5-9-05 1 Change out the marquee. 1 Assist Santos in the cafeteria. 6 Repair water lines at A&B annexs. 5/9 - 8	5/13/2005 5/9/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
721	Complete (2) L-1 Best padlocks need repair. They are in the Maintenance office. rekey 2 padlocks for gates	3/31/2005 4/4/2005 Medium	Eddie Baeza Hector Lozoya		La Union ES
710	Closed Work Orders 3-30-05 1.5 Check systems on campus. 1.5 Repair leaking faucet rm. 303. 4 Perform Maint. plan inspections. 1 Perform paper work.	3/30/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
739	Work In Progress Exterior light at the front parking lot near storm drain is out.	3/31/2005 Medium	Eddie Baeza Carlos Castillo		La Union ES
870	Closed Work Orders 4-1-05 1 Check systems on campus. 2 Move picnic tables to the playground. 3 Fertilize playground. 1 Go to PPD. 4/1 - 8	4/5/2005 4/1/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
873	Closed Work Orders 4-4-05 1 Check systems on campus. 3 Remove sand and gravel from curbs. 3 Mow grass on campus and leach fld. 1 Go to GHS for fertilizer spreader. 4/4 - 8	4/5/2005 4/4/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
874	Closed Work Orders 4-5-05 1 Check systems on campus. 7 Prepare basketball courts for painting. 4/5 - 8	4/5/2005 4/5/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
881	Complete Water fountain in rm. 303 is leaking. WATER FTN WAS LEAKING, EDD IS GOING TO ASK PLUMBERS GASKET, WAS LEAKING FROM THREAD ON PUSH VALVE, HE WILL TAKE CARE OF IT.	4/6/2005 4/11/2005 Medium	Eddie Baeza Jose Ambriz		La Union ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
868	Closed Work Orders 3-31-05 1.5 Check systems on campus. 3 Set out sprinklers and water trees. 1 Work on pad locks. 1 Change out the marquee. 1 Repair flush valve rmf. 204. .5 Meet with Ms. Tutor.	4/5/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1045	Closed Work Orders 4-6-05 1 Check systems on campus. 7 Prepare basketball courts for painting. 4/6/05 - 8	4/12/2005 4/6/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1046	Closed Work Orders 4-8-05 1 Check systems on campus. 5 Prepare and paint basketball courts. 4/8/05 - 6	4/12/2005 4/8/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1047	Closed Work Orders 4-11-05 1 Check systems on campus. 7 Service a/c units at new addition. 4/11/05 - 8	4/12/2005 4/11/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1138	Closed Work Orders (3) Keys are requested to secure file cabinet in rm. 210. There is no key for this cabinet at this time.	4/14/2005 4/27/2005 Medium	Eddie Baeza Hector Lozoya		La Union ES
1222	Complete Cell deck pad media is requested for 12000 cfm a/c unit, at the main bldg. pads are 44 1/2" X 48" wide. GAVE TO EDDIE THIS PAD'S TO BE REPLACED, BORROW FROM RUBEN'S WAREHOUSE, WHEN I RECEIVED P.O WILL RETURN THEM TO RUBEN	4/18/2005 4/25/2005 Medium	Eddie Baeza Jose Ambriz		La Union ES
1176	Closed Work Orders 4-12-05 1 Check systems on campus. 7 Service a/c units. 4/12 - 8	4/15/2005 4/12/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1177	Closed Work Orders 1 Check systems on campus. 2.5 Go to Chaparral with Mike Munoz. 1.5 Set out sprinklers. 2 Assist David Villalobos at STMS. 1 Change out marquee.	4/15/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1178	Closed Work Orders 4-14-05 2 Deliver art boards to GMS. 6 Service a/c units. 4/14 - 8	4/15/2005 4/14/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1224	Duplicate Request Cell deck pad media is requested for a 12000 cfm mastercool at the main bldg. Pads are 8" X 44 1/2" X 48" wide. Same as 1222	4/18/2005 4/25/2005 Medium	Eddie Baeza Jose Ambriz		La Union ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1259	Closed Work Orders 4-18-05 2 Pick up art boards at GMS. 6 Service a/c units. 4/18 - 8	4/19/2005 4/18/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
1260	Closed Work Orders 4-19-05 8 Service a/c units. 4/19 -8	4/19/2005 4/19/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
618	Closed Work Orders 3-21-05 1 Check systems on campus. 7 120574 Assist at GHS.	3/24/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
619	Closed Work Orders 3-22-05 3.5 Attend safety meeting. 1.5 Check systems on campus. 3 Cut grass and weeds.	3/24/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
621	Closed Work Orders 3-23-05 1.5 Check systems on campus. 6.5 125365 Install flush valves.	3/24/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
622	Closed Work Orders 3-24-05 1.5 Check systems. 1.5 Repair water leak at playground. 3 Spray roundup on campus weeds. 2 125365 Install flush valves.	3/24/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
412	Closed Work Orders 3-15-05 1.5 Check systems on campus. 1.5 Replace basket strainer on sink rm. 206. 1.5 125584 2 125582 1 125583 .5 125585	3/15/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
413	Complete Lithonia emergency lights at main bldg. need batteries or replacement,(2). supplied bldg mechanic w/batteris.	3/15/2005 3/17/2005 Medium	Eddie Baeza Carlos Castillo		La Union ES
529	Closed Work Orders 3-17-05 1 Check systems on campus. 2 Assist with staff BBQ. 1 Assist David at LUJTP. 2 124646 Assist Jose. 2 Cut weeds on campus.	3/18/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
527	Closed Work Orders 3-16-05 2 Check systems on campus. 2 Assist Caly at GHS. 2 Cut weeds on campus. 1 Move oicnic tables. 1 Move boxes at LUJTP.	3/18/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
525	Work In Progress 600 Pounds of fertilizer is requested for the playground area.	3/18/2005 Medium	Eddie Baeza Lorenzo Hernandez		La Union ES
166	Work In Progress A motor starter coil is requested for the boiler pump at new addition	3/8/2005 Medium	Eddie Baeza Jose Ambriz		La Union ES
167	Complete A motor starter coil is requested for the boiler pump at new addition REMOVE OLD BURN MAGNETIC START COIL AND REPLACE IT WITH A NEW ONE 1200 - 75D73070A FURNACE, HOOKUP 3 PHASE MAGNETIC STARTE, START IT UP WORKING OK, WILL ORDER MORE FOR STOCK.	3/8/2005 3/9/2005 Medium	Eddie Baeza Jose Ambriz		La Union ES
168	Closed Work Orders 3-2-05. 2 Check systems on campus. 5 Spray arsenol on campus. 1 Fill holes around sewage cleanouts @ LUJTP.	3/8/2005 3/8/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
169	Closed Work Orders "3-1-05 2 Check systems on campus. 2 Clean dirt and sand from curbs. 2.5 Spray round up. .5 Replace light bulbs in restrm. at portable. .5 Repair door jamb at LUJTP. .5 Meet with Ms. Tutor."	3/8/2005 3/8/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
170	Closed Work Orders "2-28-05 2 Check systems on campus. 4 Remove dirt and sand from bus turnaround. 1.5 Assist in setting up desks for testing. .5 Meet with Ms. Tutor."	3/8/2005 3/8/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
171	Closed Work Orders "2 Check systems on campus. 3 Cut weeds on campus. 1 Set up for assm. and lunch in Cafe. 1 Install paper towel dispenser @LUJTP."	3/8/2005 3/8/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
172	Closed Work Orders "2-24-05. 2 Check systems on campus. 1 Repair flush valve in girls bathrm @ main. 1.5 Install rain gutter rm. 104. 1.5 Install coat hooks @ portable. 1 Repair copier mach. cart. 1 Service chainsaw."	3/8/2005 3/8/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
130	Complete An extra key is requested for the display cabinet near the office. REPAIR LOCK AT DISPLAY CABINET AND MAKE 3 KEYS.	3/7/2005 3/22/2005 Medium	Eddie Baeza Hector Lozoya	Hallway/Corridor	La Union ES
301	Closed Work Orders 3-7-05 1.5 Check systems on campus. 1.5 Service 935 lawnmower. 4 Cut grass and weeds on campus and at leach fld. 1 Repair copier mach.	3/11/2005 3/11/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
302	Closed Work Orders 3-8-05 1.5 Cfheck systems on campus. 6.5 wo# 123921 Assist Caly @ GAC.	3/11/2005 3/11/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
304	Closed Work Orders 3-9-05 1.5 Check systems on campus. 6 wo#123921 Assist Caly @ GAC. .5 Cut weeds at east fence.	3/11/2005 3/11/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
306	Closed Work Orders 3-10-05 1.5 Check systems on campus. 1 Repair lockset rm. 302. 2.5 wo# 184 Assist Caly at LUJTP. 1 Install pencil sharpener rm. 203	3/11/2005 3/11/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
362	Closed Work Orders 3-14-05 1.5 Check systems on campus. 4 Cut weeds on campus. 1.5 Work on basket strainer rm. 206. 1 Install metered faucet in boys restrm. at main.	3/14/2005 3/14/2005 Medium	Eddie Baeza Margret Villalobos		La Union ES
363	Complete A basket strainer is requested for wash basin rm. 206. installed basket strainer	3/14/2005 3/15/2005 Medium	Eddie Baeza David Villalobos		La Union ES
359	Closed Work Orders 3-11-05 1.5 Check systems on campus. 4.5 Service a/c units at offices. 1.5 Go to fill propane tank. .5 Meet with Ms. Tutor.	3/14/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2830	Complete A compressor replacement is requested for Trane mini-split system in the server room. RECOVER FREON REMOVE OLD COMPRESSOR WITH DRIER. INSTALL NEW COMPRESSOR , BRAZED 1635 DRIER AND VACUUM , RECHARGE R22 65 PSI UNDER WARRANTY - TRANE	6/16/2005 6/16/2005 Medium	Eddie Baeza Jose Ambriz		La Union ES
2803	Closed Work Orders 6-8-05 3.5 Chop weeds. 3.5 Repair sprinkler system. 1 126571 Extinguishers. 6/8 - 8	6/15/2005 6/8/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2804	Closed Work Orders 6-9-05 8 Chop weeds along fence at leach fld. 6/9 - 8	6/15/2005 6/9/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2820	Closed Work Orders 6-14-05 1 Check systems on campus. 7 WO#2056 Assist Caly at STMS. 6/14 - 1	6/16/2005 6/14/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2821	Closed Work Orders 6-15-05 1 Check systems on campus. 1 WO# 2534 Disconnect Marquee @ STMS. 6 WO# 2056 Assist CALY @ STMS. 6/15 - 1	6/16/2005 6/15/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2592	Closed Work Orders 6-6-05 4 Chop weeds. 4 Water trees. 6/6 - 8	6/7/2005 6/6/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2593	Closed Work Orders 6-7-05 3 Chop weeds. 1.5 Mow leach fld. 3 Run weed-eater. .5 Meet w/Ms Tutor and Sound & Signal Tech. 6/7 - 8	6/7/2005 6/7/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2523	Closed Work Orders 6-3-05 5 Cut grass on campus. 1 Remove posters from walls rm. 304. 6/3 - 6	6/6/2005 6/3/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2524	Closed Work Orders 6-4-05 8 WO#2518 GAC "C" wing. 6/4 - SEE WO 2518	6/6/2005 6/6/2005 Medium	Eddie Baeza Eddie Baeza		La Union ES
2547	Work In Progress (4) Modesto Ash trees are requested for the playground and the campus.	6/6/2005 Medium	Eddie Baeza Lorenzo Hernandez		La Union ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
409	Complete WARMER IS SHOCKING THE LADIES. LINDA YANAGA SNP MGR 589-2040 HAD TO RUN GROUN ON BOTH WARMERS	3/15/2005 3/22/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	La Union ES
817	Complete Hookup of washer & dryer at La Union JTP (Alvarez) building. STUBED OUT FOR WASHER HOOK-UP DRAIN AND WATER.	4/4/2005 6/2/2005 Medium	David Villalobos David Villalobos		La Union ES JTP - Alvarez
2477	Complete PATCH UP WHERE PLUMBING WAS INSTALLED. patch wall and texture	6/3/2005 6/14/2005 Medium	David Villalobos Danny Miranda		La Union ES LUJTP
884	Duplicate Request Alvarez farms. After May 17th washer and drier can be installed. same as 817	4/6/2005 Medium	Michael Munoz David Villalobos		La Union ES
658	Complete ROOM 101 - HEATING COIL IS LEAKING. (INFORMED JOSE) brazed, had hole in a tubeline.	3/29/2005 3/29/2005 Medium	Margret Villalobos Jose Ambriz		La Union ES
2970	Work In Progress The Wet & Dry needa repair and need a replacement as soon as possible.	6/24/2005 Medium	Santos Galindo Jimmy Carbajal		La Union ES
2079	Closed Work Orders 5-18-5 3-hours put together new file cabnets and art paper rack. 5/18 - 3	5/18/2005 5/18/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Office	Loma Linda ES
2153	Closed Work Orders 5-19-5 8- HOURS GROUNDS MAINT. 5/19 - 8	5/20/2005 5/19/2005 Medium	Michael Mc Dermott Michael Mc Dermott		Loma Linda ES SCHOOL GROUNDS
2154	Closed Work Orders 5-20-5 8- HOURS GROUNDS MAINT. 5/20 - 8	5/20/2005 5/20/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Athletic Field	Loma Linda ES
1924	Closed Work Orders 5-12-5 8-HOURS GROUNDS MAINT. 5/12 - 8	5/13/2005 5/12/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Athletic Field	Loma Linda ES
1925	Closed Work Orders 5-13-5 8- HOURS PAINT FIRE AND YELLOW ZONES. 5/13 - 8	5/13/2005 5/13/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Parking Lot	Loma Linda ES
2351	Closed Work Orders 5-24-5 8-HOURS GROUNDS MAINT. 5/24 - 8	5/27/2005 5/24/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Athletic Field	Loma Linda ES
2352	Closed Work Orders 5-23-5 8HOURS PAINTING ENTRY TO RR. 5/23 - 8	5/27/2005 5/23/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Hallway/Corridor	Loma Linda ES 100,200
2075	Closed Work Orders 5-16-5 8-hours grounds maint, trim and water trees in front of school. 5/16 - 8	5/18/2005 5/16/2005 Medium	Michael Mc Dermott	Athletic Field	Loma Linda ES school front area
2077	Closed Work Orders 5-17-5 8-hours set up and take down tents and games for school rec day. 5/17 - 8	5/18/2005 5/17/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Classroom	Loma Linda ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1832	Closed Work Orders 5-10-5 8- HOURS GROUNDS MAINT. 5/10 - 8	5/11/2005 5/10/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Athletic Field	Loma Linda ES GROUNDS
1833	Closed Work Orders 5-11-5 8- HOURS PAINT TAGGING ON OUTSIDE OF SCHOOL. 5/11 - 8	5/11/2005 5/11/2005 Medium	Michael Mc Dermott Michael Mc Dermott		Loma Linda ES OUT SIDE AREA
2348	Closed Work Orders 5-27-5 2-HOURS CHECK OUTAGE AT BERINO ELEM. 2-HOURS PICK UP SUPPLYS AND PAPER WORK. 4-HOURS GROUNDS MAINT. 5/27 - 8	5/27/2005 5/27/2005 Medium	Michael Mc Dermott Michael Mc Dermott		Loma Linda ES BERINO ELEM. OUTAGE
2349	Closed Work Orders 5-26-5 8-HOURS ATTENDED ELECTRICAL CLASS IN LAS CRUCES. 5/26 - 8	5/27/2005 5/26/2005 Medium	Michael Mc Dermott Michael Mc Dermott		Loma Linda ES SCHOOLING
1562	Closed Work Orders 5-2-5 2-HOURS HANG 2 LARGE BULLITIN BOARDS 5/2 - 2	5/2/2005 5/2/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Classroom	Loma Linda ES RM. 107
1563	Closed Work Orders 5-2-5 1 HOUR REPLACE A/C PUMP AND 15AMP FUSE. 5/2/05 - 1	5/2/2005 5/2/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Classroom	Loma Linda ES RM 201
1564	Closed Work Orders 5-2-5 5-HOURS WATER AND BUILD BOARDERS FOR WEST SIDE PINE TREES. 5/2 - 5	5/2/2005 5/2/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Athletic Field	Loma Linda ES GROUNDS
1668	Closed Work Orders 5-3-5 8-HOURS ELECTRICAL OUTAGE AT HIGH SCHOOL. 5/3 - 1552	5/5/2005 5/5/2005 Medium	Michael Mc Dermott Michael Mc Dermott		Loma Linda ES GHS
1669	Closed Work Orders 5-4-5 8-HOURS GROUNDS MAINT. 5/4 - 8	5/5/2005 5/4/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Athletic Field	Loma Linda ES GROUNDS
1830	Closed Work Orders 5-5-5 4-HOURS PM MAINT WO- 126277,12678,12679. 5/5 - 4	5/11/2005 5/11/2005 Medium	Michael Mc Dermott Michael Mc Dermott		Loma Linda ES HALL WAYS
3069	Closed Work Orders 6-27-5 8-HOURS GROUNDS MAINT. 6/27 - 8	6/29/2005 6/27/2005 Medium	Michael Mc Dermott	Parking Lot	Loma Linda ES GROUNDS
3071	Closed Work Orders 6-28-5 8-HOURS HOOK UP POWER TO PORTABLES AT BERINO AND CHAPARRAL MID. 6/28 - 8	6/29/2005 6/28/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Classroom	Loma Linda ES
2949	Closed Work Orders 6-20-5 8-HOURS INSTALL RAMPS FOR PORTABLES 6/20-8	6/23/2005 6/20/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Portables	Loma Linda ES NEW PORTABLES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2950	Closed Work Orders 6-21-5 4-HOURS INSTALL NEW RAMPS FOR PORTABLES. 6/21-4	6/23/2005 6/21/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Portables	Loma Linda ES NEW PORTABLES
2951	Closed Work Orders 6-22-5 8-HOURS PAINTED ENTRYWAYS IN MAIN HALLWAY 6/22-8	6/23/2005 6/22/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Hallway/Corridor	Loma Linda ES MAIN HALL
2952	Work In Progress TO GROUNDS- NEED RAMP TO PORTABLE WELDED. I HAVE TALKED WITH SPEEDY ABOUT PROBLEM.	6/23/2005 Medium	Michael Mc Dermott Lorenzo Hernandez	Portables	Loma Linda ES RAMPS
2852	Closed Work Orders 6-16-5 8-HOURS PAINTING , AND TOUCH UP OF HALL. 6/16 - 8	6/17/2005 6/16/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Hallway/Corridor	Loma Linda ES MAIN
2853	Closed Work Orders 6-17-5 8-HOURS LEVEL AND SET UP RAMPS. 6/17 - 8	6/17/2005 6/17/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Portables	Loma Linda ES
2824	Closed Work Orders 6-14-5 8-HOURS GROUNDS MAINT. 6/14 - 8	6/16/2005 6/14/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Athletic Field	Loma Linda ES GROUNDS
2825	Closed Work Orders 6-15-5 8-HOURS GROUNDS MAINT. 6/15 - 8	6/16/2005 6/15/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Athletic Field	Loma Linda ES GROUNDS
2826	Closed Work Orders 6-16-5 8-HOURS PAINT ENTRY WAYS TO REST ROOMS. 6/15 - 8	6/16/2005 6/15/2005 Medium	Michael Mc Dermott Michael Mc Dermott	Hallway/Corridor	Loma Linda ES 100,200
1676	Work In Progress NEED ANOTHER ROYAL BAG FOR THE VACUUM CLEANER. TO REPLACE TWO WITH SOME HOLES (DAMAGED). THANK YOU.	5/5/2005 Medium	Luis Solis Jimmy Carbajal		Loma Linda ES
1643	Complete NEED SERVICE FOR (2) VACUUM CLEANERS #1.- HANDLE ANDTHE ELECTRIC CORD ARE DAMAGED.,#2.-NOT WORKING PROPERLY.,(THANK YOU). REPLACED PARTS & DID P.M.	5/4/2005 5/4/2005 Medium	Luis Solis Jimmy Carbajal		Loma Linda ES
1644	Complete WE NEED (3) ROYAL BELTS AND (1) ROYAL BAG FOR THE ROYAL VACUUM CLEANERS. THANK YOU. DELIVERED BELTS	5/4/2005 5/11/2005 Medium	Luis Solis Jimmy Carbajal		Loma Linda ES
1928	Complete NEED SERVICE FOR MY VACUUM CLEANER (IT MAKES A BIG NOISE WENT I TURN ON).THANK YOU. REPLACED ABOVE PARTS ALSO DID P.M.	5/13/2005 5/20/2005 Medium	Luis Solis Jimmy Carbajal		Loma Linda ES
1929	Complete NEED SERVICE FOR THE BUFFER MACHINE (DO NOT TURN ON) DON"T START., (THANK YOU). REPLACED SWITCH	5/13/2005 5/20/2005 Medium	Luis Solis Jimmy Carbajal		Loma Linda ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
148	Complete NEED SERVICE FOR THE BUFFER MACHINE (DO NOT TURN ON) DON'T START.,(THANK YOU) REPLACED TOGGLE SWITCH AND REWIRED FOR ELECTRICAL SHORT. 3/3/05. REFERENCE W.O. 1364	3/8/2005 3/17/2005 Medium	Luis Solis Jimmy Carbajal		Loma Linda ES
960	Complete NEED SERVICE FOR THE BUFFER MACHINE(DO NOT STOP .TURN ON BUT NOT OFF.,)THANK YOU. REPLACED ELECTRICAL CORD FROM MOTOR TO HANDLE, HAD A SHORT	4/8/2005 4/15/2005 Medium	Luis Solis Jimmy Carbajal		Loma Linda ES
2636	Complete NEED SERVICE FOR THE EXTRACTION MACHINE (IT IS DROOPING WATER CONSTANTLY WHEN IS ON AND WON'T STOP.) THANK YOU. REPLACED FLO JET PUMP (ISSUED THRU ACT 1000) AS PER JIMME	6/8/2005 6/13/2005 Medium	Luis Solis Jimmy Carbajal		Loma Linda ES
3063	Work In Progress 12 WINDOWS BROKEN/5 WINDOWS FORM EAST SIDE OF THE BLDG (BUSES DROP UP AREA) 5 WNDOWS EAST NORTH SIDE BACK CAMPUS AREA 2- WINDOWS FROM THE DOUBLE SIDE PORTABLE. CASE# 2005-05397 BEN CASILLAS	6/29/2005 Medium	Luis Solis Ruben Ronquillo		Loma Linda ES
1126	Complete Keys - Need to issue keys to Mike Mc Dermott transferring from CHMID to LL. Danny Vega will be turning in his keys. (April 29, 2005 Payday)	4/14/2005 4/29/2005 Medium	Michael Munoz Hector Lozoya		Loma Linda ES
484	Complete Please generate a w.o for Manny and have him assign the keys to the cafeteria mangager before the end of the week. Have Manny test the keys before he issues them out. LL Key (Gate Key)	3/17/2005 3/17/2005 Medium	Michael Munoz Hector Lozoya	Cafeteria	Loma Linda ES
2481	Work In Progress CONNECT UTILITIES TO PORTABLE.	6/3/2005 Medium	Fred Appenzoller Fred Appenzoller		Loma Linda ES PORTABLES
1319	Closed Work Orders 4-21-05 1-CK WK ORDERS/OFFICE 1-RM#207 REPLACE 1/2 INCH BALL VALVE A/C UNIT 6-CUT CAMPUS LAWN 4/21 - 8	4/21/2005 4/21/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
1383	Closed Work Orders 4-22-05 1-ck wk orders 2-repair door closure/ne wg 6-repair sprinklers 4/22 - 8	4/25/2005 4/22/2005 Medium	Danny Vega Danny Vega		Loma Linda ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1411	Closed Work Orders 1-ck wk orders/office 1-a/c in kitchen /hoy air 2-glue baseboard/hallways 4-assemble shelves /office 8	4/25/2005 4/25/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
1466	Closed Work Orders 4-27-05 1-ck wk orders/office 1.5-take tools to sme/meet with principal 5.5-wk on tree planters/irragtion 4/27 - 8	4/27/2005 4/27/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
1467	Closed Work Orders 4-26-05 1-ck wk orders/office 1-walk-thru/mike mackdermett 6-wk on west tree line /bubblers 4/26 - 8	4/27/2005 4/26/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
116	Complete need key for file cabinet number listed on cabinet is 734 repair lock on file cabinet	3/7/2005 3/29/2005 Medium	Grace Alvarado Hector Lozoya	Computer Lab	Loma Linda ES
352	Work In Progress UNABLE TO LOCK ROOM	3/14/2005 Medium	Grace Alvarado Hector Lozoya	Classroom	Loma Linda ES 114
311	Work In Progress locks in Mr. Ramos windonws are broken and need to be replaced. also the window on south end of room could use new blinds Blinds are changed every 6 months in this room none in stock order thru PPD. Locks in order thru PPD. - Danny Vega	3/11/2005 Medium	Grace Alvarado Margret Villalobos		Loma Linda ES
452	Work In Progress DISTRICT ART SHOW SETUP AT GADSDEN MIDDLE SCHOOL, PUT UP IS APRIL 14, 2005 AT 8:30 AM TAKE DOWN IS APRIL 18, 2005 AT 10:00 AM	3/16/2005 Medium	Grace Alvarado Danny Vega		Loma Linda ES
2150	Complete NEEDING NEW CHAIN WELDED ONTO GATE. CHAIN WAS CUT DURING A EMERGENCY MEDIVAC LANDING. NEEDED AS SOON AS POSIBLE welded padlock to gate.	5/20/2005 6/1/2005 Medium	Grace Alvarado Hector Lozoya	Parking Lot	Loma Linda ES
1761	Work In Progress Needing Speedy to fertilize within next 2 weeks, also needing dirt to build borders for trees	5/9/2005 Medium	Grace Alvarado Lorenzo Hernandez		Loma Linda ES
1302	Closed Work Orders 4-20-05 1-ck wk orders/office 2-san miguel walk-thru 1-clean boiler rm 1-ck rm#201-209 a/c units 3-clean morgan bldg 4/20 - 8	4/21/2005 4/20/2005 Medium	Danny Vega Danny Vega		Loma Linda ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1172	Closed Work Orders 4-14-05 1-CK WK ORDERS/OFFICE 6-WK ON A/C UNITS/GYM 1-ASSEMBLE SHELVES/OFFICE 4/14 - 8	4/15/2005 4/14/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
1219	Closed Work Orders 4-15-05 1-CK WK ORDERS/OFFICE 1.5-PICK-UP SUPPLYS/PPD 2.5-ASSEMBLE SHELVES/OFFICE 3-SPRAY ROUND-UP ON CAMPUS 4/15 - 8	4/18/2005 4/15/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
1220	Closed Work Orders 4-18-05 1-CK WK ORDERS/OFFICE 1-RM111 A/C UNIT NOT WORKING 6-WK ON KITCHEN A/C UNITS 4/18 - 8	4/18/2005 4/18/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
1221	Duplicate Request 4-18-05 1-CK WK ORDERS/OFFICE 1-RM111 A/C UNIT NOT WORKING 6-WK ON KITCHEN A/C UNITS	4/18/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
1113	Closed Work Orders 4-13-05 1-ck wk orders/office 7-wk on a/c units nw wg 4/13-8	4/13/2005 4/13/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
1048	Closed Work Orders 4-8-05 1-CK WK ORDERS/OFFICE 7-WK AT GHS/REMOVE BLEACHERS 4/8/05 - 8	4/12/2005 4/8/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
1073	Closed Work Orders 4-12-05 1-CK WK ORDERS/OFFICE 1-CLOGGED SINK TEACHER RESTROOM BY LOUNGE 6-WK ON A/C UNITS SW WG 4/12 - 8	4/12/2005 4/12/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
941	Closed Work Orders 4-7-05 1-ck wk orders/office 2-assemble metal shelves/office supply rm 5-wk on a/c units sw wg 4/7 - 8	4/7/2005 4/7/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
871	Closed Work Orders 4-05-05 1-ck wk orders/office 7-wk on a/c units front office /nurses/libray etc. 4/5 - 8	4/5/2005 4/5/2005 Medium	Danny Vega Danny Vega		Loma Linda ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
899	Closed Work Orders 4-6-05 1-CK WK ORDERS/OFFICE .5-REPAIR STUDENTS DESK/RM#207 6.5-WK ON A/C UNITS NE WG 4/6 - 8	4/6/2005 4/6/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
897	Complete need 12 in. x 3/4 blower wheel pulley and two 4- L/610 BELTS FOR MASTERCOOL.PLEASE ADD KEYWAY KEY delivered materials to danny vega	4/6/2005 4/8/2005 Medium	Danny Vega Jaime Gomez		Loma Linda ES
812	Closed Work Orders 1-ck wk orders 2-clogged -up urinal 1.5-pick-up supplys/ppd 1.5-repair baes ball back stop 2-wk on sprinklers	4/4/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
833	Closed Work Orders 1-ck wk orders/office 1-chng marquee letters 6-wk on a/c units -clean & start-up/east wg 8	4/5/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
698	Closed Work Orders 1-ck wk orders/office 1-rm118/window screens vandalized 1.5-make and replace window screen 2.5-hand wash basin -replace electric eye/bys west wg 2-book rm/repair metal shelves/east wg	3/30/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
699	Work In Progress need window latches for rms 103-106-105-204 asap- need to secure windows at end of day- sent sample to ppd	3/30/2005 Medium	Danny Vega Danny Miranda	Classroom	Loma Linda ES
700	Closed Work Orders 1-CK WK ORDERS/OFFICE 1-KITCHEN DRAIN CLOGGED 2-DOOR /BOOK RM /OFF ALINGMENT HITS AT TOP FRAME 1-PICK-UP FLOOR TILE AT PPD 1-WATER LEAK/LIBRARY COURT YARD FOUNTAIN 1-EAST WG SECURITY CAMERA/NOT WORKING/PULLED CABLE 1-ROOF TOP LOOSE A/C COVERS	3/30/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
718	Complete driverside door will not close/please ccheck it out asap driverside door was repaired to close properly veh 87	3/31/2005 4/1/2005 Medium	Danny Vega Angel Gonzales		Loma Linda ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
749	Closed Work Orders 1-ck wk orders/office 1-start boiler-up 1-replace exhaust fan motor/bys rr nw wg 3-remove benches on tables by front office 1-purge boiler lines /gym 1-replace ballast/music rm	3/31/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
383	Duplicate Request SCHOOL TRUCK #87 VANDALIZED /DRIVER- SIDE ROLL-UP WINDOW BROKEN.PLEASE REPLACE(vandalism report 3-11-05)	3/15/2005 Medium	Danny Vega Angel Gonzales		Loma Linda ES
272	Closed Work Orders 1-vandalism report/truck window case#2005- 02110 1-ck boiler/pumps 1-ck wk orders/office 5-wk on sprinklers (3-9-05)	3/10/2005 3/10/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
290	Complete Vandalism report/truck window case#2005- 02110 replaced door glass on vehicle 87	3/11/2005 3/31/2005 Medium	Danny Vega Pete Flores		Loma Linda ES
135	Closed Work Orders 3-4-05 1-ck boiler/gauges 1-ck wk orders/office 1.5-pick-up material/ppd 2.5-ck roof leaks/clean drains 2-wo#121420	3/7/2005 3/8/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
136	Closed Work Orders 1-ck boiler/gauges 1-ck work orders/office 3-graffiti on rock wall 1-flush hot water lines/custodial closets 1-ck a/c water supply lines/damage 1-valve box silinoid/sprinkler	3/7/2005 3/8/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
137	Closed Work Orders 1-ck boiler/gauges 1-ck work orders/office 3-graffiti on rock wall 1-flush hot water lines/custodial closets 1-ck a/c water supply lines/damage 1-valve box silinoid/sprinkler	3/7/2005 3/8/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
163	Work In Progress side walk by front entrance has buckled and lifted/safety hazard/redo portion of sidewalk. 1395 wo	3/8/2005 Medium	Danny Vega Michael Munoz		Loma Linda ES
164	Work In Progress need tractor&scraper to clean west pine tree- line/also rock wall sand	3/8/2005 Medium	Danny Vega Lorenzo Hernandez		Loma Linda ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
165	Complete need pad locks for north walk-in gates(2)ea MAKE 2 PADLOCKS FOR NORTH WALKIN GATE.	3/8/2005 3/23/2005 Medium	Danny Vega Hector Lozoya		Loma Linda ES
222	Closed Work Orders 3-8-05 1-CK BOILER/PUMPS 1-CK WK ODRS/OFFICE 5-UNCOVER A/C UNITS START VENTS 1-FIRE ALARM/DRILL	3/9/2005 3/9/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
224	Closed Work Orders 3-9-05 1-CK BOILER/PUMPS 1-CK WK ORDERS 2-REPAIR A/C WATER SUPPLY LINES 1-REPLACE BALLAST LIBRARY 3-GRDS WK /SPRINKLERS	3/9/2005 3/9/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
180	Complete need all classrooms sprayed // kitchen/restrooms/nurses office/library/front offices Waiting on Purchase Order.	3/8/2005 4/13/2005 Medium	Danny Vega Margret Villalobos		Loma Linda ES
499	Closed Work Orders 1-ck boiler/pumps 1-ck wk orders/office 1-burnt ballast in lounge 2-replace base board/east hllwy 1.5-wk on shelves rm109 1.5-door closure/east hllwy exit /wont close	3/17/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
490	Work In Progress need tractor to clean-up walk-in paths by north fence line/also east fence line	3/17/2005 Medium	Danny Vega Lorenzo Hernandez		Loma Linda ES
491	Work In Progress need fill-dirt on baseball diamonds/puddling water	3/17/2005 Medium	Danny Vega Lorenzo Hernandez		Loma Linda ES
492	Work In Progress need to re-do borders around playground equipment/plus remove sand from rockwall	3/17/2005 Medium	Danny Vega Lorenzo Hernandez		Loma Linda ES
493	Work In Progress need tractor to level off dirt in library courtyard	3/17/2005 Medium	Danny Vega Lorenzo Hernandez		Loma Linda ES
494	Work In Progress need tractor to level off rain erosion in bus parking run-off circle/eastside	3/17/2005 Medium	Danny Vega Lorenzo Hernandez		Loma Linda ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
423	Closed Work Orders 1-ck boiler/pumps 1-ck wk orders/office 1.5-rm 114 wk on door handle-key cylinder 1.5-unclogged floor drain /kithcen 1.5-replace flush valves/diaphrams/gls&bys nw wg 1.5-ck fire extinguishers	3/15/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
466	Closed Work Orders 1-CK BOILER/PUMPS 1-CK WK ORDERS/OFFICE/CHNG MARQUEE 1-RM 208 SPED NO HEAT 1-WK OD ID #125589 1-WK OD ID#125590 1-WK OD ID#125591 1-CHNG BALLAST NW HLLWY 1-REPAIR TEACHER DESK RM#207	3/16/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
467	Closed Work Orders 1-CK BOILER/PUMPS 1-CK WK ORDERS/OFFICE/CHNG MARQUEE 1-RM 208 SPED NO HEAT 1-WK OD ID #125589 1-WK OD ID#125590 1-WK OD ID#125591 1-CHNG BALLAST NW HLLWY 1-REPAIR TEACHER DESK RM#207	3/16/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
609	Closed Work Orders 3-22-05 THRU 3-24-05 PAINT GIRLS & BOYS RESTROOMS NW-SW WINGS -EAST LOBBY -NORTH LOBBY-20HRS TOTAL/ 4HRS MTG AT STMS=24HRS	3/24/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
616	Closed Work Orders 1-ck boiler/pumps 1-ck wk orders/office 2-pick supplies/ppd 1-clogged urinal east lobby 2-door closure north exit/wont close 1-unplug all appilances for sprng brk	3/24/2005 Medium	Danny Vega Danny Vega		Loma Linda ES
617	Complete broken 1/2 in. insolated window 28 1/4 x 29 1/2 also sw exit door 47 3/4 x 29 3/4 clear safety glass case#05-02473 REPLACE BROKEN WINDOWS	3/24/2005 3/29/2005 Medium	Danny Vega Ruben Ronquillo	Classroom	Loma Linda ES east wing/rm202
795	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. COMPLETED PER LUIS	4/1/2005 4/20/2005 Medium	Aida Salcedo Luis Solis		Loma Linda ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2511	Void Monthly - Loma Linda ES Roof Inpsection - Refer to PM schedule details.	6/5/2005 Medium	Alfredo Holguin Michael Mc Dermott		Loma Linda ES
782	Void 03/30/05 4-cleaning master cools on ch/ desert t. 1-serveise restroom on room 128 3- painting new doors rooms 96 57 and54	4/1/2005 Medium	Aida Salcedo		Loma Linda ES
783	Void 03/30/05 4-cleaning master cools on ch/ desert t. 1-serveise restroom on room 128 3- painting new doors rooms 96 57 and54	4/1/2005 Medium	Aida Salcedo		Mesquite ES
796	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. INSPECTION COMPLETED AS PER RUBEN SOLIS	4/1/2005 4/29/2005 Medium	Aida Salcedo Ruben Solis		Mesquite ES
887	Complete need to pour concrete and asphalt where gas line was repaired. NEW CONCRETE WAS POURED AND SET AROUND GREASE TRAPS, NEW SIDEWALK AND ASPHALT WERE POURED AFTER REPAIR OF GAS LINE.	4/6/2005 5/9/2005 Medium	Michael Munoz		Mesquite ES
2637	Work In Progress BOTTOM LEFT BLODGETT OVEN NOT HEATING UP AT ALL ALICE FLOURNOY - SNP MANAGER 505 233- 2341	6/8/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Mesquite ES
1022	Complete need five art stands mesquite elem.	4/11/2005 4/11/2005 Medium	Danny Miranda Danny Miranda		Mesquite ES
273	Closed Work Orders 1hr. reported checked b. rm. 1hr. attached weather strip to door,installed 2 door stop solis rm. 2hr. met w/ plumber w/ mr. john fine installed pressure reducer and 60 psi. relief valve.1hr. cut suckers from mex. elms.2hr. assited h.v.a.c. w/ heater leak..5 p.o.. .5 computer work.	3/10/2005 3/10/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
274	Complete need 5 4x6 peg boards,20 2x4x8 studs.to make stands for art show. the old ones are to damaged .attn. ruben ronquillo. PURCHASE PEGBOARDS AND 2 X4X8	3/10/2005 4/12/2005 Medium	Romauldo Apodaca Ruben Ronquillo		Mesquite ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
275	Complete hot water return leaking in solis rm. 2nd grade wing. drained entire boiler system, removed leaking unio and replaced with new one.	3/10/2005 4/1/2005 Medium	Romauldo Apodaca Jaime Gomez		Mesquite ES
158	Closed Work Orders 02/28/05 1.0 Checked boiler room. 5.0 Grounds; Cut weeds, around fence lines, sprayed round up. 2.0 Checked playground equipment, re-adjusted slide.	3/8/2005 3/8/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
223	Closed Work Orders 3/9/05 1hr reported checked b. rm.. .5hr. p.o.. 5hr. met w. leyva. 4hr. replace 3 sprinklers,adjusted radius on sprinklers. 1.5 hr. herbicide fence lines..5 computer and paper work.	3/9/2005 3/9/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
235	Closed Work Orders 1hr. reporte checked b. rm.4hr. grounds,weed eat,prune trees.1hr. worked on clogged sink.1hr. deliverd toys and furniture to a.d.v...5hr. p.o. .5 computer work.	3/10/2005 3/10/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
237	Work In Progress need 25 bags fertilizer.	3/10/2005 Medium	Romauldo Apodaca Lorenzo Hernandez		Mesquite ES
238	Complete need to replace broken glass size is 23 1/2 x 23 3/4 clear safety. thanx. replace broken window	3/10/2005 3/10/2005 Medium	Romauldo Apodaca Ruben Ronquillo		Mesquite ES
232	Closed Work Orders 3/4/05 1hr. reported checked b. rm.1hr.worked on clogged toilet.2.5 reported to p.p.d...5 hr. p.o.. 1hr. assited h.v.a.c. w/ unloading of risers and stads.	3/10/2005 3/10/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
233	Closed Work Orders 3/7/05 1hr. reported checked b. rm.5hr. cleaning,arranging,organizing storage.1hr. cleaning truck..5 p.o.. .5 computer work.	3/10/2005 3/10/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
548	Closed Work Orders 3/18/05 1hr. reported checked b.rm.1hr. checked playground equipt.2hr. reported to p.p.d. 4hrs assited mr. leyva and ruben w/ setting up for spring fling festival.and w/trash cleanup.	3/18/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
504	Closed Work Orders 3/16/05 1hr. reported checked b.rm.2hr. emptied trash cans play ground.weed wacked pine trees and all trees. 3hr.1.5 cleaned irrigation ditch..5 p.o..	3/17/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
505	Closed Work Orders 3/17/05 1hr. reported checked b. rm.weed wacked front and coves and edged. 4hr.2hr. getting playground ready for spring fling..5 p.o. .5 met w/ phillips.	3/17/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
506	Complete rick , need grease traps secured w/ locks safety issue. replace old lid with new cast iron lid and ring, needs concrete around it.	3/17/2005 4/8/2005 Medium	Romauldo Apodaca Ricardo Jacquez		Mesquite ES
498	Closed Work Orders 3/11/05 1hr. reported checked b. rm.3hr. leak in solis rm.took wet tiles down found leak hot water h.v.a.c. called jaimie to assist.looked fpr shut off,turned water heater off.2hr. changed ballast 2.a.d.v..5 hr. met w/ leyva..5 p.o..1hr. checking sprinkler system.	3/17/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
501	Closed Work Orders 3/11/05 1hr. reported checked b. rm.3hr. leak in solis rm.took wet tiles down found leak hot water h.v.a.c. called jaimie to assist.looked fpr shut off,turned water heater off.2hr. changed ballast 2.a.d.v..5 hr. met w/ leyva..5 p.o..1hr. checking sprinkler system.	3/17/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
631	Closed Work Orders 3/22/05 1hr. checked bm. rm.,checked campus.3.5 hr. assited dimmar.3.5 safety training.	3/24/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
632	Closed Work Orders 3/16/05 1hr. checked b. rm.6.5 assited kiki w/ electrical a/c,s..5 computer and paper work.	3/24/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
633	Closed Work Orders 1hr. reported checked b. rm. 6.5 assited jaimie and kiki a/c,s..5 computer and paper work.	3/24/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
561	Closed Work Orders 3/21/05 1hr. reported checked b. rm.2hr. picking up branches and trsash front.1hr. set up sprinklers front.2hrs. fixed broken 1" WATER LINE tulips.1hr. assited dimmar..5 p.o.. .5 computer and paper wwork.	3/21/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
984	Closed Work Orders 4/08//5 1HR. REPORTED CHECKED B. RM.4HR. GROUNDS,WEED EAT ,MOW MAIN FIELD.1HR. ASSITED RICK W/ MAN HOLE COVERS .1HR. ASSITED MAN W/ 3 FILING CABINETS..5 P.O. .5 COMPUTER AND PAPER WORK. 4/8 - 8	4/8/2005 4/8/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
971	Work In Progress NEED FILING CABINETS CYLINDERS REPLACED.THANX.	4/8/2005 Medium	Romauldo Apodaca Hector Lozoya		Mesquite ES
945	Closed Work Orders 4/07/05 1HR. REPORTED CHECKED B. RM.4HR. GROUNDS,WEED EAT,TRIM MEMORIAL..5 MARQUI..5 P.O..1HR. INSPECT PLAY STRUCTURES..5 MET W/ PHILLIPS..5 COMPUTER AMD PAPER WORK. 4/7 - 8	4/7/2005 4/7/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
904	Closed Work Orders 4/6/05 1HR. REPORTED CHECKED B.RM..5 SET UP SPRINKLERS FRONT..5 P.O..5HR. GROUNDS,WEED EAT,HERBICIDE..5 MET W/ PHILLIPS..5 COMPUTER NAND PAPER WORK. 4/6 - 7	4/6/2005 4/6/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
865	Closed Work Orders 4/1/05. .5 REPORTED. REPORTED TO P.P.D.2HR.5HR. WORKING ON GAS LEAK..5 COMPUTER WORK. 4/1 - 8	4/5/2005 4/1/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
862	Closed Work Orders 3/30/05 .5 REPORTED . 6.5 WORKED ON GAS LEAK..5 COMPUTER WORK.	4/5/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
863	Closed Work Orders 3/31/05. .5 REPORTED . 6.5 GAS LEAK..5 COMPUTER WORK.	4/5/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
867	Closed Work Orders 3/05/05. 1HR. REPORTED.7HRS. COVERING UP EXCAVATION TAMPERING,PICKING UP TOOLS DEBRIS FROM GAS LEAK.	4/5/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
860	Closed Work Orders 3/29/05 .5 REPORTED .6.5 WORKED ON GAS LEAK..5 COMPUTER WORK.	4/5/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
855	Closed Work Orders 3/22/05 1HR. REPORTED CHECKED B. RM. 1HR. GROUNDS.6HR. GAS LEAK DETECTED BY CITY OF LAS CRUCES.EVACUATE KIDS AND STAFF.CALLED MIKE ,FRED, STARTED TO FIND LEAK. 3/22 - 8	4/5/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
856	Closed Work Orders 3/23/05 .5 REPORTED 6.5 WORKING ON LEAK, DIGGING TO FIND GAS LINE..5 COMPUTER WORK. 3/23 - 7.5	4/5/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
857	Closed Work Orders 3/24/05 .5 REPORTED 6.5 WORKING ON GAS LEAK..5 COMPUTER WORK.	4/5/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
858	Closed Work Orders 3/25/05 .5 REPORTED.6.5 WORKING ON GAS LEAK. .5 COMPUTER WORK.	4/5/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
765	Complete BUS TURNAROUND - GAS LEAK. found gas leak, trenched for new gasline, contracted out gas line and tested, back filled trench and get ready for ashpalt.	3/29/2005 4/5/2005 Emergency	Romauldo Apodaca Fred Appelzoller		Mesquite ES
1085	Closed Work Orders 4/11/05 1hr. reported checked b. rm. 7hr. made 5 art stands w/ danny miranda, w/o 1022. 4/11 - 1	4/12/2005 4/11/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
1086	Closed Work Orders 1hr. reported checked b., rm. .5 p.o. .5 set sprinklers front. 1hr. assited kiki w/ electric panel. 4hr. staining and caulked art stands..5 met w/ leyva. .5 computer and paper work.	4/12/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
1116	Closed Work Orders 4/13/05 1hr. reorted checked b. rm. 1.5 HR. CHANGED OUT 9 LIGHT BULBS PEARCE AND REYES PORTABLE..5 P.O.. 3HR. SECOND COAT OF STAIN FOR ART STANDS AND CAULKED OTHER SIDE. 1HR. MARQUI. .5 MET W/ PHILLIPS..5 COMPUTER AND PAPER WORK. 4/13 - 8	4/13/2005 4/13/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
1117	Work In Progress NEED TO MAKE 6 FT. OPENING IN BOOK RM. TO ENTER NEXT RM. PER PHILLIPS.	4/13/2005 Medium	Romauldo Apodaca Michael Munoz		Mesquite ES
1118	Complete NEED TIRE ON VACUM CLEANER REPAIRED FOR CARLOS CASAS. REPLACED BELT, FAN, REAR AXLE ASSY, WHEEL RETAINER & WHEELS AND ALSO DID P.M.	4/13/2005 3/18/2005 Medium	Romauldo Apodaca Jimmy Carbajal		Mesquite ES
1151	Closed Work Orders 4/14/05 1hr. reported checked b.rm. 2hr. delivered art stands to gms, and set up. 4.5 a/c, s start up..5 computer and paper work. 4/14 - 8	4/14/2005 4/14/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1194	Closed Work Orders 4/15/05 1hr. reported checked b. rm..5 p.0...5 met w/ phillips.3hr. reported to p.p.d.,supplies,checked truck,gas,paper work.2.5 a/c,s start up..5 computer and paper work. 4/15 - 8	4/15/2005 4/15/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
1188	Complete manny need lock for filing cabinet for balduf. replace locks on 2 file cabinets	4/15/2005 4/19/2005 Medium	Romauldo Apodaca Hector Lozoya		Mesquite ES
1505	Complete having trouble unclogging comode 2nd grade wing.thanx removed w/c and unclogged it.	4/28/2005 4/28/2005 Medium	Romauldo Apodaca Fred Appelzoller		Mesquite ES
1506	Complete need electrical outlet installed in kitchen for milk cabinet . installr con moldura 500 outlet para Mike cabinet en cosina.	4/28/2005 4/28/2005 Medium	Romauldo Apodaca Enrique Sotelo	Cafeteria	Mesquite ES
1507	Closed Work Orders 4/28/05 1hr. reported checked b. rm.1hr. marqui..5 p.0.3hr. grounds main field..5 jump started car gardner.1hr. assited fred w/ comode..5 met w/ phillips. .5 computer and paper work. 4/28 - 8	4/28/2005 4/28/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
1468	Closed Work Orders 4/27/05 1hr. reported checked b. rm.3hr. grounds,set up sprinklers front.1hr. assited david w/ leak in solis rm.1hr. checking sprinklers.1hr. grounds..5 p.o..5 computer and paper work. 4/27 - 8	4/27/2005 4/27/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
1317	Complete faucets on sinks new wing not working 3.	4/21/2005 4/25/2005 Medium	Romauldo Apodaca Fred Appelzoller		Mesquite ES
1361	Closed Work Orders 4/18/05 1hr. reported checked b. rm.p.o. .5 .5 met w/ leyva.2hr. picked up art stands at g.m.s. 3.5 hrs. a/c start up..5 computer and paper work. 4/18 - 8	4/22/2005 4/18/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
1362	Closed Work Orders 4/19/05 1hr. reported checked b. rm.6.5 a/c start up..5 computer and paper work. 4/19 - 8	4/22/2005 4/19/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
1363	Closed Work Orders 4/20/05 1hr. reported checked b. rm.5hr.a/c start up.pancho assist. 1hr. unclogged comote w/ auger..5 p.o. .5 computer and paper work. 4/20 - 8	4/22/2005 4/20/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1364	Closed Work Orders 4/21/05 1hr. reported checked b. rm..5 loaded buses w/ lunch for field trip..5 p.o..1.5 went to p.p.d. to pick up a/c supplies.5.5 a/c start up. 4/21 - 8	4/22/2005 4/21/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
1365	Closed Work Orders 4/22/05 3hr. set up 3 canopys for animal day.2hr. watering main field.2hr. a/c start up..5 p.o. .5 computer work. 4/22 - 8	4/22/2005 4/22/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
1442	Closed Work Orders 4/25/05 1hr. reported checked b. rm.5hr. a/c start up,cleaning ,leveling,lubbing.1hr. troubling shooting refrigerated unit taylor portable..5 p.o...5 computer and paper work. 4/25 - 8	4/26/2005 4/25/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
1444	Closed Work Orders 4/26/04 1hr. reorted checked b. rm.5hr. grounds,tractor, edging wedd wack.1hr. changing out bad ball valve..5 p.o...5 computer and paper work. 4/26 - 8	4/26/2005 4/26/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
1724	Closed Work Orders 5/06/05 1hr. reported checked b. rm.2hr. set up canopys 2 chairs ,tables for school party.1hr. checked 3 a/cs intalled pump,1 fuse,over fflow.2hr. took down canopys ,chairs,tables trash.1hr. assiting cementers..5 p.o. .5 computer and paper work. 5/6 - 8	5/6/2005 5/6/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
1690	Closed Work Orders 5/5/05 1hr. assited cutodial w/ portables trash no sub.4hr. grounds.1hr. met w/ jj paving.1hr. washing trash bins platform..5 met w/ cathy. .5 computer and paper work. 5/5 - 8	5/5/2005 5/5/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
1621	Work In Progress need replacement of a/c side draft in portable 610.	5/3/2005 Medium	Romauldo Apodaca Jaime Gomez		Mesquite ES
1622	Work In Progress need replacement of indusrial unit on barracks,per phillips and leyva.	5/3/2005 Medium	Romauldo Apodaca Jaime Gomez		Mesquite ES
1617	Closed Work Orders 5/02/05 1hr. reported ,checked campus for vandalism,,etc..3hr. a/c start up.2hr. assited rivk j. w/ lift station..5 removed bird from hall way..5 p.o..5 met w/ leyva..5 computer and paper work. 5/2 - 8	5/3/2005 5/2/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1618	Closed Work Orders 5/3/05 1hr. reported checked b.r m.4hr. assited lorenzo solis w/ info. and condition of all a/c units.2.5 a/c start up...5 computer and paper work. 5/3 - 8	5/3/2005 5/3/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
1619	Work In Progress have leak between wall in rm. 401 rest rm.thanx.	5/3/2005 Medium	Romauldo Apodaca Fred Appelzoller		Mesquite ES
1632	Complete need to fix vacum cleaner.per ruben solis. REPLACED PARTS (ISSUED THRU SITE NET) AND DID P.M.	5/4/2005 5/24/2005 Medium	Romauldo Apodaca Jimmy Carbajal		Mesquite ES
1863	Closed Work Orders 5/10/05 1HR. REPORTED CHECKED B. RM.2HR. GROUNDS.1HR. MARQUI.2HR. ASSITED KIKIW/ BALLAST AND OUTLET AT A.D.V.1HR. ASSEMBLED 2 DESKS.1HR. UNCLOGGED SINK LOUNGE. 5/10 - 8	5/11/2005 5/10/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
1859	Closed Work Orders 5/11/05 1HR. REPORTED CHECKED,CAMPUS.1HR. ASSITED FRED W/ REMOVAL AND FIXING OF URINAL.3HR. A/C,S START UP AT A.D.V.ASSEMBLING OF ARCHED FOR GRADUATION.2HR..5 MET W/ LEYVA..5 COMPUTER AND PAPER WORK 5/11 - 8	5/11/2005 5/11/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
2135	Closed Work Orders 5/17/05 1HR. REPORTED CHECKED B. RM.1HR. PICKED UP TRACTOR SAN MIGUEL.4HR. ASSITED JAIME W/ A/C REMOVAL AND INSTALL IN MUSIC PORTABLE.1.5 GROUNDS..5 PAPER WORK. 5/17 - 8	5/19/2005 5/17/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
2132	Closed Work Orders 5/16/05 1HR. REPORTED CHECKED B. RM..5 MAIL RUN.1.5 CHANGED OUT BELT ON LIBRARY A/C UNIT.3HR. GROUNDS.1HR. TIGHTEND BOLTS ON OUTSIDE BENCHES..5 UNCLOGGED COMODE..5 PAPER WORK. 5/16 - 8	5/19/2005 5/16/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
2128	Closed Work Orders 5/13/05 1HR. REPORTED CHECKED B. RM.1HR. LOADED A/C. PADS TO DELIVER TO P.P.D.2HR. REORTED TO P.P.D.1HR. UNLOADED A/C PADS AT MESQUITE.2HR. CHECKED A/CS GYM..5 MET WW/ LEYVA. .5 PAPER WORK. 5/13 - 8	5/19/2005 5/13/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2183	Closed Work Orders 5/19/05 1HR. REPORTED CHECKED B. RM.4HR. GROUNDS.1HR. MET W/ MIKE,ALFREDO,CHAVEZ.1HR. FIXING COMODE..5 MET W/ PHILLIPS..5 PAPER WORK. 5/19 - 8	5/20/2005 5/19/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
2184	Closed Work Orders 5/20/05 1HR. REWPORTED CHECKED B. RM.2HR. ADJUSTING GYM A/C,S.1HR. ADV CHANGING COOLER PUMP.1.5 MONITORING LIFT STATION..5 MAILRUN..5 CLEANING UP KOVAC,CHILD GOT SICK. NO CUSTODIAN.1HR. ASSISTING KIKI W/ BALLAST CUSTODIAL CLOSET..5 PAPER WORK. 5/20 - 7.5	5/20/2005 5/20/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
2139	Closed Work Orders 5/18/05 2HR. ASSITED PANCHO AT LA MESA W/ CANOPYS..5 MAIL RUN..5 MET W/ LEYVA.22HR. GROUNDS.3HR. ASSITED PANCHO AT LA MESA CANOPYS AND CHAIRS, TABLES, TRASH. 5/18 - 8	5/19/2005 5/18/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
2152	Work In Progress PORTABLE 612 - DOOR HANDLE BROKEN.	5/20/2005 Medium	Romauldo Apodaca Hector Lozoya	Portables	Mesquite ES
2394	Closed Work Orders 5/31/05 1hr. reported checked b. rm.2hr. introduced summer youth helper to campus,introduced him to tools for grounds.1.5 fixed leaking a/c kitchen..5 mail run.bolted on covers for drains 1hr.1 hr changed out 7 light bulbs..5 checking out sprinklers..5 paper work. 5/31 - 8	5/31/2005 5/31/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
2414	Closed Work Orders 6/01/05 1hr. reorted checked b. rm/.1hr. set up canopy at a.d.v..5 met w/ door co..5 mail run.2hr. setting up for cookouts.1hr. put up canopys.1hr. met w/ danny miranda..5 met w/ leyva..5 paper work. 6/1 - 8	6/1/2005 6/1/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
2457	Closed Work Orders 6/02/05 1hr. reported checked b. rm.met w/ door instalers. 1hr.4 hrs grounds..5 marqui..5 mail run..5 met w/ phillips. .5 paper work. 6/2 - 8	6/2/2005 6/2/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
2335	Closed Work Orders 5/25/05 1hr. reported checked b.r m.2hr. washed and delivered tractor to danny at s. mike..5 p.o.1hr. marqui.1hr. fixing popcorn rm. a/c.1hr. fixed broken light cover kitchen.1hr. met w/ summer workers to tour them through school..5 paper work. 5/25 - 8	5/26/2005 5/25/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2369	Closed Work Orders 5/26/05 1hr. reoported checked b. rm.5hr. grounds,weed wack trim trees,pick up trash water trees and memorial..5 mail run..5 lubricated locks old wing..5 met w/ leyva..5 paper work. 5/26 - 8	5/27/2005 5/26/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
2370	Closed Work Orders 5/27/05 reported checked b.r m.1hr.2hr. assited ruben w/ cafeteria set up,chairs,tables etc..2hr. working on leak in portable 610.2hr. reported tp p.p.d. pick up supplies,etc..5 met w/ phillips. .5 paper work. 5/27 - 8	5/27/2005 5/27/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
2327	Closed Work Orders 5/24/05 1hr. reported checkeed b. rm.2hr. checked a/c,s main bldg.2hr. put grill together.1hr. unloaded fertilizer, 30 bags 50 lb.1.5 changed out 6 light bulbs,main bldg..5 paper work. 5/24 - 8	5/26/2005 5/24/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
2332	Closed Work Orders 1hr. reported checked b. rm.1hr. ,marqui. assited kiki w/ electrical problem at a.d.v. a/c.2hr.3hr. cuuting grass main field..5 mail run. .5 paper work. 5/24/05 5/24 - 8	5/26/2005 5/24/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
2644	Closed Work Orders 6/7/05 1hr. reported checked campus.5hr. irrigated main field,grounds weed eat .1.5 playground inspect. added sand to play structure..5 paper work. 6/7 - 8	6/8/2005 6/7/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
2645	Closed Work Orders 6/8/05 2hr. grounds a.d.v. 2hr. herbicide fence lines.2hr. mowing grass front memorial,coves.2hr. replacing tiles,garcia.flores pena. 6/8 - 8	6/8/2005 6/8/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
2664	Work In Progress need tile replaced rm. 113,111,110. 602 carpet instead of tile.	6/9/2005 Medium	Romauldo Apodaca Michael Munoz	Classroom	Mesquite ES 602,113,111,110.
2672	Closed Work Orders 6/9/05 1hr. reported checked b. rm.2hr. grounds..5 mail run.3hr. repairing sprinklers..5 met w/ phillips..5 met w/ leyva..5 paper work. 6/9 - 8	6/9/2005 6/9/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
2859	Closed Work Orders 6/13/04 1hr. reported checked b. rm. 3hr. painting fire lanes. 6/13 - 4	6/17/2005 6/13/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2860	Closed Work Orders 6/16/05 4hr. painting fire lanes.4hr. changing ballast and light bulbs. 6/16 - 8	6/17/2005 6/16/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
2861	Closed Work Orders 6/17/05 4hr. painting fire lanes,parking lanes.4hr. grounds and watering. 6/17 - 8	6/17/2005 6/17/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
2924	Closed Work Orders 6/21/05 1hr. checked campus and boiler rm.6hr. grounds,cut grass main field,cut weeds by canal and cleaned ditch..5 measuerd white boards for unstalation..5 paper work. 6/21-8	6/21/2005 6/21/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
3042	Closed Work Orders 6/27/05 1hr. checked campus& b. rm. 1hr. met w/ mesquite water concerning sewage.3hr. assited rick jaquez w/ pulling out sewage pump.replaced motor on master cool.1hr.1hr. greasing mowing tractor & checking fluids..5 p.o. .5 paper work. 6/27 - 8	6/28/2005 6/27/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
3046	Closed Work Orders 6/22/05 1hr. checking campus.1hr. checking ramps.1hr. checking sidewalks and pavement.2hr. checking doors.1hr. unclogged 2 comodes lobby.1hr. met w/ phillips..5 p.o..5 paper work. 6/22 - 8	6/28/2005 6/22/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
3044	Closed Work Orders 2hr. water main field.5hr. grounds,edging weed wacking,spinkler set up..5 poured oder degreaser kitchen drain..5 paper work. 6/28 - 8	6/28/2005 6/28/2005 Medium	Romauldo Apodaca Romauldo Apodaca		Mesquite ES
964	Complete STOLEN DEWALT DRILL (BATTERY) DURING SPRING BREAK WAS LEFT IN BOOKROOM.	4/8/2005 3/25/2005 Medium	Jose Ambriz Jose Ambriz		Mesquite ES
2116	Work In Progress BERNICE SAPIEN - ROOM 304 NEED A NEW LOCK FOR FILING CABINET - KEY BROKE INSIDE LOCK.	5/19/2005 Medium	Luz Griego Hector Lozoya	Classroom	Mesquite ES
1745	Complete NEED TO FIX TWO VACCUM CLEANERS (PLEASE BRING A LOANER) REPLACED PARTS (ISSUED THRU SITE NET) AND DID P.M.	5/9/2005 5/24/2005 Medium	Ruben Solis Jimmy Carbajal		Mesquite ES
811	Complete broken window (VANDALISM)	4/4/2005 4/4/2005 Medium	Ruben Solis Ruben Ronquillo	Hallway/Corridor	Mesquite ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
351	Complete we need two royal vaccum bags and two rollers DELIVERED 2 BRUSH ASSY & 2 BAG ASSY. REMOVED FROM INVENTORY THRU ACT 1000	3/14/2005 3/18/2005 Medium	Ruben Solis Jimmy Carbajal		Mesquite ES
685	Complete need to fix two vaccum cleaners REPLACED PARTS (ISSUED THRU SITE NET) AND DID P.M. AS PER JIMMY	3/30/2005 3/30/2005 Medium	Ruben Solis Jimmy Carbajal		Mesquite ES
3122	Work In Progress wet and dry machine's motor (BURNED)	7/1/2005 Medium	Ruben Solis Jimmy Carbajal	Hallway/Corridor	Mesquite ES
993	Work In Progress Need concrete poured around grease trap lids.	4/8/2005 Medium	Ricardo Jacquez Michael Munoz		Mesquite ES
3099	Work In Progress ON JULY 5TH AT 8:00 A.M. NEED FOR RUBEN RONQUILLO, RAFA LARA AND MANUEL PROSPERO TO PICK UP IN OUR RED CUSTODIAL VAN, MAINTENENCE SUPPLIES & EQUIPMENT FROM MAINTENACE WAREHOUSE, TAKE BACK TO STORE IN STORAGE SHED AT THE GAC. RUBEN TO DRIVE RED VAN, SO THAT HE CAN BRING VAN BACK TO US.	6/30/2005 Medium	Maria Sitters Ruben Ronquillo		Physical Plant Complex
1333	Closed Work Orders 4*19*05 .50 Ck in with office. 1.5 Serviced A/C autoshop. .50 Washed truck. 3.0 Cutting weeds bus turnaround. 1.0 clogged urinal B-WING. 1.5 Cleaned up tagging Boys RR main bldg. 4/19 - 8	4/22/2005 4/19/2005 Medium	Rudy Arreola Rudy Arreola		Physical Plant Complex
1150	Closed Work Orders 4/6/05 .5 building walk thru. 3.0 a/c service. 1.5 pulling weeds at student drop off. 3.0 working on swings. 4/6 - 8	4/14/2005 4/6/2005 Medium	Joe Ramirez Margret Villalobos		Physical Plant Complex
583	Closed Work Orders 2/28/05 .5 building walk thru. 2.5 chopping weeds along building. 2.5 pruning trees. 2.5 helping plumber install water fountain.	3/23/2005 3/29/2005 Medium	Joe Ramirez Joe Ramirez		Physical Plant Complex
2767	Complete Need to order ac adapter for Dell Computer (Tracer Summit) rec. a/c adapter from J. Valenzuela - mkv	6/14/2005 6/16/2005 Medium	Jose Ambriz Margret Villalobos		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
3112	Closed Work Orders 06/30/06 2.0 Loaded trailer with wet pads for ultra cools for GHS and delivered them. 2.0 Loaded wood material for Chaparral Elementary to repair floor on barrak on E wing. 4.0 Worked on floor for portable #141 at Berino Elementary. 6/30 - 8	6/30/2005 6/30/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
3070	Closed Work Orders 06/28/05 8.0 Worked on remodeling at the GAC, assisting Danny M. 6/28 - 8	6/29/2005 6/28/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
3086	Closed Work Orders 5.0 Worked on remodeling at GAC. 1.0 Road. 2.0 Worked on floor at Berino. 6/29 - 8	6/29/2005 6/29/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
3014	Closed Work Orders 6/27/05 1.5 Delivered material for floor at Chaparral Elementary 6.5 Worked on floor at Berino Elementary, Assisting Danny Miranda. 6/27 - 8	6/27/2005 6/27/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
3012	Closed Work Orders 06/24/05 8.0 Inventory at HVAC. 6/24 - 8	6/27/2005 6/24/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
2864	Closed Work Orders 06/17/05 4.0 Finished removing old floor from portable #142. 1.5 Road and landfill. 2.5 Continued to get information on all A/C's at Gadsden High School. 6/17 - 8	6/17/2005 6/17/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
2844	Closed Work Orders 6/16/05 8.0 Assisted Danny Miranda, at Berino Elementary and Chaparral Elementary at E wing replacing floor and throw trash at Sunland Park Landfill. 6/16 - 8	6/16/2005 6/16/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
2959	Closed Work Orders 06/23/05 8.0 Inventory at HVAC SHOP. 6/23 - 8	6/23/2005 6/23/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
2960	Closed Work Orders 06/23/05 8.0 Inventory at HVAC SHOP. 6/23 - 8	6/23/2005 6/23/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2599	Closed Work Orders 06/07/05 2.5 Road & Landfill to throw trash from GAC demo. 2.5 Finished collecting information from A/C's at Santa Teresa High School. 3.0 Started to collect information on all A/C's at Gadsden High School was assisted by building mech Fernie Moncayo. 6/7 - 8	6/7/2005 6/7/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
2510	Closed Work Orders 06/03/05 1.0 Road. 4.0 Removed cooling units from portables at Berino Elem. 2.0 Assisted Pancho Lara at La Mesa Elem. installed fence back on where portable was taken out through. 1.0 Assisted Freddy App. repairing 2 busted sprinkler lines. 6/3 - 8	6/3/2005 6/3/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
2556	Closed Work Orders 06/06/05 1.0 Road 7.0 Took Information on all A/C's units at Santa Teresa High School. 6/6 - 8	6/6/2005 6/6/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
2648	Closed Work Orders 06/08/05 1.5 Took trash to landfill at Sunland Park. 1.0 Road. 1.5 Assisted Danny Miranda removed carpet from portable at Berino Elementary and throw to landfill. 5.0 GAC assisted Danny Miranda delivered construction Material for remodeling at GAC and continued with demo. 6/8 - 8	6/9/2005 6/8/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
2676	Closed Work Orders 06/09/05 2.5 Road, and went to Sunland Park to throw trash. 5.5 Worked at Berino Elementary assisting Danny Miranda with repairing floor. 6/9 - 8	6/9/2005 6/9/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
2749	Closed Work Orders 06/13/05 9.5 Worked at Berino Elementary, repairing floor, on portable. 6/13 - 9.5	6/13/2005 6/13/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2375	Closed Work Orders 05/27/05 1.0 Road 7.0 Assisted Jose Ambriz install duck work at Santa Teresa High School, re-locate electrical tubing. 5/27 - 8	5/27/2005 5/27/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
2463	Closed Work Orders 06/02/05 1.0 Road 1.5 Assisted Danny Miranda pick up trailer and throw trash that was left on trailer. 1.5 Assisted Jose Ambriz at GAC troubleshoot a refrigeration unit. 4.0 Started to collect information from all A/C's at Santa Teresa High School, was Assisted by Joel Herrera BM. 6/2- 8	6/2/2005 6/2/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
2229	Closed Work Orders 05/23/05 1.0 Road. 2.0 Repaired Master cool at River Side Elementary as per Jaime and Rosy. 5.0 Finished collecting information on all A/C's at Desert view Elementary. 5/23 - 8	5/23/2005 5/23/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
2254	Closed Work Orders 05/24/05 1.0 Road. 7.0 Assisted Jose Ambriz HVAC, with installing duck work, at Santa Teresa High School, and to trouble shoot a wallmount unit on DOL portable. 5/24 - 8	5/24/2005 5/24/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
2142	Closed Work Orders 05/19/05 1.0 Road 5.0 Finished collecting information from all A/C's at River Side Elementary. 2.0 Started collecting information from all A/C's at Sunland Park Elementary. 5/19 - 8	5/19/2005 5/19/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2101	Closed Work Orders 05/18/05 1.0 Road, 5.0 Finished collecting information for all A/C units at Santa Teresa Middle School. 2.0 Started collecting information on all A/C units at River side Elementary. 5/18 - 8	5/18/2005 5/18/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
2188	Closed Work Orders 05/20/05 2.0 Road 2.0 Assisted Jaime HVAC throw old Master Cools to land field. 4.0 Completed roof survey and turned in to Margret. 5/20 - 8	5/20/2005 5/20/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
2055	Closed Work Orders 05/17/05 1.0 Road 4.0 Collected information on all A/C at GAC. 3.0 Started collecting information on Geothermo System, at Santa Teresa Middle School. 5/17 - 8	5/17/2005 5/17/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
1970	Closed Work Orders 05/13/05 1.0 Road 2.0 Finished collecting information on A/C's units at Anthony Elementary. 5.0 Collected information on all A/C's at Gadsden Middle School. 5/13 - 8	5/16/2005 5/13/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
1966	Closed Work Orders 05/16/05 1.0 Road 5.0 Collected information on al A/C's at La Union Elem. 2.0 Collected information on al A/C's at Desert Pride School. 5/16 - 8	5/16/2005 5/16/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
1784	Closed Work Orders 05/09/05 1.0 Road. 5.0 Took information on all A/C units on Chaparral Elem. 2.0 Started to take information on all units at Anthony Elem. 5/9 - 8	5/10/2005 5/9/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1796	Closed Work Orders 05/10/05 1.0 Road 4.0 Anthony Elementary finished taking information on all A/C units at this site. 3.0 Started to take information on all units A/C at Gadsden Middle School. 5/10 - 8	5/10/2005 5/10/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
1743	Closed Work Orders 05/06/05 1.0 Road 4.0 Took information on all A/C units at Chaparral Middle. 3.0 Started to take information on all A/C units at Chaparral Elementary School. 5/6-8	5/9/2005 5/6/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
1701	Closed Work Orders 05/05/05 4.0 Sunrise Elementary, took information on all a/c information. 4.0 Desert Trail intermediate, took information on all A/C information. As Per Mike. 5/5 - 8	5/5/2005 5/5/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
1629	Closed Work Orders 05/02/05 4.0 La mesa elementary, took information on all the A/C mastercools and refrigeration units.. 4.0 San Miguel Elementary, took information on all the A/C Mastercools and refrigeration units.. As per Mike Munoz. 5/2 - 8	5/3/2005 5/2/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
1631	Closed Work Orders 5/03/05 6.0 Mesquite Elementary, took information on all Units, Refrigeration, Evaporative coolers, Master cools etc. as per Mike Munos. 2.0 Installed used tool box on working truck, at the Shop. 5/3 - 8	5/3/2005 5/3/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
1666	Closed Work Orders 5/04/05 1.0 Assisted Danny Vega At San Miguel Elem, with irrigation timer, Okayed by Margaret. 4.0 Took information on all Air conditioning units, at Berino Elementary. 3.0 Took information on all Air conditioning unit, at Loma Linda elementary. 5/4 - 8	5/5/2005 5/4/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2806	Closed Work Orders 06/15/05 1.5 Took Trash to landfill at Sunland Park. 6.5 Finished removing old floor from portable #142 at Berino Elementary assisting Danny Miranda. 6/15 - 8	6/15/2005 6/15/2005 Medium	Lorenzo Solis Lorenzo Solis		Physical Plant Complex
1242	Complete Need to issue keys to Rudy Burciaga Custodial Warehouse, Closet, PPD Gate and GHS Gate. make 4 keys for Rudy Burciaga	4/19/2005 4/20/2005 Medium	Margret Villalobos Hector Lozoya		Physical Plant Complex
2263	Work In Progress Maint. Office - Need to fix door closer to main door.	5/24/2005 Medium	Margret Villalobos Hector Lozoya		Physical Plant Complex
1673	Work In Progress Transporation Office - Need to install door w/window.	5/5/2005 Medium	Margret Villalobos Danny Miranda		Physical Plant Complex
308	Complete DRAINS BACKING UP. 1425 WO UNCLOG FLOOR DRAINS IN AUTO SHOP WITH SEW MACHINE.	3/11/2005 3/7/2005 Medium	Margret Villalobos Fred Appelzoller		Physical Plant Complex
2529	Work In Progress WAREHOUSE - EDUCATIONAL RESOURCES OFFICE WHEN THE NEW A/C WAS INSTALLED SEVERAL MONTHS AGO. NO ONE EVER CAME BACK TO SEAL AROUND IT. THE DIRT BLOWS IN EVERYTIME THE WIND BLOWS, THIS IS A VERY DAMAGING TO THE EQUIPMENT LOCATED NEAR IT. THANKS - MARTA JACQUEZ Went w/Rudy had trouble w/lady put silicone and sealed around unit.	6/6/2005 6/8/2005 Medium	MARTA JACQUEZ Rudy Arreola		Physical Plant Complex
2657	Work In Progress LADIES RR - THE FAUCET SHOOTS THE WATER OUT IN UNEVEN SPURTS AND ON THE TOILET THE LINE CONNECTING TO THE WALL, MAKES A LOUD SOUND AND RATTLES AND THE WATER FILLING IN COMES IN DIRTY.	6/9/2005 Medium	Marta Jacquez Fred Appelzoller	Restroom (Girls)	Physical Plant Complex
3091	Work In Progress Maintenance Office - Please check ref. unit it is not working properly.	6/30/2005 Medium	Margret Villalobos Jaime Gomez		Physical Plant Complex
1434	Complete BARRACKS - NEED A PRICE QUOTE FOR BATS. REMOVED COVERS ON WINDOWS AND BATS WERE DISPOSED OF. DANNY MIRANDA WILL COVER WINDOWS AGAIN.	4/26/2005 5/3/2005 Medium	Ruben Ronquillo Margret Villalobos		Physical Plant Complex
2997	Work In Progress TRANSP. OFFICE - NEED TO RELOCATE ELEC. OUTLETS A/S/A/P.	6/27/2005 Medium	Sitters Walter Enrique Sotelo		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2998	Work In Progress TRANSP. OFFICE - NEED TO MOVE DOOR OVER 12 INCHES A/S/A/P.	6/27/2005 Medium	Walter Sitters Danny Miranda		Physical Plant Complex
364	Complete Please paint new dry wall that was installed. painted entire hallway and office	3/14/2005 3/22/2005 Medium	Michael Munoz Margret Villalobos		Physical Plant Complex
1626	Complete BARRACKS - NEED TO COVER UP WINDOWS AGAIN.	5/3/2005 5/4/2005 Medium	Michael Munoz Danny Miranda		Physical Plant Complex
353	Work In Progress Need to installing emerg. lights as per pm 125559.	3/14/2005 Medium	Rudy Arreola Enrique Sotelo		Physical Plant Complex
1091	Closed Work Orders 4/12/05 (1)paper work @ call contractors (1.5)service @ wash truk (1.5)1068 (3.5)1078 (.5)back to shop 4/12 - 3	4/13/2005 4/12/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1051	Closed Work Orders 4/11/05 (1)paper work @ call contractors (6.5)1022 (.5)back to shop 4/11/05 - 1.5	4/12/2005 4/11/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
239	Closed Work Orders (1.5)PAPER WORK @ CALL CONTRACTORS (3)123509,96963,105518,124502 (2)118797 (1)123810 (1)121716 (.5) back to shop	3/10/2005 3/10/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
241	Closed Work Orders (1.5)paper work @ call contractors (1.5)110027 (1)115742 (3.5)122652 (.5)back to shop	3/10/2005 3/10/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
242	Closed Work Orders (2)paper work @ make w/o list call contrsctors (1)wash truck (5.5)122601 (.5)back to shop	3/10/2005 3/10/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
243	Closed Work Orders (1)paper work @ call contractors (1.5)123509 (2.5)113676 (1)122601 (1.5)123510 (.5)back to shop	3/10/2005 3/10/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
244	Closed Work Orders (.5)paper work @ call contractors (1)116138 (1)116138 (1)112306 (4)113676 (.5)back to shop	3/10/2005 3/10/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
245	Closed Work Orders 3/4/05 (1.5)paper work @ call contractors (2.5)118925 (3.5)113676 (.5)back to shop	3/10/2005 3/10/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
2848	Closed Work Orders 6/16/05 (1)paper work @ call contractors (3.5)1080 (1)121930 (2)1387, 1749 (.5)back to shop 6/16 - 2	6/17/2005 6/16/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
2935	Closed Work Orders 6/21/05 (.5)paper work @ call contractors (7)121930 (.5)back to shop 6/21-8	6/21/2005 6/21/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
2906	Closed Work Orders 6/20/05 (1)paper work @ call contractors)5.5)pisk up materials at barracks @ lowes, deliver to berino (1.5)inventory 6/20-8	6/21/2005 6/20/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
2948	Closed Work Orders 6/22\05 (8)inventory 6/22 - 8	6/23/2005 6/22/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2992	Closed Work Orders 6/23/05 (8)inventory 6/23 - 8	6/27/2005 6/23/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
2993	Closed Work Orders 6/24/05 (8)inventory 6/24 - 8	6/27/2005 6/24/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
3020	Closed Work Orders 6/27/05 (.5)paper work @ call contractors (5)121930 (2)1080 (.5)back to shop (4)GAC 6/27 - 10	6/28/2005 6/27/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
3052	Closed Work Orders 6/28/05 (1)paper work @ call contractors (11)G.A.C. 6/28 - 12	6/29/2005 6/28/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1173	Closed Work Orders 4/14/05 (.5)paper work @ call contractors (7)pick up materials @ lowes deliver to school sites S.M. BERINO, ANTHONY, AUTO SHOP, @ MAINT. SHOP (.5)BACK TO SHOP 4/14 - 8	4/15/2005 4/14/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1265	Closed Work Orders 4/15/05 (1)paper work @ call contractors (2)115243 (2)118114 (1.5)542 (1)1020 (.5)back to shop 4/15 - 1.5	4/19/2005 4/15/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1295	Closed Work Orders 4/20/05 (1)paper work @ call contractors (5.5)1080 (1)pickup scaffolding @ s.t.h.s. (.5)back to shop 4/20 -2.5	4/20/2005 4/20/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1267	Closed Work Orders 4/19/05 (1)paper work @ call contractors (6.5)1080 (.5)back to shop 4/19 - 1.5	4/19/2005 4/19/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1125	Closed Work Orders 4/13/05 (1.5)paper work @ call contractors,make p/o requests @ material lists (1)1067 (5)1080 (.5)back to shop 4/13 - 2	4/14/2005 4/13/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
912	Closed Work Orders 4/6/05 (.5)PAPER WORK @ CALL CONTRACTORS (7)123269 (.5)BACK TO SHOP	4/7/2005 4/6/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
880	Closed Work Orders 4/4/05 (.5)PAPER WORK @ CALL CONTRACTORS (7)123269 (.5)BACK TO SHOP 4/4 - 8	4/6/2005 4/4/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
951	Closed Work Orders 4/7/05 (7)123269 (.5)back to shop 4/7 - 7.5	4/8/2005 4/7/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
995	Closed Work Orders 4/8/05 (.5)paper work @ call contractors (7)124330 (.5)back to shop 4/8 - 8	4/8/2005 4/8/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
755	Closed Work Orders (4)paper work @ call contractors,make p/o @ material list (2)123269 (1.5)124330 (.5)back to shop	4/1/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
722	Closed Work Orders 3/29/05 (1)PAPER WORK @ CALL CONTRACTORS (1.5)124330 (3.5)123169 (1.5)219 (.5)BACK TO SHOP	3/31/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
738	Complete NEED TO CHANGE LIGHT IN MAINT. RESTROOM install new lamp in rr at shop.	3/31/2005 4/11/2005 Medium	Danny Miranda Enrique Sotelo		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
808	Closed Work Orders 4/1/05 (1)paper work @ call contractors (1.5)124330 (5)123269 (.5)back to shop	4/1/2005 4/1/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
836	Closed Work Orders 4/4/05 (.5)paper work @ call contractors (2)make list for SB-9, or HB-33projects (5)123269 (.5)back to shop 4/6 - 8	4/5/2005 4/6/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
635	Closed Work Orders 3/23/05 (1)paper work @ call contractors (6.5)578 (.5)clean up	3/24/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
636	Closed Work Orders 3/24/05 (1)paper work @ call contractors (1)122601 (3.5)578 (2)repairs @ mesquite elem. east wing restrooms (.5)back to shop	3/24/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
578	Complete need to repair restroom in maint. office put camlite on walls.	3/23/2005 3/31/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
579	Closed Work Orders 3/23/05 (1)paper work @ call contractors (3)578 (4)training s.t.m.s.	3/23/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
558	Closed Work Orders 3/18/05 (.5)paper work @ call contractors (3.5)118925 (3.5)94507,94502,94500,94492,94504,123392,123513 (.5)back to shop	3/21/2005 3/29/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
567	Closed Work Orders 3/21/05 (1.5)paper work @ call contractors (1.5)358 (1)212 (1)219 (1)542 (1.5)123269 (.5)back to shop	3/22/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
431	Closed Work Orders 3/15/05 (1.5)paper work @ call contractors (6)118925 (.5)back to shop	3/16/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
513	Closed Work Orders 3/17/05 (.5)paper work @ call contractors (7)118925 (.5)back to shop	3/18/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
487	Closed Work Orders 3/16/05 (1)PAPER WORK @ CALL CONTRACTORS (6.5)118925 (.5)BACK TO SHOP	3/17/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
366	Closed Work Orders 3/14/05 (1.5)paper work @ call contractors (6)118925 (.5)back to shop	3/14/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
344	Closed Work Orders 3/7/05 (1)paper work @ call contractors (3)183 (1)122601 (2.5)118929 (.5)back to shop	3/14/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
346	Closed Work Orders 3/8/05 (1)paper work call contractors (1.5)111753 (2.5)118925 (1)108756 (1.5)113625 (.5)bzck to shop	3/14/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
347	Closed Work Orders 3/9/05 (.5)paper work @ call contractors (3)206 (4)118925 (.5)back to shop	3/14/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
349	Closed Work Orders 3/10/05 (1)paper work @ call contractors (1.5)212 (1.5)118925 (1)repair door at maint. barracks (1.5)219 (1)212 (.5)back to shop	3/14/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
350	Closed Work Orders 3/11/05 (1)paper work @ call contractors (4.5)measure doors with contractor @gms,ghs,anthony elem,chap. mid,la mesa elem,@ stms (1)118925 (1)clean shop (.5)back to shop	3/14/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
2374	Closed Work Orders 5/26/05 (.5)paper work @ call contractors (1.5)295 (2)2367 (1.5)261 (1)110027 (1)207 (.5)back to shop	5/27/2005 5/26/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
	5/26 - 2				
2398	Closed Work Orders 5/31/05 (1)paper work@ call contractors (1.5)121930 (2.5)1950 (1.5)261 (1)110027 (.5)back to shop	5/31/2005 5/31/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
	5/31 - 4				
2513	Closed Work Orders 6/3/05 (1.5)paper work @ call contractors (1.5)263 (1.5)261 (3)1950 (.5)back to shop	6/6/2005 6/3/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
	6/3 - 2				

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2465	Closed Work Orders 6/2/05 (.5)paper work @ call contractors (1.5)went to A L S locksmith to get quote for materials, (1.5)107504 (1.5)110027 (2.5)work on material list for p/o requests (.5)back to shop	6/2/2005 6/2/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
	6/2 - 8				
2443	Closed Work Orders 6/1/05 (1)paper work @ call contractors (1)124231 (1.5)2347 (2)107504 (.5)back to shop	6/2/2005 6/1/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
	6/1 - 4.5				
2295	Closed Work Orders 5/25/05 (.5)paper work @ call contractors (2)1673 (2.5)1950 (1.5)meeting with clark @ associates (1)2205 (.5)back to shop	5/25/2005 5/25/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
	(1.5)meeting with clark @ associates 5/25 - 4				
2266	Closed Work Orders 5/24/05 (1)paper work @ call contractors (1)2027 (2)2059 (1)94493 (1)94497 (1.5)407 (.5)back to shop	5/25/2005 5/24/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
	5/24 3.5				
2227	Closed Work Orders 5/23/05 (1)PAPER WORK @ CALL CONTRACTORS (1.5)2205 (1.5)261 (3.5)657,94505,94506 (.5)BACK TO SHOP	5/23/2005 5/23/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
	5/23 -1.5				

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2345	Closed Work Orders 5/26/05 (1)paper work @ call contractors (2)1020 (3)542, 2059 (1.5)2210 (.5)back to shop 5/26 - 1.5	5/27/2005 5/26/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
2114	Closed Work Orders 5/19/05 (.5)paper work @ call contractors (3)115243, 118114 (.5)358 5/19 - 4	5/19/2005 5/19/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
2099	Closed Work Orders 5/8/05 (1)paper work call contractors @make p/o requests (6.5)1976 (.5)back to shop 5/18 - 1.5	5/18/2005 5/18/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1950	Work In Progress DEMO WALLS @ G.A.C C-WING Medium	5/16/2005	Danny Miranda Danny Miranda		Physical Plant Complex
1922	Closed Work Orders 5/12/05 (1)paper work @ call contractors (6.5)1696 (.5)back to shop 5/12 - 1.5	5/13/2005 5/12/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1923	Closed Work Orders 5/13/05 (.5)paper work @ call contractors (7.5)help in werehouse 5/13 - 8	5/13/2005 5/13/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
2053	Closed Work Orders (.5)paper work @ call contractors (1)1391 (1.5)1828 (4.5)1950 (.5)back to shop 5/17 - 1	5/17/2005 5/17/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
2054	Closed Work Orders (1)paper work @ call contractors (1.5)115243, 118114 (5)1976 (.5)back to shop 5/16 - 8	5/17/2005 5/16/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1485	Closed Work Orders 4/27/05 (.1)paper work @ call contractors (2)pickup materials @ lowes and diliver to school site (2)check floors @ anthony elem portables (2.5)124231, 119456 (.5)back to shop 4/27- 8	4/28/2005 4/28/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1518	Closed Work Orders 4/28/05 (1)clean and wash truck (.5)paper work @ call contractors (2)measure for countr tops and cabinets at g.h.s. (2)measure and make mterial list for vandal of gym g.m.s. (2) automatic doors GAC (.5)back to shop 4/28 - 8	4/29/2005 4/28/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1519	Closed Work Orders 4/29/05 (.5)paper work @ call contractors (7.5)help with warehouse and building mech. 4/29 - 8	4/29/2005 4/29/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1594	Closed Work Orders 5/2/05 (1)paper work @ call contractors (6.6)1565 (.5)back to shop 5/2 - 1.5	5/3/2005 5/2/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1421	Closed Work Orders 4/25/05 (.5)paper work @ call contractors (7)1080 (.5)back to shop 4/25-1	4/26/2005 4/25/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1448	Closed Work Orders 4/26/05 (1)paper work @ call contractors (2)121930 (2)361 (2.5)1080 (.5)back to shop 4/26 - 3.5	4/27/2005 4/26/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1338	Closed Work Orders 4/21/05 (1)paper work @ call contractors (1)111753 (2)263, 261 (1.5)94506, 207 (2)1080 (.5)back to shop 4/21 - 2.5	4/22/2005 4/21/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1776	Closed Work Orders 5/9/05 (1)paper work @ call contractors (5.5)1749 (1)work on custodial list for construction (.5)back to shop 5/9 - 2.5	5/10/2005 5/9/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1867	Closed Work Orders 5/11/05 (.5)PAPER WORK @ CALL CONTRACTORS (7)1086 (.5)BACK TO SHOP 5/11 - 1	5/11/2005 5/11/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1865	Closed Work Orders 5/10/05 (1)PAPER WORK @ CALL CONTRACTORS (3)1749 (3.5)1387 (.5)BACK TO SHOP 5/10 - 1.5	5/11/2005 5/10/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1661	Closed Work Orders 5/4/05 (1)paper work @ call contractors (1.5)1626 (1.5)1657 (2)1067 (1.5)1565 (.5)back to shop 5/4 - 1.5	5/4/2005 5/4/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1633	Closed Work Orders 5/3/05 (1)paper work @ call contractors (6.5)1067 (.5)back to shop 5/3 - 1.5	5/4/2005 5/3/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1304	Duplicate Request Need key for new shop. Medium	4/21/2005	Carlos Castillo Hector Lozoya	Electrical Room	Physical Plant Complex
1549	Complete need replace #7 key replace 7 pin master Medium	5/2/2005 4/29/2005	Carlos Castillo Hector Lozoya	Electrical Room	Physical Plant Complex
2679	Closed Work Orders 6/9/05 (1)paper work @ call contractors (1)725 (2)2376,2585 (2)1884 (1.5)121930 (.5)back to shop 6/9 - 3	6/10/2005 6/9/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2715	Closed Work Orders 6/10/05 (1.5)paper work @ call contractors (2.5)121930 6/10 - 4	6/13/2005 6/10/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
2727	Void 6/13/05 need to replace doors @ 10x56 window kit	6/13/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
2525	Closed Work Orders 6/4/05 (8)1950 SEE WO 1950	6/6/2005 Medium	Danny Miranda		Physical Plant Complex
2562	Closed Work Orders 6/6/05 (1)paper work @ call contractors (2)121930 (3.5)2477 (1)1950 (.5)back to shop 6/6 - 3.5	6/7/2005 6/6/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
2605	Closed Work Orders 6/7/05 (1.5)paper work @ call contractors (2)116109 (4)121930 (.5)back to shop 6/7 - 8	6/7/2005 6/7/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
2655	Closed Work Orders 6/8/05 (1)paper work @ call contractors (3)pick up materials @ ace hardware & builders specialies and deliver to GAC (2.5)121930 (5.5)1950 6/8 - 6.5	6/9/2005 6/8/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
2865	Closed Work Orders 6/17/05 (1.5)paper work @ call contractors (1)2812 (1.5)1749 (2)1080 (1.5)121930 (.5)back to shop 6/17 - 3.5	6/17/2005 6/17/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1309	Work In Progress Need to make material list and request for general maintenance duties	4/21/2005 Medium	Carlos Castillo Carlos Castillo	Electrical Room	Physical Plant Complex
1245	Complete Electrical Shop - Need a new key for office. duplicate 2-a16 for electricians	4/19/2005 4/22/2005 Medium	Carlos Castillo Hector Lozoya		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2810	Closed Work Orders 6/15/05 (1)paper work @ call contractors (4)121930 (2.5)1080 (.5)back to shop 6/15 - 5.5	6/15/2005 6/15/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
2782	Closed Work Orders 6/14/05 (1)paper work @ call contractors (2)2761 (3)2477 (1.5)1080 (.5)back to shop 6/14 - 1.5	6/15/2005 6/14/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
2759	Closed Work Orders 6/13/05 (1)paper work @ call contractors (2)1950 (1.5)263 (1.5)2477 (1.5)2635 (.5)back to shop 6/13 - 1.5	6/14/2005 6/13/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1698	Closed Work Orders 5/5/05/ (1)paper work @ call contractors (6.5)1698 (.5)back to shop 5/5 - 1.5	5/5/2005 5/5/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1699	Duplicate Request need to repair walls at panther hut 5/5/2005 Medium	5/5/2005	Danny Miranda Danny Miranda		Physical Plant Complex
1379	Closed Work Orders 4/22/04 (1)paper work @ call contractors (4)111753 (2.5)1080 (.5)back to shop 4/22 5.5	4/25/2005 4/22/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
2112	Complete A/C UNIT ON THE WAREHOUSE SIDE IS BLOWING HOT AIR. float was stuck	5/19/2005 5/18/2005 Medium	ENRIQUE BRIONES Rudy Arreola		Physical Plant Complex
152	Complete Food Service Warehouse - Loading Dock Area dirt needs to be removed. remove sand build up and fill in with crusher fine.	3/8/2005 3/9/2005 Medium	Robert Sanchez		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1248	Complete Transportation Office - Needs to be painted before June (before furniture comes in). Thanks PAINTED TRANSPORTATION OFFICE. SUPPLIES PROVIDED BY MAINTENANCE DEPT.	4/19/2005 5/20/2005 Medium	Guillermo Hernandez		Physical Plant Complex Walter Sitters
1606	Complete NEED TO CHANGE LOCKS ON HVAC BARRACK TO DC-2 AS PER MIKE MUNOZ. (MS) rekey barrack to DC1	5/3/2005 5/2/2005 Medium	Hector Lozoya		Physical Plant Complex
1866	Complete need to provide flooring to auto shop. aztec NEW VCT W/COVEBASE INSTALLED.	5/11/2005 6/10/2005 Medium	Michael Munoz		Physical Plant Complex
2235	Work In Progress please order material for fill for district portable re- location. please include site and material that will be delivered on w.o . (per site)	5/24/2005 Medium	Lorenzo Hernandez		Physical Plant Complex
2357	Work In Progress Custodial Office - Need to correct cooling in Mary and Aida's Office.	5/27/2005 Medium	Alfredo Holguin Jaime Gomez	Custodial	Physical Plant Complex
3092	Work In Progress Install Speed limit signs and speed bumps on access road. See me on specifics	6/30/2005 Safety	Alfredo Holguin Michael Munoz		Physical Plant Complex
1728	Closed Work Orders 5/6/05 (1)paper work @ call contractors (2)1020 (2)1727 (1.5)542 (1)122796 (.5)back to shop 5/6 - 2.5	5/6/2005 5/6/2005 Medium	Danny Miranda Danny Miranda		Physical Plant Complex
1241	Complete START UP A/C AT THE SNP WAREHOUSE STARTED UP AIR CONDITIONERS AFTER CLEANING, INSTALLING NEW FLOAT VALVE ON ONE OF THEM AND REPLACING BROKEN WATER LINE	4/19/2005 4/20/2005 Medium	Danny Orozco Danny Orozco		Physical Plant Complex
3085	Complete WALK-IN FREEZER #3 NOT COOLING REMOVED AND REPLACED BAD DEFROST TIMER	6/29/2005 6/30/2005 Medium	Danny Orozco Danny Orozco		Physical Plant Complex
2412	Complete Jimmy I need a vacuum cleaner bag. Thank you RECEIVED 1 VACUUM BAG	6/1/2005 6/3/2005 Medium	Guillermo Hernandez Jimmy Carbajal		Physical Plant Complex Custodial
2413	Duplicate Request Jimmy I need a vacuum cleaner bag. Thank you DUPLICATE, SEE W.O. #2412	6/1/2005 Medium	Guillermo Hernandez		Physical Plant Complex Custodial
2631	Work In Progress Need to replace door knob to outside Double Doors.	6/8/2005 Medium	HECTOR LOZOYA Hector Lozoya		Physical Plant Complex

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2070	Work In Progress FREEZER #3 LIGHT SWITCH IS OUT.	5/18/2005 Medium	Jacqueline Aguilar Danny Orozco		Physical Plant Complex
744	Complete NEED TO REPLACE BOTH BATTERIES ON THE AUTOMATIC SCRUBBER AT DESERT TRAIL REPLACED 2 DEEP CYLCE BATTERIES AND VACUUM HOSE	3/31/2005 5/20/2005 Medium	Jimmy Carbajal Jimmy Carbajal	Custodial	Physical Plant Complex
1187	Complete RUDY COULD YOU PLEASE GET OUR A.C. GOING WE WOULD REALLY APPRECIATE IT, THANK YOU:)	4/15/2005 4/18/2005 Medium	Jimmy Carbajal Margret Villalobos	Custodial	Physical Plant Complex
2734	Complete EXTRACTOR NOT SPRAYING WATER PROPERLY REPLACED PARTES (ISSUED THRU ACT 1000) AND ALSO DID P.M. AS PER JIMMY	6/13/2005 6/13/2005 Medium	Jimmy Carbajal Jimmy Carbajal	Custodial	Physical Plant Complex
1430	Work In Progress OVEN NOT WORKING AT ALL. NANCY ROLLIN SNP MGR 589-2550	4/26/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	Riverside ES
1868	Duplicate Request BOTTOM OVEN IS OUT. NANCY ROLLIN SNP MGR 589-5332 DUPLICATE WORK ORDER #1430	5/12/2005 5/13/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	Riverside ES
2479	Void CONNECT UTILITIES TO PORTABLE. THIS PORTABLE DOES NOT HAVE ANY PLBG CONNECTIONS	6/3/2005 6/30/2005 Medium	David Villalobos David Villalobos		Riverside ES PORTABLE
797	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. COMPLETED AS PER MIGUEL AGUILAR	4/1/2005 5/23/2005 Medium	Aida Salcedo Miguel Aguilar		Riverside ES
784	Void 03/30/05 4-cleaning master cools on ch/ desert t. 1-servise restroom on room 128 3- painting new doors rooms 96 57 and54	4/1/2005 Medium	Aida Salcedo		Riverside ES
262	Complete Nancy Rollin - SNP Manager - Garbage disposal is stopped (plugged) up. 1407 wo Informed Nancy not to drop full pans of food in disposal. Had to remove trap from garbage disposal unplug drain and repalce trap.	3/10/2005 3/4/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Riverside ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2940	Work In Progress Door to Walk-In Refrigerator is icing up Nancy Rollin - SNP Manager 589-2550	6/22/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Riverside ES
3100	Work In Progress ON JULY 5TH, SAL, JIMMY & GUILLERMO - NEED TO PICK UP TABLES & CHAIRS FROM RIVERSIDE AND DELIVER TO LA MESA CAFETERIA.	6/30/2005 Medium			Riverside ES
1971	Work In Progress Please remove carpet and install VCT with covebase in the following classrooms. 32,34,35,36,37,39,41. Faxed PO 45013991 on 6/17/05 - mkv	5/16/2005 Medium	Michael Munoz	Classroom	Riverside ES
2085	Work In Progress RM 39, PLEASE REMOVE OLD CAULK AND BLOW OUT WITH AIR. INSTALLED NEW SEAL TO PREVENT AIR FROM ENTERING. ROOF TOP	5/18/2005 Medium	Adan Duran	Classroom	Riverside ES
2086	Work In Progress PLEASE INSTALL NEW WEATHER STRIPPING TO ALL DOORS AND WINDOWS TO PREVENT SAND FROM ENTERING ROOM.	5/18/2005 Medium	Adan Duran	Classroom	Riverside ES
2087	Work In Progress PLEASE REMOVE OLD TAR AND APPLY NEW ONE WHERE 90 WEIGHT IS BETWEEN CAFETERIA AND AUDITORIUM. ALSO REMOVE SAND FROM ROOF TOP.	5/18/2005 Medium	Adan Duran	Cafeteria	Riverside ES
2088	Work In Progress PLEASE REMOVE OLD SEAL, INSTALL NEW ONE WITH NEW CAULKING AND 45 CONCRETE AGAINST WALL AND FLOOR. OUTSIDE PATIO WHERE MAIN HALL WAY ENTERS TOWARDS CAFETERIA. THIS WILL PREVENT WATER FROM ENTERING TO BUILDING.	5/18/2005 Medium	Adan Duran	Cafeteria	Riverside ES
2151	Complete KITCHEN HOOD SUPPRESSION SYSTEMS WAS DISCHARGED BY ACCIDENT. NEED TO RE- CHARGE SYSTEM. DIMAR SYSTEMS RECHARGED AND RESET SYSTEM	5/20/2005 6/8/2005 High	Danny Orozco	Cafeteria	Riverside ES
2982	Work In Progress 6/24/05 MR JOSE AMBRIZ SIR THE HEATING COIL IN THE WOMANS BATHROOM NEW WING IS LEAKING ALONG THE WALL THANK YOU SIR	6/24/2005 Medium	Adan Duran Jose Ambriz		Riverside ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2983	Closed Work Orders 6/24/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 1 WATERED PLAYGROUND TREES 1 REPAIR 5 BUBLERS HEADS VANDALS 11/2 PICKED UP SUPPLIES AND FUEL TRUCK 3 PAINT YELLOW STRIPS FRONT PARKING AREA 1/2 CLOSE GATES 1/2 FILE WORK REPORT AND SIGN OUT 6/24 - 8	6/24/2005 6/24/2005 Medium	Adan Duran Adan Duran		Riverside ES
2947	Work In Progress MR JOSE AMBRIZ JOSE HAVE A WATER FOUNTAIN LEAKING SMALL BLUE WATER LINE BUSTED WILL NEED FITTINGS TO REPAIR THANK YOU SIR	6/22/2005 Medium	Adan Duran Jose Ambriz		Riverside ES
2945	Closed Work Orders 6/22/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 31/2 DRILL AND SEAL WINDOWS 3 CAULK WINDOWS 1/2 CLOSE GATES 1/2 FILE WORK REPORT AND SIGN OUT 6/22 - 8	6/22/2005 6/22/2005 Medium	Adan Duran Adan Duran		Riverside ES
2958	Closed Work Orders 6/23/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 41/2 CAULK WINDOWS 1 CHANGE OUT LIGHT BULBS IN CAFETEIRA 1 CUT WEEDS SOUTH PLAYGROUND 1/2 CLOSE GATES 1/2 FILE WORK REPORT AND SIGN OUT 6/23 - 8	6/23/2005 6/23/2005 Medium	Adan Duran Adan Duran		Riverside ES
2914	Closed Work Orders 6/21/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 31/2 SEAL WINDOWS 1 REPLACE BROKEN WINDOW RM 22 2 START CAULKING WINDOWS 1/2 CLOSE GATES 1/2 FILE WORK REPORT AND SIGN OUT 6/21-8	6/21/2005 6/21/2005 Medium	Adan Duran Adan Duran		Riverside ES
2857	Closed Work Orders 6/17/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 61/2 SWEEP ALL PARKING LOTS FRONT BACK SIDES WITH BOBCAT SWEEPER 1/2 CLOSE GATES 1/2 FILE WORK REPORT AND SIGN OUT 6/17 - 8	6/17/2005 6/17/2005 Medium	Adan Duran Adan Duran		Riverside ES
2858	Closed Work Orders 6/16/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 61/2 CLEAN AND REMOVE SAND FROM CURBS AND WALL BOBCAT LOADER 1/2 CLOSE GATES 1/2 FILE WORK REPORT AND SIGN OUT 6/16 - 8	6/17/2005 6/16/2005 Medium	Adan Duran Adan Duran		Riverside ES
2895	Closed Work Orders 6/20/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 21/2 MOWED GRASS 1 WASH AND CLEAN MOWER AND FUELED 2 DRILL AND SEAL WINDOWS 1 SPREAD SAND WITH BOBCAT 1/2 CLOSE GATES 1/2 FILE WORK REPORT AND SIGN OUT 6/20-8	6/20/2005 6/20/2005 Medium	Adan Duran Adan Duran		Riverside ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2707	Closed Work Orders 6/10/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 2 DRILL AND SEAL WINDOWS 11/2 PICKED UP SUPPLIES AND FUEL TRUCK 2 HAD LUNCH AT UTILITYS WITH MR SPEEDY REPORT BACK TO SCHOOL SITE 1 UNLOAD SUPPLIES AND STORE IN MORGAN BUILDING 1/2 CLOSE GATES 1/2 FILE WORK REPORT AND SIGN OUT 6/10 - 8	6/10/2005 6/10/2005 Medium	Adan Duran Adan Duran		Riverside ES
2743	Closed Work Orders 6/13/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 21/2 MOWED GRASS 1 TRIM AROUND CIRCLE 2 SEAL MORE WINDOWS 11/2 REMOVE SAND FROM CURBS BOB CAT 1/2 FILE WORK REPORT AND SIGN OUT 6/13 - 8	6/13/2005 6/13/2005 Medium	Adan Duran Adan Duran		Riverside ES
2744	Work In Progress MR LORENZO HERNANDEZ SPEEDY SIR WILL NEED ABOUT 70 TONS OF SAND FOR NORTH PLAYGROUND VERY LOW UNDER SLIDES THANK YOU SIR	6/13/2005 Medium	Adan Duran Lorenzo Hernandez		Riverside ES
2535	Closed Work Orders 6/3/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 1 REPAIR DOOR LOCKS RM 121 1 MOVE SHELFS FROM ROOM 38 TO 137 1 CHECKED OUT ENTRANCE GATES WITH MIKE MUNOZ 1/2 SPREAD ANT POSION ANT HILLS 11/2 PULL OUT WOOD PELETS OUT OF COURT YARD 11/2 SETTING UP OF NEW PORTABLE 1/2 CLOSE GATES 1/2 FILE WORK REPORT AND SIGN OUT 6/3 - 8	6/6/2005 6/3/2005 Medium	Adan Duran Adan Duran		Riverside ES
2532	Complete 6/6/05 MANNY LOZOYA MANNY WILL NEED KEY CHANGED ON NEW PORTABLE BUILDING THAT WAS DELIVERED TO RIVERSIDE ON FRIDAY THE DOOR IS UNLOCK AT THIS TIME THANK YOU SIR REKEY CORE TO SA63	6/6/2005 6/6/2005 Medium	Adan Duran Hector Lozoya		Riverside ES
2549	Closed Work Orders 6/6/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 1/2 DIG OUT AND REPLACE BROKEN SPRINKLER 11/2 PRUN PALM TREES AND WATERD 1 WATERD PLAYGROUND TREES 1/2 FILED TWO WORK ORDERS 3 MOWED GRASS FUEL AND WASH MOWER 1/2 CLOSE GATES 1/2 FILE WORK REPORT AND SIGN OUT 6/6 - 8	6/6/2005 6/6/2005 Medium	Adan Duran Adan Duran		Riverside ES
2586	Complete 6/7/05 MR MIKE MUNOZ SIR WOULD LIKE TO USE BOB CAT TO CLEAN SAND FROM PARKING AREA AND FRONT CIRCLE DEL BOBCAT WITH SCRAPER	6/7/2005 6/17/2005 Medium	Adan Duran Angel Gonzales		Riverside ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2596	Closed Work Orders 6/7/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 1/2 REPLACE BROKEN BUBLER SOUTH SIDE PINE TREES 1 PICK UP JOHNDEERE FOR DESERTVIEW 1 START REMOVING SAND FROM CURB TRATOR HEATING UP HAD TO STOP 11/2 SPRAY ROUND UP AROUND SCHOOL BUILDING 11/2 CHANGE OUT BLADES ON MOWER 1 REPAIR TWO EXIT DOORS GETTING STUCK 1/2 CLOSE GATES 1/2 FILE WORK REPORT AND SIGN OUT 6/7 - 8	6/7/2005 6/7/2005 Medium	Adan Duran Adan Duran		Riverside ES
2663	Closed Work Orders 6/9/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 1 CUT AND INSTALLED LIGHT COVER PORTABLE RM A 1 DRILL AND HANG CHARTS IN MAIN OFFICE 11/2 126548 FIRE EXTINGUISHERS 1 126546 EMERGENCY LIGHTING 1 126547 EXIT SIGNS 1 SEAL WINDOWS NORTH SIDE 1/2 CLOSE GATES 1/2 FILE WORK REPORT AND SIGN OUT 6/9 - 7	6/9/2005 6/9/2005 Medium	Adan Duran Adan Duran		Riverside ES
2447	Closed Work Orders 6/2/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 5 PIPE DRAG PLAYGROUND AND ALL AROUND SCHOOL 1 CHECK AC ROOM 116 KEEPS GOING OFF 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 6/2 - 8	6/2/2005 6/2/2005 Medium	Adan Duran Adan Duran		Riverside ES
2395	Closed Work Orders 5/31/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 1/2 CAULK AC REM 25 21/2 MOWED GRASS 11/2 TRIM EDGES WEED TRIMER 11/2 CLEAN OFF SIDEWALKS 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 5/31 - 8	5/31/2005 5/31/2005 Medium	Adan Duran Adan Duran		Riverside ES
2416	Closed Work Orders 6/1/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 1 CHANGE OUT TRASH BAGS PLAYGROUND 2 CHOP WEEDS NORTH SIDE PARKING 1 SPREAD POISON FIRE ANTS 1 CLEAN OUT ELECTRICAL ROOM BY CAFETERIA 1 CLEAN OUT WATER HEATER ROOM OUTSIDE CAFETERIA 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 6/1 - 8	6/1/2005 6/1/2005 Medium	Adan Duran Adan Duran		Riverside ES
2444	Work In Progress 6/2/05 MR JOSE AMBRIZ ROOM 116 NEW WING ELECTRICAL BOX THE FUSE HOLDERS ARE VERY WEAK WILL NOT HOLD FUSES AC KEEPS GOING OFF NEED TO REPLACE THANK YOU SIR	6/2/2005 Medium	Adan Duran Jose Ambriz		Riverside ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2371	Closed Work Orders 5/27/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 11/2 CHOP WEEDS WEST SIDE OF SCHOOL 11/2 PICKED UP SUPPLIES AND FUEL TRUCK 3 1/2 MONTHLY INSPECTIONIS 1/2 FILE WORK REPORT AND SIGN OUT 5/27 - 8	5/27/2005 5/27/2005 Medium	Adan Duran Adan Duran		Riverside ES
2326	Closed Work Orders 5/26/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 3 CHOP WEEDS WEST AND SOUTH FENCE 1 PICKED UP TRASH FROM PLAYGROUND 2 CLEAN OUT ELECTRICAL ROOMS NORTH SIDE AND SOUTH 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 5/26 - 8	5/26/2005 5/26/2005 Medium	Adan Duran Adan Duran		Riverside ES
2313	Duplicate Request 5/26/05 ANGEL GONZALES NEED NEW BLADES FOR JOHNDEERE MOWER REAL BAD NOT OVER LAPING AND CUTTING THANK YOU SIR DUPLICATE 1576	5/26/2005 6/29/2005 Medium	Adan Duran Angel Gonzales		Riverside ES
2251	Complete MR MANNY LOZOYA MR VALTIERRA WOULD LIKE FOR YOU TO CHANGE LOCKES IN THE NEW PORTABLE THE TWO INSIDE DOORS THANK YOU SIR	5/24/2005 5/31/2005 Medium	Adan Duran Hector Lozoya		Riverside ES
2252	Closed Work Orders 5/24/05 1SIGN IN CLOSE WEST AND NORTH GATES AND REOPEN 11/2 CHOP WEEDS NORTH EAST FENCE 1 REPAIR WATER FOUNTAIN 1/2 ADJUST WATER FLOW OUTSIDE FOUNTAINS 11/2 126252 FIRE EXTINGUISHERS 1 126250 EMERGENCY LIGHTING 1/2 MADE COPS OF WO SHEEDS 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 5/24 7.5	5/24/2005 5/24/2005 Medium	Adan Duran Adan Duran		Riverside ES
2293	Closed Work Orders 5/25/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 1/2 LOAD LUNCHS ON BUS 1 WORKED WITH FIRE SAFTY PEOPEL IN CAFETERIA 11/2 CHOP WEEDS SOUTH EAST 1 TURN ON PILOT LIGHTS IN KITCHEN 1 PRUN MESQITE TREES IN FRONT 1 WATER PLAYGROUND TREES 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 5/25 - 8	5/25/2005 5/25/2005 Medium	Adan Duran Adan Duran		Riverside ES
2185	Work In Progress 5/20/05 MR CARLOS CASTILLO WILL NEED LIFT TO CHANGE OUT LIGHTS IN GYN AND CAFETERIA BURN OUT THANK YOU SIR	5/20/2005 Medium	Adan Duran Carlos Castillo		Riverside ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2187	Closed Work Orders 5/20/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 2 1/2 MOWED GRASS 1/2 CHECK AC NOT COOLING 1 REPLACE BUBLERS HEAD VANDAL AGAIN 1 HELP MR CASTILLO CHANGE OUT WATER PUMP SWITCHS IN CAFETIERA 1 START AND WO 2074 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 5/20 - 7.5	5/20/2005 5/20/2005 Medium	Adan Duran Adan Duran		Riverside ES
2092	Closed Work Orders 5/18/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 1 CHECKED AC UNITS WITH LORENZO 1 1/2 DISASSEMBLE AND DIG OUT SOCCOR GOAL POST 1/2 HELP PUT BACK EXHUST FEN 1 BREAK CEMENT OFF POST AND STORE 2 SCRAPE SOCCOR FIELD WITH 5510 JOHNDEERE 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 5/18 - 8	5/18/2005 5/18/2005 Medium	Adan Duran Adan Duran		Riverside ES
2126	Closed Work Orders 5/19/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 4 SCRAPE PLAYGROUND 5510 JOHNDEERE 1 ALARM SYSTEM WENT OFF CHECK OUT 1 START UP AC UNITS LIBRARY AND OFFICE 1/2 CLOSE WEST AND DROP OFF 1/2 FILE WORK REPORT AND SIGN OUT 5/19 - 8	5/19/2005 5/19/2005 Medium	Adan Duran Adan Duran		Riverside ES
1961	Closed Work Orders 5/13/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 1 WORKED AN AC UNIT RM 22 REPLACE SWITCH 1/2 LUBRICATE EXIT DOOR 1 1/2 PICKED UP SUPPLIES AND FUEL TRUCK 1 125251 CHECK ALL EXIT SIGNS 1 REPAIR SPRINKLER HEADS REMOVED BY VANDALS 1 COVER BROKEN WINDOW WITH GLASS PATCH 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 5/13 - 8	5/16/2005 5/13/2005 Medium	Adan Duran Adan Duran		Riverside ES
1962	Closed Work Orders 5/16/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 3 CHOP WEEDS NORTH AND EAST FENCE 1 MET WITH MIKE MUNOZ CHECK OUT ROOMS 2 PIPE DRAG EAST SIDE OF SCHOOL 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 5/16 - 8	5/16/2005 5/16/2005 Medium	Adan Duran Adan Duran		Riverside ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1911	Closed Work Orders 5/12/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REPOEN 1 CHECKED OUT VANDALS BROKEN WINDOWS 2 FINISHED WORKING ON WATER FOUNTAIN WITH MR VILLALOBOS 1 CLEAN AND REMOVE GRAFFITI FROM PLAYGROUND 1 REPAIR 3 LEAKING FACETS BATHROOM 1 UNPLUG BOYS BATHROOM URNAL 1/2 CLOSE WEST GATES AND DROP OFF 1/2 FILE WORK REPORT AND SIGN OUT 5/12 - 8	5/12/2005 5/12/2005 Medium	Adan Duran Adan Duran		Riverside ES
2048	Complete 5/17/05 MR JOSE AMBRIZ NEED TO CHANGE OUT MOTOR EXHUST FAN ELECTRICAL ROOM NEW WING THANK YOU SIR REMOVE OLD EXHAUST FAN MOTOR, ELEC REPLACE IT WITH A NEW ONE RE-HOOK UP.	5/17/2005 5/19/2005 Medium	Adan Duran Jose Ambriz		Riverside ES
2049	Complete 5/17/05 MR CARLOS CASTILLO NEED TO CHANGE OUT SWITCH FOR AC IN CAFETERIA WATER PUMP NOT WORKING THANK YOU SIR replace worn out switch	5/17/2005 6/22/2005 Medium	Adan Duran Carlos Castillo		Riverside ES
2051	Closed Work Orders 5/17/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 1 CHECKED ALAARM SYSTEM WITH MR VIGIL 2 REMOVE SOCCOR GOALS FROM PLAYGROUND VANDALS MESSED UP PRETTY BAD 1 HELP MR AMBRIZ CHANGE PULL OUT EXHAST FAN AND MOTOR 2 DIG UP REMOVE TWO CEMENET POSTS 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 5/17 - 8	5/17/2005 5/17/2005 Medium	Adan Duran Adan Duran		Riverside ES
1844	Closed Work Orders 5/11/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 1 WORKED ON AC REPLACE WATER PUMP 1 WATERED PLAYGROUND TREES 1 PICK UP TRASH ALONG FENCE 2 WORKED ON WATER FOUNTAIN EAST SIDE WITH MR VILLALOBOS 1 CHOP WEEDS NORTH FENCE 1/2 CLOSE WEST GATES AND DROP OFF 1/2 FILE WORK REPORT AND SIGN OUT 5/11 - 8	5/11/2005 5/11/2005 Medium	Adan Duran Adan Duran		Riverside ES
1801	Closed Work Orders 5/10/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 11/2 SHOVEL AND REMOVE SAND FROM FRONT ENTRANCE 11/2 UNPLUG AND REPAIR WATERFOUNTAIN 1 WORKED ON AC UNIT BLOWING HOT AIR CAFTETIRA 2 WORK WITH MR CASTILLO ELECTRICAL 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 5/10 - 8	5/10/2005 5/10/2005 Medium	Adan Duran Adan Duran		Riverside ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1620	Closed Work Orders 5/3/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 1 REPAIR TABLE AND SHUT OFF 3 BLOWERS 2 CLEAN SIDEWALK SOUTH ENTRANCE AND CHOP WEEDS 1 AC UNIT RM 145 NOT WORKING REPLACE WATER PUMP 1 1/2 CHOP WEEDS AND HAUL OFF BY LIBRARY 1/2 CAP OFF BROKEN BUBLER 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 5/3 - 8	5/3/2005 5/3/2005 Medium	Adan Duran Adan Duran		Riverside ES
1687	Closed Work Orders 5/4/05 1 CLOSE NORTH AND WEST GATES AND REOPEN 4 1/2 REPACED AC PADS GYM CAFETERIA AND KITCHEN 1 START UP AC UNIT ROOM 37 NOT WORKING 1/2 CHECK DOOR HANDLE CAME OFF 1/2 CLOSE WEST GATES AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 5/4 - 8	5/5/2005 5/4/2005 Medium	Adan Duran Adan Duran		Riverside ES
1688	Closed Work Orders 5/5/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 1 REPAIR BROKEN CHAIR RM 21 1 REPAIR GYM DOOR CAME APART 1/2 MET WITH SUNLAND POLICE VANDALS 1 1/2 REMOVE GARFITTI FROM BOTH PLAYGROUNDS 1 REPLACE AC AIR FILTERS PORTABLE 1 RESTART AC UNIT TEACHERS WORK ROOM 1/2 CLOSE WET AND DDROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 5/5 - 8	5/5/2005 5/5/2005 Medium	Adan Duran Adan Duran		Riverside ES
1684	Complete 5/5/05 MR CASTILLO HAVE TWO ELECTRICAL LINE EXPOSE BY THE WATER FOUNTAIN NEED TO COVER LINES KIDS KEEP PULLING PLUGS OUT THANK YOU SIR ck'd and found water ftn cords are exposed wires, no hazard or problem.	5/5/2005 5/10/2005 Medium	Adan Duran Carlos Castillo		Riverside ES
1718	Closed Work Orders 5/56/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 4 121322 REPORT TO DESERT VIEW WELD FRAME FOR AC UNIT 1 RESET AND START UP AC LIBRARY 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 1 START AC UNIT RM137 NOT WORKING 5/6 - 8	5/6/2005 5/6/2005 Medium	Adan Duran Adan Duran		Riverside ES
1755	Complete 5/9/05 MR CASTILLO WILL NEED TO REPLACE BELAST ROOM 121 BATHROOM NO LIGNT PRETTY DARK THANK YOU SIR replace ballast	5/9/2005 5/10/2005 Medium	Adan Duran Carlos Castillo		Riverside ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1753	Closed Work Orders 5/9/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 21/2 MOWED GRASS 1/2 CLEAN AND GREASED MOWER 1 CHECKED IN TO STMS REPORT BACK TO RS 11/2 TRIME EDGES WITH T RIMER 1/2 RESET AC UNIT OFFICE 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 5/9 - 8	5/9/2005 5/9/2005 Medium	Adan Duran Adan Duran		Riverside ES
1571	Closed Work Orders 5/2/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 21/2 MOWED GRASS 1/2 SHOVEL SAND FROM SIDEWALK 2 TRIM EDGES WITH TRIMER 1 CLEAN SIDEWALKS WITH BLOWER 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 5/2 - 8	5/2/2005 5/2/2005 Medium	Adan Duran Adan Duran		Riverside ES
1576	Complete 5/2/05 MR ANGEL GONZLES WILL NEED NEW BLADES FOR JOHNDEERE MOWER OLD ONES ARE SHOT THANK YOU SIR REPLACED BLADES LAWNMOWER	5/2/2005 6/10/2005 Medium	Adan Duran Angel Gonzales		Riverside ES
1540	Closed Work Orders 4/29/05 1 SIGN IN CLOSE WEST AND NORTH GATES AND REOPEN 1/2 HELP LOAD LUNCHS IN BUSSIES FILED TRIP 1 PICK UP TRASH ALONG WEST FENCE 11/2 PICKED UP SUPPLIES AND FUEL TRUCK 31/2 MONTHLY INSPECTIONS 1/2 FILE WORK REPORT AND SIGN OUT 4/29 - 8	4/29/2005 4/29/2005 Medium	Adan Duran Adan Duran		Riverside ES
1471	Complete 4/27/05 MR DAVID VILLALOBOS WATER FOUNTAIN WILL NEED REPLACEING WILL NOT TURN OFF THE NEW ONES ON THE WEST SIDE THE INSIDE NO GOOD THE OLD ONES ON THE EAST SIDE NEED PARTS THANK YOU SIR CHANGED OUT BUBBLERS AND WATER LINES UNDER FTN.	4/27/2005 5/11/2005 Medium	Adan Duran David Villalobos		Riverside ES
1469	Closed Work Orders 4/27/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 1 REPAIR SPRINKLERS VANDALS SOUTH SIDE 1 REPAIR WATER FOUNTAIN EAST SIDE 21/2 WORKED ON WATER FOUNTAIN NORTH WEST BROKEN LINE REPLACE P TRAP 1 HELLPED MR LOZOYA DOOR HANDLE 1/2 REPLACE NOB AC UNIT RM 126 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 4/27 - 8	4/27/2005 4/27/2005 Medium	Adan Duran Adan Duran		Riverside ES
1503	Closed Work Orders 4/28/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 1 WATER PLAYGROUND TREES 2 PRUN PALM TREES AND CLEAN UNDER AND WATER 1 PRUN SHADE TREES IN FRONT 2 DIG OUT AND REPLACED 6 SPRINKLER HEADS 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 4/28 - 8	4/28/2005 4/28/2005 Medium	Adan Duran Adan Duran		Riverside ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1367	Closed Work Orders 4/22/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 4 CLEAN AND SERVICE AC UNITS 1 REPAIR MEDECIN CABINET 1 REPLACE SPRINKLERS HEADS AND COVER HOLE 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 4/22 - 8	4/22/2005 4/22/2005 Medium	Adan Duran Adan Duran		Riverside ES
1368	Complete MR MANNY LOZOYA THE BATHROOM DOOR HANDLE IS COMING APART NEED TO REPAIR OR REPLACE ASAP THANK YOU SIR repair locset	4/22/2005 5/3/2005 Medium	Adan Duran Hector Lozoya		Riverside ES
1325	Closed Work Orders 4/21/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 6 CLEAN AND SERVICE AC UNITS 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 4/21 - 8	4/21/2005 4/21/2005 Medium	Adan Duran Adan Duran		Riverside ES
1413	Closed Work Orders 4/25/05 1 SIGN IN CLOES NORTH AND WEST GATES AND REOPEN 2 1/2 MOWED GRASS 1/2 REMOVE TENER BALL STAND FROM ROCK WALL 1 EXCHANGE TRUCKS AND TOOLS 2 CHOP WEEDS IN FRONT 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 4/15 - 8	4/25/2005 4/15/2005 Medium	Adan Duran Adan Duran		Riverside ES
1438	Closed Work Orders 4/26/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REPOEN 3 CHOP WEEDS NORTH SIDE 3 SPRAY ROUND UP ALONG WEST FENCE NORTH FENCE EAST FENCE PARKING 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 4/25 - 8	4/26/2005 4/25/2005 Medium	Adan Duran Adan Duran		Riverside ES
1291	Closed Work Orders 4/20/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 6 CLEAN AND SERVICE AC UNITS 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 4/20 - 8	4/20/2005 4/20/2005 Medium	Adan Duran Adan Duran		Riverside ES
1257	Closed Work Orders 4/19/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 6 CLEAN AND SERVICE AC UNITS 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUTE 4/19 - 8	4/19/2005 4/19/2005 Medium	Adan Duran Adan Duran		Riverside ES
1225	Closed Work Orders 4/18/05 1 SIGN IN CLOSE WEST AND NORTH GATES AND REOPEN 4 REMOVE SAND FROM ROCKWALL BOBCAT 2 PICK UP ART STANDS FROM GMS BACK TO SCHOOL SITE AND STORE 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 4/18 - 8	4/18/2005 4/18/2005 Medium	Adan Duran Adan Duran		Riverside ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1196	Closed Work Orders 4/15/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 2 1/2 REMOVE SAND FROM ROCK WALL 2 PICK UP SUPPLIES CHANGE OVER TRUCKS MY TRUCK IN SHOP 1/2 CHECK IN WITH STMS 1 HELP JOSE AMBRIZ CHANGE OUT PUMP 1/2 CLOSE NORTH AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 4/15 - 8	4/15/2005 4/15/2005 Medium	Adan Duran Adan Duran		Riverside ES
1112	Closed Work Orders 4/13/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 1 1/2 STMS PAINT NURSE OFFICE 4 1/2 REMOVE SAND FORM WEST ROCKWALL WITH BOBCAT 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 4/13 - 8	4/13/2005 4/13/2005 Medium	Adan Duran Adan Duran		Riverside ES
1147	Closed Work Orders 4/14/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 1 1/2 SET UP ART DISPLAY AT GMS 1 REPORT TO STMS EVERY THING OK 3 1/2 REMOVE SAND FROM ROCKWALL BOBCAT 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 4/14 - 8	4/14/2005 4/14/2005 Medium	Adan Duran Adan Duran		Riverside ES
1034	Closed Work Orders 4/11/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 1 SHOVEL SAND NORTH ENTRANCE AND UNDER GATES 1/2 REPAIR LIGHT FIXTURE ROOM 30 3 1/2 WORKED WITH JOSE AMBRIZ ON BOILERS 1 REPAIR BATHROOM STALLS 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 4/11/05 - 8	4/11/2005 4/11/2005 Medium	Adan Duran Adan Duran		Riverside ES
1035	Complete MR MIKE MUNOZ WOULD LIKE TO USE BOBCAT HAVE ALOT OF SAND BACK OF SC HOOL NEED TO REMOVE AND CLEAN BY ROCKWALL AND PORTABLE BUILDING THANK YOU SIR del bobcat and sweeper on 4/12 and picked up on 4/21	4/11/2005 4/12/2005 Medium	Adan Duran Angel Gonzales		Riverside ES
1066	Closed Work Orders 4/12/05 1 SIGN IN CLOSE NORTH AND WEST GATE AND REOPEN 1 SHOVEL SAND ALL WEST ENTRANCES 2 STMS MOVED SHELFs FROM NORTH BUILDING TO SOUTH BUILDING AND INSTALLED 3 WORKKED ON AC UNIT COMPUTER LAB ALSO CHANGE OUT ALL FILTER ON ALL AC UNITS 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT 4/12/05 - 8	4/12/2005 4/12/2005 Medium	Adan Duran Adan Duran		Riverside ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
937	Closed Work Orders 4/7/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 21/2 MOWED GRASS 2 TRIM EDGES WITH TRIMER 1 CLEAN SIDEWALKS WITH BLOWER 1 CLEAN AND LUBEIRATE DOORS ROOM 105 AND LIBRARY GETTING STUCK 1/2 CLOSE SOUTH AND WEST GATES 1/2 FILE WORK REPORT AND SIGN OUT 4/7 - 8	4/7/2005 4/7/2005 Medium	Adan Duran Adan Duran		Riverside ES
977	Closed Work Orders 4/8/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 31/2 SHOVEL AND REMORE ALL SAND FRONT ENTRANCE OF SCHOOL 3 SHUT DOWN ALL FURNANCES AND BOILERS SHUT OFF SWITCHS 1/2 CLOSE SOUTH AND WEST GATES 1/2 FILE WORK REPORT AND SIGN OUT 4/8 - 8	4/8/2005 4/8/2005 Medium	Adan Duran Adan Duran		Riverside ES
902	Closed Work Orders 4/6/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 61/2 SCRAPE OLD PAINT FROM FIRE LANE AND RE PAINT 1/2 CLOSE SOUTH AND WEST GATES 1/2 FILE WORK REPORT AND SIGN OUT 4/6 - 8	4/6/2005 4/6/2005 Medium	Adan Duran Adan Duran		Riverside ES
853	Complete ATT MR RUBEN RONQILLO MR RONQILLO WILL NEED ANOTHER 5 GAL OF VANILLA BEAN PAINT FOR THE OTHER TWO BATHROOMS MIDDLE WING THANK YOU SIR	4/5/2005 4/12/2005 Medium	Adan Duran Ruben Ronquillo		Riverside ES
854	Closed Work Orders 4/5/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 11/2 CHECK ALL FIRE EXTINGUISHERS 125795 4 SHOVEL AND REMOVE SAND FORM CURBS 1 EMERGENCY LIGHTING 125793 1/2 CLOSE SOUTH AND WEST GATES 1/ 2 FILE WORK REPORT AND SIGN OUT 4/5 - 8	4/5/2005 4/5/2005 Medium	Adan Duran Adan Duran		Riverside ES
747	Closed Work Orders 3/31/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 31/2 INSTALLED NEW STALL DOOR GIRLS BATHROOM UPPER GRADE 2 MOWED GRASS IN FRONT 1 HELPED MR CASTILLO WITH ELECTRICAL 1/2 CLOSE SOUTH AND WEST GATES 1/2 FILE WORK REPORT AND SIGN OUT	3/31/2005 Medium	Adan Duran Adan Duran		Riverside ES
813	Complete 4/4/05 JOSE AMBRIZ MR AMBRIZ WE NEED TO COVER UP VENT OR PLUG UP VENT IN MRS FLORES OFFICE OR REMOVE IT HOW EVER YOU WANT TO DO IT THANK YOU SIR closed damper in main supply duct, remove diffuser, cap off flex tin, install ceiling tile.	4/4/2005 4/12/2005 Medium	Adan Duran Jose Ambriz		Riverside ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
806	Closed Work Orders 4/1/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 2 CHOP WEEDS AND PICK UP TRASH ALONG WEST FENCE 11/2 PICK UP SUPPLIES FUEL UP 1 CLEAN AND LUBRICATE EXIT DOOR GETTING STUCK 2 HELP MR CASTILLO WITH ELETRICAL 1/2 CLOSE SOUTH AND WEST GATES 1/2 FILE WORK REPORT AND SIGN OUT	4/1/2005 4/1/2005 Medium	Adan Duran Adan Duran		Riverside ES
821	Closed Work Orders 4/4/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 1 SCRAP PAINT OFF CURB 4 HELP MR CASTILLO DRILL WALLS AND PULL WIRE 1 CHECK EXIT SIGN 12579 1/2 REPLACE RECIPTCAL AND COVER 1/2 CLOSE SOUTH AND WEST GATES 1/2 FILE WORK REPORT AND SIGN OUT 4/4 - 7	4/4/2005 4/4/2005 Medium	Adan Duran Adan Duran		Riverside ES
584	Closed Work Orders 3/23/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 21/2 PAINT WEST EXIT DOORS 1/2 WALK THROUGH WITH IMAR SYSTEMS 1/2 WASH PAINT BRUSHES ROLLER ECT 31/2 REMOVE MORE BROKEN TILE AND POUR NEW CEMENT 1/2 FILE WORK REPORT AND SIGN OUT	3/23/2005 3/29/2005 Medium	Adan Duran Margret Villalobos		Riverside ES
560	Closed Work Orders 3/21/05 1/2 SIGN IN CHECKED SCHOOL GROUND 6 REMOVE BROKEN TILES CHESILE OUT CEMENT AND POUR NEW CEMENT 1 PICKED UP TRASH AND WASH TOOLS 1/2 FILE WORK REPORT AND SIGN OUTE	3/21/2005 Medium	Adan Duran Adan Duran		Riverside ES
581	Closed Work Orders 3/22/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 31/2 PAINT DOORS AND SOME CEMENT TILE 31/2 SAFETY TRAINING STMS 1/2 FILE WORK REPORT AND SIGN OUT	3/23/2005 Medium	Adan Duran Adan Duran		Riverside ES
629	Closed Work Orders 3/24/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 31/2 REMOVE MORE BROKEKKN TILES CLEAN TRASH POUR NEW CEMENT 1 RE INSTALL TWO AC COVERS BLOWN OFF BY WIND 1 UNPLUG FLOOR DRAIN UPPER GRADE BATHROOMS 11/2 MOWED GRASS IN FRONT 1/2 FILE WORK REPORT AND SIGN OUT	3/24/2005 Medium	Adan Duran Adan Duran		Riverside ES
659	Closed Work Orders 3/29/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 1/2 HELP MOVE FILEING CABINETS 3 REPLACED BROKEN BATHROOM DOOR MIDDLE WING 3 MONTHLY INSPECTIONS 1/2 CLOSE WEST AND SOUTH GATES 1/2 FILE WORK REPORT AND SIGN OUT	3/29/2005 Medium	Adan Duran Adan Duran		Riverside ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
694	Complete ATT MR RUBEN RONQUILLO WILL NEED 5 GAL OF PAINT FOR BATHROOMS VANILLA BEAN THANK YOU SIR	3/30/2005 3/30/2005 Medium	Adan Duran Ruben Ronquillo		Riverside ES
701	Closed Work Orders 3/30/05 1/2 SIGN IN CHECK SCHOOL GROUNDS 1 SHOVEL SAND FROM SIDEWALK AND DIG OUT DRAIN 21/2 INSTALLED NEW DOOR BATHROOM STAL UPPER GRADE BOYS 11/2 REPLACED BROKEN BRAKETS BOYS BATHROOM MIDDLE WING 1/2 STRIGHTEN BENT RECEPTICAL COVER RM 39 1 WATER PLAYGROUND TREES NORTH SIDE 1/2 CLOSE SOUTH AND WEST GATES 1/2 FILE WORK REPORT AND SIGN OUT	3/30/2005 Medium	Adan Duran Adan Duran		Riverside ES
418	Complete JOSE AMBRIZ WILL NEED COVERS FOR AC UNITS 42X18 WILL NEED 6 OLD ONES RUSTED OUT THANK YOU SIR	3/15/2005 4/21/2005 Medium	Adan Duran Jose Ambriz		Riverside ES
420	Closed Work Orders 3/15/05 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 1 REMOVE GRAFFITI FROM PLAYGROUNDS 11/2 EMERGENCY LIGHTING 125555 1/2 DIG OUT DRAIN FULL OF SAND 1 FENCE INSPECTION 1 ASPHALT INSPECTION 1/2 LOAD 4 WATER FOUNTAINS ON TRUCK 1/2 CLOSE WEST GATES AND DROP OFF GATES 1/2CHECK FOR BEES 1/2 FILE WORK REPORT AND SIGN OUT	3/15/2005 Medium	Adan Duran Adan Duran		Riverside ES
463	Closed Work Orders 3/16/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 1 PICK UP WELDER AND REFUEL TRUCK 21 1 STOPED AT GHS TO PICK UP TORCHES AND HOSES 1 REPORT BACK TO RIVERSIDE AND START TO CUT METAL 3 WELD STAND FOR MAILBOX AND PAINT 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT	3/16/2005 Medium	Adan Duran Adan Duran		Riverside ES
500	Closed Work Orders 3/17/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 3 INSTALLED MAIN BOX STAND BUILD FORM AND POUR CEMENT SLAP 11/2 CHECKED ALL ROOFS 125558 1 REMOVE TV AND TV STAND FORM ROOM 17 1/2 LUBERICATE DOOR ROOM 101 GETTING STUCK 1/2 CLOSE WEST AND DROP OFF GATES 1/2 FILE WORK REPORT AND SIGN OUT	3/17/2005 Medium	Adan Duran Adan Duran		Riverside ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
549	Closed Work Orders 3/18/05 1 SIGN IN CLOSE NORTH AND WEST GATES AND REOPEN 3 CUT GRASS 11/2 PICK UP SUPPLIES AND FUEL TRUCK 11/2 TRIM EDGES WITH GRASS TRIMER 1/2 CLOSE WEST GATES AND DROP OFF 1/2 FILE WORK REPORT AND SIGN OUT	3/18/2005 Medium	Adan Duran Adan Duran		Riverside ES
140	Closed Work Orders 1/2 SIGN IN SET UP TRAFFIC CONES 1 CLOSE NORTH AND WEST GATES AND REOPEN 1 CHANGE OUT TRASH BAGS PLAYGROUND 21/2 CHOP WEEDS SOUTH AND SOUTHEAST ROCKWALL 11/2 REMOVE BROKEN GLASS CUT PLYWOOL AND COVER UP WINDOW 1/2 CLOSE WEST AND DROP OFF GATES 1/2 PICK UP TRAFFIC CONES AND STORE 1/2 FILE WORK REPORT AND SIGN OUT	3/7/2005 3/8/2005 Medium	Adan Duran Adan Duran		Riverside ES
249	Complete MR RUBEN RONQUILLO WILL NEED 5 GAL OF VANILLA BEAN PAINT NEED TO PAINT BATHROOMS THANK YOU SIR	3/10/2005 3/11/2005 Medium	Adan Duran Ruben Ronquillo		Riverside ES
246	Closed Work Orders 3/8/05 1/2 sign in set up traffic cones 1close north and west gates and reopen 11/2 chop weeds north fence in side 1change out blow out tire 21/2 pipe drag playground 1/2 close west and drop off gates 1/2 pick up traffic cones and store 1/2 file work report and sign out	3/10/2005 3/10/2005 Medium	Adan Duran Danny Miranda		Riverside ES
247	Closed Work Orders 3/9/05 1/2 sign in set up traffic cones 1 close west and north gates and reopen 1/2 load lunches on school bus 2 pipe drag westside playground 21/2 chop weeds along north fence outside 1/2 close west gate and drop off 1/2 pick up traffic cones and store 1/2 file work report and sign out	3/10/2005 3/10/2005 Medium	Adan Duran Adan Duran		Riverside ES
296	Closed Work Orders 3/10/05 1/2 SIGN IN SET UP TRAFFIC CONES 1 CLOSE NORTH AND WEST GATES AND REOPEN 1 FILE WORK ORDERS 3 SPRAY ROUND UP SOUTH AND EAST FENCES 1 WORK ON FILE CABINED DRAWER 1/2 CLOSE WEST GATE AND DROP OFF 1/2 PICK UP TRAFFIC CONES AND STORE 1/2 FILE WORK REPORT AND SIGN OUT	3/11/2005 3/11/2005 Medium	Adan Duran Adan Duran		Riverside ES
336	Closed Work Orders 3/11/05 1/2 SIGN IN SET UP TRAFFIC CONES 1 CLOSE NORTH AND WEST GATES AND REOPEN 11/2 WO 125557 FIRE EXTINGUISHER 1 WO 125556 11/2 SPRAY ROUND UP INSIDE COURTYARDS AND BACK OF SCHOOL 1 WATER PLAYGROUND TREES 1/2 CLOSE WEST AND DROP OFF GATES 1/2 PICK UP TRAFFIC CONES AND STORE 1/2 FILE WORK REPORT AND SIGN OUT	3/11/2005 Medium	Adan Duran Adan Duran		Riverside ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
338	Complete MR CARLOS CASTILLO WILL NEED TO REPLACE LIGHT COVERS IN PORTABLE BROKEN AND SOME IN NEW WING NEED TO COME OVER SO THAT YOU WILL KNOW WHAT KIND TO GET THANK YOU SIR order and provide covers for bldg mechanic.	3/11/2005 4/14/2005 Medium	Adan Duran Carlos Castillo		Riverside ES
2309	Complete no ovens working FOUND ALL THE PANEL FOR THE OUTLETS UNDER HOOD TRIPPED, RESET BREAKER EVERYTHING WORKING FINE	5/26/2005 5/31/2005 Medium	Danny Orozco Danny Orozco	Cafeteria	Riverside ES
2623	Complete Run power to relocated portable RUN POWER TO CONNECT PORTABLES.	6/8/2005 6/29/2005 Medium	Carlos Castillo Carlos Castillo	Portables	Riverside ES
709	Complete S. Roof- expansion tank needs to be checked for proper operation, the necessary repairs or replacement made for proper operation. As per Boiler Inspector. CLOSE VALVES TO REPLACE THERM GUAGES, REPLACE VALVE THAT WA NOT CLOSIN, CK EXPANSION TANK TO 12PSI BLEED OFF AIR.	3/30/2005 4/11/2005 Medium	Michael Munoz Jose Ambriz		Riverside ES
711	Complete N. Roof - replace temp/pressure gage. As per Boiler Inspector. TEMP PRESS. GAUGES WERE RUSTED AND BROKEN, HAD A HARD TIME REMOVING INSIDE GLASS AND 1/2 PLASTIC BUSHING REMOVING AND REPLACE THEM WITH NEW WELLS AND PRESS. GAUGES.	3/30/2005 5/3/2005 Medium	Michael Munoz Jose Ambriz		Riverside ES
707	Complete Kitchen - need to replace relief valve. As per Boiler Inspector. WAS GOING TO REPLACE REFLIEF VALVE, GUT OUTLET VALVE WAS CLOSED, RELECT IS STUCK, SHUTOFF POWER AND CALLED DAVID, HE SAID HE WILL TAKE CARE OF AS PRECAUTION AND SHUST OF WATER.	3/30/2005 4/7/2005 Medium	Michael Munoz Jose Ambriz		Riverside ES
3098	Work In Progress JIMMY, WHEN DELIVERING SUPPLIES TO RS NEXT WEEK, PLEASE TRAIN RAUL ROMERO (NEW H.C.) ON SEMS FOR ABSENCES, SITE NET FOR SUPPLIES & SCHOOL DUDE FOR W.O. PLEASE ASK ME FOR USER NAME & I.D.S BEFORE YOU GO OUT THERE. tHANKS ,MARY	6/30/2005 Medium	Maria Sitters		Riverside ES
123	Work In Progress Mr. Valtierra, Principal RS, is requesting new carpet/flooring in Rm#36.	3/7/2005 3/2/2005 Medium	Miguel Aguilar Michael Munoz	Classroom	Riverside ES
125	Complete Need (3) vacuum bands for Royal Vacs. DELIVERED 3 BELTS ON 3/3/05. REFERENCE W.O. #1350	3/7/2005 3/2/2005 Medium	Miguel Aguilar Jimmy Carbajal	Custodial	Riverside ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2540	Work In Progress Need copies (3) made of regular master padlocks located in halls used to secure exits with chain.	6/6/2005 Medium	Miguel Aguilar Hector Lozoya		Riverside ES
2015	Complete Royal vacuum issued 1-31-02 serial #59f E006 00004077 not functioning properly, machine very loud. REPLACED PARTS & ALSO EXT CORD AND DID P.M.	5/17/2005 5/23/2005 Medium	Miguel Aguilar Jimmy Carbajal		Riverside ES
2206	Complete Need air conditioner checked/repared in Rm 101 Ms.Perez, air is not turning on. re-installed pulley and adjusted belt, ck'd amperage.	5/23/2005 5/23/2005 Medium	Miguel Aguilar Margret Villalobos		Riverside ES
2072	Void Need microphone cord to reach opposite end of gym for kinder presentations, per request Ms.Flores Asst.Principal RS. NEED TO ROUTE TO THE TECHNOLOGY DEPARTMENT.	5/18/2005 Medium	Miguel Aguilar	Gym	Riverside ES
2073	Complete Need dampers or other to restrict air into main office, refrigeration unit supplies air to main office, nurses office, and counselor. Main office too cold while counselors office is too hot, per request Mr.Martinez. COMPLAINING TO HOT IN MR. MARTINEZ OFFICE HAD TO BALANCE AIR STARTING FROM OFFICE, HIS DIFFUSER WAS SET TOWARD THE ROOF, LOWER VENT DOWN WIL SET UP T-STAT AT 70.	5/18/2005 5/19/2005 Medium	Miguel Aguilar Jose Ambriz		Riverside ES
2074	Work In Progress When fire alarm system replaced, ceiling light in upper grade library storage was removed and not placed back. Refrigeration air escaping and may cause overheating of unit and server located in room.	5/18/2005 Medium	Miguel Aguilar Adan Duran		Riverside ES
2283	Complete Vacuum broken, loud and not working properly, serial#F96A00001406, model#1020P, tag#970166, issued 10-24-96. REPLACED PARTS (ISSUED THRU ACT 1000) AND ALSO DID P.M. AS PER JIMMY	5/25/2005 6/3/2005 Medium	Miguel Aguilar Jimmy Carbajal		Riverside ES
2571	Complete Need to have wall cabinet checked in Room #110 Main key in office area. REKEY 2 DOORS TO D106 - ROOM 101	6/7/2005 6/15/2005 Medium	Olga Arias Hector Lozoya		Riverside ES
2569	Complete Need to have keys replaced and/or locked checked having problems opening cabinet. Thanks REKEY 4 ROOMS TO OFF MASTER	6/7/2005 6/6/2005 Medium	Olga Arias Hector Lozoya		Riverside ES
2567	Complete Need replacement for wall cabinet in Room 126 Wall cabinet lock is off. REPAIR LOCKS AT WALL CABINETS	6/7/2005 6/15/2005 Medium	Olga Arias Hector Lozoya		Riverside ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2575	Complete Need Classroom keys for Room #32. duplicate keys and check lockset SA40 2 keys	6/7/2005 6/15/2005 Medium	Olga Arias Hector Lozoya		Riverside ES
2573	Complete Need to order new key for HON # 342. Main key in office area. Thanks	6/7/2005 6/15/2005 Medium	Olga Arias Hector Lozoya		Riverside ES
2729	Work In Progress We (the school) is having problems with insects; ants and roaches, spiders would it be possible to have the school fumigated before we start classes again. All the wings and classrooms, storage areas. Thanks.... FAXED PO 45014025 6/22/05 - MKV	6/13/2005 Medium	Olga Arias Margret Villalobos		Riverside ES
2241	Work In Progress Need to repair carpet. (edge) is picking-up within the office area. Doorway to the back copy room. Adan can you glue this down? - As per Mike.	5/24/2005 Medium	Olga Arias Adan Duran		Riverside ES
2388	Complete Need to replace filing cabinet keys for room 13, Mr. Enrique Moreno duplicate key for file cabinet.	5/31/2005 6/1/2005 Medium	Olga Arias Hector Lozoya		Riverside ES
2110	Complete RM 13 - 3 BROKEN WINDOWS	5/19/2005 5/19/2005 Medium	REYES VALTIERRIA Ruben Ronquillo		Riverside ES
2781	Work In Progress PORTABLE SM 45 - CONNECT UTILITIES.	6/15/2005 Medium	Michael Munoz Fred Appenzoller	Portables	San Miguel ES
1296	Closed Work Orders 04/20/05 2.0 Removed sprinklers, gave David Vega a school tour. 1.0 Replaced 3/4 hp for 1/2 hp motor, Master cool A/C. 5.0 Grounds; cut weeds around fence line and lawn grass playground area. 4/20 - 8	4/20/2005 4/20/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
1266	Closed Work Orders 04/19/05 1.0 Removed sprinklers, 2.0 Replaced broken water line supply for A/C, and float. 5.0 Grounds; cut weeds around portables. 4/19 - 8	4/19/2005 4/19/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
1170	Closed Work Orders 04/14/05 1.0 Checked boiler and cheked in. 2.5 Delivered art partitions at GMS for art fair. 3.0 Cleaned commercial master cools for main building. 1.5 Set timer for watering and set sprinklers. 4/14 - 8	4/14/2005 4/14/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1201	Closed Work Orders 04/15/05 1.0 Removed sprinklers, checked in. 2.0 Went to warehouse to pick up material, fill tank with gas, and delivered paperwork. 4.0 Cleaned Commercial master cools for main building. 1.0 Set sprinklers. 4/15 - 8	4/15/2005 4/15/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
1230	Closed Work Orders 04/18/05 2.5 Removed sprinklers, picked up art partitions display at gms. 2.5 Replaced water pump for master cool, troubleshoot wall A/C unit Room #42. 3.0 Cut weeds, lawn grass, set sprinklers for watering. 4/18 - 8	4/18/2005 4/18/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
869	Closed Work Orders 04/05/05 2.0 Checked boiler, removed sprinklers. 1.0 Made hole to set rain gage for teacher and students science project. 5.0 Cleaned Master cools. 4/5 - 8	4/5/2005 4/5/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
872	Complete Jaime, Please check pump for boiler. FILLED BOILER UP TO 12 PSI WITH WATER, BLEED OFF ALL ACCESS AIR.	4/5/2005 4/8/2005 Medium	Lorenzo Solis Jaime Gomez	Mechanical Room	San Miguel ES Boiler room
842	Closed Work Orders 04/04/05 2.0 Checked boiler, removed sprinklers, repaired broken bake sale table. 5.0 Cleaned master cool A/C's. 1.0 Set sprinklers. 4/4 - 8	4/5/2005 4/4/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
810	Closed Work Orders 04/01/05 2.0 Checked boiler, fill pressure tanks with water. checked gages. 2.0 Cleaned working truck and checked oil gages, took it with Angel to fill them up. Picked up material with Ruben and delivered paper work. 4.0 Grounds: lawn grass north east area by leach lines.	4/1/2005 4/1/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
708	Closed Work Orders 03/30/05 3.0 Checked boiler, turned pilot on, rised preasure on preasure tanks, purged lines on coils for annex building. replaced blown 60 amp fuse for wall unit portable #40. 5.0 Lawn grass all front area cut weeds with weed eater around fence line front area of school.	3/30/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
754	Closed Work Orders 03/31/05 1.0 Checked boiler and checked in. 3.0 Assisted speedy with moving bleachers to GHS. 3.0 PM work orders and Maintenace preventive inspections. 1.0 Set sprinklers to water.	3/31/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
339	Closed Work Orders 03/11/05 2.0 Checked boiler, adjusted office chairs for school principal. 2.0 Made and installed coat hooks for SPED head start class room. 2.0 Reprogramed irrigation timer to water and set sprinklers. 2.0 Assembled new stereo system for music teacher and set skunk trap.	3/11/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
367	Closed Work Orders 03/14/05 3.0 Checked Boiler, turned pilot on for furnace, checked oven for kitchen ladies reset it. 2.0 Assisted Plumber unclogged boys restroom drain and repaired water line to portable. 3.0 Cut weeds and lawn grass north east of school.	3/14/2005 3/14/2005 Medium	Lorenzo Solis Margret Villalobos		San Miguel ES
276	Closed Work Orders 03/10/05 2.0 Checked boiler, removed trapped skunk away from kids. replaced burned light bulbs room 32. 2.0 Adjusted tables and desks for SPED classroom, delivered boxes of paper to La mesa Elem. 4.0 Grounds; Cut weeds around fence line, sprayed round up, set sprinklers to water on front of school.	3/10/2005 3/10/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
211	Closed Work Orders 03/07/05 2.0 Checked boiler, was call that skunk was at trap, kept kids away while animal control arrived. 1.0 Assisted Pacho at La Mesa hang a bulletin board. 2.0 Fixed broken sprinkler. 30 Installed paper towel dispenser, femenine towel dispenser girls rest room, assembled playhouse for K-classroom.	3/9/2005 3/9/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
225	Closed Work Orders 03/09/03 2.0 Checked boiler, set skunk trap, unclogged urinal in cafet. 1.0 Repaired broken table. 5.0 Grounds; cut weeds east fence line and lawn grass on front of school.	3/10/2005 3/10/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
213	Closed Work Orders 03/08/05 2.0 Checked boiler, installed tire on lawn mower. 2.0 Fixed broken sprinkler. 4.0 Grounds; cut weeds around cafeteria, on front of school, lawn grass on playground.	3/9/2005 3/9/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
214	Work In Progress Please replace nonlocking door knob with locking one. Mrs. Avalos portable#45.	3/9/2005 Medium	Lorenzo Solis Hector Lozoya		San Miguel ES
215	Complete Floor drain in boys restrooms overflowed please check it out. unclogg floor drain in boys rr.	3/9/2005 3/14/2005 Medium	Lorenzo Solis Fred Appellzoller		San Miguel ES
216	Work In Progress Replaced falling apart door knob with new one on entrace door in cafeteria.	3/9/2005 Medium	Lorenzo Solis Hector Lozoya		San Miguel ES
109	Complete "Head Custodian has 2 vacuum cleaners broken, need to come and pick up for repair ASAP. Thank You!!!!!!!!!" REOMVED WAD OF TRASH FROM FRONT OF MACHINE & REPLACED BELT, HANDLE STOP PLATE, HANDLE FORK & FAN. 3/4/05	3/7/2005 3/17/2005 Medium	Lorenzo Solis Jimmy Carbajal		San Miguel ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
112	Closed Work Orders "03/02/05 2.0 Checked boiler and repaired broken sprinkler. 3.0 Assisted Plumber installed water heater for sped room #21. 2.0 Re-anchored hand bar for non tripping side walk. 1.0 Removed broken window blinds for room #33."	3/7/2005 3/16/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
124	Work In Progress As per School Pricipal, Need a truck load of 3/4 inch rock for spreading in front of portable. Need it ASAP. Thank You!	3/7/2005 3/2/2005 Medium	Lorenzo Solis Lorenzo Hernandez		San Miguel ES
126	Void 02/25/05	3/7/2005 3/2/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
146	Work In Progress "Please sent one of you employees to assist me with fixing 9 broken sprinklers, ASAP need to start watering grass. Please bring the following. Tees 1 1/2 inch to 1 inch screw in. niples 1 inch 12 and 8 inch long. easy fix 1 1/2 inch. "	3/8/2005 Medium	Lorenzo Solis Lorenzo Hernandez		San Miguel ES
128	Closed Work Orders "02/28/05 2.0 checked boiler, replaced 2 pencil sharpeners. Assisted Plumber with preparations for installing new water heater. 2.0 Assisted Electrician and HVAC trouble shooting irigation timer, and to take measurements for new AC split system. 4.0 Ground; cut weeds with weed eater and picked up papers around school grounds, lawn eat side of grass."	3/7/2005 2/28/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
129	Closed Work Orders "03/01/05 2.0 checked boiler, adjusted ramp for portable. 3.0 Repaired 2 broken sprinklers. 3.0 Repaired broken Tee for water gountains outside, reprogramed irrigation timer, delivered boxes for room #9."	3/7/2005 3/1/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
634	Closed Work Orders 03/24/05 2.0 Checked boiler, removed sprinklers to different area to water, sprayed round up fence line weeds. 6.0 Cleaned Master cool A/C's.	3/24/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
676	Closed Work Orders 03/29/05 1.0 Checked boiler, replaced screen for projector room #30. 7.0 As per Margret, assisted "Speedy" moving bleachers to the Gadsden High School. He will need assistance tomorrow also.	3/29/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
563	Closed Work Orders 03/21/05 1.0 Checked boiler, removed sprinklers. 1.0 Cleaned A/C. 6.0 Assisted HVAC complete work order #123950. Removed old split system and installed new one.	3/21/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
573	Closed Work Orders 03/22/05 3.5 Safety meeting at Santa Teresa. 4.5 Cleaned A/C and grounds cut weeds around fence line.	3/22/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
553	Closed Work Orders 03/18/05 2.0 Checked boiler, removed sprinklers, fixed one that was broken. 2.0 Assisted custodian with set up for assembly at playground repaired table to be used for bake sale. 2.0 Went to warehouse; delivered paperwork, filled gas tank, picked up material with ruben. 2.0 Grounds; weed eat at fence line by parking lot, set skunk trap, and sprinklers to water.	3/18/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
591	Closed Work Orders 03/23/05 7.0 Cleaned Master cools, 1.0 Set sprinklers to water	3/23/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
511	Closed Work Orders 03/16/05 2.0 Checked boiler, removed sprinklers, adjusted panic bar on door for room #41. 2.0 Assisted young guns' coaches to paint field for prep rally' replaced soap dispensers for rest rooms on annex building 4.0 Grounds; cut weeds, and lawn grass around portables and fence line.	3/18/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
473	Closed Work Orders 03/16/05 2.0 Checked boiler, removed sprinklers, replaced door stop for SPED classroom. 3.0 Repaired busted copper water line going to portable #31. 2.0 Started to clean A/C's. 1.0 Set skunk trap and set sprinklers to water.	3/16/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
424	Closed Work Orders 03/15/05 3.0 Checked Boiler, purged hot water line at annex building for heating coils. 2.0 Installed door stopper entrance main door, Replaced faulty emergency light. 1.0 Repaired lock for teachers desk and assembled book binder for K- teacher. 2.0 Grounds; lawn grass and cut weeds north east side of school.	3/15/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
1546	Closed Work Orders 04/29/05 8.0 Cleaned morgan shed, moved to Physical Plant Dept. 4/29 - 8	4/29/2005 4/29/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
1511	Closed Work Orders 04/28/05 2.0 Removed sprinklers, Assisted custodian delivered water flavor drinks to kitchen fridge. 2.0 Replaced busted copper water line for master cool, annex building. 4.0 Grounds; cut weeds around fence line in front of school picked up trash, and set sprinklers to water. 4/28 -8	4/28/2005 4/28/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1475	Closed Work Orders 05/27/05 2.0 Removed sprinklers, cut hanging branches off tree. 2.0 Assisted fire stinguisher inspectors, cleaned morgan maintenace shed. 2.0 Replaced section of old cove base room #32 and broken molding around door. 2.0 Grounds; Picked papers around fence line, set sprinklers to water grass. 4/27 - 8	4/27/2005 4/27/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
1447	Closed Work Orders 04/26/05 2.0 Removed sprinklers, Assisted custodian remove old shelves for new ones to be installed. 2.0 Replaced belt and water float for Master cool. 2.0 Repaired toy bed for kinder teacher, and installed name tags on doors for teachers. 2.0 Preventive maintenance inspection. 4/26 - 8	4/27/2005 4/26/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
1416	Closed Work Orders 04/25/05 2.0 Removed sprinklers, installed P-trap for refrig. Unit. 2.0 Fixed 2 broken sprinklers. 2.0 PM work Orders. 2.0 Grounds: cut weeds and sprayed round up around fence line. 4/25 - 8	4/25/2005 4/25/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
1377	Closed Work Orders 4/22/05 4.0 Removed sprinklers, finished cleaning master cools. 4.0 Grounds; cut weeds around fence line in front of school, picked trash, and set sprinklers to water. 4/22 - 8	4/22/2005 4/22/2005 Medium	Lorenzo Solis Lorenzo Solis		San Miguel ES
717	Work In Progress Boiler Room - relief valve drain is not properly supported. As per Boiler Inspector.	3/30/2005 Medium	Michael Munoz Jaime Gomez		San Miguel ES
2268	Complete CONNECT NEW PORTABLE.	5/25/2005 6/8/2005 Medium	Michael Munoz Enrique Sotelo		San Miguel ES
2382	Complete Connect utilities to relocated portable. INSTALL SEWER, WATER AND GAS.	5/31/2005 6/3/2005 Medium	Michael Munoz Fred Appetzoller	Portables	San Miguel ES
2383	Complete Connect utilities to relocated portable. CONNECT NEW PORTABLE	5/31/2005 6/14/2005 Medium	Michael Munoz Enrique Sotelo	Portables	San Miguel ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1127	Complete Keys - Need to issue keys to Danny Vega transferring from LL to SM. Lorenzo Solis will be turning in his keys. (April 29, 2005 - Payday) issued keys to new schools	4/14/2005 4/29/2005 Medium	Michael Munoz Hector Lozoya		San Miguel ES
1777	Work In Progress Need a lock installed in a filing cabinet in the Library.	5/10/2005 Medium	Barbara Cardenas Hector Lozoya		San Miguel ES
952	Complete Portables #47 and #48 electricity went out, the only thing working is the computers. ARREGLAR PROBLEMA DE LUCES DE PORBO 47 & 48 , PROBLEM IN BREAKER.	4/8/2005 4/11/2005 Medium	Barbara Cardenas Enrique Sotelo	Classroom	San Miguel ES
1063	Complete AIR CONDITIONER IN THE CAFETERIA DINNING AREA IS NOT WORKING. started up unit replaced water pump	4/12/2005 4/13/2005 Medium	Barbara Cardenas Jaime Gomez	Cafeteria	San Miguel ES
1528	Complete PLEASE CHECK A VACUMM CLEANER, MAKE TO MUCH NOISE AND IT DOESN'T HAVE POWER TO PICK UP. THANK YOU REPLACED PARTS & DID P.M.	4/29/2005 5/3/2005 Medium	Cervando Padilla Jimmy Carbajal		San Miguel ES
1727	Duplicate Request need gutter san miguel cafeteria 1749	5/6/2005 Medium	Danny Miranda Danny Miranda		San Miguel ES
1826	Work In Progress NEED 14X30X1 PLEATED FILERS 8EA	5/11/2005 Medium	Danny Vega Jaime Gomez		San Miguel ES
1820	Work In Progress need filetrs for units 12ea) 20x20x1 pleated 12ea)12x25x1 pleated 12ea)12x25x1 pleated -asap	5/11/2005 Medium	Danny Vega Jaime Gomez		San Miguel ES
1821	Work In Progress ramp not level- door hits bottom platform -need to lift with chains asap	5/11/2005 5/12/2005 Medium	Danny Vega Danny Vega	Classroom	San Miguel ES #37
1828	Complete METAL DOOR FRAME -OFF ALIGNMENT/BINDS AT BOTTOM&SIDE .PRIMARY FIRE DRILL EXIT DOOR.PLEASE CHECK IT OUT ASAP	5/11/2005 5/16/2005 Medium	Danny Vega Danny Miranda	Classroom	San Miguel ES LIBRARY
1812	Closed Work Orders 5-9-05 1-remove sprinklers 1-ck wk orders/office 1-clogged-up toilet/boys- main 1-repair door panic bar rm#47 3-remove old rain gutters /cafeteria 1-set-up sprinklers 5/9 - 8	5/11/2005 5/9/2005 Medium	Danny Vega Danny Vega		San Miguel ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1813	Closed Work Orders 1-remove sprinklers .5-ck wk orders/office 1.5-wk on cafeteria door lock 1-set-up chairs by office .5-pick-up chairs/back to cafeteria 2.5-cut campus lawn/north side 1-set-up sprinklers 5/10 - 8	5/11/2005 5/10/2005 Medium	Danny Vega Danny Vega		San Miguel ES
1766	Work In Progress KEY JAMMED IN CORE/CORE WILL NOT TURN - OVER	5/10/2005 Medium	Danny Vega Hector Lozoya	Classroom	San Miguel ES PORTABLE#37
1869	Closed Work Orders 5-11-05 1-REMOVE SPRINKLERS .5-CK WK ORDERS/OFFICE 1-RM#37 A/C NOT WORKING 1-REPAIR WATER FOUNTAIN/MAIN HALLWAY .5-REPLACE TOWEL DISPENCER/BOYS MAIN 2-CK & REPLACE REFRIGRATION A/C UNIT FILTERS/PORTABLES 1-LIBRARY DOOR WONT CLOSE 1-SET-UP SPRINKLERS 5/11 - 8	5/12/2005 5/11/2005 Medium	Danny Vega Danny Vega		San Miguel ES
1881	Work In Progress NEED TOP PIVOT LACTH HINGE/RIGHT SIDE FOR METAL DOOR IN LIBRARY ASAP	5/12/2005 Medium	Danny Vega Hector Lozoya	Classroom	San Miguel ES LIBRARY
1882	Duplicate Request NEED TOP PIVOT LACTH HINGE/RIGHT SIDE FOR METAL DOOR IN LIBRARY ASAP DUPLICATE REQUEST, SEE W.O. #1881	5/12/2005 Medium	Danny Vega Hector Lozoya	Classroom	San Miguel ES LIBRARY
1883	Duplicate Request ICE MAKER FILTER CANISTER BROKE HALF/D. OROSCO NEEDS REPLACEMENT DUPLICATE WORK ORDER #1879	5/12/2005 5/18/2005 Medium	Danny Vega Danny Orozco		San Miguel ES
1630	Closed Work Orders 5-3-05 1-ck wk orders/office 1-hang school banners 1-weed-eater by benches/playground 3-mow lawn/tractor 2-set-up sprinklers/timer 5/3 - 8	5/3/2005 5/3/2005 Medium	Danny Vega Danny Vega		San Miguel ES
1660	Closed Work Orders 5-4-05 1-remove sprinklers 1-ck wk orders/office 6-grds wk on campus grass 5/4 - 8	5/4/2005 5/4/2005 Medium	Danny Vega Danny Vega		San Miguel ES
1705	Closed Work Orders 5-5-05 1-REMOVE SPRINKLERS 1-SET-UP ART PANELS/CAFETERIA 2-SPRAYROUND-UP BY PORTABLES 4-CUT GRASS /SOUTH-SIDE 5/5 - 8	5/6/2005 5/5/2005 Medium	Danny Vega Danny Vega		San Miguel ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1725	Complete hot air blowing/please check-out removed and replaced air filter.	5/6/2005 5/9/2005 Medium	Danny Vega Jaime Gomez	Classroom	San Miguel ES rm30
1726	Complete panic bar stuck/loose parts/please chect-out asap repair panic bar and remove stricker.	5/6/2005 5/9/2005 Medium	Danny Vega Hector Lozoya	Classroom	San Miguel ES rm47
1734	Closed Work Orders 5-6-05 1-ck wk orders/office 1-set eletrcal cords/field day 2.5-set-up tents at mesquite 1-ck a/c unit rm#30 1.5-secure rm#47 DOOR/SEND WK OD TT LOCKSMITH 1-SET-UP SPRINKLERS 5/6 - 8	5/9/2005 5/6/2005 Medium	Danny Vega Danny Vega		San Miguel ES
1749	Work In Progress NEED TO REPLACE GUTTERS IN KITCHEN ROOF/NEED SCAFFOLDS/ D.MIRANDA NEED TO ORDERS GUTTERS.	5/9/2005 5/9/2005 Medium	Danny Vega Danny Miranda	Cafeteria	San Miguel ES
1750	Complete NEED REFRIGIRATION A/C UNIT FILTERS FOR PORTABLES removed and replace air filter	5/9/2005 5/9/2005 Medium	Danny Vega Jaime Gomez	Classroom	San Miguel ES
3084	Work In Progress 6-29-05 1-move sprinklers 2-pick supplys ppd 5-backed up sewer/kitchen 6/29 - 8	6/29/2005 Medium	Danny Vega Danny Vega		San Miguel ES
3048	Closed Work Orders 6-28-05 2-cut campus grass 1-repair sink leak rm#32 5-wk on broken sprinklers/main 6/28 - 8	6/28/2005 6/28/2005 Medium	Danny Vega Danny Vega		San Miguel ES
3030	Work In Progress main sprinkler line is broken in two places by new portables/need help & material /i need to water asap	6/28/2005 Medium	Danny Vega Fred Appelzoller		San Miguel ES
2832	Closed Work Orders 6-16-05 6-GRDS WK 1-HOOK-UP WATER TO PORTABLE A/C 1-CHANGE BALLAST BOYS RR/MAIN 6/16 - 8	6/16/2005 6/16/2005 Medium	Danny Vega Danny Vega		San Miguel ES
2863	Work In Progress NEW PORTABLES NEED WK ON WALLS & CEILING &WALL PAPER IS TORN /CEILING GRID IS HANGING/NEED HELP ON THIS /BEFORE PAINT	6/17/2005 Medium	Danny Vega Danny Miranda	Portables	San Miguel ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2603	Closed Work Orders 6-7-05 1-ck a/c units main bldg 1-move shelves to book rm 6-shelves assemble in book rm 6/7 - 8	6/7/2005 6/7/2005 Medium	Danny Vega Danny Vega		San Miguel ES
2541	Closed Work Orders 5-27-05 3-cut campus grass 1.5-pick-up supplys 1.5-replace lamps in hallway 5/27 - 6	6/6/2005 5/27/2005 Medium	Danny Vega Danny Vega		San Miguel ES
2559	Closed Work Orders 6-6-05 .5-ck wk w/h-d cust. 5.5-grds wk on campus 1.5-replace ballast rm 33-32 .5-meet w/MRS DUNCAN ON LA MESA(furniture) 6/6 - 8	6/7/2005 6/6/2005 Medium	Danny Vega Danny Vega		San Miguel ES
2746	Closed Work Orders 6-13-05 2-REPAIR LOCK/KITCHEN 5-GRDS WK 1-REPLACE BALLAST RM#45 6/13 - 8	6/13/2005 6/13/2005 Medium	Danny Vega Danny Vega		San Miguel ES
2709	Closed Work Orders 2-REPAIR BOOK SHELVES 2-PPD SUPPLYs 2-REPAIR SPRINKLERS 2-CLEAN MORGAN BLDG 6/10 - 8	6/10/2005 6/10/2005 Medium	Danny Vega Danny Vega		San Miguel ES
2677	Closed Work Orders 3-la mesa furniture(2 loads) 2-hook-up a/c units 2-clean parking lot 1-assemble furniture vice/principal 6-8-05 6/8 - 8	6/9/2005 6/8/2005 Medium	Danny Vega Danny Vega		San Miguel ES
2678	Closed Work Orders 2-la mesa furniture 2-run water to a/c units new portables 1-portable door locks 3-grds wk 6/9 - 8	6/9/2005 6/9/2005 Medium	Danny Vega Danny Vega		San Miguel ES
2686	Work In Progress need bob-cat sweeper to clean staff parking & re-stripe	6/10/2005 Medium	Danny Vega Lorenzo Hernandez		San Miguel ES
2687	Work In Progress two loads playground sand	6/10/2005 Medium	Danny Vega Lorenzo Hernandez		San Miguel ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2800	Closed Work Orders 1-remove sprinklers 2-clean -up fence line s&w pine trees 3-install 16 ft chalk board rm25 2-use weed eater by portables 6/15 - 8	6/15/2005 6/15/2005 Medium	Danny Vega Danny Vega		San Miguel ES
2801	Closed Work Orders 6-14-05 1-wo /126543 1-wo/126544 1-wo/126545 1.5-replace lamp ballast 1.5-replace security lamps main bldg 2-repair broken sprinkler 6/14 - 8	6/15/2005 6/14/2005 Medium	Danny Vega Danny Vega		San Miguel ES
1852	Work In Progress Please order paint so when portables arrive you can go ahead and paint. You site will be receiving one PLease see mike or call him for more info.	5/11/2005 Medium	Danny Vega	Portables	San Miguel ES
3101	Work In Progress ON JULY 5TH, SAL, JIMMY & GUILLERMO - NEED TO PICK UP TABLES & CHAIRS FROM SAN MIGUEL AND DELIVER TO LA MESA CAFETERIA.	6/30/2005 Medium			San Miguel ES
3088	Complete Sewer backing up to custodial sinks. cable out main sewer line to cafeteria restrooms.	6/29/2005 6/29/2005 Medium	David Villalobos	Restroom (Boys)	San Miguel ES
1634	Complete Monitoring data for DP 1088 is due in this office before May 31, 2005 PREPARE DATA AND TURN INTO OFFICE	5/4/2005 5/27/2005 Scheduled	Ricardo Jacquez	Mechanical Room	San Miguel ES
1879	Complete FILTER TO ICE MACHINE FELL OFF - WATER ALL OVER THE PLACE (THEY DID TURN OFF THE WATER) REMOVED AND REPLACED BROKEN WATER FILTER HOUSING	5/12/2005 6/30/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	San Miguel ES
1214	Complete WALK IN REFRIGERATOR - VERY WARM, NOT COOLING AT ALL EVA MIRANDA - SNP MANAGER 505-233-2860 REMOVED AND REPLACED BAD FAN PRESSURE CONTROL	4/18/2005 6/30/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	San Miguel ES
785	Void 03/30/05 4-cleaning master cools on ch/ desert t. 1-servise restroom on room 128 3- painting new doors rooms 96 57 and54	4/1/2005 Medium	Aida Salcedo		San Miguel ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
798	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. COMPLETED PER CERVANDO PADILLA	4/1/2005 4/28/2005 Medium	Aida Salcedo Cervando Padilla		San Miguel ES
3087	Work In Progress Double portable relocated to site was labeled as SM17DM1R there is no portable with that ID. Re-label this and all portables correctly.	6/29/2005 Low	Alfredo Holguin Michael Munoz	Portables	San Miguel ES
2198	Work In Progress NEED TO COMPLETE INSPECTION AND EVALUATION ON RALH REYES BY AUG 3, 2005	5/23/2005 Medium	Aida Salcedo Cervando Padilla		San Miguel ES
2199	Work In Progress NEED TO COMPLETE INSPECTION AND EVALUATION ON RALH REYES BY SEPT 7, 2005	5/23/2005 Medium	Aida Salcedo Cervando Padilla		San Miguel ES
2200	Work In Progress NEED TO COMPLETE INSPECTION AND EVALUATION ON RALH REYES BY OCT 5, 2005	5/23/2005 Medium	Aida Salcedo Cervando Padilla		San Miguel ES
2201	Work In Progress NEED TO COMPLETE INSPECTION AND EVALUATION ON RALH REYES BY NOV 2, 2005	5/23/2005 Medium	Aida Salcedo Cervando Padilla		San Miguel ES
2195	Complete NEED TO COMPLETE INSPECTION AND EVALUATION ON RALH REYES BY JUNE 1, 2005 INSPECTION COMPLETED AS PER MR. PADILLA	5/23/2005 6/6/2005 Medium	Aida Salcedo Cervando Padilla		San Miguel ES
2196	Work In Progress NEED TO COMPLETE INSPECTION AND EVALUATION ON RALH REYES BY JULY 6TH, 2005	5/23/2005 Medium	Aida Salcedo Cervando Padilla		San Miguel ES
1589	Closed Work Orders 5-2-05 1-ck wk orders/office 1.5-wk on sink faucets/boys 1-thropy-case shelves/lower 2.5-wk on shelves/rm#20 .5-repair desk rm#2 1.5-set-up sprinklers 5/2 - 8	5/3/2005 5/2/2005 Medium	Danny Vega Danny Vega		San Miguel ES
2330	Closed Work Orders 5-26-05 1-wo#126247 1-wo#126248 1-wo#126249 2-wk on rm#46 ramps 2-help set -up/portable 1-wk on office furniture 5/26 - 8	5/26/2005 5/26/2005 Medium	Danny Vega Danny Vega		San Miguel ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2347	Work In Progress need to open & install door between rms 37 and 38	5/27/2005 Medium	Danny Vega Danny Miranda	Portables	San Miguel ES rm#37-38
2308	Closed Work Orders 5-25-05 1-rm#28 ck a/c unit 1-replace lamps in lounge 1-repair office chair 5-wk on replacing ramp boards rm46 5/25 - 8	5/26/2005 5/25/2005 Medium	Danny Vega Danny Vega		San Miguel ES
2231	Closed Work Orders 5-20-05 1-REMOVE sprklrs 1-ck a/c library 1-ck a/c rm#33 5-wk On campus grds 5/20 - 8	5/24/2005 5/20/2005 Medium	Danny Vega Danny Vega		San Miguel ES
2232	Closed Work Orders 1-remove sprkls 5.5-wk on a/c units mesquite rm#104-401-4-223/623 door handle .5-ck wk orders for summer w/principal 1-secure bldg 5-23-05 5/23 - 8	5/24/2005 5/23/2005 Medium	Danny Vega Danny Vega		San Miguel ES
2255	Closed Work Orders 1-remove spklrs 1-ck a/c library 1-ck a/c rm28 2-repair broken sprklrs 1.5-cap sprklrs/by new portable 1.5-repair gate 5-24-05 5/24 - 8	5/24/2005 5/24/2005 Medium	Danny Vega Danny Vega		San Miguel ES
2280	Complete need flourescent lamp DEL LAMPS AND BALLASTS TO D. VEGA.	5/25/2005 6/27/2005 Medium	Danny Vega Enrique Sotelo		San Miguel ES
2050	Closed Work Orders 5-17-05 1.5-setup chairs for graduations 1-ck a/c unit kitchen 1-pick -chairs 3.5-cut campus grass/north 1-service mowers 5/17 - 8	5/17/2005 5/17/2005 Medium	Danny Vega Danny Vega		San Miguel ES
1919	Closed Work Orders 5-12-05 1-REOMVE SPRINKLERS .5-CK WK ORDERS/OFFICE 1-CLEAN STORAGE BLDG 1.5-WATER LEAK IN KITCHEN/ICE MAKER 4-GRNDS WK /COVER-UP HOLES IN LAWN 5/12 - 8	5/12/2005 5/12/2005 Medium	Danny Vega Danny Vega		San Miguel ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1942	Closed Work Orders 5-13-05 1-remove sprinklers .5-ck wk orders/office 1.5-cut weeds by play grd equipment 1.5-pick-up supplys at ppd 1-repair water fountain/main 1.5-spray round -up by bus parking area 1.-replace ceiling tiles/caferia 5/13 - 8	5/16/2005 5/13/2005 Medium	Danny Vega Danny Vega		San Miguel ES
1983	Closed Work Orders 5-16-05 1-remove spkls .5-ck wk orders/office .5-chng marquee letters 1-repair towel dispensers/boys 1-spray wasp nest/bldg 3-cut campus lawn /south 1-set-up spklrs/north 5/16 - 8	5/17/2005 5/16/2005 Medium	Danny Vega Margret Villalobos		San Miguel ES
2103	Work In Progress need number (stick-on)plates for all class rm doors as per MRS DUNCAN (PRINCIPAL) 1 THRU 60	5/19/2005 Medium	Danny Vega Hector Lozoya		San Miguel ES
2118	Work In Progress REFG. AIR UNIT PORTABLE#33/IS NOT WORKING/USED FOR SUMMER SCHOOL /NEED HVAC -TECH	5/19/2005 Medium	Danny Vega Jaime Gomez		San Miguel ES
2140	Work In Progress 1-THROW TRASH 1-REPAIR CHAIR RM#19 1-CK A/C UNIT RM#33 5-GRDS WK ON CAMPUS 5/19 - 8	5/19/2005 Medium	Danny Vega Danny Vega		San Miguel ES
2137	Duplicate Request 1-THROW TRASH FROM TRUCK BED TO DUMPSTERS	5/19/2005 5/20/2005 Medium	Danny Vega Danny Vega		San Miguel ES
3053	Complete WALK-IN REFRRIG. HAS ALOT OF ICE FORMING BEHIND THE FANS. EVA MIRANDA SNP MGR 233-2860 HAD TO DEFROST EVAP. COIL AND UNCLOGG CONDENSATE PAN DRAIN	6/29/2005 6/30/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	San Miguel ES
3054	Complete MILK COOLER IS NOT COOLING. (TEMP. IS AT 50) EVA MIRANDA SNP MGR 233-2860 CLEANED COND. COIL AND UNCLOGGED CONDENSATE PAN DRAIN	6/29/2005 6/30/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	San Miguel ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1711	Closed Work Orders 4/27/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 2-LEVELED SAND IN P.-GROUND AREAS. 1-MET WITH B&H REP. ABOUT WARRANTY WK. TO BE DONE. 2-CHECKED OUT HVAC. IN RMS. 310, AND TEACHERS LOUNGE. 1-ADJ. DRS. IN RMS 310 AND 107. 1-SHOWED GEO THERMAL ENG. AROUND BLDG. 4/27 - 8	5/6/2005 4/27/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
1712	Closed Work Orders 4/28/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 1.5-CLEANED SAND OFF ENTRY-WAYS AND S.WALKS. 1.5-DID MONTHLY DR. AND WINDOW INSP. 1.5-WORKED WITH PLUMBER IN BOILER RM. 1-DID WALK THRU WITH FIRE EXT. REPS. 1.5-DID LIGHTING INSP. 4/28 - 8	5/6/2005 4/28/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
1713	Closed Work Orders 4/29/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 1-CLEANED OFF ENTRY WAYS. 2-WENT TO PPD. FOR MATERIALS AND TURN IN TIME. 1-DID LANDSCAPE INSP. 1-DID FENCE INSP. 1-DID CONCRETE INSP. 1-DID GAS INSP. 4/29 - 8	5/6/2005 4/29/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
1315	Complete ATTN. MIKE MUNOZ. MIKE COULD YOU PLEASE HAVE EL PASO DISP. CHANGE OUT OUR DUMPSTERS FOR SOME CLEAN ONES. THE ONES WE HAVE NOW HAVE SMELL REALLY BAD. THANKS. Contacted Troy and EP Disposal and he will change out dumpsters.	4/21/2005 4/26/2005 Medium	Gerardo Marquez Juliet Parra		Santa Teresa ES
1308	Forwarded ATTN. D.BOYD. DAVE, NEED FOR CONTR. TO FINISH WORK ON BOLLARDS AT CAFET. ALSO NEED THEM TO FINISH WARRANTY WORK .	4/21/2005 Medium	Gerardo Marquez David Boyd		Santa Teresa ES
1305	Void ATTN. MANNY. NEED FOR YOU TO INSTALL LOCKS ON CABINETS IN THE RESOURCE RM.	4/21/2005 Medium	Gerardo Marquez Hector Lozoya		Santa Teresa ES
1306	Complete ATTN. MANNY. MANNY NEED FOR YOU TO CHECK OUT LOCKSET AT NURSES RR. DR. STILL HAVING PROBLEMS WITH IT. repair lockset	4/21/2005 4/22/2005 Medium	Gerardo Marquez Hector Lozoya		Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1547	Closed Work Orders 4/26/05 1-INSPECT BLDG. AND GRNDS. PICKED UP TRASH. 2-CLEANED ENTRY WAYS AND SIDEWALKS. 1-CLEANED AND INSP. P. GROUND EQUIP. 2-CLEANED SCREENING AND SAND OFF BB. BALL COURTS AND ASPHALT. 1-PAINT TOUCH UP IN RM. 202. 1-PAINTED SHELF IN RM.101. TOUCHED UP WALLS. 4/26 - 8	4/29/2005 4/26/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
1545	Closed Work Orders 4/25/05 1-INSPECT BLDG.AND GRNDS. PICKED UP TRASH. 3-REMOVED MARKER BOARD AND PUT UP BOOK SHELF IN RM 202. 4-WORKED ON LANDSCAPE AT BACK AND NORTH SIDE OF BLDG. 4/25 - 8	4/29/2005 4/25/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
1455	Forwarded ATTN. D.BOYD. DAVE, HERE IS A LIST OF WARRANTY WK. STILL NEEDING TO BR DONE. 1-HOLES IN SUB-CEILING STILL NOT SEALED. 2-J. BOX COVERS NEED TO BE PUT ON. 3-SCUPPER AT CAF. NEEDS TO BE INSTALLED. 4-STAINS ON SOUND PANELS IN CAF. BLED OUT AGAIN. 5-WARPED DRS. NEED TO BE REPLACED. 6-FILED DOWN STRIKES NEED TO BE REPLACED. 7-HANDICAP OPENER STILL NOT FIXED. 8-DOUBLE DRS. STILL NEED ADJ. 9-DOGGING DEVICE AT CAF. DRS WERE NEVER INSTALLED. 10-NEED TO FINISH REPLACING CRACKED V.C.T. 11-RAIN STILL PONDING AT S.PLAY AREA. 12-RAIN STILL UNDERCUTTING SIDEWALK AT FRONT ENTRANCE. 13-HOLE IN ASPHALT NEEDS TO BE REPAIRED. DAVE, ON THE PUNCH LIST UNDER ITEM #4. DID YOU DECIDE ALL WOOD DOORS ARE TO TAKE THRU BOLTS OR JUST CERTAIN ONES?.	4/27/2005 Medium	Gerardo Marquez David Boyz		Santa Teresa ES
2175	Closed Work Orders 5/19/05 1-INSP. BLDG.AND GRNDS. 1-PICKED UP TRASH IN GRASS AREA. 1-CHECKED OUT HVAC IN RM. 302. 1-WORKD ON LEAK AT ICE MACHINE. 2-CLEANED UP CONFETTI MESS LEFT BY 6TH GRADE FAREWELL CELEBR. 2-CLEANED DIRT AT PARENT PICK UP AREA. 5/19 - 8	5/20/2005 5/19/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2179	Closed Work Orders 5/20/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 1.5-ATTENDED END OF THE YEAR MEETING AS PER MR. Y. 1.5-MET WITH SPED DEPT. ABOUT PARTITION DESIGN. 2-CHECKED HVAC FILTERS IN A AND B WINGS. CHANGED OUT AS NEEDED. 2-DELEVERED TABLES AND CHAIRS AS PER MR.Y. 5/20 - 8	5/20/2005 5/20/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2164	Closed Work Orders 5/9/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 1-DID M. VEHICLE INSP. &COMM. INSP. 1-CLEANED AND INSP. P.G. EQUIP. 1-CLEANED OFF ENTRY WAYS. 4-CUT AND PICKED UP WEEDS AT N.W. PONDING AREAS. 5/9 -8	5/20/2005 5/9/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2165	Closed Work Orders 5/10/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 3-CUT WEEDS AT BACK P.G.AREA,RAKED AND LEVELED SCREENING. 1-WORKED ON LOCK AT NURSES R.R. DR. 3-PRUNED TREES AND DISPOSED OF TRIMMINGS. 5/10 - 8	5/20/2005 5/10/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2166	Closed Work Orders 5/11/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 1-CLEANED OFF ENTRYWAYS. 2-WORKED ON SPRINKLER SYST.WITH JUAN FROM G.H. 2-CLEANED LIGHT FIXTURES ON OUTSIDE WALL, S.SIDE. 2-CLEANED SCREENING OFF BACK ROADWAY. 5/11 - 8	5/20/2005 5/11/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2167	Closed Work Orders 5/12/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 3-LEVELED OFF DIRT IN N.PONDING AREAS. 2.5-WASHED OFF TABLES AND CONCRETE UNDER CANOPIES. 1.5-WENT FOR BLEACHER AT STHS. AND SET UP IN CAFET. 5/12 - 8	5/20/2005 5/12/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2168	Closed Work Orders 5/13/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 1.5-EMPTIED AND WASHED OUT TRASH CANS FROM P.G.AREA. 1.5-WENT TO PPD TO TURN IN TIME AND PICK UP MATERIAL. 3-WORKED ON HVAC UNIT TO TESTING RM. 1-PICKED UP TRASHBAGS FROM SPRING JAM. 5/13 - 8	5/20/2005 5/13/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2170	Closed Work Orders 5/16/05 2-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 2-DRAINED WATER FROM BACK P.G. AREA. 2-SHOWED L. SOLIZ AROUND FOR HIS INVENTORY OF HVAC UNITS. 2-CHECKED OUT HVAC TO TESTING RM. WITH J. AMBRIZ AND SUPPLIER. 5/16 - 8	5/20/2005 5/16/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2171	Closed Work Orders 5/17/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 1-TOOK PHOTOS OF RAIN DAMAGE AND E-MAILED TO M.MUNOZ AND D.BOYD. 1-CHECKED OUT HVAC IN NURSES OFFICE WITH J. AMBRIZ 2-LEVELED SAND IN BACK P.G. AREA. 3-DID WATER DAMAGE CLEAN UP AT S.W. AREAS. 5/17 - 8	5/20/2005 5/17/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2172	Closed Work Orders 5/18/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 2-WORKED ON DR. CLOSURE DEVICE WITH APCO INSTALLERS. 1-LEVELED SAND AT FRONT P.G. AREA. 2-WORKED ON LOCK AT NURSES RR. DR. 2-MET WITH GEN CON AND APCO. REPS ABOUT WARRANTY WK. 5/18 - 8	5/20/2005 5/18/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
1982	Complete ATTN. ANGEL GONZALEZ ANGEL COULD YOU DELIVER THE BOBCAT AND SWEEPER ATTACHMENT TO ME ON MONDAY ,MAY 23. THANKS JERRY. DELIVERED BOBCAT AND SWEEPER ON 5/23 AND PICKED UP 5/26.	5/17/2005 5/26/2005 Medium	Gerardo Marquez Angel Gonzales		Santa Teresa ES
2020	Closed Work Orders 5/2/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 1-FILED POLICE REPORT ON VANDLISM OF BACK GATE. 2-FIXED BACK GATE. PAINTED OVER GRAFFITI. 1-CLEARED ENTRYWAYS. 2-HELPED PLUMBER WITH FLOW SWITCHES. 1-CHECKED OUT HVAC. IN RM. 208. 5/2 - 8	5/17/2005 5/2/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2021	Closed Work Orders 5/3/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 1.5-CLEANED OFF ENTRYWAYS. 1.5-WENT TO GHS. TO PICK UP MATERIAL FROM SPEEDY. 1-TRIED TO REPAIR ICE MACHINE. 3-CUT AND RAKED WEEDS AT FRONT FENCE AREA. LEVELED SCREENING. 5/3 - 8	5/17/2005 5/3/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2022	Closed Work Orders 5/4/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 1-CUT WEEDS AT N. END OF CAF. LEVELED SCREENING. 2-LEVELED SAND IN P. GROUND AREAS. CLEANED OFF EQUIP. AND DID M. INSP. 3-PULLED WEEDS IN ROCK AREA BY FRONT GATE. RELEVELED ROCKS TO COVER BALD SPOTS. 1-CHECKED OUT HVAC IN RM 208. 5/4 - 8	5/17/2005 5/4/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2023	Closed Work Orders 5/5/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 3-CLEANED COURTYARDS , LEVELED SCREENING. 1-TALKED TO BOB CARSON FROM GEN CON ABOUT UNFINISHED WARRANTY WORK, AS PER D. BOYD. 1-FIXED LEAKING WATER FILTER ON ICE MACHINE. 1-ADJ. WATER PRES. OF BUILDING AS PER B&H MECH. 1-CLEANED UP SHATTERED GLASS IN PARKING LOT. 5/5 - 8	5/17/2005 5/5/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2024	Closed Work Orders 5/6/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 1-CAUGHT SNAKE IN P. GROUND AREA. RELEASED IN DESERT. 4-HELPED ELECTR. INSTALL HEATERS IN RM. 101, CONNECT FLOW VALVES IN BOILER RM. AND REPLACE GFI. IN MECH. RM. A-WING. 1-CHECKED OUT HVAC IN TEACHERS LOUNGE. 1-ANNUAL LEAVE. (SEMSWK # 20395). 5/6 - 7	5/17/2005 5/6/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2475	Work In Progress ATTN; JOSE AMBRIZ. NEED FOR YOU TO FIX HVAC TO TESTING RM.	6/3/2005 Medium	Gerardo Marquez Jose Ambriz		Santa Teresa ES
2476	Closed Work Orders 6/2/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 1.5-CLEANED SIDEWALK AT P. PICK-UP AREA. 1.5-CHECKED HVAC UNITS IN RMS. 110,111,112, AND TESTING WITH J. AMBRIZ. 2-CLEANED DIRT OFF FRONT PARKING LOT AREA. FILLED IN WASH OUT BY FRONT GATE. 1-PAINT TOUCH UP IN A-WING. 1-INSTALLED NEW P.TOWEL DISP. IN A-WING. 6/2 - 8	6/3/2005 6/2/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2494	Complete ATTN. CALI; NEED FOR YOU TO ORDER ME 5 PLASTIC PANELS FOR THE 2FT. X4FT. LIGHT FIXTURES. THANKS	6/3/2005 6/24/2005 Medium	Gerardo Marquez Carlos Castillo		Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2432	Work In Progress ATTN. MARGRET; NEED FOR YOU TO CALL EXTERMINATOR TO SPRAY FOR FLYING ANTS. HAVE BEEN SPRAYING WITH THE DEAD-SURE, BUT I STILL CANT GET RID OF THEM. PARENTS HAVE BEEN COMPLAINING TO RITA. I TALKED TO MIKE, AND HE SAID TO SEND YOU A WK. ORDER. Faxed PO on 6/8/05 45013796	6/2/2005 Medium	Gerardo Marquez Margret Villalobos		Santa Teresa ES
2433	Closed Work Orders 6/31/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 1-STOPPED WATER FILTER ON ICE MACHINE FROM LEAKING. 1-DID MONTHLY OFFICE INSP. 1-CHECKED HVAC IN RMS. 211 AND 212. 4-WORKED ON MONTHLY INSP. 5/31 - 8	6/2/2005 5/31/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2434	Closed Work Orders 6/1/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 2-PULLED WEEDS AT BACK GRASS AREA, ALONG FENCE. 1-CLEANED LIGHT FIXTURES ON OUTSIDE WALLS AT A-WING AND W. COURTYARD. 1-CHECKED HVAC IN RM.104. 3-PAINT TOUCH-UP IN A-WING. 6/1 - 8	6/2/2005 6/1/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2261	Closed Work Orders 5/25/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 1-CLEANED AND INSP. P.G. EQUIP. 1-CHECKED OUT SPRINKLER SYST. WITH JUAN, FROM G.H. NURSERY 5-WORKED ON CLEANING UP WASH-OUT AT BACK ROAD AND P.G. AREA. 5/25 - 8	5/24/2005 5/25/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2230	Closed Work Orders 5/23/05 1.5-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 2-PICKED UP TABLES AND CHAIRS. UNLOADED, CLEANED AND STORED THEM. 2.5-WEED CONTROL. SPRAYED ROUND UP AT SE. N. AND E. SIDES. 2-CLEANED WASH OUT AT FRONT ENTRANCE. 5/23 - 8	5/23/2005 5/23/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2358	Forwarded ATTN MIKE MUNOZ. MIKE, WOULD YOU CHECK THE STATUS ON THE PARTS FOR THE RR. FAUCETS THAT THE CONTR. WAS SUPPOSE TO REPLACE AS OF ABOUT 3 MONTHS AGO.	5/27/2005 Medium	Gerardo Marquez David Boyd		Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2353	Closed Work Orders 5/25/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 1-CHECKED OUT WORK WITH ALLEN FROM GEN CON. 1-CHECKED OUT DR. WORK TO BE DONE WITH APCO. 5-WORKED ON WASH OUT AT FRONT GATE AREA. 5/25 - 8	5/27/2005 5/25/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2354	Closed Work Orders 5/26/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 1-SHOWED CONT. AREAS TO BE FIRE SEALED IN B-WING AREA. 3-CLEANED DIRT FROM PARKING LOTS,AND ROAD AREAS. 1-DID MONTHLY EMERG. LIGHT INSP. 1-DID MONTHLY EXIT SIGN INSP. 1-DID MONTHLY FIRE EXT. INSP. 5/26 - 8	5/27/2005 5/26/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2355	Work In Progress ATTN. JOSE AMBRIZ. JOSE, I NEED FOR YOU TO ORDER ME 3 BOXES OF HVAC FILTERS. 20"X30"X1" THANKS.	5/27/2005 Medium	Gerardo Marquez Jose Ambriz		Santa Teresa ES
2323	Work In Progress 5/26/05 MIKE; I NEED FOR YOU TO GET ME A COPY OF THE PAINT SCHEDULE. THANKS.	5/26/2005 Medium	Gerardo Marquez Michael Munoz		Santa Teresa ES
453	Work In Progress ATT. ANGEL GONZALEZ. ANGEL I NEED FOR YOU TO SERVICE TRUCK 107.WOULD YOU LET ME KNOW WHEN YOU CAN FIT IT IN TO YOUR SCHEDULE. THANKS.	3/16/2005 Medium	Gerardo Marquez Angel Gonzales		Santa Teresa ES
454	Work In Progress ATT. CALI CASTILLO. CALI, NEED FOR YOU TO FOLLOW UP ON WK. OR. 124323. THANKS. NEED FOR YOU TO COME CHECK A COUPLE OF LIGHT FIXTURES THAT I AM HAVING TROUBLE WITH.	3/16/2005 Medium	Gerardo Marquez Carlos Castillo		Santa Teresa ES
455	Complete ANGEL. GONZALEZ. ANGEL COULD YOU BRING ME THE BOB CAT WITH THE BUCKET AND ALSO THE SWEEPER . IF YOU COULD BRING IT TO ME ON FRIDAY THAT WOULD BE GREAT. delivered bobcat on 3/21 and picked up on 3/24/05	3/16/2005 3/24/2005 Medium	Gerardo Marquez Angel Gonzales		Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
674	Closed Work Orders 3/8/05 1-INSPECT BLDG.AND GRNDS. PICKED UP TRASH. 2-HELPED CONTR. PUT SAFETY BOLTS ON BACKBOARDS IN CAFET. 1-CLEANED OFF SCREENING FROM BB.BALL COURTS. 2-CHANGED AND CLEANED FILTERS ON HEAT RECOVERY UNITS. 2-DID MONTHLY FIRE EXT. AND EMERGENCY LIGHT, AND EXIT LIGHT INSP.	3/29/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
675	Closed Work Orders 3/9/05 INSP. BLDG.AND GRNDS. PICKED UP TRASH. 1-CLEANED OFF ENTRYWAYS. 1-CLEANED P.GROUND EQUIP. 1-DID MONTHLY ASPHALT INSP. 1-DID MONTHLY OFFICE INSP. 2-DID MONTHLY WINDOW AND DR. INSP. 1-UNLOCKED CAR FOR PARENT WHO LEFT KEYS IN CDAR.	3/29/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
672	Closed Work Orders 3/7/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 1-CLEARED DIRT OFF FRONT SIDEWALK.; 1-CLEANED AND INSP. P.GROUND EQUIP. 1-MARKED TILES TO BE CHANGED OUT IN HALLWAY BY T.LOUNGE. 1-CLEANED COURTYARD BETWEEN BAND C-WINGS. 2-CHECKED HVAC IN NURSES OFFICE AND ADMIN AREA WITH J.AMBRIZ. 1-CLEANED DUMPSTER AREA.	3/29/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
669	Closed Work Orders 1/4/05 INSP. BLDG.AND GRNDS. PICKED UP TRASH. 1-WORKED ON DEAD-BOLT IN RM.101. 2-WENT TO PPD. TO TURN IN TIME AND PICK UP MATERIAL. 1-REHUNG P.TOWEL DISP. IN RM.209. 1-INSP. TILES CHANGED OUT IN A-WING. MARKED ONES THEY MISSED. 2-BUILT SHELF IN WK.RM.B-WING.	3/29/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
664	Closed Work Orders 2/28/05 1-INSPECT BLDG.AND GRNDS. PICKED UP TRASH. 1-CHECKED OUT HVAC IN RM. 302. 1-MARKED FLOOR TILES TO BE CHANGED OUT BY CONTR. IN A-WING. 1-CLEANED AND INSP. P. GROUND EQUIP. 2-CHECKED OUT WATERING SYSTEM WITH G.H. NURSERY REP. 2-CUT AND PICKED UP WEEDS AT N.SIDE OF GRNDS.	3/29/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
665	Closed Work Orders 3/1/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 1-CLEARED OFF ENTRYWAYS. 2-CLEANED TRASH IN ROCKS AT FRONT OF SCHOOL. 2-CHECKED OUT HVAC UNITS IN A-WING. CHANGED OUT FILTERS AS NEEDED 2-WORKED ON DRESSING UP WASHED OUT AREAS.	3/29/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
667	Closed Work Orders 3/2/05 1-INSP. BLDG.AND GRNDS. PICKE UP TRASH. 1-WORKED ON URINAL IN B.RR.B-WING. 3-WEED CONTROL. SPRAYED ROUND UP . 3-WORKED ON IRRIG. SYST. WITH G.H. NURSERY. CHANGED OUT VALVE NO.15, AND DRIP LINES AT SW. AREAS.	3/29/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
678	Closed Work Orders 3/10/05 INSP. BLDG.AND GRNDS. PICKED UP TRASH. 1.5-WORKED ON ROLL-UP DR. IN CAFET. TIGHTENED BOLTS AND LUBED. 1-CLEANED P.GROUND EQUIP. .5-WORKED ON D.BOLT IN RM.1O1. 2-CLEANED SCREENING OFF RD. AND SIDEWALKS AT P.GROUND AREA. 2-DID MONTHLY EXIT AND EMERG. LIGHT INSP.	3/29/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
679	Closed Work Orders 3/11/05 1-INSP.BLDG AND GRNDS. PICKED UP TRASH. 1-WORKED ON URINAL IN C-WING. 1-SHOWED APCO DRS. NEEDING WARRANTY WK. 1-CLEANED AND INSP. P.GROUND EQUIP. 2-CLEANED OUT MECH.RMS. CHECKED OUT PUMPS. 2-TRIED TO UNCLOG DRAIN IN CAFET. STORAGE RM.	3/29/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
651	Complete LOCKSET IN NURSES RR. SEEMS TO BE INSTALLED BACKWARDS. LATCH LOCKS ON THE INSIDE , BUT DOES NOT LOCK ON THE OUTSIDE. NEED FOR APCO TO CORRECT THE PROBLEM. repair locks at nurses office.	3/29/2005 3/30/2005 Medium	Gerardo Marquez Hector Lozoya		Santa Teresa ES nurses restroom
357	Forwarded warranty wk for D. Boyd. womens faculty RR. has been smelling bad . need for B&H mech. to check that they didnt leave off any clean out caps like in other RRms.	3/14/2005 Medium	Gerardo Marquez	Restroom (Girls)	Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
907	Closed Work Orders 3/14/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 2-CLEANED SAND OFF ENTRY-WAYS.AND DOORS IN COURTYARD. 1-CLEANED AND INSP. P.-GROUND EQUIP. 1-WORKED ON HVAC UNIT IN RM. 302. 1-CHECKED RR. AT END OF WINGS FOR CAUSE OF ROTTEN EGG SMELL. 2-DID MONTHLY CONCRETE AND FENCE INSP.	4/6/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
908	Closed Work Orders 3/16/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 3-WORKED WITH CONTR. TRYING TO FIND ROOF LEAK. 1.5-DID MONTHLY LANDSCAPE INSP. 2.5-DID MONTHLY P-GROUND INSP. TIGHTENED NUTS AND BOLTS.	4/6/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
909	Closed Work Orders 3/17/05 INSP. BLDG.AND GRNDS. PICKED UP TRASH. 2-CLEANED BIRD DROPPINGS FROM ENTRY-WAYS AND SIDEWALKS. 1-CLEANED AND INSP. P-GROUND EQUIP. 1-MARKED FLOOR TILES TO BE REPLACED BY CONTR. IN B-WING. 3-SWEPT OFF BOTH COURTYARDS.	4/6/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
910	Closed Work Orders 3/18/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 1-DID MONTHLY SIGN INSP. 2-LEVELED SAND IN P-GROUND AREAS. 4-COMP-TIME.	4/6/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
894	Closed Work Orders 3/15/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. .5-POURED H-20 IN P-TRAPS. HOPING TO GET RID OF SMELL 2.5-WORKED ON HVAC IN PARENTS WK. RM. C-WING. CHECKED OUT PUMP,WIRING, AND PHASING WITH JOSE A. 1.5-BROKE DOWN TABLES NOT IN USE AND STORED THEM. 1.5-REMOVED OLD T.P. HOLDERS THROUGHOUT BLDG. 1-CLEANED AREA BY DUMPSTERS.	4/6/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
921	Forwarded ATTN. D.BOYD. NEED TO CHECK ON PRINTS TO VERIFY IF PONY WALLS ON ROOF ARE SUPOSE TO HAVE A METAL CAP LIKE THE REST OF THE STUCCO WALLS. THIS MAY BE THE REASON THEY ARE CRACKING.	4/7/2005 Medium	Gerardo Marquez David Boyd		Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
922	Forwarded ATTN. D.BOYD. PLASTIC SIDES ON FIRE ENGINE NO#9 ARE CRACKING. NEED TO CONTACT DONNY WITH REC. CREATIONS. as per David Boyd forward this wo to Pam Wright. xc: Pam Wright on 4/7/05 - mkv	4/7/2005 Medium	Gerardo Marquez David Boyd		Santa Teresa ES
961	Closed Work Orders 3/31/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 1-WORKED ON CLOGED TOILET IN FACULTY RR. A-WING. 1-CLEANED OFF P.GROUND EQUIP. 2-CLEARED SAND OFF ENTRYWAYS. 1-REMOUNTED POWDER DETERGENT DISP. FOR HOBART WASHER IN CAFET. 1-REMOVE TRAP PRIMER IN FACULTY RR. CLEANED IT AND REINSTALLED. 1-DID MONTHLY FIRE EXTINGUISHER INSP.	4/8/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
957	Closed Work Orders 3/28/05 8-HOLIDAY	4/8/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
958	Closed Work Orders 3/29/05 1-INSP.BLDG.AND GRNDS. PICKED UP TRASH. 2-SWEPT SAND OFF ENTRYWAYS. 2-INSP. P. GROUND EQUIP. AND LEVELED SAND. 2-REMOVED STAPLES,TAPE AND GLUE FROM CORRIDOR WALLS. 1-WORKED ON DAILY LOGS.	4/8/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
959	Closed Work Orders 3/30/05 1-INSP. BLDG.AND GRNDS. PICKED UP[TRASH. .5-HELPED PABLO MOVE TABLES IN LIBRARY. 2.5-WORKED ON LOCK IN NURSES RR. DR. 1.5-FIXED RAILING IN CAF. STAGE AREA. REPLACED ANCHOR BOLTS. 2.5WORKED ON PLUMBING WITH DAVE FROM B&H MECH.	4/8/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
947	Closed Work Orders 3/21/05 1-INSPECT BLDG.AND GRNDS. PICKED UP TRASH. 3-PULLED AND PICKED UP WEEDS AT PONDING AREA. 4-PULLED AND PICKED UP WEEDS IN SCREENING AREAS.	4/7/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
948	Closed Work Orders 3/22/05 4-ATTENDED SAFETY MEETING AT S.T.M.S. 4-CLEANED DIRT OFF P.LOT AND ROAD AROUND SCHOOL.	4/7/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
949	Closed Work Orders 3/23/05 1-INSPECT BLDG.AND GRNDS. PICKED UP TRASH. 2-WENT OVER TILE WK. TO BE DONE WITH CONTR. 1-CHECKED OUT LOCK AT NURSES RR.DR. 4-WORKED REMOVING DIRT FROM WASHED- OUT AREAS.	4/7/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
950	Closed Work Orders 3/24/05 2-INSP. BLDG.AND GRNDS. PICKED UP TRASH. PICKED UP BROKEN BOTTLES AND TRASH IN ROCKY AREAS. 6-REMOVED REMAINING DIRT FROM S.E.PLAY AREA,AND FROM N.E. AREAS. RESWEPT ALL ASPHALT AND CONCRETE.	4/7/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
1303	Forwarded MIKE, THE TREES OUT HERE NEED TO BE PRUNED.COULD YOU LET ME KNOW IF I CAN DO IT , OR IF GREENHOUSE NEEDS TO DO IT. as per Mike this is for David Boyd.	4/21/2005 Medium	Gerardo Marquez David Boyd		Santa Teresa ES
1154	Closed Work Orders 4/4/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 1-CLEARED OFF ENTRYWAYS. 2-WORKED ON HOBART MIXER IN CAFET. 1-SHOWED PLASTER CONTR. WALL WITH CRACKS TO BE REPAIRED. 3-CUT WEEDS AND LEVELED SCREENING AT N.AND E. OF BLDG. 4/4 - 8	4/14/2005 4/4/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
1158	Closed Work Orders 4/5/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 2-CLEARED SAND FROM ENTRY-WAYS. 1-BUILT AV. CART FOR COMP. LAB. 2-WORKED WITH PLASTER CONTR. REPAIRING WALLS. 2-CLEANED LIGHT FIXTURES IN A,B,AND C- WINGS. 4/5 - 8	4/14/2005 4/5/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1161	Closed Work Orders 4/6/05 1-INSPECT BLDG.AND GRNDS. PICKED UP TRASH. 1-REPLACED STAINED CEILING TILES. 1-LEVELED SAND IN BACK P.GROUND AREA. 1-CLEANED SIDEWALKS AND ENTRYWAYS IN BACK AREA. 2-WORKED WITH PLASTER CONTR. 2-CLEANED BB. COURTS AND LEVELED SCREENING. 4/6 - 8	4/14/2005 4/6/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
1166	Closed Work Orders 4/7/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 2-SHOVELED SAND THAT OVERFLOWS FROM PLAY AREA ONTO SCREENING. 1-DID BOILER RM. INSP. WITH J.AMBRIZ. 1-FIXED WHEELCHAIR FOR MR.PEREZ STUDENT. 3-FINISHED SHOVELING SAND AT FRONT P.GROUND AREA. AND LEVELED SCREENING. 4/7 - 8	4/14/2005 4/7/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
1168	Closed Work Orders 4/8/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 1-FIXED V. CLEANER FOR PABLO. 1-CLEANED AND INSP. P.GROUND EQUIP. 2-SPRAYED ROUND UP AT FRONT AREAS. 3-RAKED ROCKS FROM S.W.GRASS AREA , WHERE WASH-OUT OCCURED. 4/8 - 8	4/14/2005 4/8/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2635	Complete ATTN. MIKE MUNOZ MIKE , THE DOOR THAT APCO CAME TO REPLACE IN RM.202, IS NOT WORKING PROPERLY. THEY LEFT THE LOCKSET ALL LOOSE AND IT KEEPS LOCKING THE TEACHERS IN. WOULD YOU SEND APCO BACK TO FIX IT. As per Mike route to Danny M. 6/10/05	6/8/2005 6/13/2005 Medium	Gerardo Marquez Danny Miranda		Santa Teresa ES
2776	Closed Work Orders 6/13/05 1-insp. bldg.and grnds. picked up trash. 2-cleared entry ways and sidewalks. 1-SPRAYED RMS. 210&212 FOR ANTS. 1-SPRAYED CAFET. FOR ANTS AND CLEANED SPRAYED AREAS OF DEAD ANTS. 3-REPLACED TREES AND SHRUBS WITH JUAN FROM G.H.NURSERY. 6/13 - 8	6/14/2005 6/13/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2777	Closed Work Orders 6/14/05 1-INSP BLDG. AND GRNDS. PICKED UP TRASH. 1.5-CHECKED OUT LOCKSET TO RR. IN RM.202. 1.5CLEANED FILTERS IN HEAT RECOVERY UNIT, C-WING. 1-CHANGED WATER PUMP TO MASTERCOOL AT CAFET. 1.5-WORKED ON LANDSCAPE WITH JUAN FROM G.H. NURSERY. 1.5-PAINT TOUCH-UP IN B-WING. 6/14 - 8	6/14/2005 6/14/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2751	Closed Work Orders 6/7/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 1-DID VEHICLE AND RADIO INSP. 1-CLEANED SCREANING OFF BB.COURTS. 2-CLEANED LIGHT FIXTURES IN C-WING .5-CHECKED OUT HVAC IN RM 212. 1.5-WORKED ON LIGHT FIXTURE IN LIBRARY.(CHANGED BALLASTS). 1-CAULKED BEHIND SINKS IN C-WING. 6/7 - 8	6/13/2005 6/7/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2752	Closed Work Orders 6/8/05 1-INSP. BLDG. AND GRNDS., PICKED UP TRASH. 1.5-WORKED ON SINK IN CONF. RM.(LEAKING FROM TRAP. 1.5-CLEANED COURTYARD BETWEEN A&B WINGS. 1-CHECKED OUT HVAC IN RM 212. 2-REPLACED LOOSE VCT. IN RM. 107. 1-SPRAYED FOR ANTS IN CAFET. 6/8 - 8	6/13/2005 6/8/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2753	Closed Work Orders 6/9/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 1-CHECKED OUT HVAC IN WK. RM. B-WING. 2-WEED CONTROL IN ROCK AREAS. 4-PERSONAL LEAVE. 6/9 - 4	6/13/2005 6/9/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2754	Closed Work Orders 6/10/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 1-CLEANED AND INSP. P.G. EQUIP. 1-FIXED LEAKING FLOAT ON MASTERCOOL. 1-STORED EXTRA TABLES IN MAINT. STORAGE RM. 2-WENT TO PPD. TO TURN IN TIME AND PICK UP MATERIAL. 1-DID M.EXIT SIGN INSP. 1-DID M. EMERG. LIGHTING INSP. 6/10 - 8	6/13/2005 6/10/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2747	Closed Work Orders 6/3/05 1-INSP. BLDG.AND GRNDS, PICKED UP TRASH. 3-DID WEED CONTROL AT PONDING AREAS. 2-LEVELED SAND IN P.GROUND AREAS. 2-CLEANED OUT MAINT. STORAGE RMS. 6/3 - 8	6/13/2005 6/3/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2748	Closed Work Orders 6/6/05 1-INSP. BLDG.AND GRNDS, PICKED UP TRASH. 2-CLEANED OFF ENTRYWAYS. 1-CLEANED AND INSP. P.G.EQUIP. 4-PAINT TOUCH UP IN C-WING. 6/6 - 8	6/13/2005 6/6/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2849	Work In Progress ATTN SPEEDY. SPEEDY, I NEED A LOAD OF SAND FOR THE PLAYGROUND EQUIP. AREAS. SAND IS NOT QUITE 12" DEEP AS REQUIRED. THANKS.	6/17/2005 Medium	Gerardo Marquez Lorenzo Hernandez		Santa Teresa ES
2850	Closed Work Orders 6/15/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 1.5-PULLED WEEDS FROM SCREENING AROUND PARKING LOTS. 1.5-CLEANED OFF ENTRYWAYS. 1.5-TOUCHED UP WALLS IN B-WING FOR PAINTING. 1-PAINT TOUCH UP IN B-WING. 1.5-SPRAYED BLDG. FOR BUGS. 6/15 - 8	6/17/2005 6/15/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2851	Complete 6/16/05 1-INSP BLDG. AND GRNDS. PICKED UP TRASH. 1-CLEANED OFF ENTRY WAYS. 2-LEVELED SAND AT FRONT PLAYGROUND AREA. 1-READJ. ROLLERS ON GATES. 2-CHECKED OUT HVAC TO TESTING RM. WITH JOSE AMBRIZ. 1-PAINT TOUCH-UP IN B-WING. 6/16 - 8	6/17/2005 6/16/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2870	Closed Work Orders 6/17/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 2-CUT WEEDS AND LEVELED SCREENING BY BACK P.G. AREA. 1-REPLACED SHRUBS WITH JUAN FROM G.H.NURSERY. 1-SET UP P. AIR CONDITIONER IN TESTING RM. 2-CLEANED OUT MECH. RMS., AND PERFORMED M. GAS LEAK CHECK. 1-DID M. FIRE EXTING. INSP. 6/17-8	6/20/2005 6/17/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
2871	Work In Progress ATTN. D.BOYD DAVE, COULD YOU FIND OUT WHY B&H MECH. HAS NOT COME TO FIX BROKEN FAUCETS AT REST RMS. DAVID BANUELOS HAD ORDERED REPLACEMENT PARTS, BUT HASNT BEEN BACK TO FIX THEM. THIS IS WARRANTY WK. THANKS.	6/20/2005 Medium	Gerardo Marquez David Boyd		Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2941	Work In Progress ATTN.MIKE MUNOZ MIKE, NEED TO HAVE SECTION OF FENCE REPAIRED, DUE TO SOMEBODY WRECKING INTO IT AT THE S.SIDE OF GRASS AREA.	6/22/2005 Medium	Gerardo Marquez Michael Munoz		Santa Teresa ES
3001	Closed Work Orders 6/20/05 INSP. BLDG.AND GRNDS. PICKED UP TRASH. 1-WEED CONTROL AT FRONT FENCE AREA &AT ROCKS BY FRONT GATE. 2-INSTALLED DR. STOPS IN ADM. AREA. 1-DID M. OFFICE INSP. 1-SPRAYED CAFET. DRS. FOR ANTS. 1-CLEANED UP DEAD ANTS. 1-DID M. FENCE INSP. 1PDID M. DOOR AND WINDOW INSP. 6/20 - 8	6/27/2005 6/20/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
3002	Closed Work Orders 6/22/05 1-INSP BLDG. &GRNDS. PICKED UP TRASH. 1.5-REPORTED DAMAGED FENCE TO SHERIFF& TO MIKE MUNOZ. MADE OUT POLICE REPORT. 1.5-PICKED UP WEEDS AND TRASH THROUGHOUT CAMPUS. 2-REPLACED BROKEN SPRINKLER HEADS AND ADJ. HEADS AT YELLOW SPOTS ON GRASS. 2-CLEANED LIGHT FIXTURES AND REPLACED BULBS AS NEEDED. 6/22 - 8	6/27/2005 6/22/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
3003	Closed Work Orders 6/23/05 1-INSP. BLDG.&GRNDS. PICKED UP TRASH. 1-CLEANED OFF ENTRY WAYS. 1-FASTED LOOSE WIND SCREEN AT S.W.FENCE AREA. 2-CUT WEEDS OUTSIDE S.W. FENCE AREA. 2-CHANGED OUT AIR FILTERS ON HVAC UNITS IN B-WING 1-FIXED HANDICAP SWING IN RM 101. 6/23 - 8	6/27/2005 6/23/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES
3004	Closed Work Orders 6/24/05 1-INSP BLDG. AND GRNDS. PICKED UP TRASH. 1-DID M. SIGN INSP. 1.5-WENT TO PPD TO TURN IN TIME AND PICK UP TOOLS. 1-RECAULKED BEHIND CLASSROOM SINKS IN B-WING. 1.5-DID M. LANSCAPE INSP. 1-WALL TOUCH UP IN B-WING. 1-PAINT TOUCH UP B-WING. 6/24 - 8	6/27/2005 6/24/2005 Medium	Gerardo Marquez Gerardo Marquez		Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
799	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. COMPLETED AS PER PABLO DIAZ	4/1/2005 4/28/2005 Medium	Aida Salcedo Pablo Diaz		Santa Teresa ES
786	Void 03/30/05 4-cleaning master cools on ch/ desert t. 1-serve restroom on room 128 3- painting new doors rooms 96 57 and54	4/1/2005 Medium	Aida Salcedo		Santa Teresa ES
2498	Complete NEED TO PICK UP SHARPS CONTAINERS FROM NURGES OFFICE ON NEXT TRIP OVERTHERE. PICKED UP SHARPS CONTAINER AS PER JIMMY	6/3/2005 6/9/2005 Medium			Santa Teresa ES
955	Complete PIN KNOB ON MIXER BROKE REPLACED BROKEN PIN KNOB	4/8/2005 5/13/2005 Medium	Danny Orozco Danny Orozco	Cafeteria	Santa Teresa ES
1624	Complete WATER FILTER HOUSING FOR ICE MACHINE CRACKED AND IS LEAKING REMOVED CRACKED WATER FILTER HOUSING AND INSTALLED NEW ONE, HAD TO RE-ROUTE SUPPLY LINE TO FIT NEW HOUSING	5/3/2005 5/31/2005 Medium	Danny Orozco Danny Orozco	Cafeteria	Santa Teresa ES
358	Complete ATT. D.BOYD. NEED TO HAVE AUTO. DR. OPENER AT BACK ENTRANCE REPAIRED. AS PER MR. BOYD SCHEDULE FOR REPAIR - COMPLETED BY DANNY MIRANDA.	3/14/2005 5/19/2005 Medium	Danny Miranda	Hallway/Corridor	Santa Teresa ES
2324	Complete jimmy could you please send me a water solution tank, rotary brashes for roto mach. a.s.a.p thanks pablo ISSUED SOLUTION TANK AS PER JIMMY	5/26/2005 6/3/2005 Medium	Pablo Diaz Jimmy Carbajal		Santa Teresa ES
2325	Duplicate Request jimmy could you please send me a water solution tank, rotary brashes for roto mach. a.s.a.p thanks pablo DUPLICATED, SEE W.O. #2324	5/26/2005 Medium	Pablo Diaz Jimmy Carbajal		Santa Teresa ES
2111	Work In Progress SOUTH GATE WAS KNOCKED OF HINGES, SE CORNER OF FENCE WAS RIPPED AND PAINTED ON. CASE# 0503832	5/2/2005 Medium	Pablo Diaz Michael Munoz		Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1397	Closed Work Orders 4/11/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 2-CLEANED SAND OFF ENTRY-WAYS. 1-CLEANED AND INSP. P.-GROUND EQUIP. 4-TOOK SICK LEAVE. (SEM JOB #15708) 4/11 - 4	4/25/2005 4/11/2005 Medium	Pablo Diaz Gerardo Marquez		Santa Teresa ES
1398	Closed Work Orders 4/12/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 2-CLEANED C.YARDS. 2-CLEANED P.GROUND EQUIP. AND TABLES UNDER CANOPIES. 3-ASSEMBLED TABLES FOR SCIENCE FAIR. 4/12 - 8	4/25/2005 4/12/2005 Medium	Pablo Diaz Gerardo Marquez		Santa Teresa ES
1399	Closed Work Orders 4/13/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 1-FINISHED ASSEMBLING TABLES FOR SCIENCE FAIR. 1-UNLOADED AND ASSEMBLED ART EXHIBIT STANDS. 1-WORKED ON HVAC IN RM.101. 1.5-HELPED SET UP CAFET. FOR SCIENCE FAIR. 2.5-WORKED ON M.COOLS AND STERLING UNITS. 4/13 - 8	4/25/2005 4/13/2005 Medium	Pablo Diaz Gerardo Marquez		Santa Teresa ES
1400	Closed Work Orders 4/14/05 2-LOADED AND DELIVERED ART EXHIBIT STANDS TO GMS. 1-SET UP TRASH CANS FOR KIDS HAVING LUNCH OUTSIDE , DUE TO SCIENCE FAIR. 1-WORKED ON HVAC IN RM.206. 1.5-PICKED UP T.CANS AND LITTER FROM P.GROUND AREA. 2.5-WORKED ON HVAC IN TESTING AND RM. 206. CHECKED OUT PUMP IN NURSES OFFICE. 4/14 - 8	4/25/2005 4/14/2005 Medium	Pablo Diaz Gerardo Marquez		Santa Teresa ES
1401	Closed Work Orders 4/15/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 2-CLEANED SCREENING OFF BB. COURTSAND ROAD. 1.5-WENT TO PPD. TO TURN IN TIME AND PICK UP MATERIAL. 1-WORKED ON HVAC IN RM.209. 1.5-TOOK TABLES AND CHAIRS TO LA UNION , AS PER MR. Y. 1.5-WORKED ON HVAC IN RMS. 209 AND 212. 4/15 - 8.5	4/25/2005 4/15/2005 Medium	Pablo Diaz Gerardo Marquez		Santa Teresa ES
1402	Closed Work Orders 4/18/05 1.5-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 3.5-CHANGED HVAC PUMP IN RM.206. 1.5-WENT TO GMS. TO PICK UP ART STANDS. 1.5-WORKED ON STERLING UNIT . 4/18 - 8	4/25/2005 4/18/2005 Medium	Pablo Diaz Gerardo Marquez		Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1403	Closed Work Orders 4/19/05 1-INSP. BLDG. AND GRNDS. PICKE UP TRASH. 2-CLEANED OFF ENTRYWAYS AND SIDEWALKS. 1-CLEANED AND INSP. P.GROUND EQUIP. 4-SERVICED M.COOLS AND FIXED BROKEN COPPER SUPPLY LINES. 4/19 - 8	4/25/2005 4/19/2005 Medium	Pablo Diaz Gerardo Marquez		Santa Teresa ES
1404	Closed Work Orders 4/20/05 1-INSP. BLDG. AND GRNDS. PICKED UP TRASH. 1-WORKED ON HVAC IN RM. 212. 6-WORKED ON M.COOLS AT STMS. 4/20 - 8	4/25/2005 4/20/2005 Medium	Pablo Diaz Gerardo Marquez		Santa Teresa ES
1405	Closed Work Orders 4/21/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 2-WORKED ON M.COOLS AT STMS. 1-CLEANED SCREENING OFF BB.COURTS. 1-WORKED ON DR.LOCK IN RM.107. 1-DID MONTHLY ASPHALT INSP. 1-DID BUSINESS OFFICE INSP. 1-DID FIRE EXTING. INSP. 4/21 - 8	4/25/2005 4/21/2005 Medium	Pablo Diaz Gerardo Marquez		Santa Teresa ES
1406	Closed Work Orders 4/22/05 1-INSP. BLDG.AND GRNDS. PICKED UP TRASH. 1-CLEANED OFF ENTRYWAYS. 2-CLEANED TRASH AND WEEDS FROM ROCK AREA. 1-WENT TO LA UNION ELEM. FOR H-20 PUMP FOR STERLING UNIT. 1.5 REPLACED PUMP ON STERLING UNIT. 1-HEIPED PETE LOAD JAIMES TRUCK FOR TRANSPORT TO SHOP. .5-DID VEHICLE INSP. 4/22 - 8	4/25/2005 4/22/2005 Medium	Pablo Diaz Gerardo Marquez		Santa Teresa ES
1390	Complete ATTN. JOSE AMBRIZ. JOSE , PUMP IN RM.206 IS LEAKING. NEED FOR YOU TO CHANGE OUT PUMPS. THANKS. HAD TO REMOVE ELECTRICAL, REMOVE PUMP AND MOTOR, REPLACE IT WITH A NEW ONE, WAS LEAKING FROM SEAL, HOOK UP ELECTRICAL, CHECK FOR ROTATION. NO LEAKS	4/25/2005 4/26/2005 Medium	Pablo Diaz Jose Ambriz		Santa Teresa ES
919	Complete ATT. JIMMY CARBAJAL NEED FOR YOU TO DO P.M. ON A VAC. CLEANER. THANKS. REPLACED BELT & ALSO DID P.M.	4/7/2005 4/15/2005 Medium	Pablo Diaz Jimmy Carbajal		Santa Teresa ES
324	Forwarded TWO ROOF LEAKS, WARRANTY WORK.	3/11/2005 3/14/2005 Medium	Rita Mendez	Hallway/Corridor	Santa Teresa ES B & C
325	Forwarded STUCCO CRACKING, ON PARAPET WALL BY NURSE'S OFFICE. WARRANTY WORK. PLEASE FORWARD TO DAVID BOYD. THANKS.	3/11/2005 3/14/2005 Medium	Rita Mendez		Santa Teresa ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2080	Complete Mrs. Virginia Gomez misplaced her keys in December 2004 and I need to know what charges she will incur with the loss of her keys? She had the following keys checked out to her. MA 7.....key to her classroom door MB 1.....key to the mailroom #143.....key to assigned mailbox change core in mailroom new key for mailbox, leave classroom #10 as is. Total cost 21.00XC: ELOISA 5/20/05 INVOICE 05-65	5/18/2005 5/19/2005 Medium	Ralph Gallegos Hector Lozoya		Santa Teresa HS
2845	Work In Progress AS PER USE OF BUILDING REQUEST #2005-320, FIELD NEEDS TO BE OUTLINED FOR BAND REHEARSAL USE. PLEASE SEE ATTACHED COPY OF BLDG USE FOR DATES. CALL MARY SITTERS IF YOU HAVE ANY QUESTIONS. THANKS!	6/16/2005 Medium	Maria Sitters Lorenzo Hernandez	Athletic Field	Santa Teresa HS
1387	Work In Progress need to repair sheetrock in gym locker room	4/25/2005 Medium	Danny Miranda Danny Miranda	Auditorium	Santa Teresa HS
2520	Complete Disconnect power to portable classroom #43-44 remove power from portable and instll underground j-box	6/6/2005 6/3/2005 Medium	Carlos Castillo Carlos Castillo	Classroom	Santa Teresa HS
2149	Complete Groundsman[Ralph}requesting 75 feet extension cord. ORDER MATERIAL AND MAKE CORD FOR GROUNDSMAN	5/20/2005 5/20/2005 Medium	Carlos Castillo Carlos Castillo	Athletic Field	Santa Teresa HS
1375	Complete WALK-IN REFRIGERATOR NOT COOLING TO SET TEMP. CLEANED CONDENSOR COIL	4/22/2005 4/22/2005 Medium	Danny Orozco Danny Orozco	Cafeteria	Santa Teresa HS
1355	Complete VOC BLDG - WOOD SHOP EXIT DOOR NEEDS TO BE SECURE BEFORE THE END OF THE DAY. repair panic bar and door frame at woodshop.	4/22/2005 4/22/2005 Medium	Hector Lozoya		Santa Teresa HS
149	Complete English Wing - Hallway, Principal, Office - No power to these areas electrical problem. trace down shorted wire in underground conduit. reroute circuit temp will replace wire when schools not in session wo 1262.	3/8/2005 3/2/2005 Emergency	Carlos Castillo	Office	Santa Teresa HS
151	Complete English Wing Hallway & Office - Need to replace damaged wire from panel box to swt box. To wire circuit properly and safely a/s/a/p AT THIS TIME CIRCUITS ARE RE-ARRANGED THERES ENOUGH AMPERAGE WITH EXISING WIRES.	3/8/2005 5/23/2005 Emergency	Carlos Castillo	Hallway/Corridor	Santa Teresa HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
787	Void 03/30/05 4-cleaning master cools on ch/ desert t. 1-serve restroom on room 128 3- painting new doors rooms 96 57 and54	4/1/2005 Medium	Aida Salcedo		Santa Teresa HS
1140	Complete Chemical Line to dishwasher broke off. REMOVE BROKEN CHEM. LINE ANE REPLACE WITH NEW ONE, ALSO UNCLOGGED INLET TO DISHWASHER	4/14/2005 4/19/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Santa Teresa HS
2937	Work In Progress Reach-In Refrigerator is at 60 degrees	6/22/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Santa Teresa HS
3005	Complete milk cooler motor making alot of noise CHECKED MILK COOLER TEMP WAS 39 DEGREES COULD HERE NO STRANGE NOISES OTHER THAN NORMAL	6/27/2005 6/30/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Santa Teresa HS
3006	Duplicate Request milk cooler motor making alot of noise DUPLICATE WORK ORDER#3005	6/27/2005 6/28/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Santa Teresa HS
3007	Duplicate Request milk cooler motor making alot of noise	6/27/2005 6/28/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Santa Teresa HS
	olga bustamante - snp manager 589-5332 DUPLICATE WORK ORDER #3005				
800	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. COMPLETED PER LUIS MURILLO	4/1/2005 4/19/2005 Medium	Aida Salcedo Luis Murillo		Santa Teresa HS
690	Complete NEED TO HAVE CHILLER WATER PRESSURE CHECKED , WATER PRESSURE TO HIGH RUNNING AT 85 P.S.I. AT PUMP GUAGE. CHILLER WAS SHUT DOWN FOR MOTOR , AND CHILLER SAFETY. THANK YOU. Pressure of water was caused by rpm was in 100% instead of 30% that's 50 pressure went down to 40 psi modulator was set up to 100%.	3/30/2005 4/5/2005 Medium	Arturo Nunez Margret Villalobos		Santa Teresa HS
691	Complete NEW BLDG. WARRANTY.. THREE WAY VALVE IN ROOM #205 IS GETTING STUCK ON HEATING MODE, WILL NOT SWITCH TO COOLING MODE. ROOM GETS TO HOT... This room was not responding, until Trane came and had to troubleshoot unit, finally room 205 is working ok, had some adj. in Tracer Summit.	3/30/2005 4/4/2005 Medium	Arturo Nunez Jose Ambriz		Santa Teresa HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
695	Work In Progress NEED TILE INSTALLED AT TRAINERS WRAPPING AREA, REQUESTED BY MR. MUNOZ,FRANK.	3/30/2005 Medium	Arturo Nunez Michael Munoz		Santa Teresa HS
693	Void NEED SIX (6) 240V OUTLET INSTALLED IN WELDING SHOP FOR WELDERS Panel is already overloaded, 12 existing 50a welders already. 225amp panel would exceed 900a w/18 welder would need service upgrade. Need to go thru CMT as per Mike Munoz. 6/01/05 - Carlos Castillo	3/30/2005 Medium	Arturo Nunez Carlos Castillo		Santa Teresa HS
438	Closed Work Orders 03/14/05 1.0 - SIGN IN P.W. 1.0 - CHECKED BOILER SYSTEMS. 2.0 - W.O. #125630. .30 - CHECKED WINDOW IN RM. #14 1.0 - UNCLOGGED LAB. SINK IN ROOM #14. 1.0 - CHECKED WATER LEAK IN KIT. MOP SINK. 1.0 - CHECKED KIT. WATER HTR. POSSIBLE LEAK.	3/16/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
439	Closed Work Orders 03/15/05 1.0 - SIGN IN P.W. 1.0 - CHECKED BOILER SYSTEMS. 1.0 - W.O. #125630. .30 - CHECKED FOUL SMELL BY ANNEX AREA.. .30 - CHECKED WATER HTR. IN BOYS DRESSING ROOM. 1.0 - REPAIRED LEAK ON MOP SINK. 1.0 - REPAIRED WATER FAUCETS. .30 - CHECKED FAUCETS IN VOC. BLDG. RESTROOMS. .30 - WORKED ON STUCK CYLINDER WARRIOR ROOM.	3/16/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
440	Complete NEED CYLINDER AT WARRIOR ROOM CHECKED OUT , KEYS ARE GETTING STUCK, ALREADY CLEANED AND LUBED. repair deadbolt and rekey cylinder.	3/16/2005 3/16/2005 Medium	Arturo Nunez Hector Lozoya	Office	Santa Teresa HS
442	Complete NEED MY MASTER KEY REPLACED IT GOT ALL BENT WHILE WORKING WITH CYLINDER. replace master key	3/16/2005 3/16/2005 Medium	Arturo Nunez Hector Lozoya		Santa Teresa HS
403	Complete NEED DAY CARE FUMIGATED FOR BUGS. As per Susan wo was completed on 4/6/05 - mkv 4/19/05	3/15/2005 4/6/2005 Medium	Arturo Nunez Margret Villalobos	Classroom	Santa Teresa HS Daycare
404	Complete NEED FOODS LAB. SPRAYED FOR BUGS, COAROCHEs. NO CHARGE - PART OF MONTHLY SERVICE.	3/15/2005 4/13/2005 Medium	Arturo Nunez Margret Villalobos		Santa Teresa HS
405	Complete NEED T-8 LIGHT BULBS 3 CASES EA. PROVIDE BLDG MECH WITH LAMPS	3/15/2005 4/5/2005 Medium	Arturo Nunez Carlos Castillo		Santa Teresa HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
406	Work In Progress NEED TO HAVE MOP SINK FAUCETS AT KITCHEN REPLACED, WE HAVE A WATER LEAK. ROUTED TO DANNY OROZCO AS PER DAVID VILLALBOS. 6/30/05 - MKV	3/15/2005 6/30/2005 Medium	Arturo Nunez David Villalobos		Santa Teresa HS
389	Closed Work Orders 02/25/05 1.0 - sign in p.w. 1.0 - checked boiler systems. 1.0 - replaced cieling tiles and burned out light bulbs in room. #18. 3.0 - worked on chiller problem, trouble shoot. 1.0 - boilers and water htrs. inspection w/inspector. 1.0 - checked clogged sink in lobby restroom.	3/15/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
390	Closed Work Orders 02/28/05 1.0 - sign in p.w. 1.0 - checked boiler systems. 3.0 - w.o.#124449 1.30 -checked and replaced exhaust fan mtr. 1.30 - helped jose installa.c. and return air defussers.	3/15/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
391	Closed Work Orders 03/01/05 6.0 - checked elec. problem in office area, and hallway 2.0 - started to work on nurses station getting rdy. to paint.	3/15/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
392	Closed Work Orders 03/02/05 6.0 - worked on painting nurses station portable. 2.0 - worked on chiller plant	3/15/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
393	Closed Work Orders 03/03/05 8.0 - cont. with painting nurses station.	3/15/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
394	Closed Work Orders 03/04/05 8.0 - continued painting nurses station.	3/15/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
395	Closed Work Orders 03/07/05 .30 - sign in. 6.0 - cont. w/ potable painting. .30 - assist trane tech. with chiller problem. .30 - responded to fire alarm. .30 - checked window in room #306.	3/15/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
396	Closed Work Orders 03/08/05 1.0 - sign in . 1.0 - checked boiler systems. 4.0 - worked on stripping door getting rdy. to paint. 2.0 - checked chiller w/ trane techs.	3/15/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
398	Closed Work Orders 03/09/05 1.0 - sign in p.w. 1.0 - checked boiler system, not on called jaimie to check on tracer summit. 4.0 - painted door on nurses station, on r.o.t.c. restrooms, and finished painting rails. 1.0 - removed and cleared items from storage room. 1.0 - checked foul sewer smell at portables.	3/15/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
399	Closed Work Orders 03/10/05 1.0 - sign in p.w. 1.0 - checked boiler systems. 5.30 - worked on nurses station, put supplies back in closet, cut doors, and cleaned up working area. .30 - removed broken key from press door.	3/15/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
400	Closed Work Orders 03/10/05 1.0 - sign in p.w. 1.0 - checked boiler systems. 5.30 - worked on nurses station, put supplies back in closet, cut doors, and cleaned up working area. .30 - removed broken key from press door.	3/15/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
401	Closed Work Orders 03/10/05 1.0 - sign in p.w. 1.0 - checked boiler systems. 5.30 - worked on nurses station,put supplies in storage,cut doors to clear carpet, and cleaned up working area. .30 - removed broken key on press box door.	3/15/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
114	Closed Work Orders 02/24/05 2.0 - SIGN IN P.W. 1.0 - BOILER INSPECTION. 1.0 - CHECKED FOUL ODOR ON PORT AREA. 1.30 - INSTALLED DOOR ON CAB. ON COOKING LAB. 1.0 - CHECKED WATER HTR. IN ENGLISH WING. .30 - CLOGGED COMMODE IN ENGLISH WING. .30 - RESPONDED TO FIRE ALARM .	3/7/2005 3/16/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
1008	Complete EMERGENCY..... NEED TO REPAIR OR REPLACE PULL HANDLE WITH CYLINDER HOLE , IT WAS VANDALIZED OVER THE WEEK END. NEED TO TAKE CARE OF IT AS SOON AS POSSIBLE, FOR SECURITY PURPOSES.... THANK YOU.... replace handle and repair bar and rekey cylinder	4/11/2005 4/11/2005 Medium	Arturo Nunez Hector Lozoya		Santa Teresa HS
1009	Complete NEED ELECTRICAL STRIPS AT NURSES STATION REMOVED , SO THAT NEW FURNITURE CAN BE INSTALLED UP AGAINST THE WALL. NEED TO HAVE REMOVED AS SOON AS POSSIBLE FOR FURNITURE INSTALLATION. REMOVE EXISTING WALL ELECTRICAL STRIPS.	4/11/2005 4/11/2005 Medium	Arturo Nunez Carlos Castillo		Santa Teresa HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1010	Complete NEED CYLINDER AT DRESSING ROOM HALLWAY CHECKED SOME ONE STUCK SOMETHING IN IT, CAN"T OPEN IT ,AFRAID SOMEONE WILL BREAK KEY. repair lock and rekey cylinder to mb62	4/11/2005 4/11/2005 Medium	Arturo Nunez Hector Lozoya		Santa Teresa HS
1011	Work In Progress NEED CYLINDER AT DRESSING ROOM HALLWAY CHECKED SOME ONE STUCK SOMETHING IN IT, CAN"T OPEN IT ,AFRAID SOMEONE WILL BREAK KEY.	4/11/2005 Medium	Arturo Nunez Hector Lozoya		Santa Teresa HS
1283	Complete NEED APAD LOCK TO SECURE BACK DOORS GOING TO FOOTBALL FIELD, STUDENTS OPENING DOOR AND GETTING INTO BLDG. SECURITY PURPOSES. rekey padlock to secure doors by gym.	4/20/2005 4/20/2005 Medium	Arturo Nunez Hector Lozoya		Santa Teresa HS
924	Complete NEED WINDOW AT LIBRAY ENTRANCE REPLACED IT IS BROKEN THE SIZE IS 23 5/8 BY 39 5/8 WIRE MESH GLASS.	4/7/2005 4/12/2005 Medium	Arturo Nunez Ruben Ronquillo		Santa Teresa HS
925	Complete NEED TO HAVE OUTSIDE LIGHTING ON FRONT PARKING LOT CHECKED, MIGHT HAVE TO REPLACE LIGHT FIXTURES, TO DARK BY FENCE AREA,	4/7/2005 6/24/2005 Medium	Arturo Nunez Carlos Castillo		Santa Teresa HS
926	Complete NEED DOOR PULL PLATE WITH DEAD BOLT HOLE FOR GYM. DOOR, WILL INSTALL IF SUPPLIED. THANK YOU. installed handle and repair deadbolt and replace core.	4/7/2005 4/8/2005 Medium	Arturo Nunez Hector Lozoya		Santa Teresa HS
927	Forwarded WARRANTY.... NEED TO HAVE T'STAT IN ROOM #205 CHECKED IT IS NOT , IT IS NOT DOING WHAT IT IS COMMANEDING TO DO , STAYS ON ALL THE TIME.	4/7/2005 Medium	Arturo Nunez David Boyd		Santa Teresa HS
1412	Complete NEED HELP ON MTRS ON GYM A.C CAN'T GET PWR TO THEM, ARE WORKING ON THEM, AND WOULD LIKE TO GET THEM READY AND WORKING. assist build.mechconctingmotorsAssist with installation of gym a/c motor connections and amp readings.	4/25/2005 4/25/2005 Medium	Arturo Nunez Carlos Castillo		Santa Teresa HS
1414	Complete NEED HELP ON A.C AT VOC. WOODSHOP, SEEMS LIKE WE HAVE A BAD CONTACTOR. NEED TO SEE IF JOSE COULD HELP ME OUT. THANK YOY Installed 1 3phase power motor, troubleshoot m/c not working bad motor.	4/25/2005 4/26/2005 Medium	Arturo Nunez Jose Ambriz		Santa Teresa HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1646	Complete NEED A MC 43 HEY MADE FOR LONG TERM SUB. AS PER LISA SANCHEZ . THANK YOU... recut MC43 and change lockset at library.	5/4/2005 5/5/2005 Medium	Arturo Nunez Hector Lozoya		Santa Teresa HS
2424	Closed Work Orders 06/01/05 3.0 - CHECKED FLUSH VALVES ON ALL COMMODES AND URINALS THROUGH CAMPUS, AFTER WATER WAS TURNED ON.5.0 - WORKED ON CLEARING OUT PORTABLE TO BE REMOVED FRON SITE ,AND STARTED REMOVING SKIRTING. GETTING READY TO GO. 6/1 - 8	6/1/2005 6/1/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2397	Closed Work Orders 1.0 - sign in ,checked tracer summit .2.0 - set up water tank by bldg. filled drums, and supplied buckets.5.0 - helped jose on duct installation on voc. bldg. 5/31 - 8	5/31/2005 5/31/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2387	Complete Need 2 sets of the following keys 106e, 115r,039 for mailbox inside gate, as per Mr. Gallegos. make keys for mailbox	5/31/2005 6/1/2005 Medium	Arturo Nunez Hector Lozoya		Santa Teresa HS
2372	Closed Work Orders 05/27/05 1.0 - sign in , tracersummit. 3.0 - went to p.p to turn in p.w.,got supplies. and serviced vechile, brought back water tank.2.0 - flushed out water tank, and refilled with water. 1.0 - got cans rdy for tuesday a.m. 1.0 - refastened cove base in Marylou's office . 5/27 - 8	5/27/2005 5/27/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2343	Closed Work Orders 05/17/05 1.0 - SIGN IN PAPER WORK. 3.0 - SUBMITTING PAPER WORK ON SCHOOL DUDE. 1.30 - CHECKED FOR FOUL SMELL AROUND PORTABLES. 1.302 - CHECKED A.C AT L.C.D.F. PORT. 5/17 - 7	5/27/2005 5/17/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2344	Closed Work Orders 05/25/05 1.0 - SIGN IN, CHECKED SYSTEM ON SUMMIT. 2.0 - DID PAPER WORK ON ROOF INFO. 1.0 - CHECKED DOOR AT CHOIR ROOM. 3.0 - HELPED JOE ON DUCT INSTALLATION AT WOOD SHOP. 1.0. - CHECKED A.C AT L.C.D.F. PORT. 5/25 - 8	5/27/2005 5/25/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2346	Closed Work Orders 05/26/05 1.0 - SIGN IN , P.W., CHECKED SUMMIT. 2.0 - CHECKED A.C. ON COUNSELORS HALLWAY. 1.0 - OPENED AND LOCKED UP ROOMS FOR OVERHEAD DOORS REPAIRS. 1.0 - HELPED JOSE AT VOC. BLDG. (DUCTS). 3.0 - STARTED ON EDGING ON ROOM #15. 5/26 - 8	5/27/2005 5/26/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2032	Closed Work Orders 05/02/05 1.0 - SIGN IN ,TRACER SUMMIT. 1.0 - SERVICED VECHILE. 6.0 - A.C. START UP. 5/2 - 8	5/17/2005 5/2/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2033	Closed Work Orders 05/03/05 1.0 - SIGN IN ,CHECKED SUMMIT. 7.0 - A.C START UP 5/3 - 8	5/17/2005 5/3/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2034	Closed Work Orders 05/04/05 2.0 - SIGN IN P.W. 6.0 - A.C.START UP. 5/4 - 8	5/17/2005 5/4/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2037	Closed Work Orders 05/05/05 1.0 - SIGN IN P.W. 7.0 START UP A.C.. 5/5 - 8	5/17/2005 5/5/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2038	Closed Work Orders 05/09/05 1.0 - SIGN IN P.W. 3.0 - MET W/ TRANE TECH. AND JOHN FINE. 4.0 - DELMAR INSPECTIONS. 5/9 - 8	5/17/2005 5/9/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2039	Closed Work Orders 05/10/05 1.0 - SIGN IN , SUMMIT. 1.0 - R.R A.C. SWT IN ROOM #35. 6.0 - REPLACED FILTERS NEW ADDITION. 5/10 - 8	5/17/2005 5/10/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2040	Closed Work Orders 05/11/05 1.0 - SIGN IN ,SUMMIT 4.0 - CLEANED STORAGE 1.0 CHECKED FOUL SMELL. 1.0 - A.H.T. MTG. 1.0 - REPLACED BROKEN LIGHT BULB. 5/11 - 8	5/17/2005 5/11/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2041	Closed Work Orders 05/12/05 1.0 - SIGN IN , SUMMIT.4.0 CLEANED AROUND STORAGE BLDG. 2.0 - RELOCATE MANHOLE COVER ON STREET 1.0 - REPLACED BULBS AT COUNSELORS OFFICE. 5/12 - 8	5/17/2005 5/12/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2042	Closed Work Orders 05/13/05 1.0 - SIGN IN P.W. SUMMIT 1.0 SERVICED TRUCK. 2.0 - CHECKED ROOMS ON SUMMIT 1.30 - INSTALLED SHELF ON GROUNDS SHOP. 1.0 CLOGGED URINAL AT ANNEX R.R. 1.30 REPLACED LIGHT BULB AT HALLWAY. 5/13 - 8	5/17/2005 5/13/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2044	Closed Work Orders 05/16/05 1.0 SIGN IN, CHECKED SUMMIT. 3.0 - WORKED ON A.H.U. UNIT ON LIBRARY. 3.0 - WORKED ON ROOF LEAK AT D.O.L. PORTABLE 1.0 - CHECKED ROOF LEAK ON GYM. 5/16 - 8	5/17/2005 5/16/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
1989	Closed Work Orders 03/18/05 3/18 - 4 1.0 - SIGN IN P.W 1.0 - CHECKED BOILER SYSTEMS. 2.0 - WENT TO P.P.D. TOTURN IN P.W 4.0 - SHUT DOWN FOR HOLIDAY.	5/17/2005 3/18/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1986	Closed Work Orders 3/16/05 3/16 - 8 1.0 - SIGN IN P.W.1.0 = CHECKED BOILER SYSTEMS2.0 - CHOPEW WEEDS AROUND NURSES STATION, CLEANED AREA. 2.0 - W.O #125630 2.0 - REPLACED BURNED OUT BULBS IN #7 &306	5/17/2005 3/16/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
1987	Duplicate Request 03/16/05 3/16 - 8 1.0 - SIGN IN P.W 1.0 - CHECKED BOILER SYSTEMS. 1.0 - REPLACED LIGHT BALAST IN COPY ROOM. 5.0 - UNCOVERED A.C DAMPERS AT ENGLISH WING,SCIENCE, AND OFFICES.	5/17/2005 5/17/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
1994	Closed Work Orders 03/21/05 3/21 - 8.30 - SIGN IN P.W.7.30 - WORKED ON FOOTBALL DRESSING ROOM GETTING RDY TO PAINT. STARTED PAINTING.	5/17/2005 3/21/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
1997	Closed Work Orders 03/22/05 3/22 - 8 3.0 - MTG AT S.T,M.S 5.0 - CONT. PAINTING IN DRESSING ROOM	5/17/2005 3/22/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
1998	Work In Progress 03/23/05 3/23 8.0 - CONT. PAINTING DRESSING ROOM	5/17/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2000	Closed Work Orders 03/24/05 3/24 8.0 - CONT. PAINTING DRESSING ROOM, CLEANED UP WORKING AREA RDY. TO BE USED.	5/17/2005 3/24/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2002	Closed Work Orders 03/29/05 3/29 8 4.0 - BROUGHT OUT APPLIANCES FROM SHUT DOWN, CHECKED BOILERS,WATER HEATERS,HTRS, ETC. 1.0 REPAIRED WATER FOUNTAIN AT VOC. BLDG. 1.0 - NO PWR IN ROOMS #305,307,311,312, CHECKED PROBLEM.1.0 - REPLACED BURNED OUT BULB AT WARRIOR ROOM.1.0 - GAVE TOUR OF SCHOOL TO S.N.M.H.D. PERSONAL.	5/17/2005 3/29/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2005	Closed Work Orders 03/30/05 3/30 - 7.30 - SERVICED VECHILE TOPPED UP FLUIDS. 1.0 - SIGN IN P.W. 2.0 - CHECKED BOILER SYSTEMS 3.0 - CHECKED PWR AT MOBLE HOME W/ LYNCO ELEC, BAD BREAKER..30 SIGN OUT.	5/17/2005 3/30/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2008	Closed Work Orders 03/31/05 3/31 - 8.30 - SIGN IN P.W. 1.0 - CHECKED BOILER SYSTEMS. 1.30 - WET FLOOR DRAINS. AT VOC. BLDG. 1.0 - CHECKED DOOR AT WOODSHOP 2.0 - CHECKED FOR FOUL SMELL 2.0 - STARTED FIRE EXT. INSP.	5/17/2005 3/31/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2011	Closed Work Orders 04/01/05 4/1 - 8.30 - SIGN IN P.W. 1.0 - CHECKED BOILER SYSTEMS. 2.0 - CHECKED EXHAUST FAN FAC. R.R.3.0 - INSTALLED COMP. AND SET UP TRACER SUMMIT HARDWARE. 1.30 - CHECKED COILS AT NEW ADDITION.	5/17/2005 4/1/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2012	Duplicate Request 04/01/05 .30 - SIGN IN P.W. 1.0 - CHECKED BOILER SYSTEMS. 2.0 - CHECKED EXHAUST FAN FAC. R.R.3.0 - INSTALLED COMP. AND SET UP TRACER SUMMIT HARDWARE. 1.30 - CHECKED COILS AT NEW ADDITION.	5/17/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2016	Duplicate Request 04/01/05 .30 - SIGN IN P.W. 1.0 - CHECKED BOILER SYSTEMS. 2.0 - CHECKED EXHAUST FAN FAC. R.R.3.0 - INSTALLED COMP. AND SET UP TRACER SUMMIT HARDWARE. 1.30 - CHECKED COILS AT NEW ADDITION.	5/17/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2014	Duplicate Request 04/01/05 4/1 - 8 .30 - SIGN IN P.W. 1.0 - CHECKED BOILER SYSTEMS. 2.0 - CHECKED EXHAUST FAN FAC. R.R.3.0 - INSTALLED COMP. AND SET UP TRACER SUMMIT HARDWARE. 1.30 - CHECKED COILS AT NEW ADDITION.	5/17/2005 5/17/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2026	Complete INSPECTION IS NEEDED ON OXYGEN AND ACETYLENE LINES POSSIBLE LEAK ON MANIFOLD SYSTEM, SYSTEM BLEEDS DOWN IN LESS THAN AN HOUR.(AS PER MR. ANGELO) THANK YOU.. CK'D PIPING HOSES, GAUGES VALVES THRU O & A SYSTEM.	5/17/2005 5/18/2005 Medium	Arturo Nunez David Villalobos		Santa Teresa HS
1967	Complete NEED PICK UP TRUCK SERVICED ON PWR. STEERING PUMP, KEY IGNITION SWT, AND MUFFLER, I WILL BE OUT ON 5/18/05 TO 5/24/05 THANK YOU..... SERVICED VEHICLE, REPAIRED POWER STEERING , IGNITION SWITCH AND REPLACED MUFFLER.	5/16/2005 5/27/2005 Medium	Arturo Nunez Angel Gonzales		Santa Teresa HS
3111	Work In Progress 06/30/05 1.30 REPAIRED A.C. UNIT IN QUINTANAS ROOM. 2.0 - CHECKED MAIN DOMESTIC WATER VALVE.3.0 - CONT. PAINTING CUST. ROOM. 1.0 - WET FLOOR DRAINS AT CONSESSION STAND. 6/30 - 7.5	6/30/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
3109	Work In Progress NEED TO HAVE PLUMBLER'S HELP WITH MAIN DOMESTIC WATER ANTI SIPHON VALVE LEAKING TO MUCH WATER	6/30/2005 Medium	Arturo Nunez David Villalobos		Santa Teresa HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
3083	Closed Work Orders 06/29/05 1.0 - SIGN IN P.W. CHECKED SUMMIT.1.0 - CHECKED A.C. UNIT IN QINTANAS ROOM DRAINED WATER TO CHANGE OVER FLOW PIPE. 1.0 - CLEARED OUR PERSONEL FOR MOCK INCIDENT. 5.0 - PAINTING CUST. CLOSET ROOM. 6/29 - 8	6/29/2005 6/29/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
3049	Closed Work Orders 06/28/05 8.0 - CONT. PAINTING AND EDGING COUNSELORS HALLWAY, STARTED GETTINGNEXT ROOM READY TO PAINT. FILLED HOLES ON WALLS , CLEANED WALLS ETC. 6/28 - 8	6/28/2005 6/28/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2989	Closed Work Orders 06/24/05 4.0 - GOT PLAYGROUND AT L.U.E. READY TO IRRIGATE, GOT WATER ORDER AND IRRIGATED PLAY GROUND. 4.0 - MOWED FRONT LAWN, PATIOS, PICKED UP CLIPPINGS, SET SPRINKLERS TO WATER, AND STARTED TO MOW GRASS AT LEACH FIELD. 6/24 - 8	6/27/2005 6/24/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
3016	Closed Work Orders 06/27/05 1.0 SIGN IN PAPER WORK. 7.0 - EDGING CLASS ROOM #10 AND STARTED EDGING HALLWAY. 6/27 - 8	6/27/2005 6/27/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2833	Closed Work Orders 06/16/05 6.0 CONT. HELPING RALPH WITH BLEACHERS INSTALLATION. 1.0 - SIGN IN P.W. CHECKED TRACER SUMMIT. 6/16 - 8	6/16/2005 6/16/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2905	Closed Work Orders 06/20/05 1.0 - SIGN IN P.W. CHECKED SUMMIT.2.0 - FINIHED EDGING ROOM #15. 1.0 - OPENED DOORS FOR ALPINE ELEC. LOOKING FOR CONDUIT FOR B.C.U. 4.0 - GETTING CONNESION ROOM READY TO PAINT, AND STARTED PAINTING. 6/20-8	6/20/2005 6/20/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2934	Closed Work Orders 1.0 - SIGN IN P.W. 7.0 - PAINTING SNACK ROOM AND ROOM #10 6/21-8	6/21/2005 6/21/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2964	Closed Work Orders 06/22/05 6.0 - WORKED ON TRACER SUMMIT PROBLEM FOUND OUT THAT BOILERS WERE COMING ON, TRIED TO TURN OFF, BUT COULD'NT DO SO. GOT SOME ASSISASTANCE FROM JAIME, AND STILL COULD'NT SHUT DOWN . GOT ASSISTANCE FROM TRANE TECHS. 2.0 - WET FLOOR DRAINS AT RAMP BY DAYCRE, AND WET TRAPS AT ROOM #54 6/22 - 8	6/23/2005 6/22/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2965	Closed Work Orders 06/23/05 8.0 - CONT. PAINTING ROOM #10. COUNSELORS HALLWAY, AND SNACK ROOM. 6/23 - 8	6/23/2005 6/23/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2809	Closed Work Orders 06/15/05 1.0 SIGN IN P.W. 6.0 - CONT. HELPING RALPH ASSEMBLING BLEACHERS. 1.0 - CHECKED ROOM'S 300, 8, AND 7 CIELING TILES. 6/15 - 8	6/15/2005 6/15/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2791	Closed Work Orders 06/14/05 7.0 HELPED RALPH ASSEMBLE BLEACHERS FOR SOCCER FIELD. 1.0 - HELP JOE VALENZUELA FROM TRANE FIND CONDUIT FOR B.C.U. CONNECTION TO NEW BLDG. 6/14 - 8	6/15/2005 6/14/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2750	Closed Work Orders 06/13/05 1.0 SIGN IN P.W. CHECKED SUMMIT. 6.0 - PAINT EDGING IN ROOM #15. 1.0 - CHECKED ICE MACHINE AT TRAINERS ROOM. 6/13 - 8	6/13/2005 6/13/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2712	Closed Work Orders 06/10/05 1.0 SIGN IN P.W. CHECKED TRACER SUMMIT. 2.0 CHECKED ICE MACHINE AT TRAINERS OFFICE. 4.0 WENT TO P.P. TO TURN IN P.W. GOT SUPPLIES, FUEL, AND HAD LUNCH WITH SPEEDY. 1.0 CHECKED DOOR ON ROOM #30 6/10 - 8	6/13/2005 6/10/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2680	Closed Work Orders 06/07/05 1.0 - SIGN IN P.W. 7.0 - CLEANED UP CEMENT DEBRIS FROM RAMP GOT READY FOR MOVERS. 6/7 - 8	6/10/2005 6/7/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2681	Closed Work Orders 06/08/05 1.0 SIGN IN P.W, SUMMIT. 1.0 - CHECKED A.C. AT CUSTODIAL ROOM.3.0 - CHECKED LIGHTS AT HOME EC., AND ROOM #33 REPLACED LIGHT BALASTS, AND LIGHT BULBS .2.0 - MOVED VECHILES AROUND PORTABLES TO MAKE ROOM FOR MOVERS. 1.0 - REPARIED THRESH HOLE ON DOOR AT ROOM #31 6/8 - 8	6/10/2005 6/8/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2682	Closed Work Orders 06/09/05 1.0 - SIGN IN P.W. TRIED TO GET INTO SUMMIT, COMPUTER DOWN, CALLED TECHNOLOGY W.O. 1.0 - CHECKED URINAL AT ACTIVITIES REST ROOM. 1.0 CHECKED OUTLETS AT ANNEX HOME EC. POPED BREAKER. 1.0 - ASSIST JESUS ON COMP. PROBLEM. 4.0 - PICKED CYLINDER BLOCKS FROM PORTABLE, GOT READY TO BE REMOVED,CLEANED UP AREA, AND HELPED JAIME TRANSPORT TO S.T.M.S. 6/9 - 8	6/10/2005 6/9/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2552	Closed Work Orders 06/02/05 1.0 - SIGN IN P.W. 3.0 - CONT. REMOVING SKIRTING ON PORT. 4.0 - STARTED TO BREAK CEMENT ON RAMP. 6/2 - 8	6/6/2005 6/2/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2553	Closed Work Orders 06/03/05 8.0 - CONT BREAKING CEMENTON RAMP. 6/3 - 8	6/6/2005 6/3/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS

7/1/2005 10:40:49 AM

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2555	Closed Work Orders 06/06/051.0 - SIGN IN P.W. 1.0 - CHECKED A.C. ON ROOM 54.3.0 - CONT. WORKING ON DEMOLISHING RAMP.1.0 - HELPED LORENZO W/ A.C. INVENTORY. 1.0 - CHECKED CIELING IN CHAVEZ'S OFFICE. 1.0 - HOOKED UP COMPUTER IN NEW MAINT. OFFICE. 6/6 - 8	6/6/2005 6/6/2005 Medium	Arturo Nunez Arturo Nunez		Santa Teresa HS
2440	Complete FAUCET TO THE SINK KEEP ON LEAKING. UNABLE TO TURN IT OFF. OLGA B. SNP MGR 589-5332 REMOVED AND REPLACED BAD FAUCET	6/2/2005 6/3/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	Santa Teresa HS
2108	Complete WALK IN REFREG. NOT COOLING. OLGA B. 589-5332 REMOVED BAD CONDENSOR MOTOR INSTALLED NEW ONE	5/19/2005 5/26/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	Santa Teresa HS
1130	Work In Progress Bus driveway - Need to fill pot holes located where Airport Road meets with the turn	4/14/2005 Medium	Michael Munoz Lorenzo Hernandez		Santa Teresa HS
714	Work In Progress Dress Room - replace electrical covers. As per Boiler Inspector.	3/30/2005 Medium	Michael Munoz Carlos Castillo		Santa Teresa HS
2245	Complete 3 COMP SINK IS LEAKING FROM THE BOTTOM. REMOVED AND REPLACED BAD BASKET STRAINER DRAIN 3-COMP SINK	5/24/2005 6/3/2005 Medium	Margret Villalobos Danny Orozco	Cafeteria	Santa Teresa HS OLGA BUSTAMANTE
305	Complete RUBEN I NEED 3 DRILL BITS STANLS STEEL SIZE 1/8" OF ON THE INCH. THANK YOU RUBEN.	3/11/2005 3/23/2005 Medium	Joel Herrera Ruben Ronquillo		Santa Teresa HS NEW WING
295	Complete MIKE MUNOZ WE NEED REPAIR OVERHEAD DOORS AT VOCATIONAL BUILDING CLASS ROOMS THANK YOU... MIKE ADJ ALL DOORS AT VOC BLDG.	3/11/2005 5/26/2005 Medium	Joel Herrera Danny Miranda		Santa Teresa HS
378	Complete BROKEN DOOR'S HANDLE OUTSIDE DOOR AT G.Y.M AREA repair panic bar and rekey cylinder.	3/15/2005 3/16/2005 Medium	Joel Herrera Hector Lozoya		Santa Teresa HS
341	Work In Progress BROKEN DOOR GLASS AT V.O.C BUILDING SIZE 23 3/4 X 23 1/4 WIRE GLASS	3/14/2005 Medium	Joel Herrera Ruben Ronquillo		Santa Teresa HS
419	Duplicate Request DOOR LOCK AT CLASS ROOM 16 IT DOESN'T LOCK PROMLY .	3/15/2005 Medium	Joel Herrera Hector Lozoya		Santa Teresa HS
411	Complete DOOR LOCK AT CLASS ROOM 16 IT DOESN'T LOCK WELL	3/15/2005 3/16/2005 Medium	Joel Herrera Hector Lozoya		Santa Teresa HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
416	Duplicate Request DOOR LOCK AT CLASS ROOM 16 NOT LOCK WELL	3/15/2005 Medium	Joel Herrera Hector Lozoya		Santa Teresa HS
414	Duplicate Request DOOR LOCK AT CLASS ROOM 16 NOT LOCK WELL.	3/15/2005 Medium	Joel Herrera Hector Lozoya		Santa Teresa HS
444	Work In Progress RUBEN RONQUILLO I NNEED REPLACE WINDOW'S SCREENS ON CLASS ROOM 308 AT ENGLISH WING SIZE 30 3/4 X 36 1/2 INCHES. THANK YOU RUBEN...	3/16/2005 Medium	Joel Herrera Ruben Ronquillo		Santa Teresa HS
449	Work In Progress MS. HILL SHE HAS A PROBLEM WITH CUCARACHAS AND GRILLOS ON CLASS ROOM 312 AT ENGLISH WING AREA Faxed PO on 4/11/05 45010704	3/16/2005 Medium	Joel Herrera Margret Villalobos		Santa Teresa HS
841	Complete MANNY LOZOYA WE NEED REPAIR AND WELD FRAME DOOR ON THE NEW HALL AREA. work on frame and door closer, repair and weld frame.	4/5/2005 4/5/2005 Medium	Joel Herrera Hector Lozoya		Santa Teresa HS
932	Complete WE NEED REPLACE MASTER KEY FROM WELDING SHOP AT V.O.C BUILDING recut key and rekey cylinder at storage.	4/7/2005 4/8/2005 Medium	Joel Herrera Hector Lozoya		Santa Teresa HS
923	Work In Progress WE NEED CHECK AND REPAIR DOOR LOCK NO WELDING CLASS ROOM AT V.O.C BUILDING	4/7/2005 Medium	Joel Herrera Hector Lozoya		Santa Teresa HS
1044	Complete BROKEN DOOR GLASS ON OUTSIDE DOOR AT G. Y. M AREA WIRE GLASS ZISE 25 5/8 X 25 5/8 INCHES. WINDOW	4/12/2005 4/12/2005 Medium	Joel Herrera Ruben Ronquillo		Santa Teresa HS
1450	Complete BRONKEN WINDOW AT ROOM 37 SIZE 42 1/2 X 32 INCHES SINGLE GLASS	4/27/2005 4/27/2005 Medium	Joel Herrera Ruben Ronquillo		Santa Teresa HS
2312	Closed Work Orders 5-25-05 8HRS HELP TO MR. GERALD D. SORENSEN INSPECTOR OPEN ALL CLASS ROOMS AND CHECK ALL BUILDINGS ROOFS 5/25 - 8	5/26/2005 5/25/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2310	Closed Work Orders 5-24-05 8HRS PAINTING BOYS REST ROOM AND G.Y.M HALLS FLOOR. 5/24 - 8	5/26/2005 5/24/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2307	Closed Work Orders 5-23-05 8HRS PREPARE HALLS FLOOR FOR PAINTING AND BOYS REST ROOM TOO AT G.Y.M AREA. 5/23 - 8	5/26/2005 5/23/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2299	Closed Work Orders 5-20-05 2HRS HELP TO JOSE AMBRIZ CHECK AND REPAIR REFRIGATOR UNIT AT NURSES POTABLE. 2HRS CHECK AND REPAIR MAIN OFFICE A/C.2HRS REPAIR WATER LEACK AT KITCHEN .2HRS REPAIR FRONT DOORS AT V.O.C BLD 5/20 -8	5/25/2005 5/20/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2337	Closed Work Orders 5-26-05 8HRS PREPARE CLASSROOM AND PAINTING AT SCIENCE WING. 5/26 - 8	5/26/2005 5/26/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2399	Closed Work Orders 5-27-05 8HRS PAINTING CLASS ROOM 5/27 - 8	6/1/2005 5/27/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2400	Closed Work Orders 5-31-05 8HRS PREPARE SCIENCE'S HALL FOR PAINTING. 5/31 - 8	6/1/2005 5/31/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
1984	Closed Work Orders 5-16-05 3HRS HELP TURY CHECK AHU 5HRS REPAIR PORTABLE ROOF AT DOL .	5/17/2005 5/16/2005 Medium	Joel Herrera Margret Villalobos		Santa Teresa HS
2017	Closed Work Orders 5-2-05 5/2 8HRS CLEAN UP	5/17/2005 5/2/2005 Medium	Joel Herrera		Santa Teresa HS
2018	Closed Work Orders 5-03-05 5/3 8HRS CLEAN UP A/C'S	5/17/2005 5/3/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2019	Closed Work Orders 5-06-05 8HRS CLEAN UP A/C'S 5/6 - 8	5/17/2005 5/6/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2013	Closed Work Orders 4-29-05 4/29 8HRS CLEAN UP A/C'S	5/17/2005 4/29/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2006	Closed Work Orders 4-26-05 4/26 8HRS CLEAN UP A/C'S	5/17/2005 4/26/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2007	Closed Work Orders 4-27-05 4/27 8HRS CLEAN UP A/C'S	5/17/2005 4/27/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2003	Closed Work Orders 4-22-05 4/22 - 8HRS CLEAN UP A/C'S	5/17/2005 4/22/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2004	Closed Work Orders 4-25-05 4/25 8HRS CLEAN UP A/C'S	5/17/2005 4/25/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2001	Closed Work Orders 4-21-05 4/21 - 8HRS CLEAN UP A/C'S	5/17/2005 4/21/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
1999	Closed Work Orders 4-20-05 4/20 8HRS CLEAN UP A/C'S	5/17/2005 4/20/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
1995	Closed Work Orders 4-18-05 4/18 -8HRS CLEAN UP A/C'S.	5/17/2005 4/18/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS

7/1/2005 10:40:49 AM

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1996	Closed Work Orders 4-19-05 4/19 8HRS CLEAN UP A/C'S	5/17/2005 4/19/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
1988	Closed Work Orders 4-11-05 4/11 -8HRS CLEAN UP A/C'S	5/17/2005 4/11/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
1990	Closed Work Orders 4-12-05 4/12 8HRS CLEAN UP A/C'S	5/17/2005 4/12/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
1991	Closed Work Orders 4-13-05 4/13 8HRS CLEAN UP A/C'S	5/17/2005 4/13/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
1992	Closed Work Orders 4-14-05 4/14 -8HRS CLEAN UP A/C'S	5/17/2005 4/14/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
1993	Closed Work Orders 4-15-05 4/15 - 8HRS CLEAN UP A/C'S .	5/17/2005 4/15/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2176	Complete DAVID I NEED YOUR HELP KITCHEN'S DRAIN IS CLOGGED AGAIN. CABLE OUT MAIN SEWER LINE.	5/20/2005 5/23/2005 Medium	Joel Herrera David Villalobos		Santa Teresa HS
2157	Complete JOSE AMBRIZ WE NEED CHECK REFRIGERATION UNIT IT DOESN'T WORKING WELL AT NURSES PORTABLE . HAD BLOWN FUSE, CLEAN COIL IT WAS DIRTY.	5/20/2005 5/24/2005 Medium	Joel Herrera Jose Ambriz		Santa Teresa HS
2119	Closed Work Orders 5-18-05 2 HRS HELP TO DAVID CHECK AND FIND IT LEACK ON OXYGEN / ACETYLENE AT WELDING SHOP. 3 HRS CUT CABLE AND OPEN ALL LOCKERS AT SCIENCE WING AND MATH WING. 3HRS CHECK AND REPAIR TWO A/CS AT ENGLISH WING. 5/18 - 8	5/19/2005 5/18/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2071	Closed Work Orders 5-17-05 1 HRS GIRLS WAS CLOGGED AT MAIN LOBBY. 3HRS ASSEMBLDE SHELVES FOR CLASS ROOMS 4HRS INSTALL PAPER DISPENSER. 5/17 - 8	5/18/2005 5/17/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2010	Closed Work Orders 4-28-05 4/28 8HRS CLEAN UP A/C'S.	5/17/2005 4/28/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2966	Closed Work Orders 6-17-05 8.0 PAINTING CLASS ROOMS 6/17 -8	6/23/2005 6/17/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2967	Closed Work Orders 5-21-05 8.0 PAINTING CLASS ROOMS. 5/21 - 8	6/23/2005 5/21/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2968	Closed Work Orders 6-22-05 8.0 PAINTING CLASS ROOMS 6/22 - 8	6/23/2005 6/22/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2969	Closed Work Orders 6-23-05 8.0 PAINTING CLASS ROOMS 6/23 - 8	6/23/2005 6/23/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2846	Closed Work Orders 6-15-05 8.0 PAINTING CLASS ROOMS 6/15 - 8	6/17/2005 6/15/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2847	Closed Work Orders 6-16-05 8.0 PREPARE CLASSROOMS FOR PAINTING 6/16 - 8	6/17/2005 6/16/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
3017	Closed Work Orders 6-24-05 4.0 GO TO PICKUP SUPPLIES AND PUT GAS ON THE TRUCK. 4.0 PREPARE CLASSROOMS FOR PAINTING 6/24 - 8	6/28/2005 6/24/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
3018	Closed Work Orders 6-27-05 8.0 PAINTING CLASS ROOMS. 6/27 - 8	6/28/2005 6/27/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2688	Closed Work Orders 5-31-05 8HRS PAINTING CLASS ROOMS 5/31 - 8	6/10/2005 5/31/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2689	Closed Work Orders 6-01-05 8HRS PAINTING CLASS ROOMS 6/1 - 8	6/10/2005 6/1/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2690	Closed Work Orders 6-02-05 8HRS PAINTING CLASS ROOMS 6/2 - 8	6/10/2005 6/2/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2691	Closed Work Orders 6-03-05 8HRS BREAKING CONCRET RAMP FOR RE-MOVE PORTABLE 6/3 - 8	6/10/2005 6/3/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2692	Closed Work Orders 6-07-05 8HRS CUT REBAR AND REMOVE CONCRET AND CLAN UP AT POTABLE'S PLACE 6/7 - 8	6/10/2005 6/7/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2693	Closed Work Orders 6-08-05 8HRS PAINTING CLASS ROOMS 6/8 - 8	6/10/2005 6/8/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2694	Closed Work Orders 6-09-05 8HRS PAINTING CLASSROOMS 6/9 - 8	6/10/2005 6/9/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2779	Closed Work Orders 6-10-05 4HRS GO TO FACILITY SERVICE AND PICKUP SUPPLIES 4 HRS PREPARE CLASSROOMS FOR PAINTING 6/10 - 8	6/15/2005 6/10/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS
2780	Closed Work Orders 6-14-05 8.0 PAINTING CLASSROOMS. 6/14 - 8	6/15/2005 6/14/2005 Medium	Joel Herrera Joel Herrera		Santa Teresa HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2653	Complete COULD YOU PLEASE SEND ME 3 PACER 30 VAC. BAGS DELIVERED 3 BAGS AS PER JIMMY	6/9/2005 6/9/2005 Medium	Jimmy Carbajal Jimmy Carbajal	Classroom	Santa Teresa HS
1395	Work In Progress GROUNDS SHOP - NEED TO RESTOCK FIRST AID KIT.	4/25/2005 Medium	Lorenzo Hernandez Ruben Ronquillo		Santa Teresa HS
1428	Complete NEED SIX PAIRS OF MEDIAUM LEATHER GLOVES THANK YOU. ISSUED 6 PAIR OF GLOVES	4/26/2005 5/20/2005 Medium	Luis Murillo Ruben Ronquillo		Santa Teresa HS
1561	Complete ROYAL VACUUM CLEANER NOT TURNING ON SERIAL* 96A-00001535. NEED A LOANER THANK YOU . REPLACED PARTS AND DID P.M.M AND ALSO HAD A SHORT	5/2/2005 5/20/2005 Medium	Luis Murillo Jimmy Carbajal		Santa Teresa HS
1559	Complete Annex Bldg Room 37 - 2 broken window.	4/28/2005 4/28/2005 Medium	Luis Murillo Ruben Ronquillo	Classroom	Santa Teresa HS
1825	Complete ADVANCE WET -N- DRY SERIAL*1372839 THROWING WATER FROM THE BOTTOM NEEDS TO BE CHECKED OUT THANK YOUUUUUUUUUUUUU. REPLACED PARTS & DID P.M	5/11/2005 5/20/2005 Medium	Luis Murillo Jimmy Carbajal		Santa Teresa HS
2439	Complete ROTO ADVANCE MACHINE SA-5120 OFF/ON SWITCH NOT WORKING THANK YOU. MACHINE HAD A SHORT.	6/2/2005 6/3/2005 Medium	Luis Murillo Jimmy Carbajal		Santa Teresa HS
656	Complete NEED SIX PAIRS OF LEATHER MEDIUM GLOVES OK BY AIDA	3/29/2005 4/22/2005 Medium	Luis Murillo Ruben Ronquillo		Santa Teresa HS
175	Complete NEW BRUSH NEDS TO BE INSTALL ON ROYAL VACUUM CLEANER SERIAL *K96A-00001535 NEED ALOANER FOR THE MEAN TIME THANK YOUUUUUUUUU. REPLACED FAN, BELT AND ALSO DID P.M. 3/9/05	3/8/2005 4/15/2005 Medium	Luis Murillo Jimmy Carbajal		Santa Teresa HS
348	Work In Progress BOTH MIORRORS FROM BOYS BATH ROOM ARE FADED THEY NEED TO BE REPLACE IN THE ENGLISH WING THANK YOU.	3/14/2005 Medium	Luis Murillo Ruben Ronquillo		Santa Teresa HS
1007	Complete CARPET HAS BEEN INSTALL IN THE BOYS DRESSING ROOM AND GIRLS WILL BE CARPETED NEXT ; CUSTODIAN IN THAT AREA WILL NEED A ROYAL VACUUM CLEANER TO DO THE CLEANING UP. DELIVERED 1 VACUUM	4/11/2005 4/14/2005 Medium	Luis Murillo Aida Salcedo		Santa Teresa HS
1247	Complete NEED TO MOVE FIRE PROOF FIELING CABINETS TO NURSES OFFICE / NEED TO USE HEAVY DUTY DOLY. A.S.A.P. THANK YOU. DELIVERED AND RETURNED DOLLY SAME DAY. 4-19-05	4/19/2005 4/19/2005 Medium	Luis Murillo Sal Acuna		Santa Teresa HS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
3029	Work In Progress NEED LOCKS TO BE CHANGE ON GYM , GOING TO START WORKING ON GYM FLOOR TUESDAY 7-5-05 THANK YOU.	6/28/2005 Medium	Luis Murillo Hector Lozoya		Santa Teresa HS
3108	Work In Progress NEED TO CHANCE LOCKS FROM GYM DOORS ON 7-18-05 INSTEAD OF 7-5-05 GOING TO WORK ON GYM FLOOR SORRY FOR THE MIX UP THANK YOU MR. LOZOYA	6/30/2005 Medium	Luis Murillo Luis Murillo		Santa Teresa HS
697	Duplicate Request Chiller Plant is not working properly. (Jose Ambriz will contact David Boyd) same as 690	3/30/2005 Medium	Jose Ambriz Margret Villalobos		Santa Teresa HS
2608	Work In Progress School campus. Need Manny B. to Blade the whole campus with the tractor. Weeds have grown all over campus.	6/7/2005 Medium	Jaime Mijarez Manuel Barrientos		Santa Teresa MS
2609	Complete School restrooms. Please order for me 10 ea. elongated toilet seats to replace damaged ones. DEL. SEATS TO JAIME MIJAREZ.	6/7/2005 6/9/2005 Medium	Jaime Mijarez David Villalobos		Santa Teresa MS
2610	Work In Progress New portable. Need Grounds to poor some kind of dirt to stop the blocks supporting the portable from weakening. I already explained to Alfredo H. The wind and rain are the cause.	6/7/2005 Medium	Jaime Mijarez Lorenzo Hernandez		Santa Teresa MS
2604	Forwarded N.bldg. North side sidewalk needs to be repaired by roofing company . David Boyd needs to call Noel. The sidewalk was damaged by their tractors.	6/7/2005 Medium	Jaime Mijarez David Boyd		Santa Teresa MS
2597	Work In Progress N.bldg. Handicap ramp side walk was repaired without expansion joint. Concrete slab cracked and needs to be repaired again. Heavy traffic area.	6/7/2005 Medium	Jaime Mijarez Michael Munoz		Santa Teresa MS
2591	Work In Progress Gym. I need the scissor lift to repair basketball court. Cable cover came off and i don't know what other damages it has.	6/7/2005 Medium	Jaime Mijarez Ruben Ronquillo		Santa Teresa MS
2764	Work In Progress S.bldg lower level teachers lounge. Principal would like a door like the one that is going to be installed in rm 36. This opens the opposite direction of rm 36 door.	6/14/2005 Medium	Jaime Mijarez Danny Miranda		Santa Teresa MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2725	Closed Work Orders 6/01/05 .50 Sign in and fill out paper work. .50 Rm 12 not cooling. 1.0 Troubleshoot thru tracer summit. .50 Office unclog drinking fountain. 1.0 Office no lights in the round rm kitchen. 4.5 Office repair round rm cabinets. 6/1 - 7.5	6/13/2005 6/1/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
2722	Closed Work Orders 5/27/05 .50 Sign in and fill out paper work. 4.5 S.bldg inspect classrooms and order materials. 3.0 Report to physical plant. 5/27 - 8	6/13/2005 5/27/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
2723	Closed Work Orders 5/31/05 8.0 Sign in and work on monthly inspection plan. 5/31 - 8	6/13/2005 5/31/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
2716	Closed Work Orders 5/25/05 .50 Sign in and fill out paper work. 3.5 Install floor tile in kitchen area. 4.0 Monthly maintenance plan. 5/25 - 8	6/13/2005 5/25/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
2713	Closed Work Orders 5/23/05 .50 Sign in and fill out paper work. 7.5 Remove floor tile from kitchen area. 5/23 - 8	6/13/2005 5/23/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
2714	Closed Work Orders 5/24/05 .50 Sign in and fill out paper work. 3.5 Troubleshoot thru tracer summit.4.0 Remove floor tile from kitchen area. 5/24 - 8	6/13/2005 5/24/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
2718	Closed Work Orders 5/26/05 .50 Sign in and fill out paper work. 3.5 Install tile in kitchen area. 4.0 Monthly maintenance plan. 5/26 - 8	6/13/2005 5/26/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
2710	Closed Work Orders 5/19/05 .50 Sign in and fill out paper work. 7.5 126285 extinguishers. 5/19 - 8	6/13/2005 5/19/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
2711	Closed Work Orders 5/20/05 .50 Sign in and fill out paper work. 5.0 126283 lights. 2.5 126284 exit lights. 5/20 - 8	6/13/2005 5/20/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
2683	Complete S.bldg Rm 33. broken glass size 32L x 35 1/2 w double pane exterior window.	6/10/2005 6/13/2005 Medium	Jaime Mijarez Ruben Ronquillo		Santa Teresa MS
2684	Work In Progress Principal Williams wants all bldgs sprayed inside and outside. There has been alot of insects, and bugs everywhere. She would like to have it done a.s.a.p because of complaints. OK - MARGRET MAKE SURE THIS WORK IS NOT DONE UNTIL THE WEEK BEFORE SCHOOL STARTS, OTHERWISE THE CUSTODIANS WILL HAVE CLEANED/REMOVED THE INSECTICED RESIDUAL. - A. HOLGUIN. 6/22/05 -FAXED PO 45014024	6/10/2005 Medium	Jaime Mijarez Margret Villalobos		Santa Teresa MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2685	Complete Principal Williams would like all electrical done on portables before school starts also including phone lines, computers, and other work that needs to be done. notify principal about Lynco connecting portables.	6/10/2005 6/17/2005 Medium	Jaime Mijarez Carlos Castillo		Santa Teresa MS
3119	Closed Work Orders 6/6/05 .50 Sign in and fill out paper work. 7.5 Paint classrooms in S.bldg upper level. 6/6 - 8	7/1/2005 6/6/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
3116	Closed Work Orders 6/02/05 .50 Sign in and fill out paper work. 5.0 Paint class rms in s. bldg upper level. 1.0 Utility relocation and gas shut-off meeting. 1.5 Paint classrooms in S.bldg upper level. 6/2/05 - 8	7/1/2005 6/2/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
2957	Work In Progress N. Bldg upper level. Need trane co. to check communication problem on hps 17 thru 22, and 25. They go on failure and restore every few minutes.	6/23/2005 Medium	Jaime Mijarez Margret Villalobos		Santa Teresa MS
1905	Closed Work Orders 5/09/05 .50 sign in and fill out paper work. 5.0 PM 125839. 2.5 PM 125840. 5/9 - 8	5/12/2005 5/9/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
2276	Closed Work Orders 5/17/05 .50 sign and fill out paper work. 1.50 trouble shoot thru tracer summit. 2.0 Assist with cooling system inventory. 3.0 Repair tile S. bldg entrance. 1.0 Parking lights are down. 5/17 - 8	5/25/2005 5/17/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
2277	Closed Work Orders 5/18/05 .50 sign in fill out paper work. 2.5 Trouble shoot thru tracer summit. 1.0 Help with student lunches. 1.5 N. bldg measure and order blinds. 2.5 Fill out paper work. 5/18 - 8	5/25/2005 5/18/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
2272	Closed Work Orders 5/12/05 .50 sign in and fill out paper work. 7.5 Monthly maintenance plan. 5/12 - 8	5/25/2005 5/12/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
2274	Closed Work Orders 5/13/05 .50 sign in and fill out paper work. 1.0 Trouble shoot thru tracer summit. 2.5 Parking lights shorted out. 4.0 Trouble shoot cafeteria for school dance and activities. 5/13 - 8	5/25/2005 5/13/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
2269	Closed Work Orders 5/10/05 .50 sign in and fill out paper work. 7.5 Trouble shoot thru tracer summit. 5/10 - 8	5/25/2005 5/10/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
2270	Closed Work Orders 5/11/05 .50 sign in and fill out paper work. 7.5 Monthly maintenance plan. 5/11 - 8	5/25/2005 5/11/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1901	Closed Work Orders 3/23/05 .50 sign in and fill out paper work. 7.5 S.bldg paint ramp upper and lower level. 3/23 - 8	5/12/2005 3/23/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
1902	Closed Work Orders 3/24/05 .50 sign in and fill out paper work. 7.5 S.bldg paint ramp upper and lower level. 3/24 -8	5/12/2005 3/24/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
1903	Closed Work Orders 4/18/05 .50 sign in and fill out paper work. 7.5 PM 125841. Duplicate to w/o 1889. 4/18 - 8	5/12/2005 4/18/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
1899	Closed Work Orders 3/22/05 .50 sign in and fill out paper work. 3.5 Safety training. 4.0 S.bldg paint ramp upper and lower level. Duplicate to w/o 1891 3/22 - 8	5/12/2005 3/22/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
1884	Work In Progress S.bldg rm36. Need to have a safety window with safety glass installed. Rm will be used for a special ed student. Requested by Ms Williams.	5/12/2005 Medium	Jaime Mijarez Danny Miranda	Classroom	Santa Teresa MS
1885	Closed Work Orders .50 sign in and fill out paper work. 5.0 PM 125596 2.5 PM 125597 5/9 - 8	5/12/2005 5/9/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
1886	Closed Work Orders .50 sign in and fill paper work. 7.5 PM 125598 5/12 - 8	5/12/2005 5/12/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
1887	Closed Work Orders .50 sign in and fill out paper work. 7.5 Maintenance plan. 5/10 - 8	5/12/2005 5/10/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
1889	Closed Work Orders .50 sign in and fill out paper work. 7.5 PM 125841 5/11 - 8	5/12/2005 5/11/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
1890	Closed Work Orders .50 sign in and fill out paper work. 7.5 S.bldg paint ramp upper and lower level. 5/11 - 8	5/12/2005 5/11/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
1891	Closed Work Orders .50 sign in fill out paper work. 3.5 safety training. 4.0 S.bldg paint ramp upper and lower level. 8	5/12/2005 5/12/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
1892	Closed Work Orders 3/16/05 .50 sign in and fill out paper work. 5.0 PM 125596. 2.5 PM 125597 Duplicate to w/o 1885 3/16 - 8	5/12/2005 3/16/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
1893	Closed Work Orders 3/17/05 .50 sign in and fill out paper work. 7.5 PM 125598. Duplicate to w/o 1886 3/17 - 8	5/12/2005 3/17/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
1894	Closed Work Orders 3/18/05 .50 sign in and fill out paper work. 7.5 Maintenance plan. duplicate to w/o 1887 3/18 - 8	5/12/2005 3/18/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1895	Closed Work Orders 3/21/05 .50 sign in and fill out paper work. 7.5 S.bldg paint ramp upper and lower level. Duplicate to w/o 1890 3/21 - 8	5/12/2005 3/21/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
1896	Closed Work Orders 3/21/05 .50 sign in and fill out paper work. 7.5 S.bldg paint ramp upper and lower level. Duplicate to w/o 1890 3/21 - 8	5/12/2005 3/21/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
497	Complete S.Bldg parking light post glass cover opened and is just hanging. I need bucket truck and operater to get up there. THIS IS A NON ELECTRICAL WO BLDG MECHANIC	3/17/2005 4/11/2005 Medium	Jaime Mijarez Carlos Castillo		Santa Teresa MS
518	Closed Work Orders 3/10/05 .50 sign in and fill out paper work. .50 Students testing check heating. 2.0 124424 Exit signs. 1.0 Hallways hot check heat pumps. 4.0 Change filters on heat pumps	3/18/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
519	Closed Work Orders 3/11/05 .50 sign in and fill out paper work. .50 Troubleshoot thru tracer summit. 3.0 Maintenance plan Monthly inspection.	3/18/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
542	Work In Progress Choir Rm . Outside metal door is damaged and old used to belong to the demolished mechanical rm. Door is to big and heavy for students to be opening every day. Would like to have it replaced to a new and smaller door. Approved by principal.	3/18/2005 Medium	Jaime Mijarez Danny Miranda		Santa Teresa MS
521	Closed Work Orders 3/14/05 .50 Sign in and fill out paper work. .50 Troubleshoot thru tracer summit. .50 Repair leaking sink in round room. 2.5 Locate water and electrical lines by tree line.4.0 Maintenance plan monthly inspection.	3/18/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
522	Closed Work Orders 3/15/05 .50 sign in and fill out paper work. .50 Troubleshoot thru tracer summit. 2.0 Report to physical plant. 1.0 Locate trees to be taken down.	3/18/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
307	Closed Work Orders 3/7/05 .50 Sign in and fill out paper work. 1.0 Students testing check heating. 1.0 Went to sths to get measurements on portable. 5.5 Prepare site for portable.	3/11/2005 3/11/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
309	Closed Work Orders 3/8/05 .50 Sign in and fill out paper work. 1.0 troubleshoot thru tracer summit. 4.5 Prepare site for portable. 4.5 Cafeteria clogged drain line	3/11/2005 3/11/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
310	Closed Work Orders 3/9/05 1.0 Went in early to check kitchen drains. .50 Check heating thru tracer summit. .50 Check sewer smell in office rr. 6.5 Prepare site for portable.	3/11/2005 3/11/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
303	Closed Work Orders 3/4/05 .50 Sign in and fill out paper work. .50 Students testing check heating. 3.0 PM 124423 Lighting. 1.0 S.bldg leaking water fountain. 1.0 Clean up maint. truck. 2.0 Report to physical plant.	3/11/2005 3/11/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
298	Work In Progress Gym - Replace westside doors.	3/11/2005 Medium	Jaime Mijarez Danny Miranda		Santa Teresa MS
299	Closed Work Orders 3/2/05 .50 sign in and fill out paper work. 1.0 Tracer summit troubleshooting students testing. 6.5 Replace light bulbs on all exterior lighting.	3/11/2005 3/11/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
300	Closed Work Orders 3/3/05 .50 Sign in and fill out paper work. 1.0 Students testing check heating. 6.5 124425 fire ext.	3/11/2005 3/11/2005 Medium	Jaime Mijarez Jaime Mijarez		Santa Teresa MS
193	Complete Cafeteria - Restroom by Cafeteria has a bad odor, also grease traps are backing up. (Informed David) cable out main sewer line to kitchen rr and sinks.	3/8/2005 3/8/2005 Medium	Jaime Mijarez David Villalobos	Cafeteria	Santa Teresa MS
173	Complete Rm 8 N.bldg- Nurses office is going to be remodeled and is going to need new electrical outlets for counter areas and office area.	3/8/2005 4/26/2005 Medium	Jaime Mijarez Carlos Castillo		Santa Teresa MS
1431	Complete NORTH BUILDING NURSES OFFICE ROOM 8 NEED ELECTRICIAN TO SET UP ELECTRICAL ACCESS DUE TO REMODLING	4/26/2005 6/24/2005 Medium	Jose Hinojosa Carlos Castillo	Office	Santa Teresa MS
2246	Work In Progress remove carpet from art room, if possible As per Mike - Route back to Jaime. - mkv	5/24/2005 Medium	Jose Hinojosa Jaime Mijarez	Classroom	Santa Teresa MS room 1
2056	Complete NEED OUTLET EXTENSIONS FOR NURSE NEW CUBICLES AND EXTRA PHONE OUTLET RUN 6 CIRCUITS TO REMODEL NURSES W/CUBICLES.	5/18/2005 6/17/2005 Medium	Jose Hinojosa Carlos Castillo		Santa Teresa MS
2057	Work In Progress ROOM 3 REFRIDGERATOR AND STOVE NEED TO BE LOOKED AT	5/18/2005 Medium	Jose Hinojosa Danny Orozco	Classroom	Santa Teresa MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2058	Void DRYER AND WASHER NEED TO BE SERVICED...HAVE NOT BEEN IN 10 YEARS Void - Washer and Dryer are not serviced thru Maint. Dept. If new ones are needed the school site will purchase them w/there funding/budget.	5/18/2005 6/13/2005 Medium	Jose Hinojosa David Villalobos	Classroom	Santa Teresa MS 3
2059	Work In Progress HINGES NEED TO BE REPLACED...DOOR NOT CLOSING IN UPPER LEVEL GIRLS BATHROOM	5/18/2005 Medium	Jose Hinojosa Danny Miranda	Restroom (Girls)	Santa Teresa MS
2060	Work In Progress WEST SIDE OF ROOM POWER STRIP SHORTED OUT...NEED REPLACING OR REPAIR	5/18/2005 Medium	Jose Hinojosa Carlos Castillo	Classroom	Santa Teresa MS 52
2191	Work In Progress door cabinets off hinges need repair	5/23/2005 Medium	Jose Hinojosa Jaime Mijarez	Office	Santa Teresa MS Round Room Kitchen
2193	Duplicate Request cabinet doors in north office kitchen need replacing...off hinges DUPLICATE W.O. AS PER MR. JOSE HINOJOSA. SEE W.O. # 2191	5/23/2005 Medium	Jose Hinojosa Michael Munoz	Portables	Santa Teresa MS
2204	Work In Progress 5 copies of cabinet key for North building kitchen cabinets	5/23/2005 Medium	Jose Hinojosa Hector Lozoya	Restroom (Boys)	Santa Teresa MS
2161	Work In Progress duplicate keys for new portables	5/20/2005 Medium	Jose Hinojosa Hector Lozoya	Portables	Santa Teresa MS
329	Complete NEED TO LINE LOCATE ON MONDAY 3/14/05 PINE TREE AREA PARALLEL TO MC NUTT ROAD. located gas & water lines by new bus turnaround.	3/11/2005 3/14/2005 Medium	Michael Munoz David Villalobos		Santa Teresa MS
330	Complete NEED TO LINE LOCATE ON MONDAY 3/14/05 PINE TREE AREA PARALLEL TO MC NUTT ROAD. locate hi voltage lines for pine tree removal.	3/11/2005 3/14/2005 Medium	Michael Munoz Carlos Castillo		Santa Teresa MS
2828	Work In Progress NEED TO REMOVE WEEDS ON OUR CAMPUS AREA AS PER. MISS WILLIAMS . NORTH AND SOUTH BUILDING AND GYM AREA.THANK YOU.	6/16/2005 Medium	Ismael Rodriguez Mike Soria		Santa Teresa MS
3117	Work In Progress I NEED FOR THE LOCKSMITH TOO CHANGE 4 KEY CYLINDERS IN SOUTH LOWER MECANICAL ROOM . CONT. MR.RODRIGUEZ.	7/1/2005 Medium	Ismael Rodriguez Hector Lozoya		Santa Teresa MS
3118	Work In Progress I NEED FOR GYM KEY CYLINDERS TOO TO BE CHANGE BEFORE 7/13/05.CONT.MR.RODRIGUEZ.	7/1/2005 Medium	Ismael Rodriguez Hector Lozoya		Santa Teresa MS
1055	Work In Progress SPEEDY HERNANDEZ NEED BACKHOE TO REMOVE SAND FROM NORTH AND SOUTHBUILDING.THANK YOU SIR.	4/12/2005 Medium	Ismael Rodriguez Lorenzo Hernandez		Santa Teresa MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1098	Duplicate Request Need a electrician to run some electrical wiring through some particians in the new nurses office. as per MS.WILLIAMS. THANK YOU. 2056	4/13/2005 6/24/2005 Medium	Ismael Rodriguez Carlos Castillo	Classroom	Santa Teresa MS
1099	Complete NEED A LOCKSMITH TO FIX A DOOR THAT IS NOT LOCKING PROPERLY COMING THROUGH THE BACK SIDE OF THE GYM. SEE MR.RODRIGUEZ. THANK YOU. repair panic bar and clean cylinders	4/13/2005 4/13/2005 Medium	Ismael Rodriguez Hector Lozoya		Santa Teresa MS
1103	Work In Progress ATTN;RUBEN RONQUILLO. I NEED A TRAILER TOO TRANSPORT ART WORK FOR MR. SANCHEZ TO THE G.M.S 4/14/05. THANK YOU.	4/13/2005 Medium	Ismael Rodriguez Ruben Ronquillo		Santa Teresa MS
1104	Complete BOYS & GIRLS RESTROOMS - DRAINS ARE BACKING UP. (INFORMED DAVID)	4/13/2005 4/13/2005 Medium	Ismael Rodriguez David Villalobos	Cafeteria	Santa Teresa MS
1301	Complete ATTN:AIDA SAUCEDO I WILL NEED 2 CAFETERIA DOLLEYS AND A REGULER WHEEL DOLLEY FOR THIS SUMMER CONTACT MR.RODRIGUEZ.THANK YOU. DELIVERED & ISSUED 2 CHAIR DOLLYS	4/21/2005 5/25/2005 Medium	Ismael Rodriguez Jimmy Carbajal		Santa Teresa MS
1271	Complete THERES A ELECTRICAL SWITCH THAT NEEDS TO BE REPAIR COMING THROUGH THE BACK DOOR OF BOYS LOCKER ROOM.SEE MR.RODRIGUEZ.	4/20/2005 4/22/2005 Medium	Ismael Rodriguez Carlos Castillo		Santa Teresa MS
1775	Work In Progress SPEEDY NEED TOO BORROW THE WHITE TRAILER ON 5/12/05	5/10/2005 Medium	Ismael Rodriguez Lorenzo Hernandez		Santa Teresa MS
1704	Complete THE TIMER FOR THE OUTSIDE PARKING LIGHTS NEEDS TOO SET TO TURN OFF AT 6.00AM. THERE TURNING OFF AT 8.00AM.THANK YOU.CONTACT MR.RODRIGUEZ. TRACE DOWN SHORT NEED TO ORDER CONTACTOR, FOUND CONTACTOR IN STOCK AND INSTALLED.	5/6/2005 6/19/2005 Medium	Ismael Rodriguez Carlos Castillo		Santa Teresa MS
1685	Complete THERE IS A WINDOW BROKEN IN THE GYM DOOR MAIN ENTRANCE. SEE MR.RODRIGUEZ. THAT NEEDS TOO BE REPLACE.THANK YOU. BROKEN WINDOW	5/5/2005 5/5/2005 Medium	Ismael Rodriguez Ruben Ronquillo		Santa Teresa MS
1336	Complete I NEED A BUILDING MECHANIC TO FIX A WATER FOUNTAIN THAT IS LEAKING BAD.A.S.A.P.CHECK WITH MR.RODRIGUEZ.THANK YOU. called Pat Aguilar to check on this work order - In Jaime's Absence	4/22/2005 4/22/2005 Medium	Ismael Rodriguez Patricio Aguilar	Hallway/Corridor	Santa Teresa MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1948	Complete MR.SALVADOR I AM GOING TO NEED 4 PAIRS OF SAFETY SLIPPERS FOR THIS SUMMER,SIZE LARGE.THANK YOU. DELIVERED 4 PAIR OF SAFETY SHOES	5/16/2005 5/20/2005 Medium	Ismael Rodriguez Guillermo Hernandez	Custodial	Santa Teresa MS
1949	Complete JIMMY CARBAJAL I NEED FOR YOU TO SERVICE A ROYAL VACUUM.CONT.MR.RODRIGUEZ. REPLACED ABOVE PARTS AND DID P.M.	5/16/2005 5/20/2005 Medium	Ismael Rodriguez Jimmy Carbajal		Santa Teresa MS
1978	Complete JIMMY CARBAJAL CAN YOU PLEASE SERVICE MY CARPET EXTRACTER.THANK YOU.MR.RODRIGUEZ. CLEANED OUT NAZZLE ASSY FILTERS	5/17/2005 5/20/2005 Medium	Ismael Rodriguez Jimmy Carbajal		Santa Teresa MS
906	Complete Ladies RR - T-Stat wires are exposed. VADALISED T-STAT REMOVE AND COVER WILL ,CTRL AREA WITH TRACER SUMMIT	4/6/2005 4/6/2005 Medium	Ismael Rodriguez Jose Ambriz	Restroom (Girls)	Santa Teresa MS
801	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. COMPLETED PER ISMAEL RODRIGUEZ	4/1/2005 4/29/2005 Medium	Aida Salcedo Ismael Rodriguez		Santa Teresa MS
2533	Work In Progress NEED TO REMOVE MARQUEE AT ENTRANCE BEFORE JUNE 17TH, 2005. STORE SIGN AT SCHOOL SITE UNTIL STATE DEPT IS DONE WITH ROAD.	6/6/2005 Medium	Alfredo Holguin Lorenzo Hernandez		Santa Teresa MS
2534	Complete NEED TO DISCONNECT MARQUEE AT ENTRANCE SO GROUNDS CAN REMOVE BEFORE JUNE 17TH, 2005. disconnect power to marquee	6/6/2005 6/15/2005 Medium	Alfredo Holguin Carlos Castillo		Santa Teresa MS
1277	Work In Progress please support with setting in of new portable and install ramps.	4/20/2005 Medium	Lorenzo Hernandez		Santa Teresa MS
2499	Complete NEED TO PICK UP SHARPS CONTAINERS FROM NURCES OFFICE ON NEXT TRIP OVERTHERE. PICKED UP SHARPS CONTAINER AS PER JIMMY.	6/3/2005 6/9/2005 Medium			Santa Teresa MS
2317	Work In Progress need to provide new side walks to new portable.	5/26/2005 Medium	Michael Munoz	Portables	Santa Teresa MS
1100	Complete Receptacle shocking staff. ELIMINATED DANGEROUS CORD, NEED TO RETURN TO REPLACED CORD.	4/13/2005 4/19/2005 Emergency	Carlos Castillo Carlos Castillo		Santa Teresa MS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
920	Complete north and south building-check flickering lights 4/7-contact epec and report problem. 4/19- follow up no more flickering.	4/7/2005 4/19/2005 Medium	Carlos Castillo Carlos Castillo		Santa Teresa MS
2728	Work In Progress need to replace doors @ 10x56 window kit	6/13/2005 Medium	Danny Miranda Danny Miranda		Santa Teresa MS
2761	Complete check new portable for setup by contractor ck portables for level	6/14/2005 6/14/2005 Medium	Danny Miranda Danny Miranda	Portables	Santa Teresa MS
3028	Work In Progress GROUNDS AREA BY MOBILE HOME - NEEDS TO BE SPRAYED FOR BLACK BUGS. (OPEN PO)	6/28/2005 Medium	Norma Alvarado Margret Villalobos		Santa Teresa MS
1872	Complete VANDALISM - REFLECTOR LENSES ON TRAILER WERE ALL BROKEN W/BB'S WERE FOUND AROUND TRAILER. MARCH 5 OR 6, 2005.	5/12/2005 5/12/2005 Medium	Mike Soria Mike Soria		Santa Teresa MS
1427	Complete Carlos Vigil - Needs a Master Key for Sound & Signal, Contractor. issued TA master to Carlos Vigil for Sound and Signal.	4/26/2005 4/27/2005 Medium	REYES VALTIERRIA Hector Lozoya		Sunland Park ES
488	Work In Progress NEED TO REPAIR WINDOWS @ OPERATORS	3/17/2005 Medium	Danny Miranda Danny Miranda		Sunland Park ES
2500	Complete NEED TO PICK UP SHARPS CONTAINERS FROM NURCES OFFICE ON NEXT TRIP OVERTHERE. PICKED UP SHARPS CONTAINER AS PER JIMMY	6/3/2005 6/9/2005 Medium			Sunland Park ES
2953	Work In Progress Please remove sand along fence line by houses. Also scrape playing area.	6/23/2005 Medium	Robert Sanchez		Sunland Park ES
1124	Complete on Monday 4-18-05 the contractors will start to repair the gas line@ 1:00p. Please make sure the school is ready for the following day. ck'd connections poly gas pipe, purged gas line, light up stove and water heater.	4/13/2005 4/18/2005 High	David Villalobos		Sunland Park ES
2512	Void Monthly - Sunland Park ES Roof Inspection - Refer to PM schedule details.	6/5/2005 Medium	Alfredo Holguin Sebastian Diaz		Sunland Park ES
802	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. COMPLETED PER LARRY FLORES	4/1/2005 5/27/2005 Medium	Aida Salcedo Larry Flores		Sunland Park ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
472	Complete BOTTOM BLODGETT OVEN NOT HEATING UP MARINA RAMIREZ - SNP MANAGER (589-2545) LOOSE CONTACT TERMINAL ADJUSTED CLEANED, WORKING FINE.	3/16/2005 3/23/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Sunland Park ES
1435	Complete INSERTED KEY TO LOCK WALK-IN REFRIGERTOR -- WHEN KEY WAS REMOVED THE WHOLE CYLINDER CAME OUT WITH THE KEY VIRGINIA FRUIT - TEMP MANAGER (505) 589- 2545 PUT KEY CYLINDER BACK IN DOOR LOCKED IN PLACE DOOR LOCKS AND UNLOCKS	4/26/2005 5/3/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Sunland Park ES
1340	Complete HAVING PROBLEMS WITH BOTTOM RIGHT BLODGETT OVEN AND WITH OVEN TO WOLFE RANGE REMOVED COVERS CLEANED BURNER AND FLAME SENSORCHECKED ALL WIRING	4/22/2005 4/25/2005 Medium	Alma Terrell Danny Orozco	Cafeteria	Sunland Park ES
1213	Complete milk cooler at 45 degrees marina ramirez - snp manager 505-589-2545 CLEANED CONDENSOR COIL	4/18/2005 4/25/2005 Medium	Alma Terrell Danny Orozco		Sunland Park ES
2411	Void THE CREWS WHO INSTALLED THE NEW INNER COM SYSTEM AND FIRE ALARM LEFT MANY ELECTRICAL BOXES UNCOVERED. S. DIAZ SPOKE TO BOTH GROUPS BUT BOXES REMAIN EXPOSED. THIS WORK ORDER IS FOR TECHNOLOGY DEPARTMENT. - MKV 126524	6/1/2005 Medium	Irene Trujillo		Sunland Park ES
2409	Work In Progress THIS IS A REQUEST FOR SAND TO BE PLACED UNDER SWING AREA AND MONKEY BAR PIT.	6/1/2005 Medium	Irene Trujillo Lorenzo Hernandez		Sunland Park ES
2319	Complete Replace pipe under sink. SUPPLIED SEBASTIAN WITH MATERIAL TO REPAIR DRAIN PIPE.	5/26/2005 5/31/2005 Medium	Irene Trujillo David Villalobos	Classroom	Sunland Park ES room 28
2320	Complete Replace faucet and pipe under sink. SUPPLIED SEBASTIAN WITH MATERIAL	5/26/2005 5/31/2005 Medium	Irene Trujillo David Villalobos	Office	Sunland Park ES teacher's lounge
2321	Work In Progress THE GRASS SHOULD BE REPLACED ON THE CIRCLE ENTERING THE SCHOOL GROUNDS. WE NEED THE AREA SMOOTHED AND SOD PLACED. REQUESTED AS PER MS. LINDA PEREZ, ASST. PRINCIPAL.	5/26/2005 Medium	Irene Trujillo Lorenzo Hernandez		Sunland Park ES GROUNDS

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1062	Complete I HAVE 2 VACUUMS WITH A SHORT THAT NEED REPAIR REPLACED 2 MALE PLUGS, MOTOR, BELT & FAN. AND ALSO DID P.M.	4/12/2005 4/13/2005 Medium	Jimmy Carbajal Jimmy Carbajal		Sunland Park ES
2915	Closed Work Orders 6/15/05 4-cut weeds in front of the school 4-start to paint room 21 6/15-8	6/21/2005 6/15/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2916	Closed Work Orders 6/13/05 4-cut weeds in the playground 4-clean walls for paint room 21 6/13-8	6/21/2005 6/13/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2917	Closed Work Orders 6/14/05 3-remove sand by the sidewalk 5-finish to paint room 28 6/14-8	6/21/2005 6/14/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2918	Closed Work Orders 6/15/05 4-cut weeds by the fence 4-continous paint room 21 6/15-8	6/21/2005 6/15/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2920	Closed Work Orders 6/16/05 4-fix water line room 28 under the sink 6/16-4	6/21/2005 6/16/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2923	Closed Work Orders 6/17/05 2-erase graffiti in the playground 3-clean play ground and throw trash can 6/17-5	6/21/2005 6/17/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2600	Void 6/6/05	6/7/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2601	Closed Work Orders 6/6/05 8-finish to paint room 40 6/6 - 8	6/7/2005 6/6/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2602	Closed Work Orders 6/7/05 8-start to paint room 28 6/7 - 8	6/7/2005 6/7/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2705	Closed Work Orders 6/10/05 2-inspect #126578,126579,126580 2-cut weeds by the sidewalk in new playground 3-went to main office to pick up material 1-peper log 6/10 - 8	6/10/2005 6/10/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2702	Closed Work Orders 6/8/05 6-cut grass with the tractor around the school 2-check door and windows 6/8 - 8	6/10/2005 6/8/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2703	Closed Work Orders 6/9/05 4-cut grass with the weedeater 4-continous paint in room 28 6/9 - 8	6/10/2005 6/9/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2100	Closed Work Orders 5/17/05 8-install rain gutter behind the cafeteria 5/17 - 8	5/18/2005 5/17/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2095	Closed Work Orders 5/18/05 2-help th first grade teacher to put water into the swiming pool for the students. 6-cut grass with the tractor and weedeater 5/18 - 8	5/18/2005 5/18/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2096	Closed Work Orders 5/18/05 2-help th first grade teacher to put water into the swiming pool for the students. 6-cut grass with the tractor and weedeater 5/18 - 8	5/18/2005 5/18/2005 Medium	Sebastian Diaz Margret Villalobos		Sunland Park ES
2093	Closed Work Orders 5/16/05 8-install rain gutter behind the cafeteria 5/16 - 8	5/18/2005 5/16/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1955	Closed Work Orders 5/13/05 1-fix broken water line south side 3-put the rastra in the playground to cut weeds 2-pick up trash can 2-went to main office pick up materil 5/13 - 8	5/16/2005 5/13/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1959	Closed Work Orders 5/16/05 2-clean up entrance doors 2.5- replce broken glass blocks in room 28 2-replace spinkler 12,13 zone .5-fix water float in room 17 5/16 - 8	5/16/2005 5/16/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1917	Closed Work Orders 5/12/05 2-fix wood steps in the ramp portable e 2-fix door knob in main entrance 2-fix and scure book shelf in the library 1-fix water pump in A/Croom 33 1-peper log 5/12 - 8	5/12/2005 5/12/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1915	Closed Work Orders 5/11/05 2-replace florescent lights in room 25,52 4-fix sprinklerin 11 zone 1-fix A/C in cafeteria 1-inspect business office 5/11 - 8	5/12/2005 5/11/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2505	Closed Work Orders 5/27/05 3-cut grass with the weedeater 3-inspect playground ,signage,fence,and decks. .2-went to pick up materal 5/27 - 8	6/3/2005 5/27/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2506	Closed Work Orders 5/31/05 8-continous paint room36 5/31 - 8	6/3/2005 5/31/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2507	Closed Work Orders 6/1,2/05 16-finish to paint room 36 and start room 40 6/1 - 8 & 6/2 - 8	6/3/2005 6/2/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2508	Closed Work Orders 6/3/05 1-spray round up by the fence top busses 2-cut weeds in front of the school 3-replace floor sinks in custodian closer 2-fix water leak in the entrane cfeteria roof 6/3 - 8	6/3/2005 6/3/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2501	Closed Work Orders 1-CHECK LIGHTS IN THE ROOM 3-check all A/C motors with Lorenzo Solis 4-start paint room 37 6/3 - 8	6/3/2005 6/3/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2502	Closed Work Orders 5/20/05 8-continous paint in room 37 5/20 - 8	6/3/2005 5/20/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
2503	Closed Work Orders 3/25,26/05 16-continous paint in room 36 3/24 -8 & 3/25- 8	6/3/2005 3/25/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1445	Closed Work Orders 4/25/05 8-WENT TO CID TO INSTALL RAIN GUTTERWITH MR MIRANDA 4/25 - 8	4/26/2005 4/25/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1446	Closed Work Orders 4/26/05 1-THOW AWAY TRASH AROUND THE BUILDING 1-FIX LSTCH WINDOW IN ROOM 40 1-FIX WROKEN WATER SPRINKLER 4-THE NEW SIDEWALK REMOVE SAND 1-SPRAY FERTEIZERAT THE GRASS 4/26 - 8	4/26/2005 4/26/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1328	Closed Work Orders 4/21/05 2-In the kinder wing south side paint hopscatch play 2-went to desert view to help pat to fix water lines 2-the trees in the playground provide water 1-remove six round tables room 12 to storage 1-check gas leak 4/21 - 8	4/21/2005 4/21/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1372	Closed Work Orders 4/22/05 2-went to homedepot to bring trees four the school 2-went to River Side school to help mr adan clean A/C 1-fix electrical switch in advance machine 1-remove sand by the side walk in the new wall 1-fix sprinkler and inspect landscape 1-pick up peper in playground 4/22 - 8	4/22/2005 4/22/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1542	Closed Work Orders 4/29/05 1-fix entrance door not close properly 5- went mid school touch upin the lobby area 2-went to main office to pick up materil 4/29 - 8	4/29/2005 4/29/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1504	Closed Work Orders 4-27/05 3-fix cable in the trap playground 1-fix table in room 15 4-went to mid school check work order and do it. 4/27 - 8	4/28/2005 4/27/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1502	Closed Work Orders 4/28/05 1-inspect playground and signage 3-fix sprinkler in northside 4-went to the mid school 4/28 - 8	4/28/2005 4/28/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1760	Closed Work Orders 5/6/05 1-help larry to set up gym for program. 1-fix sprinkler in play area. 6-cut weeds and trim lilltle trees by principal area . 5/6 - 8	5/9/2005 5/9/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1692	Closed Work Orders 5/3/05 8-GROUNDS;REMOVE SAND ,PICKUP TRASH,CUT WEEDS 5/3 - 8	5/5/2005 5/3/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1693	Closed Work Orders 5/4/05 5-CUT WEEDS IN FRONT OF THE SCHOOL 2-UNCLOG DRAIN INTHE BOILER ROOM 1-FIX LATCH WINDOW IN ROOM 40 5/4 - 8	5/5/2005 5/4/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1697	Closed Work Orders 5/5/05 2-FIX CAFETERIA DOOR THE DOOR CLOSER I HAVE TO REPLACE. 6-REMOVE SAND IN THE PARQUING LOT 5/5 - 8	5/5/2005 5/5/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1762	Closed Work Orders 5/9/05 2-clean up entrance doors 2-clean and paint rust metal in portable E 1-fix sprinkler broken north side 3-remove sand by parking lot busses 5/9 - 8	5/9/2005 5/9/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1798	Void 5/10/05	5/10/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1799	Closed Work Orders 5/10/05 4-remove sand in the stop busses area 2-cut grass with the tractor in front of the school 2-inspect #126280,126281,126282 5/10 - 8	5/10/2005 5/10/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
677	Closed Work Orders 3/29/05 2-clean up spots birds in front of the school entrance ,5 -fix round table in room 15 2-work in water fountain in the cafeteria's clog need to remove the machine. 2-went to the mid school to check the work or der 1.5-start to clean the A/C in the cafeteria	3/29/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
673	Closed Work Orders 3/18./05 2-finish to cut grass with weedeater 2.5-inspect #125592,125593,125594,125595 ,5fix leg tableroom 101-cut weeds in decks portables 2-went to maint office pick up material	3/29/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
666	Closed Work Orders 3/21/05 8-paint red zone in the cafeteria	3/29/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
705	Closed Work Orders 3/30/05 2-FIX LATCH WINDOW IN ROOM 38 1-CHECK LINE GAS AND CUT WEEDS BY THE FENCE LACAPE 2-WENT TO THE MID SCHOOL FIX A SINK IN THE ROOM 14 AND FIX THE ROPE OF THE FLAG 1-FIX WATER FONTAIN IN THE CAFETERIA	3/30/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
546	Work In Progress Room 28 - Need to replace door glass on outside door.	3/18/2005 Medium	Sebastian Diaz Ruben Ronquillo	Classroom	Sunland Park ES
502	Closed Work Orders 3/17/05 2-fix broken door knob in office restroom 6-cut grass with the tractor in front of the school	3/17/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
507	Closed Work Orders 3/10/05 1-went Sam,s Club to pick up ice cream 1-install organaiser on the wall computer room 1-fix clog toilet in the boys restroom 1-fix seat swing playground.	3/17/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
120	Closed Work Orders WENT TO MAIN OFFICE TO TAKE PERSONAL EVALUATION.	3/7/2005 3/8/2005 Medium	Sebastian Diaz Sebastian Diaz	Office	Sunland Park ES
121	Closed Work Orders 2/25/05 1-INSPECT GAS LINES.1-fix broken sprinkler 2-install chalkboard room 33.2-fix door gate in busses entrance.3-start paint cafeteria trim.2/28/05 3-pick up trash around the school.1-fix flirescent lighth in different room.2-inspect land scape.2-remove graffiti in playground.3/1/05 4-clean in front of the school parking lot.2-trim trees in behind office.1-unclog toilet in room 24.3/2/05 1-remove graffiti in laidies restroom.2-went to maint office to persanal evaluation.2-remove dirt with tiller for plant seed grass.3-start to install exhaust fan in office restroom.3/3/051-fix hinge doorin room 26.1-fix toilet in room 25.2-put rastra to cut weeds in main area. 4-continous work in office restroom. 3/4/05 1-fix overhead procector in room27.2-fix swing chain and replace.3-finish to install exhaust fanin the office	3/7/2005 3/8/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
122	Duplicate Request 2/25/05 1-INSPECT GAS LINES.1-fix broken sprinkler 2-install chalkboard room 33.2-fix door gate in busses entrance.3-start paint cafeteria trim.2/28/05 3-pick up trash around the school.1-fix flirescent lighth in different room.2-inspect land scape.2-remove graffiti in playground.3/1/05 4-clean in front of the school parking lot.2-trim trees in behind office.1-unclog toilet in room 24.3/2/05 1-remove graffiti in laidies restroom.2-went to maint office to persanal evaluation.2-remove dirt with tiller for plant seed grass.3-start to install exhaust fan in office restroom.3/3/051-fix hinge doorin room 26.1-fix toilet in room 25.2-put rastra to cut weeds in main area. 4-continous work in office restroom. 3/4/05 1-fix overhead procector in room27.2-fix swing chain and replace.3-finish to install exhaust fanin the office	3/7/2005 3/8/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
138	Complete NEED A SNAKE TO UNCLOG A TOILET THANK YOU 1-I USED THE FLANCH TO UNCLOG. BUT I NEED THE SNAKE TO UNCLOG IT.4/11 - Supplied Sebastian with snake and he unclogged it.	3/7/2005 4/11/2005 Medium	Sebastian Diaz David Villalobos	Restroom (Boys)	Sunland Park ES RESTROOM BOYS
139	Closed Work Orders 3/7/05 3-PICK UP TRASH AROUND THE SCHOOL. CHECK SWINGS AND GRAFFITI. 2-CUT WEEDS WITH THE WEEDEATER. 1-WORK IN THE RESTROOM TOILET. 1-TROW AWAY TRASH CAN. 1-PEPER LOG	3/7/2005 3/8/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
202	Closed Work Orders 3/8/05 5-clean up spots birds in front of the school and cut weeds 1-replace lights in the hall 2-fix broken sprinkler in kinder area	3/9/2005 3/9/2005 Medium	Sebastian Diaz Sebastian Diaz	Auditorium	Sunland Park ES
220	Closed Work Orders 3/9/05 4-plant seed in the kinder area 1-fix in the playground loss bolts 2-put water in the trees playground 1-peper log	3/9/2005 3/9/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
818	Closed Work Orders 4/1/05 1-CHECK ROOM 27 THE COMPUTER CORD WAS BURNING .1-FIX DOOR CLOSER IN THE OFFICE 2-WENT TO THE MID SCHOOL TO FIX COMPUTER TABLE IN ROOM 20. 1-INSTALL BOLETTIN BOARD IN ROOM 33 2-WENT TO MAINT OFFICE TO PICKUP MATERIL 1- MAKE MY PEPER LOG - 4/1 - 8	4/4/2005 4/1/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
819	Closed Work Orders 4/4/05 1-SET TIME ALL CLOCKS 2-REMOVE SAND IN FRONT OF THE SCHOOL 1-CUT WEEDS IN FRONT OF THE CAFETERIA 1-FIX OFFICE DESK IN PRINSIPAL 1-FIX BACK DOOR IN ROOM 29 2-CONTINOUS CLEANING A/C 4/4 - 8	4/4/2005 4/4/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
723	Complete need to replace door knob in outside restroom thank you Manny need to replace door knob in the outside restroom thank you. replace lockset on rr an drepair panic bars and door closer at nside doors and fix door at room 32.	3/31/2005 3/31/2005 Medium	Sebastian Diaz Hector Lozoya		Sunland Park ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
752	Closed Work Orders 3/31/05 1-CUT WEEDS BY THE ROCK WALL IN FRONT SCHOOL 2-CONTINOUS CLEANING A/C IN THE GYM 3-FIX TWO DOORS KNOB IN THE MAIN ENTRANCE 2-WENT TO THE MID SCHOOL TO CHECK THE WORK ORDER	3/31/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
750	Void 3/31/05	3/31/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
788	Complete ROOM 27 NEED TO CHECK BURNING WIRE SMELL. trace down burning smell to a computer, notified principal.	4/1/2005 4/1/2005 Medium	Sebastian Diaz Carlos Castillo		Sunland Park ES
989	Closed Work Orders 4/8/05 8-WORK IN A/C CLEAN 4/8 - 8	4/8/2005 4/8/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
942	Closed Work Orders 4/6/05 8- GROUNDS;CLEAN ARROUND SCHOOL 4/6 - 8	4/7/2005 4/6/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
943	Closed Work Orders 4/7/05 2-CLEAN UP SPOTS OF BIRDS 1.5-WENT TO HOMEDEPOT TO BRING BLOCKS 2.5-HELP CALI TO FIX ELECTRC WIRES INTHE GYM 2-CONTINOUS CLEAN A/C 4/7 - 8	4/7/2005 4/7/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
939	Void 4/5/05	4/7/2005 Medium	Sebastian Diaz		Sunland Park ES
940	Closed Work Orders 4/5/05 3-CUT WEEDS WITH THE TRACTOR 2-CLEAN THE LITLLE GARDEN IN THE OFFICE 1-FIX LIGHT IN PORTABLE B 2-CONTINOUS CLEANING THE A/C 4/5 - 8	4/7/2005 4/5/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1293	Closed Work Orders 4/20/05 2-cut weeds by the fence and inspect 2-fix clog sink in room 28 1-paint yellow lines in the parking lot 2.5-replace broken wood ramp in portable E .5-paper log 4/20 - 8	4/20/2005 4/20/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1256	Closed Work Orders 4/18/05 2-inspect extinguisher exit emergency and door windows 2-clean up main entrance 2-turn on A/C in all class rooms 2-went to pick up ART SHOW in the mid school 4/18 - 8	4/19/2005 4/18/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1258	Closed Work Orders 4/19/05 2-cut weeds in font of the school 2-work in the cafeteria A/C 1-fix weather strip in the room 28 1-inspect deck snd land 1-fix chart board and broken table in room 24 1-peper log 4/19- 8	4/19/2005 4/19/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1199	Closed Work Orders 4/15/05 2-inspect fire extinguisher 1-fix door strip in room 28 3-cut weeds behind the cfeteria 2-went to main office pick up material 4/15 - 8	4/15/2005 4/15/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1050	Complete 4/13/05 need to deliver ART SHOW at the mid school and pick up on monday 18 thank you	4/12/2005 4/18/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1029	Closed Work Orders 4/11/05 1-fix soccer goal nets in playground 2-remove sand by pine trees 5-continous clean A/C 4/11 - 8	4/11/2005 4/11/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1082	Complete 4/12/05 need to replce relif volve in boiler on the roof side thank you replace water relief valve and copper union.	4/12/2005 4/11/2005 Medium	Sebastian Diaz Jose Ambriz		Sunland Park ES
1083	Complete 4/12/05 need 4 metal cover for A/C THANK YOU GAVE 4 A/C COVERS TO SEBASTIAN TO REPLACE.	4/12/2005 6/14/2005 Medium	Sebastian Diaz Jose Ambriz		Sunland Park ES
1077	Closed Work Orders 4/12/05 1-clean up spots of birds in front entrance 1.5-replace relif vauve in boiler on the roof 5.5-clean A/C 4/12 - 8	4/12/2005 4/12/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
1121	Closed Work Orders 4/13/05 2-WENT TO DELIVER ART SHOW IN GAD MID SCHOOL .5-FIX TABLE IN THE PORTABLE E .5-FIX DOOR KNOB IN ROOM 29 5-CONTINUOUS CLEANING THE A/C 4/13 - 8	4/13/2005 4/13/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1149	Closed Work Orders 4/14/05 1-pick up peper by the south fence 1-put water hose inthe trees playground 6-continous cleaning the A/C 4/14 - 8	4/14/2005 4/14/2005 Medium	Sebastian Diaz Sebastian Diaz		Sunland Park ES
485	Complete Please generate a w.o for Manny and have him assign the keys to the cafeteria mangager before the end of the week. Have Manny test the keys before he issues them out. 1C1 Key (Gate Key) made duplicat key	3/17/2005 3/17/2005 Medium	Michael Munoz Hector Lozoya	Cafeteria	Sunrise ES
2891	Closed Work Orders 6-14-05 1.0,CHECK IN WITH OFFICE,AND CHECK SCHOOL GROUNDS 2.5,BLOW DOWN CONDENSATE DRAINS WING A. 2.0,SWEEP SAND FROM PARKING LOT 2.5,CONTINUE PAINTING GUARD RAILS 6/14-8	6/20/2005 6/14/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2892	Closed Work Orders 6-15-05 .5,CHECK IN WITH OFFICE 3.5,CHANGE OUT AIR FILTERS 1.5,FILL PLAY GROUND WITH SAND 2.5,BLOW DOWN CONDENSATE DRAINS LIRARY,AND COMPUTER LAB 6/15-8	6/20/2005 6/15/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2893	Closed Work Orders 6-16-05 .5,CHECK IN WITH OFFICE 3.0,BLOWDOWN CONDENSATE DRAINS WING B 2.5,PATCH UP WALL IN CLASSROOM 305,AND PAINT 2.0,CHANGE OUT AIR FILTERS 6/16-8	6/20/2005 6/16/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2894	Closed Work Orders 6-17-05 4.0,PAINT IN CLASSROOMS IN WING C 3.0,ROUND UP WEEDS GROUNDS 1.0,BLOW DOWN CONDESATE DRAINS MAIN OFFICE NURSES AREA,AND PARENT CONFRENCE RM. 6/17-8	6/20/2005 6/17/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2978	Void SMOKE DETECTOR IN COMPUTER LAB WILL NOT RESET, NOR TURN ON.PROBLEM SHOWING OTHER THAN DIRTY FILTER ON MAIN CONTROL PANEL IN FRONT OFFICE. This wo goes to Technology - 6/27/05 - mkv ROUTED 126709	6/24/2005 Medium	Paul Quinones Danny Orozco		Sunrise ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2979	Closed Work Orders 6-20-05 .5,CHECK SCHOOL GROUNDS 3.0,TOUCH UP PAINT CLASSROOMS IN WING B. 1.0,RESET SMOKE DETECTOR IN ELECTRICAL CLOSET 1.5,REMOVE DRIP SECTION,AND REROUTE PLANTING AREA ON THE SIDE OF SCHOOL 2.0,EDGE GRASS WEED EATER 6/20 - 8	6/24/2005 6/20/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2980	Closed Work Orders 6-21-05 2.0,TOUCH UP PAINT WING A 2.0,TOUCH UP PAINT BATHROOM WING C BOYS 1.0,REPLACE CIELING TILE 1.0,PICK UP TRASH OUTSIDE FRONT ENTRANCE 2.0,HANG PROJECTOR SCREEN IN COMPUTER LAB 6/21 - 8	6/24/2005 6/21/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2981	Closed Work Orders 6-22-05 2.0,CAULK SINKS IN CLASSROOMS BACK SPLASH WATER PENTETRATING COUNTR TOPS 2.0,PICK UP WEEDS,TRASH PATIO AREAS 4.0,PAINT GIRLS BATHROOM WING B 6/22-8	6/24/2005 6/22/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2987	Work In Progress I NEED SLEEVES,AND ALSO GASKETS THAT CONNECT TO THE MOTOR,AND PUMP HOUSING. THANKS	6/24/2005 Medium	Paul Quinones Jaime Gomez		Sunrise ES
2985	Closed Work Orders 6-23-05 1.0,REPLACE CIELING TILE COMPUTER LAB 2.0,BUG SPRAY CLASSROOMS 3.0,UNIT IN LIBRARIAN OFFICE NOT LEVEL.LEVEL UNIT,AND BLOWDOWN CONDENSATE DRAIN 1.0,CHECK LIFT STATION ALARM WENT OFF CHECK,RESET 1.0,SWEEP BOILER RMS 6/23 - 8	6/24/2005 6/23/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2671	Closed Work Orders 6-8-05 .5,CHECK IN WITH OFFICE 1.5,RAISE BASKETBALL BACK BOARD PRE-K ,AS PER COACH REQUEST 2.0,HANG BULLITEN BOARDS IN RM.108 2.5,BLOW DOWN CONDENSATE DRAINS IN WING C. 1.5,SWEEP SAND FROM PARKING LOT 6/8 - 8	6/9/2005 6/8/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2667	Closed Work Orders 6-7-05 .5,CHECK IN WITH OFFICE 2.0,REPLACE LEAKING CIRCULATING PUMP TO UNIT IN MECH RM. 2.5,CLEAN OUT RAIN GUUTTERS ON ROOF 3.0,MONTHLY INSPECT. EMERGENCY LIGHTING ,FIRE EXTING. EXIT SIGNS 6/7 - 8	6/9/2005 6/7/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2537	Closed Work Orders 6-1-05 .5,CHECK IN WITH OFFICE 1.5,PICK UP TRASH PATIO AREAS 4.0,CHANGE OUT AIR FILTERS 2.0,ROUND UP WEEDS 6/1 - 8	6/6/2005 6/1/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2538	Closed Work Orders 6-2-05 .5,CHECK IN WITH OFFICE 2.0,PICK UP TRASH GROUNDS 1.0 REPLACE LIGHT BULBS IN MECH. RM IN WING A 4.5,CHANGE OUT AIR FILTERS 6/2 - 8	6/6/2005 6/2/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2539	Closed Work Orders 6-3-05 .5,CHECK IN WITH OFFICE 2.0,PICK UP TRASH PATIO AREA,AND EMPTY TRASH CANS 4.0,CHANGE OUT AIR FILTERS 1.5,TRIM GRASS EDGES WITH WEED EATER 6/3 - 8	6/6/2005 6/3/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2769	Closed Work Orders 6-9-05 .5,CHECK IN WITH OFFICE 2.0,PAINT GUARD RAILS 3.0,SCRAPE DIRT WITH SCRAPER BACK FENCING AREA 2.5,MONTHLY VISUAL INSPECTIONS 6/9 - 8	6/14/2005 6/9/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2770	Closed Work Orders 6-10-05 .5,CHECK IN WITH OFFICE 1.0,TURN IN TIME SHEET,AND PICK UP MATERIALS 3.0,MEETING IN P/PLANT 3.5,CONTINUEW/ MONTHLY VISUAL INSPECTIONS 6/10 - 8	6/14/2005 6/10/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2665	Closed Work Orders 6-6-05 .5,CHECK IN WITH OFFICE,WRITE OUT POLICE REPORT BREAK IN,AND VANDILISIM DURING THE WEEK END. 1.0,CHECK SCHOOL GROUNDS 6.5,SERVICE,AND CHANGE OUT FILTERS TO VENTILATERS 6/6 - 8	6/9/2005 6/6/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
879	Closed Work Orders 4-5-05 3.5,CLEAN FILTERS STERLING UNITS,AND CLEAN WET SECTION 4.5,SET UP ROLL GATE,HIGH WINDS BLOW OFF RAILING 4/5 - 8	4/6/2005 4/5/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
875	Closed Work Orders 4-1-05 2.5,PICK UP MATERIALS,TURN IN TIME SHEET 5.5,CHANGE OUT AIR FILTERS 4/1 - 8	4/6/2005 4/1/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
876	Closed Work Orders 4-4-05 1.5,CHECK SCHOOL GROUNDS,AND PICK UP TRASH 2.5,CONNECT WATER LINES TO MASTERCOOLS,AND CHECK FOR LEAKS 4.0,INSTALL CIELING TILE,AND REMOVE DUCT WORK AT CHAPARRAL ELEM. 4/4 - 8	4/6/2005 4/4/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
946	Work In Progress I NEED SAND FOR BOTH PLAY GROUNDS	4/7/2005 Medium	Paul Quinones Lorenzo Hernandez		Sunrise ES
944	Closed Work Orders 4-6-05 3.0,INSTALL CIELING TILE,AND SHEETMETAL DUCT WORK AT CHAPARRAL ELEM.WORK ORDER #123219. 5.0,INSTALL MASTERCOOL UNITS AT CHAPARRAL MIDDLE SCHOOL. 4/6 - 8	4/7/2005 4/6/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
741	Closed Work Orders 3-24-05 1.5,PAINT GAURD RAILS BACK OF KITCHEN 2.5,REPLACE CIELING TILES 2.0,HANG PROJECTOR SCREEN 2.0,CHANGE OUT AIR FILTERS	3/31/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
742	Closed Work Orders 3-29-05 4.0,CHANGE OUT AIR FILTERS 4.0,ROUND UP WEEDS	3/31/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
743	Closed Work Orders 3-30-05 4.0,CHANE OUT AIR FILTERS 4.0,ROUND UP WEEDS	3/31/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
1092	Closed Work Orders 4-11-05 .5,CHECK IN WITH OFFICE 1.0,CHECK UNIT IN MECH. RM. 3.5,SWEEP SAND FROM PARKING LOT 3.0,ASSIST JAIME WITH PROBLEM WITH UNIT IN MECH. RM. 4/11 - 8	4/13/2005 4/11/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
1093	Closed Work Orders 4-12-05 .5,CHECK IN WITH OFFICE 1.0,ADD WATER TO PRIMER DRAINS IN BOYS,AND GIRLS RESTROOMS. 4.0,CONTINUE SWEEPING SAND FROM PARKING LOT 1.0,PICK UP TRASH GROUNDS 1.5,USE BLOWER,AND SWEEP GRAVEL FROM BASKETBALL COURTS,AND SIDEWALKS 4/12 - 8	4/13/2005 4/12/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
1133	Complete IM REQUESTING TWO 1CM MASTER LOCKS FOR THE TWO ENTRANCES GOING BEHIND INTO THE G.I.S.D VEHICLES ONLY AREA, TOO MANY NON G.I.S.D VEHICLES COMING THROUGH. THANKS rekey 2 padlocks for sunrise gates	4/14/2005 4/15/2005 Medium	Paul Quinones Hector Lozoya		Sunrise ES
1134	Closed Work Orders 4-12-05 .5,CHECK IN WITH OFFICE 1.0,CHANGE OUT AIR FILTERS IN BACK MECH. RM. 4.0,CONTINUE SWEEPING SAND FROM PARKING LOT. 2.5,SWEEP GRAVEL FROM BASKETBALL COURTS,AND SIDEWALKS. 4/12 - 8	4/14/2005 4/12/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
1135	Closed Work Orders 4-13-05 .5,CHECK IN WITH OFFICE 2.0,PICK UP TRASH,AND EMPTY OUTSIDE TRASHCANS. 4.0,CLEAN VENTILATORS WASHABLE FILTERS 1.5,ROUND UP WEEDS 4/13 - 8	4/14/2005 4/13/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
1025	Complete UNIT IN MECHANICAL RM.WILL NOT COOL BAD RELAY NO 24 VOLTS TO CONTACTOR. CK'D VOLTAGE INTO UNIT, NOT SUPPLYING VOLTAGE TO CONTACTOR RELAY, REPLACED.	4/11/2005 4/11/2005 Medium	Paul Quinones Jaime Gomez		Sunrise ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1015	Closed Work Orders 4-7-05 2.5,CLEAN BOILER RMS.,AND CHECK PUMPS,AND MOTOR CONTROLS. 2.0,PICK UP TRASH GROUNDS 2.0,TIE DOWN WIND SCREEN FENCING AREA 1.5,CONNECT WATER LINES TO STERLING UNITS,AND CHECK FOR WATER LEAKS. 4/7 -8	4/11/2005 4/7/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
1016	Closed Work Orders 4-8-05 2.5,ASSIST JAIME INSTALL CONTACTER COIL TO VENTILATER#1,AND CHECK OTHER CONROLS 1.5,SWEEPCRUSH FINE ROCK FROM BASKETBALL COURTS,AND SIDEWALKS. 4.0,CHANGE OUT FILTERS TO VENTILATERS 4/8 - 8	4/11/2005 4/8/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
1235	Closed Work Orders 4-14-05 .5,CHECK IN WITH OFFICE 2.5,DELIVER PARTITIONS TO G.M.S FOR THE ART SHOW 2.0,OUTSIDE WATER FOUNTAIN CLOGGED CLEAN P-TRAP 3.0,MONTHLY VISUAL INPECTIONS 4/14 - 8	4/19/2005 4/14/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
1236	Closed Work Orders 4-15-05 .5,CHECK IN WITH OFFICE 2.5,PICK UP MATERIALS,AND TURN IN TIME SHEET 1.5,POWR SURGES IN AREA CHECK POWER IN SCHOOL BUILDING. 3.5,LUBRICATE KEY CYLINDERS TO ALL OUTSIDE DOORS 4/15 - 8	4/19/2005 4/15/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
1237	Closed Work Orders 4-18-05 1.0,CHECK IN WITH OFFICE,AND CHECK SCHOOL GROUNDS 3.0,CONTINUE W/ MONTHLY VISUAL INSPECTIONS 2.5,PICK UP PARTITIONS AT G.M.S 1.5,PICK UP TRASH,AND SWEEP GRAVEL FROM BASKETBALL COURTS. 4/18 - 8	4/19/2005 4/18/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
1233	Void 4-14-05	4/19/2005 Medium	Paul Quinones		Sunrise ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
143	Closed Work Orders "3-2-05 .5 CHECK IN WITH OFFICE 3.0 CIRRCULATING PUMPS OUT-REPLACED FUSE AND CHECKED B & C CONTROLS IN MECHANICAL ROOM 2.5 CHECK EXIT SIGNS, EMERGENCY LIGHTING, AND FIRE EXTINGUESHERS 2.0 CLEANING ERV'S"	3/8/2005 3/16/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
101	Closed Work Orders "3-2-05 .5,check in with office 1.0,replace vacuum breaker,boys restroom back entrance 4.5,continue to clean filter wheels erv,s 2.0,remove motor to exhaust fan#3,and replace"	3/7/2005 3/3/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
105	Closed Work Orders "3-1-05 .5,check in with office 1.0,check erv#b bad contactor coil 5.5,started to clean erv filter wheels 1.0,check exhaust fan motor bad windings"	3/7/2005 3/3/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
106	Closed Work Orders "2-28-05 .1.0,check in with office,and check school grounds 4.0,continue to clean air ventilaters,and replace air filters 1.5,assist rick in cleaning clean filters 1.5,pick up out side trash"	3/7/2005 3/16/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
187	Closed Work Orders 3-4-05 .5,CHECK IN WITH OFFICE 3.0,PICK UP MATERIALS,AND TURN IN TIME SHEET 1.0,REPLACE TIRE WORK TRUCK #139 AT THE MECH.SHOP 2.0,CLEAN AIR FILTERS STERLING UNITS 1.5,CHECK WATER STATIONS,RAIN BIRD CONTROLS	3/8/2005 3/8/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
188	Closed Work Orders 3-7-05 1.0,CHECK IN WITH OFFICE,AND CHECK SCHOOL GROUNDS 2.0,CHECK UNITS IN RMS. 209,AND 211. 2.0,PICK UP TRASH,AND SWEEP SIDEWALKS WITH BLOWER .5,INSTALL ELECTRICAL COVER OUTLET FOR SODA MACHINE 2.5,CLEAN P-TRAP IN RESTROOM RM.201 CLOGGED	3/8/2005 3/8/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
189	Complete UNIT IN RM. 211 OFF ON LOW PRESSURE. NO CIRCULATING WATER BEING PUMPED NEED TO REPLACE MOTOR RUBBER GEAR WHEEL. 1 MOTOR COUPLER	3/8/2005 3/9/2005 Medium	Paul Quinones Jaime Gomez		Sunrise ES
221	Closed Work Orders 3-8-05 .5,CHECK IN WITH OFFICE 4.0,SERVICE MASTERCOOLS CLEAN CELDIC PADS 3.5,ASSIST JAIME G.W/UNIT PROBLEMS IN RMS. 209,AND 211 CHECK SET POINTS	3/9/2005 3/9/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
355	Forwarded MR.BOYD REQUESTING THE COLOR CODES FOR SUNRISE ELEM. INTERIOR,AND EXTERIOR COLORS.FOR FUTURE PAINTING PROJECTS THANKS!	3/14/2005 3/14/2005 Medium	Paul Quinones		Sunrise ES
356	Closed Work Orders 3-11-05 .5,CHECK IN WITH OFFICE 3.0,CONTINUE TO SERVICE STERLING UNITS 2.0,CHECK MASTER COOL CONTROLS 2 POSITION SWITCH 2.5,GREASE ERV,GYM EXHAUST FAN MOMTORS WITH GREASE GUN.	3/14/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
397	Closed Work Orders 3-14-05 1.0,CHECK IN WITH OFFICE,AND CHECK SCHOOL GROUNDS 3.0,CONTINUE TO GREASE MOTORS,AND BEARINGS.ROOF TOP UNITS 3.0,ASSEMBLE FURNITURE FOR LIBRARY 1.0,SET UP VOLLEY BALL POLES	3/15/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
287	Closed Work Orders 3-9-05 .5,CHECK IN WITH OFFICE 2.5,CLEAN MASTERCOOLS 5.0,HELP J.C.AT CHAPARRAL ELEM. UNLOAD MATERIAL,AND LAY OUT FLOORING	3/11/2005 3/11/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
297	Closed Work Orders 3-10-05 .5,CHECK IN WITH OFFICE 1.5,SWEEP BOILER RMS.AND CHECK PUMPS,AND MOTORS IN WING A,B,C 5.0,CLEAN AND SERVICE STERLING UNITS WET SECTION 1.0,SECURE BOLTS PRE-K PLAYGROUND	3/11/2005 3/11/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
495	Closed Work Orders 3-15-05 .5,CHECK IN WITH OFFICE 2.0,PICK UP OUTSIDE TRASH GROUNDS 2.5,ASSIST JAIME G. INSTALL MOTOR GEAR WHEEL TO UNIT IN RM.211 1.5 PROBLEM W/ OVEN IN KITCHEN,BAD GAS VALVE 1.5,REPLACE SPUD WASHER IN BOYS REST ROOM,AND VACUME BREAKER	3/17/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
496	Closed Work Orders 3-16-05 .5,CHECK IN WITH OFFICE 4.0,RESET SMOKE DETECTORS CLEAN DIRTY FILTERS 3.5,CLEAN EXHAUST FANS IN THE ELECTRICAL,AND COMMUNICATION CLOSET	3/17/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
630	Closed Work Orders 3-23-05 4.0,ASSIST GEN.CON INSTALL GUARD RAILS,TO PROTECT GAS PIPING BEHIND KITCHEN ENTRANCE. 2.0,SECURE BOLTS ON BOTH PLAY GROUNDS 2.0,REPLACE FLUORESCENT LAMPS	3/24/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
589	Closed Work Orders 3-21-05 3.0,CONTINUE TO MARK,AND PAINT 4-SQUARE GAME ON BASKETBALL COURTS. 3.0,MONTHLY INSPECTIONS EXIT SIGNS,EMERGENCY LIGHTING,FIRE EXTINGUISHERS. 2.0,CAULK SINKS IN CLASS ROOMS	3/23/2005 3/29/2005 Medium	Paul Quinones Margret Villalobos		Sunrise ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
590	Closed Work Orders 3-22-05 4.0,SWEEP SAND FROM MAIN PARKING LOT 4.0,SAFETY MEETING AT SANTA TERESA MIDDLE SCHOOL	3/23/2005 3/29/2005 Medium	Paul Quinones Margret Villalobos		Sunrise ES
585	Closed Work Orders 3-17-05 .5,CHECK IN WITH OFFICE 7.5,MONTHLY VISUAL INSPECTIONS	3/23/2005 3/29/2005 Medium	Paul Quinones Margret Villalobos		Sunrise ES
586	Closed Work Orders 3-18-05 .5,CHECK IN WITH OFFICE 2.5,TURN IN TIME SHEET,AND PICK UP MATERIALS 4.0,STARTED TO MARK 4-SQUARE GAME ON BASKETBALL COURTS. 1.0,PICK UP MATERIALS AT CHAPARRAL ELEM.2X14X16 STUDS.	3/23/2005 3/29/2005 Medium	Paul Quinones Margret Villalobos		Sunrise ES
1458	Closed Work Orders 4-25-05 1.0,CHECK IN WITH OFFICE,AND CHECK SCHOOL GROUNDS 3.0,ASSEMBLE METAL WAGON FOR P.E. TEACHER 3.0,MONTHLY INSPECTIONS FOR EXIT SIGHNS,EMERGENCY LIGHTING,AND FIRE EXTINGUISHERS. 1.0,PICK UP OUTSIDE TRASH 4/25 - 8	4/27/2005 4/25/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
1459	Closed Work Orders 4-26-05 .5,CHECK IN WITH OFFICE 3.0,SWEEP SAND FROM MAIN PARKING LOT 3.5,INSTALL WOOD SHELIVING IN MORGAN SHED FOR MATERIALS. 1.0,EMPTY OUTSIDE TRASH CANS 4/26 - 8	4/27/2005 4/26/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
1456	Void 4-25-05	4/27/2005 Medium	Paul Quinones		Sunrise ES
1536	Closed Work Orders 4-27-05 .5,CHECK IN WITH OFFICE 2.5,USE BLOWER TO REMOVE GRAVEL FROM PAVEMENT,AND BASKETBALL COURTS. 3.5,CONTINUE TO WORK ON SHELIVING,MORGAN SHED. 1.5,ASSEMBLE FURNITURE KITCHEN AREA. 4/27 - 8	4/29/2005 4/27/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1539	Closed Work Orders 4-28-05 .5,CHECK IN WITH OFFICE 3.5,CONTINUE TO WORK ON SHELVING,MORGAN SHED 3.0,PICK UP TRASH PATIO AREA,ROUND UP WEEDS 1.0,CHECK CONTROLS TO UNIT IN RM.203 4/28 - 8	4/29/2005 4/28/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
1598	Closed Work Orders 4-29-05 .5,CHECK IN WITH OFFICE 2.5,PICK UP MATERIALS,AND TURN IN TIME SHEET 1.5,DROP OFF MATERIALS AT CHAPARRAL ELEM. 1.0,LOCATE BALL VALVE TO PRE-K SHOWER FOR EMERGENCY SHUT OFF OR REPAIR W/ B/H MECH. 2.5,SWEEP SAND BACK PARKING LOT,AND PICK UP TRASH 4/29 - 8	5/3/2005 4/29/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
1601	Closed Work Orders 5-2-05 1.0,CHECK IN WITH OFFICE,AND CHECK SCHOOL GROUNDS 2.0,ASSEMBLE FURNITURE 1.5,CHECK LIGHTING RM.105 BAD BALLAST 2.0,EMPTY OUTSIDE TRASH CANS,AND PICK UP TRASH 1.5,TIE DOWN WIND SCREEN BACK FENCING AREA 5/2 - 8	5/3/2005 5/2/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
1603	Complete CHECK LIGHTING IN RM.105 BAD BALLAST ,I NEED TO TALK TO YOU IN ORDERING SOME BALLAST. THANK YOU VERY MUCH. CAMBIAR BALLAST	5/3/2005 5/11/2005 Medium	Paul Quinones Enrique Sotelo		Sunrise ES
1311	Closed Work Orders 4-19-05 .5,CHECK IN WITH OFFICE 7.5,SERVICE COOLERS,AND SOLDER 1/2 INCH.COPPER WATER LINES,WATER MAKE UP FOR MASTERCOOLS AT CHAP.ELEM. 4/19 - 8	4/21/2005 4/19/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1312	Closed Work Orders 4-20-05 .5,CHECK IN WITH OFFICE 1.5,PICK UP TRASH,AND EMPTY OUT SIDE TRASH CANS 2.0,SWEEP,AND BLOW GRAVEL FROM BASKETBALL COURTS 1.0,INSTALL PENCIL SHARPENERS CLASSROOMS,AND HANG CLOCK IN NURSES STATION 2.0,MANUAL CHECK WATER STATION#10 SPRINKLER HEAD STUCK 1.0,ADJUST MIXING VALVE WATER TOO COLD PRE-K SHOWER. 4/20 - 8	4/21/2005 4/20/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
1318	Complete EXHAUST FAN IN KITCHEN THAT INTERLOCKS WITH STERLING UNIT SHUTS DOWN ON HIGH AMPS I NEED A HIGHER RATING HEATING ELEMENT.THANKS cambiar heaters on control for a/c in kitchen.	4/21/2005 5/11/2005 Medium	Paul Quinones Enrique Sotelo		Sunrise ES
1408	Closed Work Orders 4-21-05 .5,CHECK IN WITH OFFICE 1.5,CHECK STERLING UNIT TRIPPING ON AMPS CHECK CONTROLS. 3.0,RAKE LEAVES IN PATIO,AND PICK UP TRASH 3.0,ROUND UP WEEDS SCHOOL GROUNDS 4/21 - 8	4/25/2005 4/21/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
1409	Closed Work Orders 4-22-05 .5,CHECK IN WITH OFFICE 2.5,ASSIST J.C.@ CHAP.ELEM. PUT UP FENCING IN FRONT OF SCHOOL. 2.0,ASSIST ENRIQUE TROUBLE SHOOT EXHAUST FAN IN KITCHEN AREA,AND COOLING. 1.5,CHECK MOTOR CONTROLS TO EXHAUST FAN IN GYM BAD SURGE PROTECTOR. 1.5,STERLING UNIT THAT INTERLOCKS W/EXHAUST FAN NO AIR FLOW,REVERSE LEADS TO CONTACTER MOTOR RUNNING ON REVERSE ROTATION 4/22 - 8	4/25/2005 4/22/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1652	Closed Work Orders 5-3-05 .5,CHECK IN WITH OFFICE 3.5,LEVEL DIRT WITH SCRAPER,AND WEEDS IN BACK OF GRASS FIELD AREA 1.5,DIRTY SMOKE ALARM FILTER IN ELECTRICAL CLOSET IN WING B. CLEAN,AND RESET. 2.5,STARTED TO ADJUST CLAMPS,AND ALL THREAD TO LEVEL MOTORS,AND PUMPS TO ALL UNITS.	5/4/2005 5/3/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
	5/3 - 8				
1790	Closed Work Orders 5-6-05 .5,CHECK IN WITH OFFICE 3.5,REMOVE TREE,TOO CLOSE TO THE GREASE TRAP,AND REPLANTED NEAR PLAYGROUND AS PER MIKE M.	5/10/2005 5/6/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
	5/6 - 4				
1787	Closed Work Orders 5-5-05 .5,CHECK IN WITH OFFICE 3.5,ASSIST B&H MECH. INSTALL FLOAT SWICH TO KITCHEN BOILER 2.0,ASSIST LORENZO SOLIS CHECK MODEL #,AND SERIAL # TO ALL HEATING,AND COOLING UNITS. 2.0,CONTINUE TO LOOSEN MOTOR BRACKETS TO UNITS AS PER JAIME G.	5/10/2005 5/5/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
	5/5 - 8				
1785	Closed Work Orders 5-4-05 .5,CHECK IN WITH OFFICE 1.5,PICK UP TRASH PATIO AREAS 2.5,SWEEP SAND FROM PARKING LOT 2.0,CONTINUE TO LOOSEN MOTOR BRACKETS TO CLASS ROOM UNITS. 1.5,SWEEP GRAVEL FROM BASKETBALL COURTS,AND SIDE WALKS.	5/10/2005 5/4/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
	5/4 - 8				
1904	Closed Work Orders 5-11-12 .5,CHECK IN WITH OFFICE 3.0,CONTINUE PRUNING TREES,AND RELOCATING DRIP SECTIONS 2.5,ROUND UP WEEDS 2.0,REPAIR DRIP SECTION#2	5/12/2005 5/11/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
	5/11 - 8				

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
1900	Closed Work Orders 5-10-05 .5,CHECK IN WITH OFFICE 3.0,STARTED TO PRUNE TREES 4.0,RELOCATE DRIP SECTION AS PER RELOCATION OF TREES .5, PICK UP TRASH 5/10 - 8	5/12/2005 5/10/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2208	Work In Progress MASTER COOL UNIT WILL NOT TURN ON AND THE EXHAUST FAN AS WELL,	5/23/2005 Medium	Paul Quinones Jaime Gomez		Sunrise ES
2209	Work In Progress STERLING UNIT WET SECTION MIXED AIR CONTROL NOT WORKING PROPERLY DAMPER STAYS SHUT AT TIMES,AND HAS TO BE MOVED MANUALLY FOR COOLING,AND HEATING AS WELL.	5/23/2005 Medium	Paul Quinones Jaime Gomez		Sunrise ES
2158	Work In Progress I NEED MORTAR MIX TO PATCH UP BRICK WALL IN WING A BRICKS COMING APART FROM TOP OF WALL.	5/20/2005 Medium	Paul Quinones Ruben Ronquillo		Sunrise ES
2159	Duplicate Request I NEED MORTAR MIX TO PATCH UP BRICK WALL IN WING A BRICKS COMING APART FROM TOP OF WALL. 2158	5/20/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2160	Duplicate Request I NEED MORTAR MIX TO PATCH UP BRICK WALL IN WING A BRICKS COMING APART FROM TOP OF WALL. 2158	5/20/2005 Medium	Paul Quinones Ruben Ronquillo		Sunrise ES
2146	Closed Work Orders 5-18-05 .5,CHECK IN WITH OFFICE 2.5,ROUND UP WEEDS 4.0,MONTHLY INSPECTIONS 1.5,SWEEP GRAVEL FROM SIDEWALKS,AND BASKETBALL COURTS 5/18 - 8	5/20/2005 5/18/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2147	Closed Work Orders 5-19-05 .5CHECK IN WITH OFFICE 3.0,MONTHLYS EXIT SIGHNS,EMERGENCY LIGHTING,AND FIRE EXTINGUISHERS 4.5,MONTHLY INSPECTIONS 5/19 - 8	5/20/2005 5/19/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2098	Closed Work Orders 5-17-05 .5,CHECK IN WITH OFFICE 2.0,CHECK UNIT IN MECH. RM.COUPLING LOOSE,SET COUPL- ING WITH MOTOR,AND CIRCULATING PUMP. 1.0,REPLACE WATER PUMP STERLING UNIT 2.0,TIE DOWN WIND SCREEN BACK FENCING AREA 2.5,ASSEMBLE FURNITURE 5/17 - 8	5/18/2005 5/17/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2094	Closed Work Orders 5-16-05 1.0,CHECK IN WITH OFFICE,AND CHECK SCHOOL GROUNDS 3.5,ASSIST B&H MECH. INSTALL ELECTRIC HEATERS IN PRE-K RESTROOM,AND SHOWER 3.5,REMOVE TREE,AND RELOCATE DRIP SECTION 5/16 - 8	5/18/2005 5/16/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2113	Work In Progress I NEED A COUPLING THAT TURNS THE CIRCULATING PUMP WITH MOTOR SHAFT,TO CIRCULATE WATER TO UNIT IN OUT DOOR MECH. RM.	5/19/2005 Medium	Paul Quinones Jaime Gomez		Sunrise ES
1951	Closed Work Orders 5-12-05 .5,CHECK IN WITH OFFICE 1.5,ASSEMBLE BARBEQUE GRILL 2.0,PICK UP TRASH PATIO AREA,AND EMPTY TRASH CANS 4.0,REMOVE DEAD TREES,AND REPLACE W/ GREEN HOUSE 5/12 - 8	5/16/2005 5/12/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
1952	Closed Work Orders 5-13-05 .5,CHECK IN WITH OFFICE 2.5,PICK UP MATERIALS,AND TURN IN TIME SHEET 3.0,SWEEP SAND FROM MAIN PARKING LOT,AND SIDEWALK 2.0,FILL PRE-K PLAYGROUND W/ SAND 5/13 - 8	5/16/2005 5/13/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2365	Closed Work Orders 5-25-05 .5,CHECK IN WITH OFFICE 1.0,CHECK UNIT IN RM.308 2.0,REPLACE SLEEVE,UNIT IN RM.211 1.0,CHECK MASTERCOOL CONTRLS 1.5,PICK UP TRASH 2.0,CHECK VENTILATERS,AND CLEAN WASHABLE FILTERS 5/25 - 8	5/27/2005 5/25/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2368	Closed Work Orders 5-26-05 .5,CHECK IN WITH OFFICE 2.0,REPLACE COUPLING TO UNIT IN RM.308 1.5,REPLACE BELTS TO EXHAUST FAN IN GYM 1.0,CLEAN CONDENSATE DRAINS RM.211,308 1.0,REPLACE SLEEVE UNIT IN MECH. RM. 2.0,SWEEP GRAVEL FROM BACK PAVEMENT ROAD SIDE 5/26 - 8	5/27/2005 5/26/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2363	Closed Work Orders 5-24-05 .5,CHECK IN WITH OFFICE 1.5,KITCHEN AREA ,CLEAN DRAINS TO STEAMMERS SERV- ING INSERTS 1.5,PICK UP TRASH PATIO AREA 2.5,CLEAN EXHAUST FANS IN ELECTRICAL,AND COMMUNI- CATION CLOSETS 2.0,SWEEP GRAVEL FROM SIDEWALKS,AND BASKETBALL COURTS 5/24 - 8	5/27/2005 5/24/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2318	Complete REQUESTING PEST CONTROL SPRAYING IN CLASS ROOMS TOO MANY SPIDERS,AND SCORPIONS. THANK YOU. AS PER ALFREDO - PAUL NEEDS TO TRY THE PRODUCT THAT THE CUST. DEPT PROVIDES. 6/17/05 - TALKED TO PAUL AND HE SAID HE USED THE CUSTODIAL SPRAY. - MKV	5/26/2005 6/17/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2278	Work In Progress UNIT IN RM.308 NO CIRCULATING WATER.A SLEEVE IS NEEDED TRIPPING ON HIGH HEAD PRESSURE AS WELL	5/25/2005 Medium	Paul Quinones Jaime Gomez		Sunrise ES
2236	Closed Work Orders 5-20-05 .5,CHECK IN WITH OFFICE 1.5,PICK UP TRASH AND EMPTY TRASH CANS 6.0,STARTED TO REPLACE BORDER PARTITIONS PLAY GROUND 5/20 - 8	5/24/2005 5/20/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2237	Closed Work Orders 5-23-05 1.0,CHECK IN WITH OFFICE,AND CHECK SCHOOL GROUNDS 3.0,ANCHOR WATER FOUNTAIN ON WALL RECONNECT PLUMBING,WATER LINES WING C. 3.0,CONTINUED REMOVING BORDER PARTITIONS PLAY- GROUND. 1.0,CHECK UNIT IN RM.211 5/23 - 8	5/24/2005 5/23/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
2407	Work In Progress 5-27-05 .5,CHECK IN WITH OFFICE 3.0,PICK UP MATERIALS,AND TURN IN TIME SHEET 2.5,REROUT 6 INCH FLEX MORE AIR FLOW NEEDED IN CAFET- ERIA MANAGERS OFFICE. 1.0,PICK UP TRASH,AND SWEEP GRAVEL FROM BASKETBALL COURTS 1.0,ASSIST RICK J. CLEAN LIFT STATION 5/27 - 8	6/1/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2408	Closed Work Orders 5-31-05 1.0,CHECK IN WITH OFFICE,AND CHECK SCHOOL GROUND 3.0,ROUND UP WEEDS 1.0,REMOVE DEAD TREE FROM PONDING AREA 3.0,ASSIST RICK J. CLEAN LIFT STATION 5/31 - 8	6/1/2005 5/31/2005 Medium	Paul Quinones Paul Quinones		Sunrise ES
2696	Complete Vandalism - Weekend 6/4,5 Two electrical outlets covers, elec. panel. Damage to equipment leaf blower, hand rake, tale light lense, side window right side of door, coke machine and rear view mirrow.	6/10/2005 6/10/2005 Emergency	Joanne Munoz Margret Villalobos		Sunrise ES
118	Complete B-Wing - Need to replace contactor for ERV. REPLACED CONTACTOR IN ERV	3/7/2005 4/8/2005 Medium	Jaime Gomez Jaime Gomez		Sunrise ES
410	Complete TOP STACK OVEN IS NOT WORKING. JUST STOPPED WARMING. MARGIE TORRES SNP MGR 824-3194 REMOVED GAS VALVE INSTALLED NEW GAS VALVE	3/15/2005 3/16/2005 Medium	Jacqueline Aguilar Danny Orozco	Cafeteria	Sunrise ES
803	Complete NEED TO COMPLETE PERFORMANCE INSPECTION ON ALL CUSTODIANS TO INCLUDE CLOSET, MSDS, LABELED SPRAY BOTTLES & SAFETY EQUIPMENT. HEAD CUSTODIANS NEED TO INCLUDE INSPECTION ON YOUR OWN AREA. INSPECTION REPORTS ALONG WITH COMPLETED WORK ORDER MUST BE RETURNED AND RECEIVED BY US NO LATER THAN APRIL 29, 2005. COMPLETED AS PER RAY	4/1/2005 4/21/2005 Medium	Aida Salcedo Ramon Dominguez		Sunrise ES
890	Complete DP 1421 Monitoring Data is due in this office before April 28, 2005 PREPARE DATA AND TURN INTO OFFICE.	4/6/2005 4/26/2005 Scheduled	Ricardo Jacquez		Sunrise ES
2651	Work In Progress WWTP - REPLACE THE BROKEN CLEANOUTS.	6/9/2005 Medium	Ricardo Jacquez Ricardo Jacquez		Sunrise ES

WOID	Status Description Action Taken	Request Date Completion Date Priority	Requester Assigned To	Area Type	Location Area Number
992	Work In Progress Need North and South leachfields cleaned out.	4/8/2005 Medium	Ricardo Jacquez Lorenzo Hernandez		Sunrise ES
1078	Complete VADO ELEM CHECK DOORS @ WALLS FOR CONSTRUCTION SET UP ck walls and construction.	4/12/2005 4/12/2005 Medium	Danny Miranda Danny Miranda		Vado ES